

August 17, 1992

Docket No. 50-458

Gulf States Utilities  
ATTN: Mr. James C. Deddens  
Senior Vice President (RBNG)  
Post Office Box 220  
St. Francisville, Louisiana 70775

Dear Mr. Deddens:

SUBJECT: RESPONSE TO NRC BULLETIN 92-01, "FAILURE OF THERMO-LAG 330 FIRE BARRIER SYSTEM" - RIVER BEND STATION, UNIT 1 (TAC NO. M83921)

By letter dated July 24, 1992 (RBG-37271), Gulf States Utilities Company (GSU) provided a response to NRC Bulletin 92-01 for the River Bend Station. Your response stated that compensatory measures in the form of hourly firewatch patrols have been implemented consistent with the plant technical specifications and that these measures have been in effect since October 26, 1989. The response further stated that GSU is participating in a NUMARC ad hoc committee on Thermo-Lag to develop appropriate actions to restore fire barrier operability. This program will include establishment of a test database, development of guidance for applicability of tests, development of generic installation guidance, and consideration and coordination of additional testing as appropriate.

We have reviewed your response and find it acceptable. Please inform us when all corrective actions associated with the above program have been completed. Further NRC review, if any, will be performed by inspection or audit. This completes the staff's activities on TAC No. M83291.

Sincerely,

Original Signed by William D. Reckley  
for Douglas W. Pickett, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File MVirgilio  
NRC/PDR EPeyton  
Local PDR DPickett  
PDIV-2 RF OGC  
PDIV-2 PF EJordan  
BBoger ACRS (10)  
CMcCracken AMasciantonio  
PHarrell, RGN-IV PMadden

\*For previous concurrences  
see attached ORC

OFFICE	PDIV-2/LA	PDIV-2/PM	PDIV-2/B	SPLB*	PDIII-I <i>com</i>
NAME	EPeyton	DPickett	SBlack	CMcCracken	AMasciantonio
DATE	8/14/92	8/17/92	8/17/92	8/13/92	08/17/92

Document Name: M83291.DP  
c:\wp\rb

9209220374 920817  
PDR ADOCK 05000458  
Q PDR

150001

*DF01/0*

Mr. James C. Deddens

- 2 -

August 17, 1992

cc:

Winston & Strawn  
ATTN: Mark J. Wetterhahn, Esq.  
1400 L Street, N.W.  
Washington, D.C. 20005-3502

Ms. H. Anne Plettinger  
3456 Villa Rose Drive  
Baton Rouge, Louisiana 70806

Mr. Les England  
Director - Nuclear Licensing  
Gulf States Utilities Company  
St. Francisville, Louisiana 70775

Administrator  
Louisiana Radiation Protection Division  
P. O. Box 82135  
Baton Rouge, Louisiana 70884-2135

Mr. Philip G. Harris  
Cajun Electric Power Coop, Inc.  
10719 Airline Highway  
P. O. Box 15540  
Baton Rouge, Louisiana 70895

Senior Resident Inspector  
P. O. Box 1051  
St. Francisville, Louisiana 70775

President of West Feliciana  
Police Jury  
P. O. Box 1921  
St. Francisville, Louisiana 70775

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. J. E. Booker  
Manager-Nuclear Industry Relations  
Gulf States Utilities  
P. O. Box 2951  
Beaumont, Texas 77704

Mr. J. David McNeill, III  
William G. Davis, Esq.  
Department of Justice  
Attorney General's Office  
P. O. Box 94095  
Baton Rouge, Louisiana 70804-9095

The attached is a corrected copy. The TAC # on the previous version was incorrect and this contains the accurate number.

*Cileen Peyton*