



Public Service®

Public Service
Company of Colorado

16805 WCR 19 1/2; Platteville, Colorado 80651

September 18, 1992
Fort St. Vrain
Unit No. 1
P-92280

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Docket No. 50-267

SUBJECT: Thermo-Lag 330 Fire Barriers


REFERENCE: NRC Bulletin 92-01, Supplement 1, dated August 28, 1992
(G-92193)

Gentlemen:

In response to the referenced Bulletin, Public Service Company of Colorado (PSC) has reviewed fire barrier materials in use at the Fort St. Vrain Nuclear Station and has determined that Thermo-Lag 330 is not used at this facility. PSC notes that the concerns of the referenced Bulletin would not appear to apply to Fort St. Vrain, since the Bulletin is addressed to holders of operating licenses and construction permits for nuclear power reactors, and Fort St. Vrain has a possession only license. However, this response is provided for your information.

If you have any questions regarding the use of Thermo-Lag 330 at Fort St. Vrain, please contact Mr. M. H. Holmes at (303) 620-701.

Sincerely,


Donald W. Warembourg
Manager, Nuclear Operations

DWW/SWC

cc: Regional Administrator, Region IV

Mr. J. B. Baird
Senior Resident Inspector
Fort St. Vrain

01011#
9209230009 920918
PDR ADOCK 05000267
Q PDR

IE49
110

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter)
)
Public Service Company of Colorado) Docket No. 50-267
Fort St. Vrain Unit No. 1)

AFFIDAVIT

D. W. Warembourg being first duly sworn, deposes and says: That he is Manager, Nuclear Operations, of Public Service Company of Colorado, the Licensee herein, that he has read the information presented in the attached letter and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

D. W. Warembourg
D. W. Warembourg
Manager, Nuclear Operations

STATE OF Colorado)
)
COUNTY OF Weld)

Subscribe and sworn to before me, a Notary Public on this
18th day of September, 1992.

Margaret O. Collins
Notary Public

My commission expires 11-14, 1992.