

FEB 15 1984

DISTRIBUTION  
CENTRAL FILE  
AEB R/F  
FAkstulewicz  
TQuay  
Plant File

MEMORANDUM FOR: George T. Ankrum, Chief  
Quality Assurance Branch  
Division of Quality Assurance, Safeguards  
and Inspection Programs

FROM: L. G. Hulman, Chief  
Accident Evaluation Branch  
Division of Systems Integration

SUBJECT: Q-LIST REVIEW FOR THE VOGTLE UNITS 1 & 2

The Accident Evaluation Branch (AEB) has reviewed the Vogtle Q-List in Table 3.2.2-1 of the applicant's FSAR. Items of safety-related structures, systems and components (SSC) that fall within the AEB's area of review responsibility are:

- (1) Control room HVAC system,
- (2) Containment spray system,
- (3) Fuel building HVAC system, and
- (4) Fuel building radiation monitors

With respect to item (1), the Q-List does not contain the hydrogen sulfide (H<sub>2</sub>S), chlorine and radiation monitors for the control room air intakes. These should be added.

Item (4) is presently missing from the Q-List and should be listed.

Items (2) and (3) are appropriately included in the Q-List.

This review was coordinated by F. Akstulewicz (X24993).

Original signed by:  
L. G. Hulman

L. G. Hulman, Chief  
Accident Evaluation Branch  
Division of Systems Integration

cc: R. Mattson  
D. Muller  
E. Adensam  
M. Miller  
J. Spraul

*dup of*  
*8403010556 XA*

OFFICE	DSI:AEB	DSI:AEB	DSI:AEB				
NAME	FAkstulewicz	TQuay	L. G. Hulman				2
DATE	ye 2/14/84	2/14/84	2/15/84				