

September 16, 1992

Docket Nos. 50-317
and 50-318

Mr. Robert E. Denton
Vice President - Nuclear Energy
Baltimore Gas & Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4
P. O. Box 1535
Lusby, Maryland 20657

DISTRIBUTION
Docket File
NRC & Local PDRs
PDI-1 Reading
SVarga
JCalvo
RACapra
DMcDonald

CVogan
OGC
ACRS (10)
Plant File
CCowgill, RI
JHuang, 7E23

Dear Mr. Denton:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION CONCERNING RELIEF REQUEST FROM THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) CODE, SECTION III, ARTICLE 9, FOR CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT 1 (TAC NO. M83999) AND UNIT 2 (TAC NO. M84000)

By letter dated June 30, 1992, Baltimore Gas and Electric Company (BG&E) requested permanent relief from the ASME Boiler and Pressure Vessel Code, Section III (1968 Edition), Article 9. The request is to allow a stop valve to remain installed downstream of thermal overpressure relief devices for the regenerative heat exchangers of each unit.

The staff is currently reviewing your submittal and has determined that additional information is needed to complete its review of your relief request. Enclosure 1 provides the staff's request for additional information (RAI). We request that the information identified in the RAI be provided within six weeks.

This request affects one respondent and, therefore, is not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,
Original Signed By:
Daniel G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
RAI

cc w/enclosure:
See next page

PDI-1:LA	PDI-1:PM <i>[Signature]</i>	PDI-1:D			
CVogan <i>[Signature]</i>	DMcDonald:smm	RACapra <i>[Signature]</i>			
9/16/92	09/16/92	9/16/92	/ /	/ /	/ /

OFFICIAL RECORD COPY
FILENAME: A:CC83999.LTR

9209240296 920916
PDR ADDCK 05000317
P PDR

NRC FILE CENTER COPY

180010

[Handwritten initials]
9/10



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 16, 1992

Docket Nos. 50-317
and 50-318

Mr. Robert E. Denton
Vice President - Nuclear Energy
Baltimore Gas & Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4
P. O. Box 1535
Lusby, Maryland 20657

Dear Mr. Denton:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION CONCERNING RELIEF REQUEST FROM
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) CODE,
SECTION III, ARTICLE 9, FOR CALVERT CLIFFS NUCLEAR POWER PLANT,
UNIT 1 (TAC NO. M83999) AND UNIT 2 (TAC NO. M84000)

By letter dated June 30, 1992, Baltimore Gas and Electric Company (BG&E) requested permanent relief from the ASME Boiler and Pressure Vessel Code, Section III (1968 Edition), Article 9. The request is to allow a stop valve to remain installed downstream of thermal overpressure relief devices for the regenerative heat exchangers of each unit.

The staff is currently reviewing your submittal and has determined that additional information is needed to complete its review of your relief request. Enclosure 1 provides the staff's request for additional information (RAI). We request that the information identified in the RAI be provided within six weeks.

This request affects one respondent and, therefore, is not subject to the Office of Management and Budget review under P.L. 95-511.

Sincerely,

A handwritten signature in cursive script, appearing to read "Daniel G. McDonald".

Daniel G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
RAI

cc w/enclosure:
See next page

Mr. Robert E. Denton
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

Mr. Michael Moore, President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of
Maryland
American Building
231 E. Baltimore Street
Baltimore, Maryland 21202-3486

D. A. Brune, Esquire
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Kristen A. Burger, Esquire
Maryland People's Counsel
American Building, 9th Floor
231 E. Baltimore Street
Baltimore, Maryland 21202

Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P. O. Box 33111
Baltimore, Maryland 21218

Mr. G. L. Detter, Director, NRM
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4, P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory
Commission
P. O. Box 287
St. Leonard, Maryland 20685

Mr. Richard I. McLean
Administrator - Radioecology
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
B3
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

REQUEST FOR ADDITIONAL INFORMATION

The following information is needed by the staff to complete its review of the BG&E Relief Request dated June 30, 1992.

1. The installation of a manual stop valve on the discharge side of a pressure relieving device is a typical design at many nuclear facilities but the safety significance of the worst failure scenario of the manual stop valve varies significantly from plant to plant. BG&E has indicated that a failure of a manual stop valve will result in damages to the regenerative heat exchanger. To determine the safety significance of the event, provide the following: (1) postulated damages including rupture of a heat exchanger; (2) design features and emergency operating procedures for isolating the damages; and (3) the adverse impact of the damages on the performance of the High Pressure Safety Injection system.
2. 10 CFR 50.55a provides the staff with two approaches of reviewing and granting relief from ASME Code requirements. 50.55a(a)(3)(i) requires demonstration of an alternative that would provide an acceptable level of quality and safety, and 50.55a(a)(3)(ii) requires demonstration that compliance with Code requirements would result in hardship or unusual difficulties without a compensating increase in the level of quality and safety. BG&E proposes no design changes or system modifications, and has indicated that the cost associated with certain changes or modifications does not offset the minimal increase in safety. Based on 50.55a(a)(3)(ii), provide a cost/benefit analysis to substantiate the sustained hardship or unusual difficulties as a result of complying with the Code requirement.
3. Address the need of a continuous or periodic valve position verification program as an alternative for ensuring that the valves are maintained in the locked open position.
4. Specify the method for locking the valves in the open position. The NRC has accepted a chain or cable in series with a key or combination lock; or a lead seal in series with a chain or cable as acceptable locking devices.