

INSTRUMENTATION

3/4.3.4 RECIRCULATION PUMP TRIP ACTUATION INSTRUMENTATION

ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.4.1 The anticipated transient without scram recirculation pump trip (ATWS-RPT) system instrumentation channels shown in Table 3.3.4.1-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.4.1-2.

APPLICABILITY: OPERATIONAL CONDITION 1.

ACTION:

- a. With an ATWS-RPT system instrumentation channel trip setpoint less conservative than the value shown in the Allowable Value column of Table 3.3.4.1-2, declare the channel inoperable until the channel is restored to OPERABLE status with the channel trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for one trip system, place the inoperable channel(s) in the tripped condition within 72 hours or be in at least STARTUP within the next 6 hours.
- c. With the number of OPERABLE channels one less than required by the Minimum OPERABLE Channels per Trip System requirement for both trip systems, place at least one inoperable channel in the tripped condition within one hour, and place the second inoperable channel in the tripped condition within 72 hours. Otherwise, be in at least STARTUP within the next 6 hours.
- d. With both trip systems otherwise inoperable, restore at least one trip system to OPERABLE status within one hour or be in at least STARTUP within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.3.4.1.1 Each ATWS-RPT system instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3.4.1-1.

4.3.4.1.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.

TABLE 3.3.4.1-1

ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM ^(a)</u>
1. Reactor Vessel Water Level - Low Low, Level 2	2
2. Reactor Vessel Pressure - High	2

(a) One trip system may be placed in an inoperable status for up to 2 hours for required surveillance provided the redundant trip system is OPERABLE.

Mr. Frank A. Spangenberg
Illinois Power Company

Clinton Power Station
Unit No. 1

cc:

Mr. J. S. Perry
Vice President
Clinton Power Station
Post Office Box 678
Clinton, Illinois 61727

Illinois Department
of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Mr. J. A. Miller
Manager Nuclear Station
Engineering Department
Clinton Power Station
Post Office Box 678
Clinton, Illinois 61727

Mr. Donald Schopfer
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603

Sheldon Zabel, Esquire
Schiff, Hardin & Waite
7200 Sears Tower
233 Wacker Drive
Chicago, Illinois 60606

Resident Inspector
U.S. Nuclear Regulatory Commission
RR#3, Box 229 A
Clinton, Illinois 61727

Ms. K. K. Berry
Licensing Services Manager
General Electric Company
175 Curtner Avenue, M/C 382
San Jose, California 95125

Regional Administrator, Region III
799 Roosevelt Road, Building 4
Glen Ellyn, Illinois 60137

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, Illinois 61727

Mr. Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph, Suite 11-300
Chicago, Illinois 60601