

September 22, 1992

Docket No. 50-445

Mr. William J. Cahill, Jr.
Group Vice President, Nuclear
TU Electric
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Dear Mr. Cahill:

SUBJECT: RESPONSE TO NRC BULLETIN 92-01, "FAILURE OF THERMO-LAG 330
FIRE BARRIER SYSTEM (TAC NOS. M83861 AND M83862)

By letter dated July 9, 1992, you provided a response to NRC bulletin 92-01 for Comanche Peak, Unit 1 and 2. Your response states that compensatory measures have been implemented consistent with the plant Technical Specifications or operating license. You also provided a description of the long-term corrective action to ensure or restore operability.

The corrective action you indicated was the implementation of fire watches, in accordance with the Fire Protection Program, as compensatory measures for those plant areas in which Thermo-Lag fire barriers are used to protect wide cable trays, small conduits, or both. According to your Fire Protection Program, the fire watches are hourly.

We have reviewed your response and find it acceptable. Please inform us when all corrective actions have been completed. Further NRC review, if any, will be performed by inspection or audit.

Sincerely,

Original Signed By

Thomas A. Bergman, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File	BBoger
NRC/PDR	MVirgilio
Local PDR	EPeyton
PDIV-2 RF	TBergman
PDIV-2 PF	DRoth
OGC	EJordan
ACRS(10)	LYandell, RGN-IV
AMasiantonio	PMadden
BHolian	

9209250315 920922
PDR ADDCK 05000445
G PDR

NRC FILE CENTER COPY

OFFICE	PDIV-2/LA	PDIV-2/PM	PDIV-2	SPLB	PDIV-2/D
NAME	EPeyton	DRoth:nb	TBergman	CMcCracken	SBlack
DATE	9/14/92	9/14/92	9/15/92	9/18/92	9/21/92

Document Name: M83861.DR
nb;c:\wp\cpl&2

DF01 10

Mr. William J. Cahill, Jr.

- 2 -

September 22, 1992

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 1029
Granbury, Texas 76048

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, Texas 75224

Owen L. Thero, President
Quality Technology Company
Lakeview Mobile Home Park, Lot 35
4793 East Loop 820 South
Fort Worth, Texas 76119

Mr. Roger D. Walker, Manager
Regulatory Affairs for Nuclear
Engineering Organization
Texas Utilities Electric Company
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 610
Bethesda, Maryland 20814

William A. Burchette, Esq.
Counsel for Tex-La Electric
Cooperative of Texas
Jordan, Schulte, & Burchette
1025 Thomas Jefferson Street, N.W.
Washington, D.C. 20007

GDS Associates, Inc.
Suite 720
1850 Parkway Place
Marietta, Georgia 30067-8237

Jack R. Newman, Esq.
Newman & Hiltzinger
1615 L Street, N.W.
Suite 1000
Washington, D. C. 20036

Chief, Texas Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, Texas 78756

Honorable Dale McPherson
County Judge
P. O. Box 851
Glen Rose, Texas 75043