

# KECO

KING EQUIPMENT COMPANY • 140 Smith Street • Keasbey, NJ 08832 • (201) 826-0800

June 20, 1984

U.S. Nuclear Regulatory Commission  
Nuclear Materials and Safeguards Branch  
Region I  
King of Prussia, Pennsylvania 19406

Attn: John E. Glenn

Ref: Materials License  
Amendment Request  
Docket 030-20702  
License 29-20671-01

RECEIVED BY LPL	
Date...	7/2/84
Log...	July 1 I
By.....	Brown
Orig. To.....	
Action Compl	4/9/84

Dear Mr. Glenn:

This is a request by Keco, Inc. for an amendment to our NRC License No. 29-20671-01 that will permit our company to install, relocate, and conduct leak tests on nuclear gauging devices containing specified radioactive materials from 1 millicurie to 4 curies, as used in our customer's plants for the purposes authorized by our license, including density, level, analysis and weight.

Installation and/or relocation of devices shall be made by and/or under the supervision of Kevin L. Ravaioli, who has attended and successfully completed a course of instruction conducted under the auspices of Texas Nuclear Corporation, Austin, Texas. The course contents are itemized in the attached Radiation Safety Training Course agenda. Installation and relocation shall be conducted in accordance with the enclosed procedure entitled "Industrial Device Installation".

Leak tests shall be conducted by Kevin L. Ravaioli, who shall use a portable Survey Meter, Model DG10, Serial #340, manufactured by Certified Radiation Instruments, which has a demonstrated capability to measure less than 0.005 uCi of the isotope being tested, namely, Cs-137, Co-60, etc. Leak tests shall be made using the QT/1S procedure enclosed.

Applicant...	1847	3M
Check No...	1847	
Amount/Fee Category	\$930	
Type of Fee	Application	
Date Check Made	7/1/84	
Received by	Brown	

Very truly yours,

*Gary L. King*  
Gary L. King  
President

GLK:bjm  
Encl.

02567

8502110124 850130  
NMS LIC30  
29-20671-01 PDR

"OFFICIAL RECORD COPY"

JUN 22 1984

Postmarked 6/20/84

RADIATION SAFETY TRAINING COURSE  
AGENDA

First Day's Session

Introduction

1. Contents and Purpose of Course
2. Agenda

Review of Preparation Material

Atomic Structure

1. Nomenclature
2. Periodic Table

Coffee Break

Radioactive Materials

1. Isotopes
2. Radioactivity
3. Decay
4. Half-Life

Lunch

Radiation Interaction with Matter

1. Ionizing Radiation
  - a. electromagnetic
  - b. Charged particle
  - c. Neutron
2. Specific Ionization

Coffee Break

Radiation Dosimetry

1. Definitions and Units of Dose
2. Quality Factor

HAPPY HOUR

Homework Assignment -

- Read over work covered.  
Study new definitions and concepts

## Second Day's Session

### Question and Answer Session

#### Radiation Dosimetry (Continued)

3. Gamma Exposure Rate
4. Neutron Exposure Rate

### Coffee Break

#### Biological Effects

1. Dose Limits
2. Radiation Protection Guides

### Lunch

### Radiation Detection

#### Detection Instruments

1. Basic Operation
2. Ionization Chambers
3. Geiger-Mueller Instruments
4. Neutron Detectors

### Personnel Dosimetry

### Coffee Break

#### Distance, Time, Shielding

1. Inverse Square Law
2. Half-Value Layer

### Discussion and Review

### Homework Assignment -

- Complete Part I of Radiation Safety Manual.
- Complete Study Quiz I.
- Briefly look over Part II of Manual.

## Third Day's Session

### Question and Answer Session

#### Device Installation

1. Requirements
2. Format
3. Responsibility

#### Travel to Texas Nuclear

#### Laboratory Work at Texas Nuclear Corporation

1. Check-out and briefing on use of portable radiation survey meters.
2. Survey density, level and belt weigh devices.
3. Leak test devices using QT/IS procedure
  - a. count swabs
  - b. prepare leak test certificates

#### Lunch

#### Working Definitions

#### Licensing

1. Title 10 Code of Federal Regulations
2. Agreement States
3. Specific License

#### Radiation Area and Posting

#### Coffee Break

#### Shipping Radioactive Material

1. Definitions
2. Classification
3. Labels

#### Coffee Break

#### Occupational Safety & Health Act

#### Emergency Procedures

1. Guidelines
2. Fire or Explosion
3. Incident Report

#### Homework Assignment -

Read Part II of Radiation Safety Manual.  
Complete Study Quiz II on regulations.  
Material Review for Exam.

Fourth Day's Session

Material Review

Question and Answer Session

Written Test on Lectures and Homework Assignments

Lunch

ADJOURNMENT



# Certificate Of Training

This is to certify that

KEVIN L. RAVAIOLI

Has Successfully Completed a Radiation Safety Training Course  
presented by Texas Nuclear Corporation.



Issued 21st Day Of May 19 84

*W. Hendrick*  
Health Physicist

*Tom Rushmore*  
President

RECORD OF PERFORMANCE

Kevin L. Ravaioli

Service Supervisor

King Equipment Co.

<u>Quiz I</u>	<u>Quiz II</u>	<u>Exam</u>	<u>Final Grade</u>
90	100	96	96

Class Average - 91

## INDUSTRIAL DEVICE INSTALLATION

"Installation" means the placement of, or supervising the placement of, the source containing components of a measurement system in an operable use condition. Some devices are shipped and authorized so that the user may already have physically mounted the device. If this is the case, proceed with the installation surveying, leak testing and instructing of the user personnel. If the device is not authorized for the user to physically mount, then installation starts with the shipping container. Each separate placement or relocation is to be construed as a new installation.

Installation of industrial devices may be conducted only by those persons specifically licensed to perform this work. The installer must be equipped with an appropriate survey meter for the type of source utilized, a source to verify the meter operability and accuracy, calibrated leak test standard, and must be physically present at the site during the entire operation.

1. Survey the shipping box or crate at the storage location to insure that the radiation levels are the same as indicated by the shipping labels. If you find significant differences (e.g., +50%), remove any customer personnel from the immediate area and suspect shipping damage. If you are going to need any equipment to move the head for examination, make sure it is available before proceeding. If it is going to be necessary to work in areas with radiation levels in excess of 100 mrem/h, control the area physically and call Texas Nuclear before proceeding.
2. Remove the outer cover of the box or shipping crate but do not remove the unit from the base skid. Visibly inspect the unit for transportation damage to the shutter assembly, locking mechanism and correctness of labeling. Verify by radiation survey that the shutter is fully closed.
3. If visible damage is evident, the unit should be leak tested for contamination. Damage or any degree of contamination precludes installation and Texas Nuclear Health Physics should be notified immediately. Following this inspection, the device may be transported to job location and mounted.
4. A radiation survey will be made by the installer in accordance with the appropriate survey pattern sheet and the original furnished the user as a permanent record. Generally, all radiation levels measured around an installed device must be less than 5 mR/h one foot from any accessible surface. If this is not the case evaluate the installation for additional shielding needs and make user aware of posting requirements.
5. The installer will conduct a leak test and complete the appropriate leak test certificate. The original should be furnished the user as a permanent record.
6. The installer will insure that individual users are furnished the applicable training, paperwork and information called for on the check list titled "Customer Training For Use of Measuring Devices".



NOTES:

- 1) THIS FORM MAY BE USED ON EITHER RADIATION SURVEY OR LEAK TEST. WHEN USED FOR LEAK TEST, WIPE AREA 1 (AROUND COVER) AND AREA 2 (AROUND FOUR BOLT HEADS). WHEN USED FOR RADIATION SURVEY, SURVEY LETTERED POINTS AT ONE FOOT FROM SURFACE AND/OR AT SURFACE.
- 2) SOME GEIGER TUBE TYPE SURVEY METERS MAY NOT HAVE SUFFICIENT RANGE TO TAKE SURFACE READINGS ON SOME APPLICATIONS. IN SUCH CASES, USE ION CHAMBER TYPE SURVEY METER OR TAKE READINGS AT ONE FOOT.
- 3) ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE SHOULD BE MAINTAINED AS A PERMANENT RECORD.
- 4) CHECK OPERATION OF SHUTTER WHEN LEAK TEST IS PERFORMED

USER \_\_\_\_\_

GAUGE LOCATION \_\_\_\_\_

SOURCE HEAD MOD. NO. \_\_\_\_\_

TAG NO. \_\_\_\_\_

SOURCE HEAD SER. NO. \_\_\_\_\_

ACTIVITY \_\_\_\_\_  $\mu$ CI \_\_\_\_\_ CS137, \_\_\_\_\_ CO60

MEASURING INSTRUMENT \_\_\_\_\_

LEAK TEST TYPE \_\_\_\_\_

RESULTS:

SHUTTER OPERATION - \_\_\_\_\_ OK

\_\_\_\_\_ NEGATIVE; \_\_\_\_\_ POSITIVE, \_\_\_\_\_  $\mu$ CI

SIGNATURE (ONLY AFTER RESULTS RECORDED) \_\_\_\_\_ DATE \_\_\_\_\_


COMPANY NAME \_\_\_\_\_

COMPANY ADDRESS \_\_\_\_\_

WITH AVAILABLE LEAK TEST KIT, MAIL TO:

TEXAS NUCLEAR  
9101 H W WAY 183, AUSTIN TEXAS 78766  
PHONE (512) 836-0801; TELEX: 77-6413

## BELT WEIGH SCALE RADIATION SURVEY OR LEAK TEST CERTIFICATE



(K) (BELOW RETURN BELT IF NORMALLY ACCESSIBLE TO PERSONNEL)

mR/h READINGS TAKEN: ☐ AT ONE FOOT; ☐ AT SURFACE

SHUTTER	A	B	C	D	E	F	G	H	I	J
OPEN										
CLOSED										

15. SURVEY LETTERED POINTS AT ONE FOOT FROM THE SURFACE AND/OR AT THE SURFACE.

SOME GEIGER TUBE TYPE SURVEY METERS MAY NOT HAVE SUFFICIENT RANGE TO TAKE SURFACE READINGS ON SOME APPLICATIONS. IN SUCH CASES, USE ION CHAMBER TYPE SURVEY METER OR TAKE READINGS AT ONE FOOT.

ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE SHOULD BE MAINTAINED AS A PERMANENT RECORD.

TE \_\_\_\_\_

IR \_\_\_\_\_

UGE LOCATION \_\_\_\_\_

\_\_\_\_\_

URCE HEAD MOD. NO. \_\_\_\_\_

S NO \_\_\_\_\_

URCE HEAD SER. NO. \_\_\_\_\_

TIVITY \_\_\_\_\_ mCi \_\_\_\_\_ Cs137, \_\_\_\_\_ Co60

ASURING INSTRUMENT \_\_\_\_\_

\_\_\_\_\_


NDINGS TAKEN : \_\_\_\_\_ AT SURFACE, \_\_\_\_\_ AT ONE FOOT

SIGNATURE (ONLY AFTER RESULTS RECORDED) \_\_\_\_\_ DATE \_\_\_\_\_

OMPANY NAME \_\_\_\_\_

OMPANY ADDRESS \_\_\_\_\_

LEVEL GAUGE RADIATION SURVEY CERTIFICATE



	mR/h													
SHUTTER	A	B	C	D	E	F	G	H	I	J	K	L	M	N
OPEN														
CLOSED														

VESSEL; EMPTY ☐ ; FULL ☐

APPLY ONLY TO CONTINUOUS OR DOUBLE POINT LEVEL

# LEVEL GAUGE RADIATION SURVEY CERTIFICATE

- NOTES:
- 1) SURVEY LETTERED POINTS AT ONE FOOT FROM THE SURFACE AND/OR AT THE SURFACE.
  - 2) SOME GRIGER TUBE TYPE SURVEY METERS MAY NOT HAVE SUFFICIENT RANGE TO TAKE SURFACE READINGS ON SOME APPLICATIONS. IN SUCH CASES, USE ION CHAMBER TYPE SURVEY METER OR TAKE READINGS AT ONE FOOT.
  - 3) ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE SHOULD BE MAINTAINED AS A PERMANENT RECORD.

DATE \_\_\_\_\_

USER \_\_\_\_\_

GAUGE LOCATION \_\_\_\_\_

SOURCE HEAD MOD. NO. \_\_\_\_\_

TAG NO. \_\_\_\_\_

SOURCE HEAD SER. NO. \_\_\_\_\_

ACTIVITY \_\_\_\_\_ mCi \_\_\_\_\_ Ci137, \_\_\_\_\_ Co60


MEASURING INSTRUMENT \_\_\_\_\_

READINGS TAKEN: \_\_\_\_\_ AT SURFACE, \_\_\_\_\_ AT ONE FOOT

SIGNATURE (ONLY AFTER RESULTS RECORDED) \_\_\_\_\_ DATE \_\_\_\_\_

COMPANY NAME \_\_\_\_\_

COMPANY ADDRESS \_\_\_\_\_



mR/h													
SHUTTER	A	B	C	D	E	F	G	H	I	J	K	L	M
OPEN													
CLOSED													

VESSEL; EMPTY ☐ ; FULL ☐


TES:  
SURVEY LETTERED POINTS AT ONE FOOT FROM THE SURFACE  
AND/OR AT THE SURFACE.

SOME GEIGER TUBE TYPE SURVEY METERS MAY NOT HAVE  
SUFFICIENT RANGE TO TAKE SURFACE READINGS ON SOME  
APPLICATIONS. IN SUCH CASES, USE ION CHAMBER TYPE  
SURVEY METER OR TAKE READINGS AT ONE FOOT.

ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE  
SHOULD BE MAINTAINED AS A PERMANENT RECORD.

DENSITY GAUGE RADIATION SURVEY CERTIFICATE

E \_\_\_\_\_  
R \_\_\_\_\_  
GE LOCATION \_\_\_\_\_  
RCE HEAD MOD. NO. \_\_\_\_\_  
NO \_\_\_\_\_  
RCE HEAD SER. NO. \_\_\_\_\_  
IVITY \_\_\_\_\_ mCi \_\_\_\_\_ Cs137, \_\_\_\_\_ Co60  
URING INSTRUMENT \_\_\_\_\_  
DINGS TAKEN: \_\_\_\_\_ AT SURFACE, \_\_\_\_\_ AT ONE FOOT  
ATURE (ONLY AFTER RESULTS RECORDED) \_\_\_\_\_ DATE \_\_\_\_\_  
RPNY NAME \_\_\_\_\_  
RPNY ADDRESS \_\_\_\_\_



mR/h

SHUTTER	A	B	C	D	E	F	G	H	I	J	K	L
OPEN												
CLOSED												

PIPE FULL ☐ PIPE EMPTY ☐



NOTES:

- 1) THIS FORM MAY BE USED ON EITHER RADIATION SURVEY OR LEAK TEST. WHEN USED FOR LEAK TEST, WIPE AREA 1 (AROUND COVER) AND AREA 2 (AROUND FOUR BOLT HEADS). WHEN USED FOR RADIATION SURVEY, SURVEY LETTERED POINTS AT ONE FOOT FROM SURFACE AND/OR AT SURFACE.
- 2) SOME GEIGER TUBE TYPE SURVEY METERS MAY NOT HAVE SUFFICIENT RANGE TO TAKE SURFACE READINGS ON SOME APPLICATIONS. IN SUCH CASES, USE ION CHAMBER TYPE SURVEY METER OR TAKE READINGS AT ONE FOOT.
- 3) ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE SHOULD BE MAINTAINED AS A PERMANENT RECORD.
- 4) CHECK OPERATION OF SHUTTER WHEN LEAK TEST IS PERFORMED

USER \_\_\_\_\_

GAUGE LOCATION \_\_\_\_\_

SOURCE HEAD MOD. NO. \_\_\_\_\_

AG. NO. \_\_\_\_\_

SOURCE HEAD SER. NO. \_\_\_\_\_

ACTIVITY \_\_\_\_\_ mCi \_\_\_\_\_ CS137, \_\_\_\_\_ CO60

MEASURING INSTRUMENT \_\_\_\_\_

LEAK TEST TYPE \_\_\_\_\_

RESULTS:

SHUTTER OPERATION - \_\_\_\_\_ OK

\_\_\_\_\_ NEGATIVE; \_\_\_\_\_ POSITIVE, \_\_\_\_\_  $\mu$ CI


SIGNATURE (ONLY AFTER RESULTS RECORDED) \_\_\_\_\_ DATE \_\_\_\_\_

COMPANY NAME \_\_\_\_\_

COMPANY ADDRESS \_\_\_\_\_

WITH AVAILABLE LEAK TEST KIT, MAIL TO:  
 TEXAS NUCLEAR  
 1101 MEWAY TRD, AUSTIN TEXAS 78766  
 PHONE (512) 836-0801; TELEX: 77-6413

## BELT WEIGH SCALE RADIATION SURVEY OR LEAK TEST CERTIFICATE



(K) (BELOW RETURN BELT IF NORMALLY ACCESSIBLE TO PERSONNEL)

mR/h READINGS TAKEN: ☐ AT ONE FOOT; ☐ AT SURFACE

SHUTTER	A	B	C	D	E	F	G	H	I	J
OPEN										
CLOSED										



# DENSITY AND LEVEL GAUGE LEAK TEST CERTIFICATE

## NOTES

- 1) NUMBERED POINTS INDICATE AREAS TO BE WIPED FOR LEAK TEST.
- 2) ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE SHOULD BE MAINTAINED AS A PERMANENT RECORD.
- 3) CHECK OPERATION OF SHUTTER WHEN LEAK TEST IS PERFORMED.

USER \_\_\_\_\_

GAUGE LOCATION \_\_\_\_\_

SOURCE HEAD MOD. NO. \_\_\_\_\_

TAG NO. \_\_\_\_\_

SOURCE HEAD SER. NO. \_\_\_\_\_

ACTIVITY \_\_\_\_\_ -CI \_\_\_\_\_ CS137 \_\_\_\_\_ COMO \_\_\_\_\_

MEASURING INSTRUMENT \_\_\_\_\_

LEAK TEST TYPE \_\_\_\_\_

RESULTS \_\_\_\_\_


SHUTTER OPERATION - \_\_\_\_\_ OR \_\_\_\_\_ -CI \_\_\_\_\_

SIGNATURE (SIGN ONLY AFTER RESULTS ARE FILLED IN) \_\_\_\_\_ DATE \_\_\_\_\_


COMPANY NAME \_\_\_\_\_

COMPANY ADDRESS \_\_\_\_\_


WITH MAINTAINABLE LEAK TEST KIT, MAIL TO:  
 TEXAS NUCLEAR  
 9101 W. WAY 182, AUSTIN TEXAS 78746  
 PHONE (512) 836-0801, TELEX 77-6113




1, 2, 3, 4 - WIPER ALL AROUND GASKET  
 9 - WIPER ALL AROUND SHUTTER HANDLE  
 SOURCE HEAD NO. 5174, 5175, 5176



1, 2 - WIPER UP AND DOWN SHUTTER (AND, OR INSIDE EDGE OF HEAD IF EXPOSED)  
 3, 4 - WIPER ALL AROUND INSIDE EDGE  
 SOURCE HEAD NO. 5189, 5190, 5191, 5192, 5193, 5199



5 - WIPER ALL AROUND PLUG (EXCEPT ON 5178 OR 5181)  
 6, 7 - WIPER ALL AROUND SHUTTER  
 SOURCE HEAD NO. 5178, 5179, 5180, 5181, 5182, 5183



1 - WITH SHUTTER CLOSED, WIPER ALL AROUND SEAM AND BOLTS TO THE EXTENT THAT THEY ARE ACCESSIBLE  
 2, 3 - WIPER ALL AROUND BOTH SHUTTER HANDLES  
 SOURCE HEAD NO. 5188

# DENSITY AND LEVEL GAUGE LEAK TEST CERTIFICATE

## NOTES:

- 1) NUMBERED POINTS INDICATE AREAS TO BE WIPE FOR LEAK TEST.
- 2) ONCE COMPLETED, DATED AND SIGNED, THIS CERTIFICATE SHOULD BE MAINTAINED AS A PERMANENT RECORD.
- 3) CHECK OPERATION OF SHUTTER WHEN LEAK TEST IS PERFORMED.

SER \_\_\_\_\_

GAUGE LOCATION \_\_\_\_\_

SOURCE HEAD MOD. NO. \_\_\_\_\_

TAG NO \_\_\_\_\_

SOURCE HEAD SER NO. \_\_\_\_\_

ACTIVITY \_\_\_\_\_ mCi \_\_\_\_\_ Cs137, \_\_\_\_\_ Co60

MEASURING INSTRUMENT \_\_\_\_\_

LEAK TEST TYPE \_\_\_\_\_

RESULTS:


SHUTTER OPERATION - \_\_\_\_\_ OK

\_\_\_\_\_ NEGATIVE; \_\_\_\_\_ POSITIVE, \_\_\_\_\_ - CI

SIGNATURE (SIGN ONLY AFTER RESULTS ARE FILLED IN) \_\_\_\_\_ DATE \_\_\_\_\_

COMPANY NAME \_\_\_\_\_


COMPANY ADDRESS \_\_\_\_\_



1, 2 - WIPE ALL AROUND GASKET

3 - WIPE PLUG SEAL


SOURCE HEAD NO. 5184



1, 2 - WIPE ALL AROUND GASKET

3 - WIPE SHUTTER SHAFT


SOURCE HEAD NO. 5194-95-96



1, 2 - WIPE AROUND BOTTOM OF BEAM SHROUD

3 - WIPE AROUND SOURCE HOLDER

SOURCE HEAD NO. 5197



1, 2 - WIPE AROUND SOURCE HEAD BASEPLATE

SOURCE HEAD NO. 5198

WITH MAILABLE LEAK TEST KIT, MAIL TO:  
TEXAS NUCLEAR  
9101 HWY 183, AUSTIN TEXAS 78766  
PHONE (512) 836-0801; TELEX: 77-6413

### CALCULATIONS FOR LEAK TESTING (QT/1S)

The following technique can be used to assess the presence of small amounts of radioactive material necessary during leak testing of gauging devices, using a Texas Nuclear Model 2652 Portable Survey Meter or equivalent that has the necessary sensitivity to detect 0.005  $\mu\text{Ci}$  or less of almost all gamma emitting isotopes and beta emitting isotopes with  $E_{\text{max}}$  greater than 80 KeV.

1. Turn on unit; check battery, verify unit operation and calibration using the supplied check source.
2. Place the appropriate certified standard source (Cs-137, Ra-226, etc.) disk on a clean flat surface and position the open end of the G. M. Tube over it and as close as possible without damaging the thin window. No fixture is necessary if the source is simply centered under the window. Set the range selector to give an approximate mid-scale reading. Note and record the observed readings;  $M_1$  (in either c/m or mR/h).
3. Remove the standard source away a few feet. With the G. M. probe in the same position, note and record the background (Bkg.) radiation in the same units as  $M_1$ .
4. Each swab end of the cotton-tipped applicators used in wiping the gauge is in turn placed in the same geometrical position as the above-noted standard. Note and record the observed meter reading,  $M_2$ .  $M_1$  and  $M_2$  must be taken in the same units.
5. To determine the degree of contamination in microcuries, a simple expression of proportionality is used:

$$\frac{A}{M_1} = \frac{C}{M_2} \quad \text{or} \quad C = \frac{A(\mu\text{Ci}) \times M_2 (\text{mR/h})}{M_1 (\text{mR/h})} \quad \text{where}$$

$A$  = activity of certified standard source in microcuries ( $\mu\text{Ci}$ );

$C$  = amount of removable contamination in microcuries ( $\mu\text{Ci}$ ); to be calculated

$M_1$  = survey meter reading with calibrated source in place in either milliroentgens per hour (mR/h) or counts per minute (cpm); minus background

$M_2$  = survey meter reading with swab in place in either mR/h or cpm minus background


Bkg. = survey meter reading with neither source nor swab near the G.M. probe in either mR/h or counts cpm. This should be subtracted as stated, however, the result can't be zero. Background will determine the lowest detectable level (conservatively taken as 2 times Bkg.).

### LEAK TEST PROCEDURE - QT/1S

QT/1S is designed for use by service people in the field and individuals who have received specific hands-on-training in its application. The gauge should not be dismantled or disassembled in order to leak test. Testing of the external seams, flanges and end plate is adequate.

1. If the gauge has a movable shutter, position the shutter actuator to the closed position. In the event that the shutter actuator is frozen, or appears damaged, notify Texas Nuclear Division, Health Physics Department (512/836-0801, Ext. 310).
  2. Refer to "Calculations for Leak Testing" before proceeding. Remove the end cap from the end window of the G.M. Survey Meter, Model 2652, or its equivalent, and with the use of the appropriate certified standard source, calibrate the unit on the proper scale. Insure that the most active side of the source faces the meter (the labeled side).
  3. Obtain as many cotton-tipped applicators as indicated on the applicable drawing and slightly moisten. (Use water, alcohol or other solvent.)
  4. With the shutter closed, wipe the areas of the source housing assembly at the locations designated on the appropriate drawings (care should be taken not to touch the Q-tips with the fingers following wiping operation).
  5. Carefully place the swab end of each Q-tip in exactly the same position as the standard source and read the results. The degree of removable contamination may be readily evaluated by the method referenced above. The highest reading obtained should be used in making the calculation.
  6. A leak test certificate should be completed and filed as a permanent record of your leak test. Amounts of radioactivity found should be recorded in microcuries ( $\mu\text{Ci}$ ). However, if no radioactivity is detected it is preferable to record the results as < (less than) the minimum detectable amount as opposed to zero. (e.g.,  $<0.003 \mu\text{Ci}$ ).\*
  7. One should send the wipes to a counting laboratory for additional analysis if any contamination appears on the wipes. Notify Texas Nuclear for instructions.
  8. Note: Generally it is advisable to use a certified standard source containing the same isotope as that being tested. However, this is not always necessary where the isotope is an energetic gamma emitter, e.g., Cs-137 standard will work for Co-60, Ir-192, Ra-226, etc., because these isotopes have higher exposure rates/ $\mu\text{Ci}$  than Cs-137.
- \* Leak Test Certificates furnished customers should include background reading and the meter reading of the certified standard source on the certificate.





May 21, 1984

King Equipment Co.  
140 Smith Street  
Keasbey, NJ 08832

Attention: Kevin L. Ravaioli

This is notification that you have successfully completed the Radiation Safety Training Course offered in May 1984 by Texas Nuclear.

Enclosed are the following:

- Record of Performance
- Certificate of Training
- Letter of Certification
- Guide For Specific License Amendment

This form letter suggests what may be said to your regulatory agency to obtain the license amendments necessary to conduct installation relocation, and leak testing on the listed Texas Nuclear industrial devices. Copies of procedures, survey and leak test forms from your course manual, with necessary changes to meet your specific requirements, should be sent with your license application as necessary.

Congratulations on your having completed the Radiation Safety Training Course. If we can be of further assistance to you, do not hesitate to let us know.

Sincerely,

TEXAS NUCLEAR CORPORATION

*W. Hendrick*

W. G. Hendrick  
Health Physicist

Enclosures





This is to certify that


Kevin L. Ravaioli  
King Equipment Co.

has attended and successfully completed a course of instruction, conducted under the auspices of Texas Nuclear Corporation and described in the attached Course Agenda. The course covers fundamentals of radiation, units of dose and quality of radiation fields, hazards of radiation exposure, detection devices, regulatory controls, industrial devices and specific training on installation and leak testing of Texas Nuclear density, level and weigh gauges.

The said course of instruction, together with prior experience, is structured to qualify persons who complete it to understand and safely perform various operations involving nuclear devices including the installation, relocation and leak testing of such equipment. The operations are to be done in accordance with the rules and regulations of the United States Nuclear Regulatory Commission and/or "Agreement States", and are in all respects subject to such rules and regulations.

This letter cannot be used in lieu of a specific license from or other sanction by an appropriate regulatory agency.

TEXAS NUCLEAR CORPORATION



W. G. Hendrick  
Health Physicist

## MATERIALS LICENSE

Pursuant to the Atomic Energy Act of 1954, as amended, the Energy Reorganization Act of 1974 (Public Law 93-438), and Title 10, Code of Federal Regulations, Chapter I, Parts 30, 31, 32, 33, 34, 35, 40 and 70, and in reliance on statements and representations heretofore made by the licensee, a license is hereby issued authorizing the licensee to receive, acquire, possess, and transfer byproduct, source, and special nuclear material designated below; to use such material for the purpose(s) and at the place(s) designated below; to deliver or transfer such material to persons authorized to receive it in accordance with the regulations of the applicable Part(s); and to import such byproduct and source material. This license shall be deemed to contain the conditions specified in Section 183 of the Atomic Energy Act of 1954, as amended, and is subject to all applicable rules, regulations and orders of the Nuclear Regulatory Commission now or hereafter in effect and to any conditions specified below.

Licensee		
1. KECO, Inc.		3. License number 29-20671-01
2. 140 Smith Street Keasbey, New Jersey 08832		4. Expiration date May 31, 1989
		5. Docket or Reference No. 030-20702
6. Byproduct, source, and/or special nuclear material	7. Chemical and/or physical form	8. Maximum amount that licensee may possess at any one time under this license
A. Cadmium 109	A. Sealed source (Texas Nuclear Model 696-696873)	A. Not to exceed 5 milli- curies per source
B. Iron 55	B. Sealed source (Texas Nuclear Model 696-696863)	B. Not to exceed 45 milli- curies per source
C. Americium 241	C. Sealed source (Texas Nuclear Model 696-696803)	C. Not to exceed 0.5 milli- curies per source
9. Authorized use		
A. through C. For use in Texas Nuclear Model 9266 portable X-ray fluorescent devices for demonstration and sales purposes.		

## CONDITIONS

10. Licensed material shall be used only at 140 Smith Street, Keasbey, New Jersey, and at temporary job sites in the State of New Jersey.
11. The licensee shall comply with the provisions of Title 10, Chapter 1, Code of Federal Regulations, Part 19, "Notices, Instructions, and Reports to Workers; Inspections" and Part 20, "Standards for Protection Against Radiation."
12. Licensed material shall be used by, or under the supervision and in the physical presence of, Gary L. King or employees who have successfully completed the Texas Nuclear training course in the safe use of the portable X-ray fluorescent devices described above.
13. A. (1) Each sealed source containing licensed material, other than Hydrogen 3, with a half-life greater than thirty days and in any form other than gas shall be tested for leakage and/or contamination at intervals not to exceed six months. In the absence of a certificate from a transferor indicating that a test has been made within six months prior to the transfer, a sealed source received from another person shall not be put into use until tested.

Date 16  
851240070

MATERIAL LICENSE  
SUPPLEMENTARY SHEET

PAGE	2	OF	3	PAGES
License number	29-20671-01			
Docket or Reference number	030-20702			

(13.A. continued)

CONDITIONS

- (2) The periodic leak test required by this condition does not apply to sealed sources that are stored and not being used. The sources excepted from this test shall be tested for leakage prior to any use or transfer to another person unless they have been leak tested within six months prior to the date of use or transfer.
- B. The test shall be capable of detecting the presence of 0.005 microcurie of radioactive material on the test sample. The test sample shall be taken from the sealed source or from the surfaces of the device in which the sealed source is permanently mounted or stored on which one might expect contamination to accumulate. Records of leak test results shall be kept in units of microcuries and maintained for inspection by the Commission.
- C. If the test reveals the presence of 0.005 microcurie or more of removable contamination, the licensee shall immediately withdraw the sealed source from use and shall cause it to be decontaminated and repaired or to be disposed of in accordance with Commission regulations. A report shall be filed within 5 days of the test with the U. S. Nuclear Regulatory Commission, Region I, 631 Park Avenue, King of Prussia, Pennsylvania 19406, describing the equipment involved, the test results, and the corrective action taken.
- D. The licensee is authorized to collect leak test samples in accordance with the procedures described in the licensee's letter dated April 26, 1984, for analysis by Texas Nuclear. Alternatively, leak test samples may be collected and/or analyzed by other persons specifically authorized by the Commission or an Agreement State to perform such services.
14. Sealed sources containing licensed material shall not be opened or removed from the portable X-ray fluorescent devices by the licensee.
15. The licensee shall conduct a physical inventory every six (6) months to account for all sealed sources received and possessed under the license. The records of the inventories shall be maintained for two (2) years from the date of the inventory for inspection by the Commission, and shall include the quantities and kinds of licensed material, location of sealed sources and the date of the inventory.
16. The licensee may transport licensed material or deliver licensed material to a carrier for transport in accordance with the provisions of Title 10, Code of Federal Regulations, Part 71, "Packaging of Radioactive Material for Transport and Transportation of Radioactive Material Under Certain Conditions."

MATERIALS LICENSE  
SUPPLEMENTARY SHEET

License number

29-20671-01

Docket or Reference number

030-20702

(continued)

## CONDITIONS

17. Except as specifically provided otherwise by this license, the licensee shall possess and use licensed material described in Items 6, 7, and 8 of this license in accordance with statements, representations, and procedures contained in application dated February 9, 1984, and letter dated April 26, 1984. The Nuclear Regulatory Commission's regulations shall govern the licensee's statements in applications or letters, unless the statements are more restrictive than the regulations.

For the U.S. Nuclear Regulatory Commission

Original Signed By:

By John E. Glenn

Nuclear Materials and Safeguards Branch  
Region I  
King of Prussia, Pennsylvania 19406

Date MAY 30 1984