



Commonwealth Edison  
1400 Opus Place  
Downers Grove, Illinois 60515

September 18, 1992

Dr. Thomas E. Murley, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attn: Document Control Desk

Subject: LaSalle County Station Units 1 and 2  
Correction to Technical Specification  
Surveillance Requirement 4.11.2.2.1  
Generic letter 89-01 Approved Changes  
NRC Docket Nos. 50-373 and 50-374

- References:
- (a) P.L. Piet letter to USNRC dated May 22, 1991; Application for Amendment to Facility Operating Licenses NPF-11 and NPF-18, Appendix A Technical Specifications, Generic Letter 89-01
  - (b) B.L. Siegel letter to T.J. Kovach dated September 1, 1992; Issuance of Amendments

Dear Dr. Murley,

In the reference (a) submittal, Commonwealth Edison (CECo) requested Amendment to the LaSalle County Station Technical Specifications to incorporate the guidance provided in Generic Letter 89-01, "Implementation of Programmatic Controls for Radiological Effluent Technical Specifications (RETS) in the Administrative Controls Section of the Technical Specifications and Relocation of Procedural Details of RETS to Offsite Dose Calculation Manual (ODCM) or Process Control Program (PCP)." In response, the NRC issued the reference (b) Safety Evaluation Report (SER) and changed Technical Specification pages.

During CECo's review of the SER, a correction to the Main Condenser Surveillance Requirement 4.11.2.2.1 for each Unit was noted. The amendment relocated the noble gas release information contained in Specification 3.3.7.11, then called Radioactive Gaseous Effluent Monitoring Instrumentation, revised to be called Explosive Gas Monitoring Instrumentation, to the ODCM. However, Main Condenser Surveillance Requirement 4.11.2.2.1 still referred to Specification 3.3.7.11 for noble gas monitoring. This Surveillance Requirement should have referenced the ODCM.

9209280133 920918  
PDR ADOCK 05000373  
PDR

ZNLD211919

AD09 11

September 18, 1992

CECo proposes that Surveillance Requirement 4.11.2.2.1 be corrected to read as follows:

The radioactivity rate of noble gases prior to the holdup line shall be continuously monitored in accordance with the ODCM.

A copy of the corrected Technical Specification pages is attached. This change does not change the intent of the original amendment request, as it corrects a reference Specification which changed as a part of relocating sections in the original request.

Please direct any questions to this office.

Respectfully,



JoAnn Shields  
Nuclear Licensing Administrator

Attachment

cc: A. Bert Davis, Regional Administrator - RIII  
B.L. Siegel, Project Manager - NRR  
D.L. Hillis, Senior Resident Inspector - LSCS  
Office of Nuclear Safety - IDNS