

GENERAL ELECTRIC

APPLICABLE TO:	
PUBLICATION NO.	<u>NEDO-24146A</u>
T. I. E. NO.	<u>79NED273</u>
TITLE	<u>LOCA ANALYSIS REPORT FOR</u>
	<u>DRESDEN UNITS 2, 3 AND QUAD</u>
	<u>CITIES 1,2 NUCLEAR POWER STATIONS</u>
ISSUE DATE	<u>April 1979</u>

ERRATA And ADDENDA SHEET

NO.	<u>10</u>
DATE	<u>April 1983</u>
<i>NOTE: Correct all copies of the applicable publication as specified below.</i>	

ITEM	REFERENCES (SECTION, PAGE PARAGRAPH, LINE)	INSTRUCTIONS (CORRECTIONS AND ADDITIONS)
1.	Page 4-11	Replace with new page 4-11.

Table 4I
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: P8DRB282

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.2	2132	0.029
1,000	11.2	2132	0.029
5,000	11.8	2183	0.033
10,000	12.0	2189	0.032
15,000	12.0	2199	0.033
20,000	11.8	2181	0.032
25,000	11.3	2110	0.025
30,000	11.1	2075	0.043
35,000	10.4	1981	0.035
40,000	9.8	1886	0.021

NOTE: Credit taken for the effects of pre-pressurization of the fuel rods

Table 4J
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: P8DRB265H/BP8DRB265H

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.5	2163	0.032
1,000	11.6	2171	0.032
5,000	11.9	2192	0.033
10,000	12.1	2198	0.033
15,000	12.1	2200	0.033
20,000	11.9	2190	0.032
25,000	11.3	2116	0.026
30,000	10.7	2018	0.018
35,000	10.2	1934	0.022
40,000	9.6	1835	0.009
45,000	8.9	1755	0.007

NOTE: Same as Table 4I

ATTACHMENT 3

NEDO-24146A E&A Sheet No. 13

dated January, 1985