

DMB

Iowa Electric Light and Power Company
January 22, 1985
NG-85-0232

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137


Subject: Duane Arnold Energy Center
Docket No: 50-331
Op. License No: DPR-49
National Pollutant Discharge Elimination
System (NPDES) Violation Report
Ref: Letter, L. Root to H. Denton, "License
Amendment 84 Regarding Water Quality
Requirements," NG-83-1424, April 25, 1983
File: A-107a, A-87g

Dear Mr. Keppler:

Per our referenced letter, Iowa Electric Light and Power Company agreed to submit to your office copies of all NPDES Violation Reports. Enclosed with this letter is a copy of the DAEC Sewage Treatment monthly monitoring report for December 1984. On December 17, 1984, total suspended solids were analyzed at 54 milligrams per liter, which is in violation of the NPDES limit of 45 milligrams per liter on an individual sample. The total suspended solids monthly average, 31 milligrams per liter, also exceeded our monthly limit of 30 milligrams per liter. These violations are the result of a power outage experienced at the DAEC Sewage Treatment Plant November 28-29, 1984, with the full biological effects developing several weeks later. Since December 17th, the conditions of the plant have been steadily improving.

Should you have any questions regarding this matter, please contact me.

Very truly yours,



Richard W. McGaughey
Manager, Nuclear Division

8502110369 850122
PDR ADDCK 05000331
S PDR

RWM/SAR/ta*
Attachment
cc: S. Reith
L. Liu
S. Tuthill
M. Thadani
H. Denton
NRC Resident Office

IE23
1/0