

September 25, 1992

Docket Nos. 50-361  
and 50-362

Mr. Harold B. Ray  
Senior Vice President  
Southern California Edison Co.  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Mr. Edwin A. Guiles  
Vice President  
Engineering and Operations  
San Diego Gas & Electric Co.  
101 Ash Street  
San Diego, California 92112

Gentlemen:

SUBJECT: WYLE TEST REPORT ON SEISMIC TESTING OF EXIDE BATTERIES

The attached letter is being provided for your use in the future for evaluating the operability of any aged and cracked Exide batteries installed at San Onofre, Units 2 and 3. It is the staff's understanding that all battery cells with cracked covers at San Onofre, Units 2 and 3, have been removed from service.

This letter, sent to Arizona Public Service Company, contains the results of the staff's review of the Wyle test report on seismic testing of aged and cracked Exide batteries. The staff concluded that the Wyle test had neither demonstrated the seismic qualification of aged and cracked batteries, nor provided an adequate justification for their continued service. The staff notes that this Wyle test report has been used in the past to justify continued operation of San Onofre, Units 2 and 3, when some of the older design Exide batteries contained in banks 2D1, 3D1, and 3D2 developed cracks in their covers. Because of the deficiencies identified by the staff in the Wyle test report, operability of aged and cracked Exide batteries of the type identified above should not be based on this Wyle test report alone. No new requirements are being established and no specific action or written response is required. If you have any questions, please contact me at (301) 504-3062.

Sincerely,

Original signed by

Mel B. Fields, Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

921001C : 920925  
PDR A K 05000361  
P PDR

Enclosure:  
9/22/92 ltr to APS

cc w/enclosure:  
See next page

DISTRIBUTION:

Docket Files BBoger TQuay  
MVirgilio ACRS (10)(P315) PDV p/f  
OGC (15B18) DFoster PDV r/f  
NRC & Local PDRs MFields KPerkins, RV

OFC	PDV/LA	PDV/PM	PDV/D	
NAME	DFoster <i>DFoster</i>	MFields <i>MFields</i>	TQuay <i>TQuay</i>	NRC FILE CENTER COPY
DATE	9/24/92	9/26/92	9/25/92	

OFFICIAL RECORD COPY

DOCUMENT NAME: SOWYLE.LTR

*DFOL*  
*1/1*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 25, 1992

Docket Nos. 50-361  
and 50-362

Mr. Harold B. Ray  
Senior Vice President  
Southern California Edison Co.  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Mr. Edwin A. Guiles  
Vice President  
Engineering and Operations  
San Diego Gas & Electric Co.  
101 Ash Street  
San Diego, California 92112

Gentlemen:

SUBJECT: WYLE TEST REPORT ON SEISMIC TESTING OF EXIDE BATTERIES

The attached letter is being provided for your use in the future for evaluating the operability of any aged and cracked Exide batteries installed at San Onofre, Units 2 and 3. It is the staff's understanding that all battery cells with cracked covers at San Onofre, Units 2 and 3, have been removed from service.

This letter, sent to Arizona Public Service Company, contains the results of the staff's review of the Wyle test report on seismic testing of aged and cracked Exide batteries. The staff concluded that the Wyle test had neither demonstrated the seismic qualification of aged and cracked batteries, nor provided an adequate justification for their continued service. The staff notes that this Wyle test report has been used in the past to justify continued operation of San Onofre, Units 2 and 3, when some of the older design Exide batteries contained in banks 2D1, 3D1, and 3D2 developed cracks in their covers. Because of the deficiencies identified by the staff in the Wyle test report, operability of aged and cracked Exide batteries of the type identified above should not be based on this Wyle test report alone. No new requirements are being established and no specific action or written response is required. If you have any questions, please contact me at (301) 504-3062.

Sincerely,

A handwritten signature in cursive script that reads "Mel B. Fields".

Mel B. Fields, Project Manager  
Project Directorate V  
Division of Reactor Projects III, IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
9/22/92 ltr to APS

cc w/enclosure:  
See next page

Messrs. Ray and Guiles  
Southern California Edison Company

cc:  
James A. Beoletto, Esq.  
Southern California Edison Company  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Chairman, Board of Supervisors  
County of San Diego  
1600 Pacific Highway, Room 335  
San Diego, California 92101

Alan R. Watts, Esq.  
Rourke & Woodruff  
701 S. Parker St. No. 7000  
Orange, California 92668-4702

Mr. Sherwin Harris  
Resource Project Manager  
Public Utilities Department  
City of Riverside  
3900 Main Street  
Riverside, California 92522

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering Nuclear Power  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Mr. Howard J. Wong  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. Don J. Womeldorf  
Chief, Environmental Management Branch  
California Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

San Onofre Nuclear Generating  
Station, Unit Nos. 2 and 3

Mr. Richard J. Kosiba, Project Manager  
Bechtel Power Corporation  
12440 E. Imperial Highway  
Norwalk, California 90650

Mr. Robert G. Lacy  
Manager, Nuclear Department  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Mr. Hank Kocol  
Radiologic Health Branch  
State Department of Health Services  
Post Office Box 942732  
Sacramento, California 94234

Resident Inspector/San Onofre NPS  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 4329  
San Clemente, California 92674

Mayor  
City of San Clemente  
100 Avenida Presidio  
San Clemente, California 92672

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 22, 1992

Docket Nos. 50-528, 50-529  
and 50-530

Mr. William F. Conway  
Executive Vice President, Nuclear  
Arizona Public Service Company  
Post Office Box 53999  
Phoenix, Arizona 85072-3999

Dear Mr. Conway:

SUBJECT: COMPLETION OF REVIEW OF WYLE TEST REPORT ON SEISMIC TESTING OF EXIDE BATTERIES - PALO VERDE NUCLEAR GENERATING STATION (TAC NOS. M84132, M84133, AND M84134)

We have completed our review of the "Seismic Simulation Test Program on Six Naturally-Aged Type 2GN Exide Batteries -- Wyle Test Report No. 42679-1." The test report contains the results of simulated seismic tests of six naturally-aged and cracked Exide Type 2GN Batteries subject to the Required Response Spectra (RRS) at the battery location in the Palo Verde Nuclear Generating Station. Although the staff did not conduct a detailed review of the input motion, it appears that the test procedures and the test input adequately follow the IEEE Standard 344-1975, except that the functional operability (voltage, current, etc.) of the batteries was not monitored. The test report concluded that the specimens still possessed some structural integrity to withstand the RRS without causing a catastrophic failure. However, the staff finds the results of the Wyle tests do not provide adequate basis to demonstrate that the aged and cracked batteries provide sufficient capacity and capability to perform their safety function in the event of an earthquake. The staff's rationale for this conclusion is provided in the following discussion.

Large lead storage batteries are used in nuclear power plants as a source of emergency power for vital instrumentation and control systems such as electrical distribution breaker control for engineering safety features, inverters for reactor protection instrument channels, and certain other safety-related equipment. Since safety-related lead storage batteries must meet design specifications throughout the batteries' installed life, the aged and cracked batteries must be qualified to the plant design specifications. In qualifying the aged and cracked battery cells, the batteries must undergo capacity tests to show that the aged and cracked battery cells are capable of performing their safety function before, during, and after a seismic event as delineated in Section 8.3.1.1 of ANSI/IEEE Standard 535. However, these capacity tests were not performed in the subject test program.


A further deficiency was noted in the Wyle test report concerning the lack of acceptance criteria and/or requirements for: (1) monitoring of the electrical functions (such as voltage, current, discharge rate for battery capacity,

~~9209280320 3pp.~~

etc.) before, during, and after the tests. Section 6.3.1 of the Wyle test report concluded that "the Batteries were still functioning electrically;" however, the report did not discuss how this determination was made; (2) initiating new cracks and/or propagating existing cracks in the battery cell cover and casing; and, (3) monitoring the acceptable fluid level in the battery cells during and after the test. The Wyle test results indicated that some of the existing cracks in the battery covers propagated and some new cracks appeared. It has also indicated that some battery fluid was lost, but it was unclear whether this loss has affected the electrical function.

Based on the above, the staff concludes that the Wyle test has neither demonstrated the seismic qualification of aged and cracked batteries, nor provided an adequate justification for their continued service. Therefore, batteries with cracks, whether in the cover or in the jar, should be replaced promptly.

Sincerely,



Charles M. Trammell, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. William F. Conway  
Arizona Public Service Company

Palo Verde

cc:

Nancy C. Loftin, Esq.  
Corporate Secretary & Counsel  
Arizona Public Service Company  
P. O. Box 53999, Mail Station 9068  
Phoenix, Arizona 85072-3999

Jack R. Newman, Esq.  
Newman & Holtzinger, P.C.  
1615 L Street, N.W., Suite 1000  
Washington, D.C. 20036

James A. Beoletto, Esq.  
Southern California Edison Company  
P. O. Box 800  
Rosemead, California 91770

Curtis Hoskins  
Executive Vice President and  
Chief Operating Officer  
Palo Verde Services  
2025 N. 3rd Street, Suite 220  
Phoenix, Arizona 85004

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
HC-03 Box 293-NR  
Buckeye, Arizona 85326

Roy P. Lessey, Jr., Esq.  
Bradley W. Jones, Esq.  
Arkin, Gump, Strauss, Hauer and Feld  
El Paso Electric Company  
1333 New Hampshire Ave., Suite 400  
Washington, D.C. 20036

Regional Administrator, Region V  
U. S. Nuclear Regulatory Commission  
1450 Maria Lane  
Suite 210  
Walnut Creek, California 94596

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering Nuclear Power  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Mr. William A. Wright, Acting Director  
Arizona Radiation Regulatory Agency  
4814 South 40 Street  
Phoenix, Arizona 85040

Chairman  
Maricopa County Board of Supervisors  
111 South Third Avenue  
Phoenix, Arizona 85003