SEP 2 3 1502

Docket Nos. 50-317 50-318

Mr. Robert E. Denton Vice President - Muclear Energy Baltimore Gas and Electric Company Calvert Cliffs Nuclear Power Plant MD Rts 2 and 4, Post Office Box 1535 Lusby, Maryland 20657

Dear Mr. Denton.

SUBJECT: VIOLATIONS 317/90-01-02 AND 318/90-01-02

This letter is in response to your actions regarding violation 317/90-01-02 and 318/90-01-02. These violations were in regard to your failure to comply with the experience requirements (3 years) for Level II visual inspectors as required by ANSI N45.2.6. The violations were issued even though the standard provides some relaxation in this area, provided other factors such as training are substituted for experience. In this case, you stated that your inspectors receive 40 hours of EPRI training in addition to a minimum of 3 months experience.

We agreed to accept your training program in this area provided you received a favorable code interpretation. On May 15, 1992, you received a favorable reply from the Code in this matter, a copy of which we have received. We accept your actions and withdraw the violations.

Thank you for your cooperation in this matter.

Sincerely,

Dr. Lordon, Blandel Lite. Success Dr. Diorr

Marvin W. Hodges Director Division of Reactor Safety

9210010145 9209 PDR ADOCK 0500

T3:01

Mr. Robert E. Denton

2

CC:

G. Detter, Director, Nuclear Regulatory Matters (CCNPP)
R. McLean, Administrator, Nuclear Evaluations
J. Waiter, Engineering Division, Public Service Commission of Maryland
K. Burger, Esquire, Maryland People's Counsel
R. Ochs, Maryland Safe Energy Coalition
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (ASIC)
NRC Resident Inspector
State of Maryland (2)

bcc w/encl:
Region I Docket Room (with concurrences)
C. Cowgill, DRP
J. Yerokun, DRP
L. Nicholson, DRP
S. Greenlee, DRP
P. Wilson, SEI - Calvert Cliffs
R. Lobel, OEDO
R. Capra, NRR
D. McDonald, NRR
DRS/EB SALP Coordinator

REDRS Kapian 1444 9/1 #92 RI:DRS Gray E/4L -9/2L/92



923/92

OFFICIAL RECORD COPY A:REPLY.CC