

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) **DIABLO CANYON UNIT 1** DOCKET NUMBER (2) **0 5 0 0 0 2 | 7 5 1** PAGE (3) **1 OF 0 1 2**

TITLE (4) **THIRTY (30) DAYS REPORTING PERIOD EXCEEDED**

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)
01	04	85	85	004	000	02	04	85		0 5 0 0 0
										0 5 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §. (Check one or more of the following) (11)

OPERATING MODE (9) 2	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(a)	<input type="checkbox"/> 90.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)
POWER LEVEL (10) 0 0 2	<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 90.36(a)(1)	<input type="checkbox"/> 90.73(a)(2)(v)	<input type="checkbox"/> 73.71(e)
	<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 90.36(a)(2)	<input type="checkbox"/> 90.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	<input type="checkbox"/> 20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 90.73(a)(2)(i)	<input type="checkbox"/> 90.73(a)(2)(vii)(A)	
	<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 90.73(a)(2)(ii)	<input type="checkbox"/> 90.73(a)(2)(vii)(B)	
	<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 90.73(a)(2)(iii)	<input type="checkbox"/> 90.73(a)(2)(x)	

LICENSEE CONTACT FOR THIS LER (12)

NAME **DAVID P. SISK, REGULATORY COMPLIANCE ENGINEER** TELEPHONE NUMBER **8 0 5 5 9 5 - 7 3 5 1**

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14) YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15) MONTH DAY YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On January 4, 1985, with Unit 1 in Mode 2 (Startup), the 30-day time period allowed for the submittal of a special report on nonfunctional fire barriers had been exceeded.

On November 28, 1984, the installation of a Public Address System cable in the 4kV cable spreading rooms caused two fire barriers to become nonfunctional. Technical Specification 3.7.10, Action Statement a. requires that a special report be submitted within 30 days for fire barriers that remain nonfunctional in excess of 7 days.

The unsealed penetrations were discovered during a walkdown on January 8, 1985. The fire barriers were repaired and declared functional on January 9, 1985.

The cause of this event was the failure to follow procedure. Construction personnel failed to list two fire barriers on a Clearance Request (CR). To prevent recurrence, all Project Team personnel who prepare CRs and the Construction Entry Permit (CEPs) are receiving additional training emphasizing that the locations for work must be correctly, completely, and uniformly identified on the CR.

IE22
4/

8502110602 850204
PDR AD0CK 05000275
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) DIABLO CANYON UNIT 1	DOCKET NUMBER (2) 0 5 0 0 0 2 7 5 8 5	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 5	0 0 4	0 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On January 4, 1985, with Unit 1 in Mode 2 (Startup), the 30 day time period allowed for the submittal of a special report on fire barriers had been exceeded.

On November 28, 1984, the installation of Public Address System cable in the 4kV cable spreading rooms caused two fire barrier penetrations to become nonfunctional. Technical Specification 3.7.10, Action Statement a. requires that a special report be submitted within 30 days for fire barriers that remain nonfunctional in excess of 7 days.

Two additional requirements of Action Statement a., however, were met as follows: The fire watch requirement was met by a previously established roving fire watch that patrols the area hourly. The operability of fire detectors in the area is verified continuously by the self-monitoring fire detection system.

The unsealed penetrations were discovered during a walkdown on January 8, 1985. The fire barriers were repaired and declared functional on January 9, 1985.

The cause of this event was the failure to follow procedure, in that construction personnel failed to list two fire barriers on the Clearance Request (CR). The Construction Entry Permit (CEP) listed five penetrations, but only three non fire barrier penetrations were listed on the CR.

To prevent recurrence, all Project Team General Construction and contractor personnel who prepare CEPs and CRs, are receiving additional training emphasizing that the locations for work must be correctly, completely, and uniformly identified on the CR. This information is being incorporated in Project Instruction PI-8, "Clearance Information and Tagging."

This event had no safety consequences and in no way affected the health and safety of the public.

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER
VICE PRESIDENT
NUCLEAR POWER GENERATION

February 4, 1985

PGandE Letter No.: DCL-85-052

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80
Diablo Canyon Unit 1
Licensee Event Report 85-004-00
Thirty (30) Days Reporting Period Exceeded


Gentlemen:

Pursuant to 10 CFR 50.73(a)(2)(i), PGandE is submitting the enclosed Licensee Event Report concerning the failure to submit a special report regarding non-functional fire barriers within 30 days as required by Technical Specification 3.7.10, Action Statement a.

This event has in no way affected the public's health and safety

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,



Enclosure

cc: J. B. Martin
Service List

IE 22

41