

Docket No. 50-416

September 24, 1992

LICENSEE: Entergy Operations, Inc.

FACILITY: Grand Gulf Nuclear Station

SUBJECT: SUMMARY OF A MEETING ON SEPTEMBER 4, 1992, REGARDING THE GRAND GULF NUCLEAR STATION SHUTDOWN RISK ANALYSIS

On September 4, 1992, representatives of Entergy Operations, Inc., and its contractor, Erin Engineering and Research, Inc., briefed NRC management and staff on Grand Gulf Nuclear Station Shutdown Risk Activities and on the methodology and generic results of the Probabalistic Shutdown Safety Assessment sponsored by the Electric Power Research Institute (EPRI) and carried out by Erin Engineering. Meeting attendees are listed in Enclosure 1. Slides presented by Entergy and Erin Engineering are in Enclosure 2.

This meeting provided an opportunity for representatives of NRC management and staff involved in probabalistic risk assessment (PRA) and shutdown risk assessment to have a detailed discussion of the methodology and results achieved thus far in the Grand Gulf shutdown risk activities.

ORIGINAL SIGNED BY:

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Meeting attendees
- 2. Slides

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File	JWechselberger
NRC & Local PDRs	EMerschhoff, RII
TMurley/fMiraglia	PO'Connor
JPartlow	PNoonan
BBoger	OGC
MVirgilio	EJordan
JLarkins	JDixon
GHolahan	ACRS (10)
PD4-1 Reading	MCaruso
HVandermolen	RRobinson
GThomas	MRubin
PD4-1 Reading	

200005

NRC FILE CENTER COPY

OFC	LA:PD4-1	PM:PD4-1 <i>fwoc</i>	PD:PD4-1 <i>fwoc</i>
NAME	PNoonan	PO'Connor:pk	JLarkins <i>STL</i>
DATE	9/24/92	9/24/92	9/24/92

OFFICIAL RECORD COPY Document Name: GGSept4.mts

9210010169 520924
PDR ADOCK 05000416
P PDR

DF01

September 24, 1992

LICENSEE: Entergy Operations, Inc.

FACILITY: Grand Gulf Nuclear Station

SUBJECT: SUMMARY OF A MEETING ON SEPTEMBER 4, 1992, REGARDING THE GRAND GULF NUCLEAR STATION SHUTDOWN RISK ANALYSIS

On September 4, 1992, representatives of Entergy Operations, Inc., and its contractor, Erin Engineering and Research, Inc., briefed NRC management and staff on Grand Gulf Nuclear Station Shutdown Risk Activities and on the methodology and generic results of the Probabalistic Shutdown Safety Assessment sponsored by the Electric Power Research Institute (EPRI) and carried out by Erin Engineering. Meeting attendees are listed in Enclosure 1. Slides presented by Entergy and Erin Engineering are in Enclosure 2.

This meeting provided an opportunity for representatives of NRC management and staff involved in probabalistic risk assessment (PRA) and shutdown risk assessment to have a detailed discussion of the methodology and results achieved thus far in the Grand Gulf shutdown risk activities.

ORIGINAL SIGNED BY:

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Meeting attendees
2. Slides

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File	JWechselberger
NRC & Local PDRs	EMerschhoff, RII
TMurley/FMiraglia	PO'Connor
JPartlow	PNoonan
BBoger	OGC
MVirgilio	EJordan
JLarkins	JDixon
GHolahan	ACRS (10)
PD4-1 Reading	MCaruso
HVandermolen	RRobinson
GThomas	MRubin
PD4-1 Reading	

OFC	LA:PD4-1 <i>pk</i>	PM:PD4-1 <i>pk</i>	PD:PD4-1 <i>pk</i>
NAME	PNoonan <i>pk</i>	PO'Connor:pk	JLarkins <i>pk</i>
DATE	9/24/92	9/24/92	9/24/92

Entergy Operations, Inc.
Grand Gulf Nuclear Station

cc:

Mr. Donald C. Hintz, President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. 31995
Jackson, Mississippi 39286-1995

Robert B. McGehee, Esquire
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39205

Nicholas S. Reynolds, Esquire
Winston & Strawn
1400 L Street, N.W. - 12th Floor
Washington, D.C. 20005-3502

Mr. Jack McMillan, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, Mississippi 39209

President,
Claiborne County Board of Supervisors
Port Gibson, Mississippi 39150

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., Suite 2900
Atlanta, Georgia 30323

Mr. Michael J. Meisner
Director, Nuclear Licensing
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

Mr. Johnny Mathis
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 399
Port Gibson, Mississippi 39150

Mr. D. L. Brannen, Vice President
Bechtel Power Corporation
P.O. Box 2166
Houston, Texas 77252-2166

Mr. C. R. Hutchinson
GGNS General Manager
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, Louisiana 70804-9005

Aiton B. Cobb, M.D.
State Health Officer
State Board of Health
P. O. Box 1700
Jackson, Mississippi 39205

Office of the Governor
State of Mississippi
Jackson, Mississippi 39201

Mike Morre, Attorney General
Frank Spencer, Asst. Attorney General
State of Mississippi
Post Office Box 22947
Jackson, Mississippi 39225

Mr. John P. McGaha
Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, Mississippi 39286-1995

Mr. S. S. Chan
Project Engineer
Bechtel Power, Corp.
P.O. Box 2166
Houston, Texas 77252-2166

Mr. William T. Cottle
Vice President, Operations, Inc.
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

September 24, 1992

LICENSEE: Entergy Operations, Inc.

FACILITY: Grand Gulf Nuclear Station

SUBJECT: SUMMARY OF A MEETING ON SEPTEMBER 4, 1992, REGARDING THE GRAND GULF NUCLEAR STATION SHUTDOWN RISK ANALYSIS

On September 4, 1992, representatives of Entergy Operations, Inc., and its contractor, Erin Engineering and Research, Inc., briefed NRC management and staff on Grand Gulf Nuclear Station Shutdown Risk Activities and on the methodology and generic results of the Probabalistic Shutdown Safety Assessment sponsored by the Electric Power Research Institute (EPRI) and carried out by Erin Engineering. Meeting attendees are listed in Enclosure 1. Slides presented by Entergy and Erin Engineering are in Enclosure 2.

This meeting provided an opportunity for representatives of NRC management and staff involved in probabalistic risk assessment (PRA) and shutdown risk assessment to have a detailed discussion of the methodology and results achieved thus far in the Grand Gulf shutdown risk activities.

ORIGINAL SIGNED BY:

Paul W. O'Connor, Senior Project Manager
 Project Directorate IV-1
 Division of Reactor Projects - III/IV/V
 Office of Nuclear Reactor Regulation

Enclosures:

1. Meeting attendees
2. Slides

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File	JWuchselberger
NRC & Local PDRs	EMerschhoff, RII
TMurley/FMiraglia	PO'Connor
JPartlow	PNoonan
BBoger	OGC
MVirgilio	EJordan
JLarkins	JDixon
GHolahan	ACRS (10)
PD4-1 Reading	MCaruso
HVandermolen	RRobinson
GThomas	MRubin
PD4-1 Reading	

OFC	LA:PD4-1	PM:PD4-1	PD:PD4-1
NAME	PNoonan	PO'Connor:pk	JLarkins
DATE	9/24/92	9/24/92	9/24/92



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 24, 1992

Docket No. 50-416

LICENSEE: Entergy Operations, Inc.

FACILITY: Grand Gulf Nuclear Station

SUBJECT: SUMMARY OF A MEETING ON SEPTEMBER 4, 1992, REGARDING THE GRAND GULF NUCLEAR STATION SHUTDOWN RISK ANALYSIS

On September 4, 1992, representatives of Entergy Operations, Inc., and its contractor, Erin Engineering and Research, Inc., briefed NRC management and staff on Grand Gulf Nuclear Station Shutdown Risk Activities and on the methodology and generic results of the Probabilistic Shutdown Safety Assessment sponsored by the Electric Power Research Institute (EPRI), and carried out by Erin Engineering. Meeting attendees are listed in Enclosure 1. Slides presented by Entergy and Erin Engineering are in Enclosure 2.

This meeting provided an opportunity for representatives of NRC management and staff involved in probabilistic risk assessment (PRA) and shutdown risk assessment to have a detailed discussion of the methodology and results achieved thus far in the Grand Gulf shutdown risk activities.

A handwritten signature in cursive script that reads "Paul W. O'Connor".

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Meeting attendees
2. Slides

cc w/enclosures:

See next page

Entergy Operations, Inc.
Grand Gulf Nuclear Station

cc:

Mr. Donald C. Hintz, President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. 31995
Jackson, Mississippi 39286-1995

Robert B. McGehee, Esquire
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39205

Nicholas S. Reynolds, Esquire
Winston & Strawn
1400 L Street, N.W. - 12th Floor
Washington, D.C. 20005-3502

Mr. Jack McMillan, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, Mississippi 39209

President,
Claiborne County Board of Supervisors
Port Gibson, Mississippi 39150

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., Suite 2900
Atlanta, Georgia 30323

Mr. Michael J. Meisner
Director, Nuclear Licensing
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

Mr. Johnny Malhis
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 399
Port Gibson, Mississippi 39150

Mr. D. L. Brannen, Vice President
Bechtel Power Corporation
P.O. Box 2166
Houston, Texas 77252-2166

Mr. C. R. Hutchinson
GGNS General Manager
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, Louisiana 70804-9005

Alton B. Cobb, M.D.
State Health Officer
State Board of Health
P. O. Box 1700
Jackson, Mississippi 39205

Office of the Governor
State of Mississippi
Jackson, Mississippi 39201

Mike Morre, Attorney General
Frank Spencer, Asst. Attorney General
State of Mississippi
Post Office Box 22947
Jackson, Mississippi 39225

Mr. John P. McGaha
Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, Mississippi 39286-1995

Mr. S. S. Chan
Project Engineer
Bechtel Power, Corp.
P.O. Box 2166
Houston, Texas 77252-2166

Mr. William T. Cottle
Vice President, Operations, Inc.
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

September 4, 1992

Grand Gulf Nuclear Station Shutdown Risk Analysis Meeting

List of Attendees

Paul W. O'Connor
Jean-Pierre Sursock
Jennifer Dixon
George Alan Zinke
Jim Hewitt
John Gaertner
Mark Caruso
Harold Vandermolen
Richard Robinson
Geroge Thomas
Mark Rubin
Gary Holahan

NRR/PD4-1
EPRI
NRR/RSIB
Entergy/Grand Gulf
ERIN/Grand Gulf
ERIN/Grand Gulf
NRR/SRXB
RES/DSIR/PRAB
RES/DSIR/PRAB
NRR/DST/SRXB
NRR/SRXB
NRR/DST

**Grand Gulf Nuclear Station
Presentation to NRC Staff
September 4, 1992**

**PRA
and
Shutdown Risk Management**

- Introduction - George Zinke
Grand Gulf shutdown
risk activities

- Probabilistic Shutdown John Gaertner/
Jim Hewitt
Safety Assessment
 - methodology
 - generic results

- Insights from Grand George Zinke
Gulf RF05

Introduction

Grand Gulf Shutdown

Risk Activities

GGNS Shutdown Risk Activities

1989

1990

1991

1992

1993

SANDIA SHUTDOWN PRA FOR GRAND GULF

BWROG OPCON 4/5 COMMITTEE

△ VOGTLE

NRC STAFF PLAN FOR EVALUATING SHUTDOWN RISK

GGNS SITE VISIT

DRAFT NUREG 1449

BWROG SHUTDOWN ISSUES COMMITTEE

NUMARC SHUTDOWN PLANT ISSUES WORKING GROUP

NUMARC GUIDELINES (91-06) PUBLISHED

RFOS PLANNING

EPRI PSSA FOR GGNS

EPRI RISK MANAGEMENT GUIDELINES FOR GGNS

GGNS IMPLEMENT NUMARC 91-06

OUTAGE RISK REVIEW

RFOS

POST OUTAGE CRITIQUE

SELECTED OUTAGE INSIGHTS SAFETY-SIGNIFICANT EVENT TRENDS

	<u>Length</u>	<u># of IRs</u>	<u>IR/day</u>	<u># of LERs</u>	<u>LERs by day</u>
RF01	88 days	60	.68	20	.23
RF02	61 days	48	.79	12	.20
RF03	44 days	30	.68	5	.11
RF04	57 days	32	.56	9	.16
RF05	52 days	25	.48	4	.08

- IRs/LERs capture all significant outage events
- Positive trend is real - i.e. not due to changing thresholds/definitions

Probabilistic Shutdown

Safety Assessment

Insights From

Grand Gulf RF05

EVENT REVIEW RESULTS

LOSS OF COOLANT ACCIDENT

- At low water levels, insufficient water in Suppression Pool for recirculation path
- Primary Containment not established

ACTIONS:

- Schedule changed to minimize low water level periods
- External water sources available
- Floodable primary containment

*Need To have proceeded to
re establish containment integrity.*

EVENT REVIEW RESULTS

STATION BLACKOUT

- Time to boil is key parameter
 - Decay heat load
 - Water volume
 - Time to recover power
- Highest risk period is early in outage (high decay heat) with vessel not flooded in upper pool (low water volume)

ACTIONS:

- Changed schedule to maintain Division III D/G operable during low water volume at beginning of outage
- Completed action based on NUREG 1410 to increase safety in switchyard activities
- Contingency plan to include actions to prevent loss of power

EVENT REVIEW RESULTS

FIRE

*when protected division
is out there needs to
be additional
measures*


- GGNS protects Division I in accordance with Appendix R
- Division I outage relies on unprotected Division II

ACTIONS:


- Focus on prevention:
 - Knowledgeable personnel
 - Limiting ignition sources *in non protected division*
 - Additional vigilance for Division II

RF04 CORE DAMAGE RISK

(Actual Events and Data)




RF04 CORE DAMAGE RISK




RF05 CORE DAMAGE RISK

(As Scheduled, February 1992)




RF05 CORE DAMAGE RISK

(As Scheduled, April 1992)




RF05 CORE DAMAGE RISK

(Actual Events and Data)




RF05 CORE DAMAGE RISK

(ACTUAL EVENTS AND DATA)




RF04 RCS BOILING RISK

(ACTUAL EVENTS AND DATA)




RF04 RCS BOILING RISK (ACTUAL EVENTS AND DATA)




RF05 RCS BOILING RISK

(AS SCHEDULED, FEBRUARY 1992)




RCS BOILING RISK IN MODES 4 AND 5

(AS SCHEDULED, APRIL 1992)




RCS BOILING RISK IN MODES 4 AND 5

(ACTUAL EVENTS AND DATA)



RISK OF RCS BOILING IN MODES 4 AND 5

(ACTUAL EVENTS AND DATA)



SELECTED INSIGHTS

- Coincidence of high decay heat and low water level should be minimized
- Sensitivity to suppression/fuel pool levels and LOCA
- Maintain RCS temperature well below Tech Spec limits to increase thermal margin
- AC power failures are a small risk contributor, unlike at-power operations
- Emergency procedures were designed with operating conditions in mind and do not reflect all unique plant configurations during shutdown
- Maintain shutdown cooling valve manipulations to a minimum
- Investigate the need for better contingency plans to restore primary containment

EPRI
OUTAGE RISK ASSESSMENT
AND MANAGEMENT (ORAM)

PROGRAM OVERVIEW

Presented to:


U.S. Nuclear Regulatory Commission

By: *ERIN*[®] *Engineering and Research, Inc.*

For: Entergy Operations, Inc.

September 1992

OUTAGE SAFETY & MANAGEMENT PROGRAM STRUCTURE




STEPS IN ORAM PROCESS

- Understanding Current Practices and Needs (Utility Survey, NSAC-173/174)
- Development of Probabilistic Shutdown Safety Assessment (PSSA, NSAC-175/176).
- Development of Risk Management Process (RMG, end of 1992)
- Applications of PSSA and RMG using ORAM-TIP (end of 1992)

BENEFITS OF ORAM PARTICIPATION

- Plan and control for outage safety
- Respond to NUMARC, INPO, NRC attention to safety
- Make decisions from safety perspective

OVERVIEW OF PSSA METHODOLOGY



FEATURES OF PSSA METHODOLOGY



- Initiators determined from experience
- Multiple endstates
- Outage model is timeline of Plant States
- Accident sequences using event trees
- Top events modeled, emphasizing
 - Human actions
 - Train unavailabilities
- Results displayed as
 - Frequencies vs. time
 - Insights for risk management

QUESTIONS ANSWERED BY PSSA


- What Initiators are of concern and when?
- What subsequent failures are important?
- What unavailabilities are important?
- What contingency plans are important?
- What human actions are critical?
- What issues are worthy of consideration?

OVERVIEW OF RISK MANAGEMENT AND CONTINGENCY GUIDELINES

USE FOR OUTAGE PLANNING





RM																						
DRR																						
IC																						
MCS																						
COR																						
SS																						



- Do's
- Don'ts
- Backup System
- Initiating Events
- Contingencies

USE FOR OUTAGE CONTROL



- Do's
- Don'ts
- Backup System
- Initiating Events
- Contingencies



FEATURES OF RMG METHODOLOGY


- Outage represented as series of plant states
- Safety reviewed in terms of shutdown safety functions
- Each plant state/safety function combination reviewed with an SSFAT
- Level of safety function support represented by "color"
- Risk Management Guidance (RMG) specific to each plant state/safety function/color
- RMGs derived from PSSA, industry experience, and lessons learned

FEATURES OF RMG METHODOLOGY (continued)

- RMG process supportive of NIMARC initiative, INPO guidance, NUREG-1449
- To be used in outage planning, control, and post-outage
- Based on "Defense in Depth"
- Identifies need for Contingency Plans
- Provides graded approach depending on level of safety function support

EXAMPLE SSFAT FORMAT

Safety Function: Shutdown Cooling



KEY SAFETY FUNCTIONS CONSIDERED IN RMG

- Reactivity Control
- Shutdown Cooling
- Fuel Pool Cooling
- Inventory Control
- Electric Power Control
- Vital Support System Control
- Primary and Secondary Containment Control

RISK MANAGEMENT GUIDELINES (INVENTORY)

Plant State(s)	Color Code	Guideline	Technical Easis
	0	<p>Maintain enough water in the suppression pool, CST, and RWST to keep suppression pool water level above 14.5 ft after a LOCA. For the CST, credit only the volume above the level of 18 ft.</p>	<p>ECCS pump operation with SP level below 14.5 ft could be unstable and cause equipment damage (EP-2, Caution #5).</p> <p>Per Technical Specifications, when in Modes 4 and 5 with suppression pool level below 12 ft 8 in, the CST must have 170,000 gallons reserved for HPCS use. This corresponds to a CST level of 18 feet. Only the volume above that level is available if HPCS injection fails. This excess volume could be transferred to the RCS through either the CRD or condensate transfer system.</p>

RISK MANAGEMENT GUIDELINES


(SHUTDOWN COOLING, SFP COOLING)

Plant State(s)	Color Code	Guideline	Technical Basis
<p>Mode 3-4</p> <p>Mode 5, UPPER POOL = "EMPTY"</p>	<p>Y</p>	<p>Avoid activities which increase the chance of disabling the decay heat removal system. In particular, surveillance testing of RPV water level instrument channels should be deferred whenever possible. These include:</p> <ul style="list-style-type: none"> • Channel checks, functional tests, and calibration • Logic system functional tests • Isolation system response time demonstrations <p>These activities have been among the dominant causes of inadvertent RPV, containment, and auxiliary building isolation events.</p>	<ul style="list-style-type: none"> • NSAC-i75 <p>The chance of decay heat removal system isolation events dominates the chance of RCS boiling when not in Mode 5 with the refueling cavity flooded. The time to recover from an isolation event may be short, but, based on industry experience, it remains significant compared to the time for RCS boiling.</p>

ORAM-TIP: WHAT IS IT?

- Outage Risk Assessment and Management -
Technology Integration Package
- Outage safety PC workstation software
- Integrates products of EPRI ORAM project

ORAM-TIP MODULES



RESOURCE REQUIREMENTS FOR PSSA

A. Creation of PSSA Plant Model

- 6-8 person-months
- Based on Peach Bottom experience

B. Evaluate a New Outage with Existing Model

- 1-2 person-months
- Based on Grand Gulf experience

C. Type of Expertise Required

- PRA experience helpful to build model
- Outage planning personnel to apply model

EPRI
BWR SHUTDOWN SAFETY ASSESSMENT:
RESULTS, INSIGHTS, AND METHOD

Presentation to:
US NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION

By:
Jim Hewitt
John Gaertner
September 4, 1992

FOUR QUESTIONS FOR A PSSA

- I. How does plant safety vary over the course of an outage?
- II. Which factors dominate risk?
- III. How can plant safety best be improved?
- IV. How do PSSA results compare with other plant safety measures?

SCOPE

Site: Grand Gulf Nuclear Station (GGNS), a BWR/6 with a modified Mark III containment.

Outage: GGNS' fourth refueling outage (RFO4).

- Fuel shuffling
- Few switchyard activities
- Major Division I outage
- ~ 2 week delay in RPV disassembly
- (Non-safety) Plant service water outage
- 3 short-lived shutdown cooling isolation events
- Suppression pool draining (~ 2 feet)

Endstates Evaluated:

- RCS boiling in Cold Shutdown and Refueling
- Spent Fuel Pool boiling
- Core damage
- Prompt criticality
- Cold overpressurization
- Fuel bundle uncover while in transit
- Radionuclide release


CONTRASTING RISK ASSESSMENT METHODS

TOPIC	STANDARD PRA	CHRONOLOGICAL RISK MODEL
Plant States	1	∞
Maintenance Unavailability	"AVERAGE" Unavailability	0-1 Values
Fault Tree	Components	Trains
Event Tree	Multiple Safety Functions	Single Safety Function
Quantification Tool	REBECA	LOTUS-123
Validity	Plant Life	Specific Outage


QUESTION #1

How does plant safety vary
over the course of an outage?

RCS BOILING RISK IN MODES 4 AND 5




MARK III SUPPRESSION POOL




RFO4 CORE DAMAGE RISK

(INVENTORY CONTROL FAILS - FUEL IN RPV)




RF04 SFP BOILING RISK




QUESTION #2

Which factors dominate
shutdown risk?


RISK OF RCS BOILING IN MODES 4 AND 5



RF04 CORE DAMAGE RISK



RF04 SFP BOILING RISK



III. How can plant safety best be improved?

SAFETY MEASURE

RCS BOILING

SAFETY MANAGEMENT INSIGHTS

- Carefully schedule key tasks (those associated with SDC or RPV isolation)
- Increase RCS thermal margin
- Keep suppression pool level near normal during Mode 4
- Plan for suppression pool use in Mode 5
- Strengthen procedures governing RHR system valves
- Recognize the risk of operating with only one DHR train available, even in Mode 5 HWL
- Reduce the number of DHR valve manipulations

BRIN

III. How can plant safety best be improved? (continued)

SAFETY MEASURE

SAFETY MANAGEMENT INSIGHTS

CORE DAMAGE

- Carefully schedule tasks requiring low suppression pool level
- Develop inventory control plan when suppression pool level is low
- Develop contingency plans for restoring containment during Mode 5

REACTIVITY EXCURSION
(Prompt Critical Event)

- Strengthen controls to avoid misplaced fuel bundles

COLD
OVERPRESSURIZATION

- Strengthen procedures governing CRD pump operation during Mode 4

IV. How do PSSA results compare with other plant safety measures?

SAFETY MEASURE	PSSA RESULT	COMPARABLE STATISTICS
RCS BOILING	1.5E-2/year	US BWRs, 1977-1989 1.6E-2/year
CORE DAMAGE	3.5E-6/year - 89% LOCA	NUREG/CR-4550 4.0E-6/year - 94% Station blackout - 6% ATWS
		RSSMAP - 72% Transient - 15% ATWS - 13% LOCA
		SEABROOK - MODES 4, 5, and 6 4.5E-5/year - 82% Loss of RHR - 18% LOCA

SHUTDOWN SAFETY ANALYSIS MODEL

INITIATING EVENTS




PLANT STATES

STATE	TIME	COMMENT	SYSTEM A - SYSTEM X
1			
2			
3			
4			
.			
.			
.			
.			
.			
.			


EVENT TREE SEQUENCES



Σ_i Initiator




Σ_j Plant State




DETAIL A

INITIATOR	SYSTEM FAILURES				SEQUENCE PROBABILITY
F_i	P_{i1}	P_{i2}	DET B	P_{in}	$\prod_{k=1}^n P_{ik}$



DETAIL B




GRAND OIL FIELD SHUTDOWN PLANT STATES DATABASE

Plant State	DATE	hour:min	Exposure Days after Shutdown	TIME	MODE	COMMENT	RPV Level	Press	Pool	Supp. Pool	Upper Pool	SFP	Containment
1	30-Sep-90	6 0	0.3	0.3	3	GREATER THAN 135 PSIG	34	+135	NORMAL		FULL	BEFORE	INTACT
2	30-Sep-90	12 0	0.1	0.3	3	LESS THAN 135 PSIG	34	+135	NORMAL		FULL	BEFORE	INTACT
3	30-Sep-90	14 3	0.0	0.3	3	3 900 Valve Manipulation Begins	34	+135	NORMAL		FULL	BEFORE	INTACT
4	30-Sep-90	14 3	0.0	0.3	3	3 START RIB A	34	+135	NORMAL		FULL	BEFORE	INTACT
5	30-Sep-90	14 3	0.1	0.2	3	3 900 Valve Manipulation Complete	34	+135	NORMAL		FULL	BEFORE	INTACT
6	30-Sep-90	16 20	0.0	0.4	4	FLOOD VESSEL ABOVE FLANGE FOR CODE BOUND	230	0	NORMAL		FULL	BEFORE	INTACT
7	30-Sep-90	17 30	0.1	0.5	4	1 B/B, DIV III B/B, NPCC Tagout	230	0	NORMAL		FULL	BEFORE	INTACT
8	30-Sep-90	19 0	0.0	0.5	4	DECOMBAT CONTAINMENT RELEASED	230	0	NORMAL		FULL	BEFORE	INTACT
9	30-Sep-90	20 10	0.1	0.6	4	SMOKE VACUUM	230	0	NORMAL		FULL	BEFORE	INTACT
10	30-Sep-90	23 30	0.0	0.7	4	PRIMARY CONTAINMENT MATCHES OPER	230	0	NORMAL		FULL	BEFORE	INTACT
11	01-Oct-90	0 0	0.2	0.8	4	8/9 COMPENSATE	230	0	NORMAL		FULL	BEFORE	INTACT
12	01-Oct-90	5 30	0.0	1.0	4	REACTOR CAVITY GATE SET	230	0	NORMAL		EMPTY	BEFORE	INTACT
13	01-Oct-90	5 40	0.0	1.0	4	Reactor Pumped Out	230	0	NORMAL		EMPTY	BEFORE	INTACT
14	01-Oct-90	6 40	0.4	1.0	4	COMPLETED CAVITY MAINT	230	0	NORMAL		EMPTY	BEFORE	INTACT
15	01-Oct-90	13 30	0.0	1.4	4	RIB B STOPPED - TEMPORARY	230	0	NORMAL		EMPTY	BEFORE	INTACT
16	01-Oct-90	16 10	0.2	1.4	4	RIB B STOPPED - TEMPORARY	230	0	NORMAL		EMPTY	BEFORE	INTACT
17	01-Oct-90	20 15	0.0	1.6	4	RIB B STOPPED - TEMPORARY	230	0	NORMAL		EMPTY	BEFORE	INTACT
18	01-Oct-90	21 13	0.1	1.5	4	START RIB B	230	0	NORMAL		EMPTY	BEFORE	INTACT
19	01-Oct-90	22 59	0.2	1.7	4	LINEUP P11 FOR CAVITY RIB B TO SP	230	0	NORMAL		EMPTY	BEFORE	INTACT
20	02-Oct-90	3 29	0.0	1.9	4	RIB B STOPPED	230	0	NORMAL		EMPTY	BEFORE	INTACT
21	02-Oct-90	3 29	0.3	1.9	4	RESTART RIB B	230	0	NORMAL		EMPTY	BEFORE	INTACT
22	02-Oct-90	11 3	0.0	2.2	4	ISOLATED RIB B PUGIL; RIB A OUT	230	0	REDUCED		EMPTY	BEFORE	INTACT
23	03-Oct-90	5 3	0.0	3.0	4	RIB B STOPPED - TEMPORARY	230	0	REDUCED		EMPTY	BEFORE	INTACT
24	03-Oct-90	5 3	0.0	3.0	4	START RIB B	230	0	REDUCED		EMPTY	BEFORE	INTACT
25	03-Oct-90	6 2	0.0	3.0	4	RIB B STOPPED	230	0	REDUCED		EMPTY	BEFORE	INTACT
26	03-Oct-90	6 2	0.4	3.0	4	START RIB B	230	0	REDUCED		EMPTY	BEFORE	INTACT
27	03-Oct-90	16 33	0.3	3.5	5	ENTERED MODE 5	180	0	REDUCED		EMPTY	BEFORE	INTACT
28	04-Oct-90	0 0	0.1	3.8	5	RIB B STARTED DECOMBAT ESTABLISHMENT	180	0	REDUCED		EMPTY	BEFORE	INTACT
29	04-Oct-90	2 30	0.2	3.9	5	RIB B STOPPED	180	0	REDUCED		EMPTY	BEFORE	INTACT
30	04-Oct-90	7 28	1.1	4.1	5	RIB B STOPPED	180	0	REDUCED		EMPTY	BEFORE	INTACT
31	05-Oct-90	0 54	0.0	5.1	5	RIB B STOPPED - TEMPORARY	180	0	REDUCED		EMPTY	BEFORE	INTACT
32	05-Oct-90	9 53	0.0	5.2	5	START RIB B	175	0	REDUCED		EMPTY	BEFORE	INTACT
33	05-Oct-90	10 5	0.0	5.2	5	REDUCING LEVEL TO 172 TO REDUCE SMOKE	175	0	REDUCED		EMPTY	BEFORE	INTACT
34	05-Oct-90	10 47	0.2	5.2	5	LEVEL 175" FOR RIB B	175	0	REDUCED		EMPTY	BEFORE	INTACT
35	05-Oct-90	14 45	0.0	5.4	5	STOP RIB B	175	0	REDUCED		EMPTY	BEFORE	INTACT
36	05-Oct-90	14 53	0.5	5.4	5	RESTART RIB B	175	0	REDUCED		EMPTY	BEFORE	INTACT
37	06-Oct-90	2 50	0.0	5.9	5	RIB A TAGOUT, RIB B ASIA A PURSUADE	185	0	REDUCED		EMPTY	BEFORE	INTACT
38	06-Oct-90	3 21	0.9	5.9	5	WATER UP TO 195"	195	0	REDUCED		EMPTY	BEFORE	INTACT
39	07-Oct-90	0 0	0.9	6.0	5	INSTALLED MAIN STEAM LINE PLUGS	190	0	REDUCED		EMPTY	BEFORE	INTACT
40	07-Oct-90	21 41	0.4	7.7	5	SCORE ALTS BEGINS	195	0	REDUCED		EMPTY	BEFORE	INTACT
41	08-Oct-90	6 14	0.0	8.0	5	RIB B STOPPED - TEMPORARY	195	0	REDUCED		EMPTY	BEFORE	INTACT
42	08-Oct-90	6 59	0.0	8.0	5	START RIB B	195	0	REDUCED		EMPTY	BEFORE	INTACT
43	08-Oct-90	21 0	0.3	8.6	5	LOST DECOMBAT COMBAT	195	0	REDUCED		EMPTY	BEFORE	INTACT
44	09-Oct-90	3 10	0.1	8.9	5	RIB B STOPPED (RIB B STOPPED)	195	0	REDUCED		EMPTY	BEFORE	INTACT
45	09-Oct-90	6 30	0.1	9.0	5	SCORE ALTS AGAIN DUE TO RIB B/SC BEGINS	195	0	REDUCED		EMPTY	BEFORE	INTACT
46	09-Oct-90	8 13	0.0	9.1	5	STOP RIB B	195	0	REDUCED		EMPTY	BEFORE	INTACT
47	09-Oct-90	8 13	1.3	9.1	5	RESTART RIB B	195	0	REDUCED		EMPTY	BEFORE	INTACT
48	10-Oct-90	15 10	0.0	10.4	5	RIB B STOPPED - TEMPORARY	195	0	REDUCED		EMPTY	BEFORE	INTACT

INITIATING EVENTS


	FREQUENCY (events/hour)	SOURCE
DnR Pump Failure	1.0E-05	IEEE Std 500 1984
SSW Pump Failure	1.0E-05	IEEE Std 500 1984
Div I AC/DC Bus Failure	2.0E-07	IEEE Std 500 1984
Div II AC/DC Bus Failure	2.0E-07	IEEE Std 500 1984
SDC Isolation	8.3E-05	NSAC-88/157
RPV Isolation	5.4E-05	NSAC 38/157
Loss of AC Power	2.0E-05	NSAC-156, NUREG-1410
Loss of Instrument Air	9.6E-08	NUREG-4550
Large LOCA	1.1E-08	NUREG-4550

COUPLING INITIATING EVENTS AND RECOVERY ACTIONS




*Formula combines historical and thermal hydraulic data

Decay Heat Loads From Reactor Fuel



CORE UNCOVERY VS. TIME AFTER SHUTDOWN

FOLLOWING LOSS OF DECAY HEAT REMOVAL




TIME UNTIL CORE UNCOVERS, HOURS

TIME EVENT STARTS, DAYS AFTER SHUTDOWN


RCS HEATUP TIME VS. TIME AFTER SHUTDOWN

FOLLOWING LOSS OF DECAY HEAT REMOVAL




LOSP EVENTS RELEVANT TO SHUTDOWN RISK

(NUREG-1410, NSAC-166 Event Data)




RCS BOILING RISK MODEL - GENERIC INITIATOR



SCENARIO	INITIATING EVENT	HEAT REMOVER	HEAT EXCHANGER	HEAT REMOVER	HEAT EXCHANGER	HEAT REMOVER	HEAT EXCHANGER	HEAT REMOVER	HEAT EXCHANGER	HEAT REMOVER	HEAT EXCHANGER	HEAT REMOVER	HEAT EXCHANGER	HEAT REMOVER	HEAT EXCHANGER
1	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
2	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
3	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
4	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
5	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
6	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
7	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
8	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
9	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
10	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
11	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
12	UP	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE	INSTRUMENTS IN SERVICE
Total Frequency: 0.00E+00															


CORE DAMAGE RISK MODEL - INVENTORY CONTROL FAILURES

GENERIC LOCA INITIATING EVENT	HPCS AVAILABLE	LPCS AVAILABLE	LPCI-A AVAILABLE	LPCI-B AVAILABLE	LPCI-C AVAILABLE	OPERATOR INITIATES ALTERNATE INJECTION
LI	HPC	LPS	LPA	LPO	LPC	OPL




NUM BER	SEQUENCE DESIGNATION	ACC IDENTI FICATION KEY	SR C E D D U E S C C E Y
1	LI	DI	
2	LI-HPC	DI	
3	LI-HPC-LPS	DI	
4	LI-HPC-LPS-LPC	DI	
5	LI-HPC-LPS-LPA-LPO	DI	
6	LI-HPC-LPS-LPC-LPC	DI	
7	LI-HPC-LPS-LPC-LPC-LPC	DI	
Total Frequency:		0.00E+00	

Fault Tree Example




Fault Tree Example



EQUIVALENT METHODS FOR LOGIC MODELS

FAULT TREE



FORMULA

IF System_status = "UNAVAILABLE"
THEN P(Fail) = 1.0
ELSE P(Fail) = $x \times E^{-y}$