

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) H. B. Robinson Plant - Unit No. 2	DOCKET NUMBER (2) 0 5 0 0 0 2 6 1	PAGE (3) 1 OF 0 2
--	--------------------------------------	----------------------

TITLE (4)
Surveillance Test MST-912 Diesel Fire Pump Batteries

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 1	0 4	8 5	8 5	0 0 1	0 0	0 1	0 4	8 5			0 5 0 0 0
											0 5 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)

OPERATING MODE (9)	20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 0 0 0	20.406(a)(1)(i)	50.38(e)(1)	50.73(a)(2)(v)	73.71(c)
	20.406(a)(1)(ii)	50.38(e)(2)	50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	20.406(a)(1)(iii)	XX 50.73(a)(2)(i)	50.73(e)(2)(viii)(A)	
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)	
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME Carson L. Wright	TELEPHONE NUMBER
	AREA CODE: 8 0 3 3 8 3 - 4 5 2 4

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFAC TURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFAC TURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)

<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15)	MONTH DAY YEAR
--	--	-------------------------------	----------------------

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On January 4, 1985, it was identified that the weekly surveillance test conducted on the Diesel Fire Pump Batteries described in Technical Specification (TS), Section 4.14.6.2.a, was not completed within the allowed interval. The test was scheduled to be run on December 31, 1984. It was run two days later on January 2, 1985, which is beyond the +25% allowed by Technical Specification. The error was caused by a misunderstanding by the technician of the rescheduled surveillance due date.

For corrective action the technicians have been properly notified of the change in the surveillance schedule.

8502110654 850204
PDR ADOCK 05000261
S PDR

IE 22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) H. B. Robinson, Unit No. 2	DOCKET NUMBER (2) 0 5 0 0 0 2 6 1 8 5 - 0 0 1 - 0 0 0 2 OF 0 2	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On January 4, 1985, during a routine review of the Technical Specification required surveillances, it was identified that the interval between the Diesel Fire Pump Battery Weekly Surveillance Test exceeded the required interval.

Technical Specifications allow 7 days +25% between weekly tests. MST-912 was scheduled to be performed on Monday, December 31, 1984. It was not performed until Wednesday, January 2, 1985.

The error was caused by the technician not checking the posted surveillance schedule. Contributing to the error was a recent change to the surveillance schedule. MST-912 had been scheduled to be run on each Wednesday. It recently was rescheduled for each Monday. The Maintenance foremen were aware of the rescheduling. MST-912 was previously run on Monday, December 24, 1984, and was scheduled to be run on Monday, December 31, 1984. Due to the holidays, the Maintenance foremen were not on Site. Although MST-912 was scheduled for Monday, the technician was accustomed to running this particular test on Wednesday and did not check the posted schedule.

To correct the cause of this problem the Maintenance personnel have been reminded of the scheduling changes. They have also been reminded of the necessity and importance of conducting surveillance tests per the posted schedule.

This corrective action should prevent further similar nonconformances.



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

February 4, 1985

Robinson File No: 13510C

Serial: RNP/85-248

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
LICENSEE EVENT REPORT 85-001

Dear Sir:

In accordance with 10CFR50.73, Licensee Event Report, the enclosed Licensee Event Report is submitted. This report fulfills the requirements for a written report within (30) days of a reportable event and is in accordance with the format set forth in NUREG-1022, September, 1983.

Very truly yours,

for R. E. Morgan
General Manager
H. B. Robinson S. E. Plant

CLW/ac

Enclosure

cc: INPO
H. E. P. Krug
J. P. O'Reilly

IE22
11