

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) <b>JAMES A. FITZPATRICK NUCLEAR POWER PLANT</b>	DOCKET NUMBER (2) <b>0 5 0 0 0 3 3 3</b>	PAGE (3) <b>1 OF 0 2</b>
--	---	-----------------------------

TITLE (4)  
**FAILURE TO MAINTAIN PROPER OPERATING SHIFT COMPLEMENT**

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		
<b>0 1</b>	<b>1 7</b>	<b>8 5</b>	<b>8 5</b>	<b>0 0 2</b>	<b>0 0 0</b>	<b>0 2</b>	<b>0 5</b>	<b>8 5</b>			
									DOCKET NUMBER(S) <b>0 5 0 0 0</b>		
									DOCKET NUMBER(S) <b>0 5 0 0 0</b>		

OPERATING MODE (9) **N**

POWER LEVEL (10) **1 0 0**

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
20.406(a)(1)(i)	50.36(c)(1)	50.73(a)(2)(v)	73.71(e)
20.406(a)(1)(ii)	50.36(c)(2)	50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 50.73(a)(2)(i)	50.73(a)(2)(viii)(A)	
20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)	
20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(x)	

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
<b>William Fernandez, Operations Superintendent</b>	<b>3 1 5 3 4 2 - 3 8 4 0</b>

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFAC-TURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFAC-TURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)  NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On January 17 and 18, 1985, for a total of approximately 8 ½ hours, there was no one on site who fulfilled the role of Shift Technical Advisor as required by Technical Specification. When it was realized, a qualified individual was called in.

The basic cause of this violation was an oversight by individuals on who was qualified as the newly instituted Senior Operator/Shift Technical Advisor.

Long term corrective actions included adding a separate sign-off in the shift turnover sheet for the STA function and posting a sign in control room which lists those individuals who must be on shift to fulfill the STA or Senior Operator/STA functions.

8502110712 850205  
 PDR ADOCK 05000333  
 S PDR

JE 22  
 1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) <b>JAMES A. FITZPATRICK NUCLEAR POWER PLANT</b>	DOCKET NUMBER (2)  0   5   0   0   0   3   3   3	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8   5	--   0   0   2	--   0   0	0   2	OF	0   2

TEXT (If more space is required, use additional NRC Form 366A's) (17)


On January 17, 1985, between the approximate hours of 1700 and 2400 and on January 18, 1985, between the approximate hours of 1700 and 1830, there was no one on site who fulfilled the role of Shift Technical Advisor (STA). On December 22, 1984, FitzPatrick instituted the Senior Operator/Shift Technical Advisor as an alternate to the sole separate STA. Due to the limited number of qualified individuals, the shift schedules were set up to ensure that either the Shift Supervisor (SS) or Assistant Shift Supervisor had the necessary qualifications. On the above days, the normally assigned Shift Supervisor, who was fulfilling the SO/STA function, had another Shift Supervisor who did not meet the qualifications of an SO/STA stand in for him. Due to the newness of the program, neither the individuals or their supervisors considered the extra qualification requirement.

When the discrepancy was recognized on January 18, 1985 an individual qualified as a STA was called in on shift. Long term corrective actions have included:

- a) Adding a separate sign-off in the shift turnover sheet for the STA function.
- b) Posting a sign in the Shift Supervisors office which lists those individuals who must be on shift to fulfill the STA or SO/STA function.
- c) Instructed the individuals who stand the SO/STA position of their responsibilities in ensuring proper qualified shift relief.
- d) Instructed the supervisors to ensure all shift requirements are met when approving personnel exchanges.

James A. FitzPatrick  
Nuclear Power Plant  
P.O. Box 41  
Lycoming, New York 13093  
315 342.3840

Harold A. Glovier  
Resident Manager



February 5, 1985  
JAFF 85-0108

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

REFERENCE: DOCKET NO. 50-333 Licensee Event Report: 85-002-00

Dear Sir:

We have enclosed the referenced Licensee Event Report in accordance with 10CFR50.73.

If there are any questions concerning this report, please contact Mr. William Fernandez at (315) 342-3840, Extension 300.

*by dir. H. A. Glovier*

H. A. GLOVIER

HAG:WF:dmh

Enclosure

CC: USNRC, Region I (1)  
INPO Records Center, Atlanta, Georgia (1)  
Internal Power Authority Distribution  
American Nuclear Insurers (1)  
NRC Resident Inspector  
Document Control Center  
LER/OR File

IEE2  
1/1