

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power Corporation
Crystal River Unit 3

Docket No. 50-302
License No. DPR-72

The following violation was identified during an inspection conducted on June 18-22, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 20, Appendix A, requires that supplied air hoods used for respiratory protection shall be operated in a manner that ensures that proper air flow rates are maintained, including use of calibrated airline pressure gauges or flow measuring devices.

Contrary to the above, on June 20, 1984, licensee personnel were observed using supplied-air hoods for respiratory protection; the supplied air system was not equipped with an airline pressure gauge or a flow measuring device.

This is a Severity Level IV violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: JUL 17 1984

8410230514 840920
PDR ADOCK 05000302
PDR