

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

84 SEP 18 P 3: 29 September 12, 1984

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNIT 1 - SUPPLEMENTAL RESPONSE TO VIOLATION  
50-438/84-01-02 - FAILURE TO PREVENT PRACTICES THAT CAUSE DETERIORATION OF  
AN ELECTRICAL PANEL COMPONENT

TVA responded to R. C. Lewis' letter dated February 17, 1984, report numbers 50-438/84-01, 50-439/84-01 concerning activities at the Bellefonte Nuclear Plant which appeared to have been in violation of NRC regulations by letter dated March 14, 1984. Below is our supplemental response to the citation.


As discussed with NRC-OIE Inspector P. E. Fredrickson on August 29, 1984, the date of September 1, 1984, for completion of corrective actions indicated in our final report on this matter would not be met. TVA found it impossible to obtain any environmentally qualified motor starters. An exact replacement will now be installed by March 30, 1985, while the qualification problem is being separately reported on under nonconformance report (NCR) BLN EEB 8413.

A second commitment to revise Bellefonte Quality Control Procedure (QCP) 3.4 has also been delayed. Because of the size of this QCP, TVA has broken it into three separate QCPs (3.4, 3.34, and 3.33) which are expected to be issued by October 14, 1984.

If you have any questions concerning this matter, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager  
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8410240128 840924  
PDR ADOCK 05000438  
PDR  
G