

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Callaway Plant Unit 1	DOCKET NUMBER (2) 0 5 0 3 0 4 8 3 1	PAGE (3) 1 OF 0 2
--	--	----------------------

TITLE (4)
Technical Specification Violation

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)																																																																																																		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)																																																																																																
0	9	1 5 8 4 8 4	0	3 9	0 0	1	0 1 5 8 4				0 5 0 0 0																																																																																																
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td colspan="12">THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)</td> </tr> <tr> <td colspan="3">OPERATING MODE (9) 3</td> <td colspan="3">20.402(b)</td> <td colspan="3">20.406(c)</td> <td colspan="3">50.73(a)(2)(iv)</td> <td colspan="3">73.71(b)</td> </tr> <tr> <td colspan="3">POWER LEVEL (10) 0 0 0</td> <td colspan="3">20.406(a)(1)(i)</td> <td colspan="3">50.38(c)(1)</td> <td colspan="3">50.73(a)(2)(v)</td> <td colspan="3">73.71(c)</td> </tr> <tr> <td colspan="3"></td> <td colspan="3">20.406(a)(1)(ii)</td> <td colspan="3">50.38(c)(2)</td> <td colspan="3">50.73(a)(2)(vii)</td> <td colspan="3" rowspan="3">OTHER (Specify in Abstract below and in Text, NRC Form 365A)</td> </tr> <tr> <td colspan="3"></td> <td colspan="3">20.406(a)(1)(iii)</td> <td colspan="3">X 50.73(a)(2)(i)</td> <td colspan="3">50.73(a)(2)(viii)(A)</td> </tr> <tr> <td colspan="3"></td> <td colspan="3">20.406(a)(1)(iv)</td> <td colspan="3">50.73(a)(2)(ii)</td> <td colspan="3">50.73(a)(2)(viii)(B)</td> </tr> <tr> <td colspan="3"></td> <td colspan="3">20.406(a)(1)(v)</td> <td colspan="3">50.73(a)(2)(iii)</td> <td colspan="3">50.73(a)(2)(ix)</td> <td colspan="3"></td> </tr> </table>												THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)												OPERATING MODE (9) 3			20.402(b)			20.406(c)			50.73(a)(2)(iv)			73.71(b)			POWER LEVEL (10) 0 0 0			20.406(a)(1)(i)			50.38(c)(1)			50.73(a)(2)(v)			73.71(c)						20.406(a)(1)(ii)			50.38(c)(2)			50.73(a)(2)(vii)			OTHER (Specify in Abstract below and in Text, NRC Form 365A)						20.406(a)(1)(iii)			X 50.73(a)(2)(i)			50.73(a)(2)(viii)(A)						20.406(a)(1)(iv)			50.73(a)(2)(ii)			50.73(a)(2)(viii)(B)						20.406(a)(1)(v)			50.73(a)(2)(iii)			50.73(a)(2)(ix)					
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)																																																																																																											
OPERATING MODE (9) 3			20.402(b)			20.406(c)			50.73(a)(2)(iv)			73.71(b)																																																																																															
POWER LEVEL (10) 0 0 0			20.406(a)(1)(i)			50.38(c)(1)			50.73(a)(2)(v)			73.71(c)																																																																																															
			20.406(a)(1)(ii)			50.38(c)(2)			50.73(a)(2)(vii)			OTHER (Specify in Abstract below and in Text, NRC Form 365A)																																																																																															
			20.406(a)(1)(iii)			X 50.73(a)(2)(i)			50.73(a)(2)(viii)(A)																																																																																																		
			20.406(a)(1)(iv)			50.73(a)(2)(ii)			50.73(a)(2)(viii)(B)																																																																																																		
			20.406(a)(1)(v)			50.73(a)(2)(iii)			50.73(a)(2)(ix)																																																																																																		

LICENSEE CONTACT FOR THIS LER (12)

NAME Charles D. Naslund - Superintendent, I&C	TELEPHONE NUMBER AREA CODE 3 1 1 4 6 1 7 1 6 1 - 1 8 1 5 1 0 0
--	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS
X	E	K J X	C	5 6 0	N				

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 0600 CDT on 9/15/84, while in Mode 3, the analog channel operational test of the Load Shedder and Emergency Load Sequencer (LSELS) failed due to no 48 VDC output from the undervoltage power supply assembly. This failure caused the action statement to Technical Specification 3/4.3.2.1-8a,b to be entered. This action statement, ACTION 19, states that STARTUP and/or POWER OPERATIONS may proceed provided the inoperable channel is placed in the tripped condition within 1 hour. Between 0600 and 0700 the channel was unable to be placed in the tripped condition because of the failed power supply, therefore Technical Specification 3.0.3 was entered. Plant cooldown was initiated at 0745 per operating procedures. At 0920 the inoperable channel was placed in the tripped condition and plant heatup commenced per plant operating procedures.

Due to plant conditions, the subject event posed no threat to the public health and safety.

IF22
1/1

8410240162 841015
PDR ADOCK 05000483
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Callaway Plant Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 4 B 13 8 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
			0 3 9	0 0	0 2	OF

TEXT (If more space is required, use additional NRC Form 366A's) (17)

At 0600 CDT on 9/15/84, while in Mode 3 at normal operating temperature and pressure, the analog channel operational test, ISF-NF-ONB02 - "FUNCTIONAL MISCELLANEOUS: NB02 Degraded and Undervoltage to Load Shedder and Emergency Load Sequencer (LSELS)," of the LSELS failed due to no 48 VDC output from the undervoltage power supply assembly (NF039B). This failure caused the action statement to Technical Specification 3/4.3.2.1-8a,b to be entered. This action statement to 3/4.3.2.1-8a,b, ACTION 19, states that STARTUP and/or POWER OPERATIONS may proceed provided the inoperable channel is placed in the tripped condition within 1 hour.

Between 0600 and 0700 the inoperable channel was unable to be put in the tripped condition due to the failed power supply, and therefore Technical Specification 3.0.3 was entered.

At 0745, plant cooldown was initiated in accordance with plant operating procedure as required by Technical Specification 3.0.3.

At 0920, the inoperable channel was placed in a tripped condition by means of a temporary jumper. Therefore, plant cooldown was suspended and plant heatup commenced in accordance with plant operating procedures.

The failed power supply (type KRB 1907-1) was replaced with a different power supply (type KRB 1907) per Temporary Modification 84-E612. The temporary modification will be cleared when a type KRB 1907-1 power supply is obtained and installed. This is considered an isolated incident and no further corrective action is deemed necessary.

Due to plant conditions, the subject event posed no threat to the public health and safety.

Previous occurrences: none

UNION ELECTRIC COMPANY
CALLAWAY PLANT

MAILING ADDRESS:
P. O. BOX 620
FULTON, MO. 65251

October 15, 1984


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

JLNRC-949

DOCKET NUMBER 50-483
CALLAWAY PLANT UNIT 1
FACILITY OPERATING LICENSE NPF-25
LICENSEE EVENT REPORT 84-039-00
TECHNICAL SPECIFICATION VIOLATION

Gentlemen:

The enclosed Licensee Event Report is submitted pursuant to 10 CFR 50.73(a)(2)(i) concerning the failure of the undervoltage power supply assembly to the Load Shedder and Emergency Load Sequencer.


S. E. Miltenberger
Manager, Callaway Plant

CDW
CDN/RRG/drs
Enclosure

cc: Distribution attached

IE22
1/1

cc distribution for ULNRC-949

Mr. James G. Keppler
Regional Administrator
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

American Nuclear Insurers
c/o Dottie Sherman, Library
The Exchange Suite 245
270 Farmington Avenue
Farmington, CT 06032

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

NRC Resident Inspector
Missouri Public Service Commission
D. F. Schnell
J. F. McLaughlin
J. E. Davis (Z40LER)
D. W. Capone
F. D. Field
R. L. Powers
A. C. Passwater/D. E. Shafer/D. J. Walker
G. A. Hughes
W. R. Robinson (QA Record)
C. D. Naslund
D. C. Poole
R. A. McAleenan
L. K. Robertson (470) (NSRB)
Merlin Williams, Wolf Creek
SEM Chrono
3456-0021.6
3456-0260
Z40ULNRC
G56.37
N. Date