WCAP-8763-A

### NEW WESTINGHOUSE CORRELATION WRB-1 FOR PREDICTING CRITICAL HEAT FLUX IN ROD BUNDLES WITH MIXING VANE GRIDS

F. E. Motley K. W. Hill F. F. Cadek J. Shefcheck

September 1978 (Original Version) July 1984 (Approved Version)

Work Performed Under DGRF 03200 and DGRF 40206

APPROVED: P. K. Dorh: / for

L. H. Boman, Manager Fuel Performance Engineering and Evaluation

WESTINGHOUSE ELECTRIC CORPORATION Nuclear Energy Systems P. O. Box 355 Pittsburgh, Pennsylvania 15230

B410250089 B41019 PDR TOPRP EMVWEST B PDR

### TABLE OF CONTENTS OF APPROVED VERSION

- NRC SER Staff Evaluation of WCAP-7956, WCAP-8054, WCAP-8567, and WCAP-8762, April 19, 1978.
- NRC-SER Acceptance for Referencing of Licensing Topical Report -WCAP-8762(P)/WCAP-8763(NP), Supplement 1, "Basis for the Applicability of the WRB-1 Correlation to 15 x 15 OFA and 14 x 14 OFA Fuel", June 29, 1984.
- 3. WCAP-8763.
- Letter from J. F. Stoltz to C. Eicheldinger, September 28, 1977, request for additional information.
- Letter from C. Eichlendinger to J. F. Stoltz, October 24, 1977, response to request for additional information on WCAP-8762 and WCAP-8763.
- 6. Supplement 1 to WCAP-8763.



UNITED STATES NUCLEAR REGULATCARY COMMISSION WASHINGTON, D. C. 20555

APR 1 9 1978

Mr. C. Eicheldinger, Manager Nuclear Safety Department Westinghouse Electric Corporation P. O. Box 355 Pittsburgh, Pennsylvania 15230

Dear Mr. Eicheldinger:

SUBJECT: STAFF EVALUATION OF WCAP-7956, WCAP-8054, WCAP-8567, AND WCAP-8762

The Nuclear Regulatory Commission staff has completed its review of the following Westinghouse Electric Corporation topical reports.

WCAP-7956 (Non-proprietary), "THINC-IV, An Improved Program for Thermal-Hydraulic Analysis of Rod Bundle Cores" June 1973

WCAP-8054 (Proprietary) and WCAP-8195 (Non-proprietary), "Application of the THINC-IV Program to PWR Design," September 1973

WCAP-8567 (Proprietary) and WCAP-8568 (Non-proprietary), "Improved Thermal Design Procedure," July 1975

WCAP-8762 (Proprietary) and WCAP-8763 (Non-proprietary), "New Westinghouse Correlation WRB-1 for Predicting Critical Heat Flux in Rod Bundles with Mixing Vane Grids," July 1976.

Our evaluations of these reports are enclosed.

As a result of our review of WCAP-7956 and WCAP-8054, we have concluded that the THINC-IV computer code is acceptable for performing steadystate hydraulic calculations in reactor cores provided suitably conservative assumptions are used with respect to plant operating conditions, fuel fabrication tolerances, and power peaking uncertanties. Fluid conditions are limited to the single phase or the homogeneous two phase flow regime. Limitations on the use of the THINC-IV code are provided and fully discussed in our evaluation of these topical reports (Enclosure 1).

WCAP-8567 describes a new procedure for calculating departure-fromnucleate-boiling ratio (DNBR) in reactor cores based on the statistical combination of uncertainties in plant parameters that affect DNBR.

#### . Mr. C. Eicheldinger

As a result of our review, of WCAP-3567, we have concluded that the new thermal design procedure is acceptable for use in licensing applications subject to the imposition of certain restrictions and changes to the procedure. The sensitivity factors for plant parameters are valid only for the W-3 DNB correlation, THINC-IV computer code, and the range of plant parameters considered in the report. Sensitivity factors, variances, and distributions for plant parameters must be included and justified in each plant safety analysis report. Code uncertainties specified by the staff (+4% for THINC-IV and +1% for transient analyses) must be included in DNBR analyses. Fuel rod bowing effects cannot be treated as described in the report; however, addition of a rod-bow penalty to the DNBR limit is acceptable. A plant transient resulting from a loss of reactor coolant flow must satisfy the design basis DNBR limit for faults of moderate frequency (ANS Condition II event) rather than the design basis limit for infrequent accidents (ANS Condition III event) as specified in WCAP-8567. The improved thermal design procedure is applicable only to DNBR analyses and cannot be used in other analyses, such as overpressure calculations. The acceptable conditions for use of the improved thermal design procedure are fully described in our safety evaluation of WCAP-8567 (Enclosure 2).

As a result of our review of WCAP-8762, we have concluded that the WRB-1 critical heat flux correlation is acceptable for use in thermal-hydraulic calculations of pressurized water reactor cores provided a DNBR limit of 1.37 is used for cores composed of fuel assemblies with an 'L" grid design. The proposed DNBR limit of 1.17 is acceptable for cores composed of fuel assemblies with an "R" grid design. The limit of 1.37 for "L" grid designs results from a large variation in data for the limited number of tests run with this design. This limit may be reduced by obtaining additional test data or by additional analytical work to improve the correlation. Our evaluation, including an independent audit of calculations to determine local coolant conditiors for the tests and an independent audit of the statistical calculations used to establish the DNBR limit, is summarized in Enclosure 3.

Accordingly, topical reports WCAP-7956, WCAP-8054, WCAP-8567, and WCAP-8762 are acceptable for reference in license applications. Topical reports WCAP-8195, WCAP-8568, and WCAP-8763 are acceptable non-proprietary versions of the proprietary reports. When these reports are used as references, both the proprietary report and the non-proprietary version must be referenced.

### Mr. C. Eicheldinger

### APR 1 9 1978

In accordance with established procedure, it is requested that Westinghouse issue revised versions of these reports within three months of receipt of this letter to include the NRC acceptance letter, the enclosed evaluations, and any changes resulting from the review.

We do not intend to repeat our review of these reports when they appear as references in a particular license application except to assure that the material presented in these reports is applicable to the specific plant involved.

Should Nuclear Regulatory Commission criteria or regulations change, such that our conclusions concerning these reports are invalidated, you will be notified and given an opportunity to revise and resubmit your topical reports.

Sincerely, Flink.

John F. Stolz, Chief Light Water Reactors Branch No. 1 Division of Project Management

Enclosures:

- Topical Report Evaluation WCAP-7956 and WCAP-8054
- Topical Report Evaluation WCAP-8567
- Safety Evaluation Report WCAP-8762

cc: D. Rawlins
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

### ENCLOSURE 3

ANALYSIS BRANCH DIVISION OF SYSTEMS SAFETY OFFICE OF NUCLEAR REACTOR REGULATION

WCAP-8762

### SAFETY EVALUATION REPORT

ON

WRB-1 CRITICAL HEAT FLUX CORRELATION

MARCH 1978

### WRB-1 SER

#### Introduction

The staff has reviewed the WRB-1 Critical Heat Flux (CHF) correlation as presented in topical report WCAP-8762. The staff evaluation of the WRB-1 CHF correlation is presented in this report.

The Westinghouse Rod Bundle, critical heat flux correlation (WRB-1) is an empirical correlation which specifies the critical heat flux (i.e., the heat flux at which departure from nucleate boiling occurs) as a function of local conditions in a rod bundle. The local corditions in the rod bundle were calculated with the standard Westinghouse thermal hydraulic design code THINC. This correlation is based on 24 test series with a total of 1147 data points. Each of the 24 test series was conducted on an electrically heated rod bundle containing from 9 to 25 rods. Each test series corresponds to a different rod bundle geometry except for one repeatability test series. The 24 test series include variations in heated length, rod size and configuratic spacer grid design, grid spacing, and axial heat flux distribution.

The range of coolant condition tested corresponds to the proposed range of coolant conditions for application to PWRs.

Westinghouse has indicated that the WRB-1 correlation may be used to replace the W-3 correlation in the core thermal hydraulic design for both the 15x15 fuel assembly design and the 17x17 fuel assembly design. The Westinghouse topical report WCAP-8762 concludes that the WRB-1 correlation is significantly more accurate than the W-3 correlation in predicting departure from nucleate boiling. On the basis of the improved correlation accuracy the proposed value of a minimum departure from nucleate boiling ratio (DNBR) to meet the reac design criterion of a 95% probability of not experiencing departure from nucleate boiling on a limiting rod at a 95% confidence level is 1.17. The comparable value for the W-3 correlation is approximately 1.3.

### Scope of Review

The staff review of WCAP-8762 has included an independent audit of the subchannel calculation performed to determine the local coolant conditions in the rod bundle. Approximately 300 calculations have been performed with COBRA-IV and the results have been compared with the published results from the Westinghouse THINC calculations. The staff review has also included an independent audit of the statistical calculations used in establishing the DNBR design limit for the correlation. The staff has reviewed the assumptions made in generating the CHF correlation and the DNBR design limit as well as the assumptions necessary in order to apply the correlation to the PWR geometry and coolant conditions. The WRB-1 correlation was also compared to other PWR CHF correlations to identify any anamalous behavior. During the review, the staff requested and received additional information in several areas.

### Review Summary

### Results of Audit Calculations

The results of the staff audit calculations are presented in Tables I, II and III. Table 1 presents a comparison of calculated local quality for THINC and COBRA-III and IV. Both the THINC code and the COBRA code have been reviewed and compared to experimental data; and we concluded that either code could be used to establish the local conditions required for the development of the CHF correlation. The comparison indicates

-2-

a very good agreement between the two methods. Since the THINC and the COBRA-III and IV calculations are both subchannel calculations the term "local conditions" refers to average conditions in a subchannel. Each subchannel in the rod bundle is represented in both codes and the effects of flow redistribution are included. Table II presents the results of a typical COBRA-IV calculation for one of the CHF tests. These calculations indicate that the enthalpy distribution in the test bundle is nearly uniform. It appears that the rod powers and the peripheral channel hydraulic diameters were chosen, in most cases, to produce a nearly equal enthalpy rise in each channel. This minimizes the effects of crossflow and interchannel mixing since fluid exchange between adjacent channels does not result in any significant energy exchange. The analysis of the local coolant conditions is therefore relatively insensitive to changes in thermal d fusion coefficient, spacer grid flow resistance, crossflow resistance and other modeling assumptions. This is a sound approach to CHF testing since it minimizes the possible effects of calculational bias and calculational uncertainties on the resulting CHF correlation.

During the initial phase of the staff review of this correlation only COBRA-III was available. Subsequently COBRA-IV became available allowing comparisons among the three subchannel codes.

Table III presents a comparison of the Measured CHF/Predicted CHF for THING and COBRA-IV. The mean values of the Measured CHF/Predicted CHF and the standard deviations are in good agreement. Table IV presents a similar comparison between COBRA-III and COBRA-IV for test series A-1 (throughout

-3-

this report the test series will be designated by the identification given in Table 3-1 of WCAP-8762). A standard, statistical analysis of variance test, the F-test, was performed on the THINC, COBRA-IV results for tests series A-1. The purpose of this test was to determine if differences in the method of calculating the local coolant condition were responsible for the observed variation in the CHF data. The results of this F-test clearly indicate (i.e., at a 99% certainty) that the variation among the mean values of Measured CHF/Predicted CHF predicted by THINC, COBRA-III and COBRA-IV is much smaller than would be expected from a random sample with the same variation among the individual data points. This implies that it is unlikely that the variation among the data points is the result of the method of solving for the subchannel coolant condition.

The good agreement between THINC and COBRA-III and IV in terms of local conditions and Measured CHF/Predicted CHF; and the relatively simple nature of the subchannel calculations indicate that the uncertainty in the local subchannel condition has only a small contribution to the overall uncertaint in the correlation. The difference between the COBRA-III and COBRA-IV individual cases was generally less than 1%; and the difference between the COBRA-III and COBRA-IV values for the mean of the Measured CHF/Predicted CHF was less than 0.1%. The differences between the THINC and COBRA-IV individual cases were generally on the order of 2% or less; and the differences between the THINC and COBRA-IV values for the mean of the Measured CHF/Predicted CHF were generally less than 1%. However, in the cas of test series A-5 a consistent bias of greater than 1% found between the THINC results and the COBRA results. This difference was traced to

-4-

the cosine axial power distribution used by Westinghouse which was not fully normalized (i.e., average axial power = 1.008 rather than 1.00). This difference results in a conservative bias in the Westinghouse results for the A-5 test series. In addition, it should be noted that many of the test series which form the basis for the WRB-1 correlation were also used to support previous Westinghouse DNBR correlations, and that many of these test series were previously subjected to review and comparisons to COBRA calculations.

### Correlation Assumptions

The assumed form of the correlation and the modeling of average subchannel coolant conditions rather than actual local coolant conditions are important considerations in determining the acceptability of the correlation. Additional assumptions related to the application of the correlation to FWRs will be discussed later. The form of the WRB-1 correlation is as follows:

g CHF = PF + A1 + B3 x Flow = B4 x Flow x Quality

where:

- PF (Performance Factor) is a function of mixing vane design
- Al is a function of Pressure, Flow, Heated Length to the CHF location, Grid Spacing and Distance from the last grid

B3 is a constant

B4 is a function of Pressure, Flow and Heated Length.

-5-

Correlations using a similar form have been used successfully in the past and the general trend of decreasing CHF with increasing fluid quality has been observed in many experiments. The correlation also depends on Pressure, local flow, heated length, grid spacing, distance from the last grid, hydraulic diamete and mixing vane design. The form of the correlation relative to these parameter: and the correlation coefficients are highly empirical. In some instances the physical basis for the individual correlation terms is not apparent. The inclusion of a term for the heated length appears to result in a more accurate correlation but the physical basis for this term is unclear. In a correlation which uses actual local conditions, a heated length term would appear to be unnecessary. Another example of an apparently non-physical representation in the WRB-1 correlation is the separation of the mixing vane design effect from the grid spacing effect. The mixing vane grids have the effect of promoting downstream turbulent mixing and an upstream flow reduction due to the flow resistance. It is reasonable to expect that the effect on CHF would be a function of the grid spacing. A large grid spacing, for example, could result in the downstream turbulent mixing effect washing out before the next mixing vane grid could reestablish the turbulent mixing pattern. Previously published Westinghouse data (WCAP-7411-1-P-A) on various mixing vane designs and grid spacing appear to show a dependence of the mixing vane design effect and on the grid spacing.

-6-

These are two examples of areas in which the correlation may not be correctly representing the physical phenomena. This has two important implications; first, a non-physical representation of phenomena in the correlation could be a contributing factor to the scatter in the comparison of Measured CHF and Predicted CHF for a given series of tests. This effect is inherently accounted for in the statistical analysis of the data for that given test series. The second implication of having non-physical representation of important phenomena is that the extrapolation of the WRB-1 correlation to other geometries of coolant conditions may not be valid. In fact the practice of combining data from different geometries in calculating an overall correlation uncertainty may not be valid. This subject will be discussed more extensively in a later section of this report.

An important new feature of the WRB-1 CHF correlation is the inclusion of a term which accounts for the distance (DG) between the CHF location and the last upstream mixing vane grid. This term reflects the observed behavior in which CHF occurred predominantly in locations just upstream of a mixing vane grid. WCAP-8762 indicates that the WRB-1 correlation, including the DG term, has an overall 81.7% accuracy in predicting the location of CHF. The method of establishing this accuracy is discussed on page 3-6 of WCAP-8762. It appears that this accuracy in predicting the correct locatior of CHF is a major factor in reducing the scatter of the data within each test series. Since there is a physical basis to expect the CHF to depend on the distance from the last mixing vane grid and since it appears to make the correlation more accurate the use of the DG term is acceptable. In response to a staff question, Westinghouse stated that in the THINC subchannel amalysis of the CHF data, the axial node just below a mixing vane grid was

-7-

assumed to have a value of DG equal to the full grid spacing. This treatment is acceptable but requires that the same assumption be made in the application of the WRB-1 correlation to PWR calculations.

The WRB-1 CHF correlation uses average subchannel coolant conditions as input. This technique inherently excludes consideration of the flow distribution, temperature distribution or void distribution (i.e., flow pattern) within a subchannel. Since the mixing vane grids and unheated rods can affect the distribution of flow, temperature and voids in the subchannel, the correlation needs empirical terms to account for these effects. The use of a subchannel analysis in developing the correlation implies that a similar technique needs to be used in the application of the correlation. Since there are important phenomena on a scale smaller than a subchannel, the use of a subchannel analysis means that the correlation must include empirical terms. As discussed previously, the empirical nature of the correlation may be one of the important contributing factors to the overall correlation uncertainty and has important implications relative to extrapolation of the correlation. The staff positions relative to the extrapolation of the correlation and the establishment of the DNBR limit will be discussed in a later section of this report.

### Statistical Review

The WRB-1 correlation has been reviewed to determine if there are any residual trends (i.e., systematic variations in the Measured CHF/Predicted CHF) as a function of coolant conditions. When the data from the 24 test series are viewed as a whole, there do not appear to be any residual trends with changes in coolant conditions. Figures 3-4, 3-5 and 3-6 in the topical were presented to demonstrate the lack of such trends. The data have also

-8-

been reviewed to determine if there are any systematic trends with changes in geometry. This can be tested by comparing the variance in the data from one test series with the variance in the data from a second test series. When looking for systematic variations among three or more test series the variation in the test series means can be compared to the variation of the data within the test series. In both cases a standard statistical analysis of variance test can be applied to determine if the differences found are statistically significant. In fact, the presence of systematic variations can be identified with any degree of confidence desired. The analysis of variance, F-test, has been used to identify systematic variations among the test-series at a 997 confidence level. The results of these tests are summarized in Table-V, which presents the calculated values of F and the theoretical range of F values at a 997 confidence le.el for truly random data. Where:

F = 582/5W2

 $S_B^2$  = variance of the means of the test series

 $S_w^2$  = variance of the data within the test series

The theoretical range given in Table V shows that if the data were truly random there is a 99% probability that the calculated value of F would fall within that range. A value of F below the range indicates that there is too little variation among the means and a value of F above the range indicates that there is too much variation among the means. Sixteen individual F-tests were performed to determine if systematic trends exist among the test series. As indicated in Table-V only three of the 16 F-tests results in values within the expected range. For truly random errors all 16 would have been expected to fall within the range. In a few instances the F-value is below.

-9-

the expected range. This appears to be the case for those test series which were used in establishing the form of the correlation or the correlation coefficients. In other words the correlation was chosen to minimize the variations in the Measured CHF/Predicted CHF. In these cases the correlation was chosen in a manner which eliminated some of the natural variations between the test series. For most of the comparisons given in Table-V, the calculated value of F significantly exceeded the maximum expected value. The implication of these systematic trends is that the change in geometry from one test series to another introduces another component of variance. The following example is presented to illustrate the potential problems associated with combining all of the test series results to establish a DNBR limit without accounting for a component of variance due to geometry changes. As indicated in Table 3-1 of WCAP-8762 the mean value of the Measured CHF/Predicted CHF for all 1147 data points is 1.0043 and the corresponding stanc deviation is 0.0873. This mean value and this standard deviation were used to establish the proposed DNBR limit of 1.17; where the intent is that a calculated value of DNBR of 1.17 corresponds to 95% probability (at a 95% confidence level of not experiencing DNB. In dealing with the CHF data the DNBR corresponds to the Predicted CHF/Measured CHF. Therefore the DNBR limit corresponds to a Measured CHF/Predicted CHF value of 1/1.17 or 0.855. The expected percentage of data points with a Measured CHF/Predicted CHF below 0.855 would therefore be approximately 5%. Test series A-20 includes 36 data points. We would therefore expect that fewer than two data points would have values of Measured CHF/Predicted CHF less than 0.855. The actual data indicate that six data points were below 0.855, which is more than three times the number which the correlation implies. Similarly, the mean value of 1.0043 for all 1147 data

-10-

points implies ~50% of the data have values above 1.0043 and ~50% have values below 1.0043. For test series A-20 none of the data points has a value of Measured CHF/Predicted CHF above 1.0043, in fact none has a value above .9402. Clearly, the mean value and standard deviation of all 1147 data points have little or no meaning when we are dealing with the test geometry for series A-20. Similar problems, generally of smaller magnitude, exist when the mean value and standard deviations based on all 1147 data points are compared to other of the test series. Combining all the data together in this manner, in establishing a DNBR limit, is only valid if there are no systematic trends among the results from the various test series.

The WRB-1 correlation appears to predict the CHF test data reasonably well; and the mean value and standard deviations of Measured CHF/Predicted CHF for each individual test series (presented in Table 3-1 of WCAP-8762) appear to be valid indications of the correlation accuracy relative to that test series. None of the 24 test series used a geometry which is exactly the same as one of the Westinghouse fuel assembly designs. Some of the test series are very close to the fuel assembly designs while these include geometry variations (8 foot and 14 foot heated lengths for example) which bound the actual values used in the fuel designs. The test series most representative of the Westinghouse 17x17, 14-foot fuel design are: A-1, A-2, A-5, A-18, the test series most representative of the 17x17, 12-foot fuel design are: A-1, A-2, A-3, A-4, A-5, A-18, A-19; the test series most representative of the Westinghouse 15x15, R grid, 12-foot fuel design are A-6, A-7, A-8, A-9, A-10. A-11, A-12, A-13, A-14, A-15, A-16, A-17; the test series most representative of the Westinghouse 14x14 L grid and 15x15 L grid, 12-foot fuel design are: A-20, A-21, A-22, A-23, A-24. An analysis of variance was performed to determine if there is any

-11-

significant components of variance among these four groups of test series. The results of this analysis indicate that the R-grid data can be treated as a single data set where the variance of the data is represented by two components, one component to account for variance within a given test series and a second component to account for the observed variance among the test series. Similarly, the L-grid data can be treated as a single data set with its own value: of variance within the test series and variance among the test series. For both groupings of data, the total variance can be calculated as follows:

$$\sigma_{\text{Total}}^2 = \sigma_W^2 + \sigma_A^2$$

where:

 $\sigma_W^2$  = variance within the test series about the mean value

 $\sigma_A^2$  = variance among the test series means.

The combined degrees of freedom for these two groupings (i.e., R-grid and L-orid have been calculated on the basis of a weighted harmonic mean of the degrees of freedom for the data within the test series and for the data among the test series. The following formula was used:

 $F_{T} = (\sigma_{W}^{2} + \sigma_{A}^{2})^{2} / (\sigma_{W}^{4}/f_{W} + \sigma_{A}^{4}/f_{A})$ where:  $F_{T} = \text{combined degrees of freedom}$   $\sigma_{W}^{2} = \text{variance within the test series about the mean}$   $\sigma_{A}^{2} = \text{variance among the test series means}$   $f_{W} = \text{degrees of freedom for the data within the test-series}$   $f_{A} = \text{degrees of freedom for data among the test series means}.$  Table VI summarizes the results of these calculations. The differences in  $\sigma_{\rm W}$  and  $\sigma_{\rm A}$  shown in Table VI for the R-grid and the L-grid data demonstrate that a single value of  $\sigma_{\rm W}$  or  $\sigma_{\rm A}$  for all the data would not be appropriate.

The cause of the increased variation among the L-grid test series means relative to the R-grid test series means is not fully known. One possible explanation is that the heated length effect is different for L-grids than for R-grids and that the heated length effect in the WRB-1 correlation is not appropriate for L-grid designs. This speculation is supported by the fact that, for the L-grid tests, the three lowest test series mean values of Measured CHF/Predicted CHF were all associated with the eight foot tests and the three highest test series mean values of Measured CHF/Predicted CHF were associated with the 14-foot tests. This can be seen by comparing the test series means on Figure 2. In addition, direct comparisons can be made between test series which are geometrically identical except for the grid design. There are four cases in which these direct comparisons can be made. For the two 8-foot comparisons, (i.e., test series A-21 vs. A-9 and A-21 vs. A-14) the L-Grid means were lower than the R-grid means (1.59% and 2.77% respectively). For the two 14-foot comparisons, (i.e., A-22 vs. A-7 and new data from tests W-206 to 216 vs. A-6) the L-grid means were higher than the R-grid means (5.58% and 4.47% respectively). These comparisons also indicate that the length effect may be different for L-grid tests and R-grid tests. If there is a real difference in the length effect of L-grids, then the length effect in the WRB-1 correlation is conservative since it produces a higher DNBR limit.

-13-

### Assumptions for PWR Application

Having reviewed the WRB-1 correlation relative to the CHF data, what remains to be determined is the applicability to PWR design. Three areas have been reviewed relative to PWk application of the WRB-1: first, limitations of the correlation related to geometry and coolant conditions; second, uncertainties introduced by CHF test atypicalities; and third, establishment of an appropriate DNBR correlation limit.

The proposed range of coolant conditions is based on the range of all the data.

Based on the empirical nature of the correlation, the range of application should be based on the range of the data. In terms of geometry, the correlation should not be applied to any PWR geometry which has not been specifically tested or which has not been bracketed by the test data. The important parameters to which this applies are: rod size, rod pitch, heated length, mixing vane design and grid spacing.

The following differences between the CHF test and the Westinghouse PWR fuel designs have been reviewed: the inclusion of simple support grids between the mixing vane grids in the CHF test but not in the actual fuel design; heated length; number of rods, grid spacing, and use of stainless steel rods.

The use of stainless steel rods is an industry standard which is not believed to introduce a significant uncertainty relative to PWR applications. Although

-14-

the heated length and grid spacing in the CHF tests is not the same as is used in Westinghouse PWR designs the values tested were sufficiently close to the design values; and the CHF tests also included ranges of heated length and grid spacing which cover the range of design values. The question of the use of simple spacer grids is more complex than the other atypicalities. In the CHF tests the rods are electrically heated and the magnetic forces resulting from the electric current could cause the rods to bow in a manner which is not typical of PWR conditions. In order to reduce or eliminate this potential rod bowing, the CHF tests include simple support grids to prevent rod motion. These simple support grids were designed to minimize their effect on the local fluid conditions. The flow resistance (K) factors for the simple support grids are approximately one third the values for the mixing vane grids. In addition, previous Westinghouse CHF tests (reported in WCAP-7411-1-P-A) were reviewed to determine the effect of the simple support grids on the CHF results. The effects of simple support grids, "T+H mixing vane grids", "mixing vane grids", and "scoop type mixing vane grids" were studied in an eight foot heated test section with 10", 20" and 26" grid spacing.

The effects of simple, minimum resistance grids have also been studied by Babcock & Wilcox (References 6, 7) and Battelle Pacific Northwest Laboratories (Reference 8). These reports generally agree that the turbulent downstream effects of simple grids is eliminated (washed out) within a distance of 8 to 10 inches. Westinghouse fuel designs use mixing vane grid spacings of greater than 20 inches. The CHF tests most closely simulating the fuel design grid spacing were done with 20, 22 and 26-inch grid spacing. For these tests the inclusion

-15-

of simple support grids half-way between the mixing vane grids results in at least a 10-inch distance between the simple support grid and the CHF location which was generally just upstream of a mixing vane grid. Although there is no direct data on the effect of including simple support grids between the mixing vane grids, the existing data on simple support grids are sufficient to indicate that the effect is small or negligible. Therefore no penalty or uncertainty is required in the correlation to account for this atypicality.

The effect of the number of rods in the CHF tests has been reviewed. The CHF tests indicate that CHF occurs on the interior rods. The subchannel analysis of the CHF tests indicates that the enthalpy gradient across the bundle is very small and the potential for CHF being effected by bundle edge effects is therefore minimal. In addition to these observations, it should be noted that the WRB-1 correlation fits the 3x3 bundle data, the 4x4 bundle data and the 5x5 bundle data reasonably well without the need for any empirical terms related to the number of rods in the bundle.

### Staff Positions

The staff has reviewed the subchannel calculations and the other assumptions used in the development of the WRB-1 correlation as well as the atypicalities in the CHF. We conclude that the inclusion of uncertainties for these areas would not significantly alter the WRB-1 correlation or the final DNBR correlation limits. Uncertainties in these areas are therefore not required.

-16-

The WRB-1 CHF correlation predicts the CHF test data reasonably well; and the mean value and standard deviation of the Measured CHF/Predicted CHF for each individual test series are acceptable measures of the accuracy of the correlation. We conclude that there is a significant component of variance associated with changes from one test series to another and that this component of variance must be accounted for in the establishment of a DNBR limit. An acceptable method of accounting for this component of variance was previously discussed. Table VI presented the total variance and degrees of freedoms based on that method. The DNBR limits presented in Table VII were calculated using the same technique for establishing the DNBR limit as proposed by Westinghouse. However, the input values of variance, degrees of freedom and correlation mean were taken from Table VI.

The unusually high DNBR limit of 1.37 for the application of the WRB-1 correlation to L-grid fuel is, in part, due to the limited number of L-grid geometries tested. It may also be the result of a difference in the heated length effect for L-grids relative to R-grids, as previously discussed. The staff acknowledges that additional data or additional analytical work on the WRB-1 correlation for L-grid application could substantially improve the results.

Because of the empirical nature of the correlation and because of the additional component of variance among the test series, as previously discussed, we conclude that the mean value, standard deviation and DNBR limit presented in Table VII are appropriate measures of the correlation accuracy; and that the mean value, standard deviation and DNBR limit, proposed by Westinghouse, based on all 1147 data points are not appropriate

-17-

representations of the correlation accuracy. We find that the WRB-1 correlation is acceptable for use in PWR thermal-hydraulic design with the DNBR correlation limits specified in Table VII.

### References

- Motley, F. E., Hill, K. W., Cadeh, F. F., Shefcheck, J., "New Westinghouse Correlation WRB-1 For Predicting Critical Heat Flux in Rod Bundles with Mixing Vane Grids" WCAP-8762
- Rowe, D. S., "COBRA IIIC: A Digital Computer Program for Steady State and Transient Thermal-Hydraulic Analysis of Rod Bundle Nuclear Fuel Elements, BNWL-1695, March 1973
- Wheeler, C. L., et al, "COBRA IV-I: An Interim Version of COBRA for Thermal-Hydraulic Analysis of Rod Bundle Nuclear Fuel Elements and Cores", BNWL-1962 March 1976.
- Hochreiter, L. E., and Chelemer, H., "Application of the THINC-IV Program to PWR Design", WCAP-8054 September 1973.
- Rosal, E. R., Cermak, J. O., Tong, L. S., "Rod Bundle Axial Non-Uniform Heat Flux DNB Tests and Data" WCAP-7411-1-P-A, January 1975
- Zielhe, L. A., Wilson, R. H., "Transient Critical Heat Flux and Spacer Grid Studies", Nuclear Technology, Volume 24. October 1974.
- Morgan, C. D., "Correlation of Critical Heat Flux in a Bundle by Pressurized Water" BAW-10036, January 1972.
- Alberman, R. T., and Rowe, D. S., "An Experimental Study of Turbulent Flow in a Model Babcock & Wilcox Fuel Bundle" PNL Report 212 B00763.

TABLE 1

15

COMPARISON OF LOCAL COOLANT CONDITIONS

Test .	Difference in Calc THINC-COLMA III	ulated % Quality* THINC-COBRA IV
W-1796	-0.6	-0.6
W-17979	-1.0	-1.0
w-1798	-0.4	-0.4
W-1799	-0.4	-0.3
W-1800	-0.1	+0.1
w-1801	+0.1	+0.1
W-1802	+0.4	+0.4
W-1803	-0.1	+0.1
W-1804	-0.4	=0.4
W-1805	-0.8	-0.8
W-1806	-0.1	-0.2
W-1807	-0.6	-0.6
W-1808	0.0	-0.5
W-1809	-0.7	-0.7
W-1810	-0.3	-0.3
W-1811	-0.3	-0.2
W-1812	-0.2	-0.1
W-1813	-0.2	-0.2

\*Difference in % Quality = THINC Quality in % - COBRA Quality in %

### TABLE II

## TYPICAL, LOCAL COOLANT CONDITIONS AT CHE LOCATION FROM COBRA

SUBCHANNEL	ENTHALPY BTU/LB	QUALITY %	MASS FLOW MLB/M FT2
1	794.8	19.0	2.755
2	793.7	18.8	2.766
3	793.1	18.6	2.773
4	792.8	18.5	2.219
5	792.5	18.4	2.217
6	792.4	18.4	1.961

### Typical Comparison of the Test Series Mean Values of Measured CHF/Predicted CHF

Using THINC and COBRA-IV

### Table III

Test Series	#Pts	Measured CHF WCAP-8762	Predicted CHF COBRA	Standard Deviation WCAP-8762 COBRA
A-1	71	.9964	.9910	.0655 .0640
A-3	73	1.0502	1.0360	.1020 .0932

### Table IV

Typical Comparison of the Test Series Mean Values of Measured CHF/Predicted CHF

Using COBRA III and COBRA IV

Test Series	# Pts	Measured CHF Predicted CHF COBRA III COBRA IV		Standard Deviation COBRA III COBRA I	
A-1	71	.9912	.9910	.0640	.0640

\*Test geometry for each series is identified in Table 3-1 of WCAP-8762

Description	Test Series	F Calculated Values	Theoretical F Range at 99% Confidence
All Data	A-1 A-24	11.2	.6 - 1.8
All R grid	A-1 A-19	6.2 -	.5 - 2.0
All L grid	A-20 A-24	46.4	.3 - 3.3
14' UNIF	A-1, A-2, A-15	15.4	.2 - 4.7
14' COSINE	A-5 A-18	1.05	.2 - 6.9
14' USINU, R Grid	A-9, A-10, A-11 A-12, A-14, A-16 A-17	6.9	.2 - 2.8
14' USINU L Grid	A-21, A-23, A-24	16.3	.2 - 4.7
14' USINU R&L Grid	A-9, A-10, A-11 A-12, A-14, A-16, A-17, A-21, A-23 A-24	8.0	.4 - 2.4
8' UNIF	A-3, A-19, A-4	2.6	.2 - 4.6
14', 5x5 TYP	A-1, A-2, A-5	.2	.2 - 4.6
14', 22" GSP	A-1, A-5, A-18	.1	.2 - 4.6
14', 4x4, TYP, R-Grid	A-9, A-10, A-11 A-12, A-14, A-15	15.7	.3 3.0
14', 5x5	A-1, A-2, A-5	.13	.3 - 3.8
14', 5x5, UNIF, TYP	A-1, A-2	.4	.2 - 6.9
8', 5x5, UNIF, TYP	A-3, A-4	.7	.2 - 6.9
5x5, UNIF, TYP	A-1, A-2, A-3, A-4	5.5	.3 - 3.8

### Table V

Analysis of Variance Test for CHF Data

## TABLE VI

## **STATISTICS FOR R-GRID AND L-GRID**

GRID TYPE	σw	٥A	۰°T	FT	AVG. M/P
R	0.0819	0.0298	0.0871	633	1.0084

L 0.0647 0.0719 0.0968 13 0.9818

$$\sigma_{T}^{2} = \sigma_{W}^{2} + \sigma_{A}^{2}$$

$$F_{T} = \left(\sum_{i=w}^{A} \sigma_{i}^{2}\right)^{2} / \sum_{i=w}^{A} \sigma_{i}^{4} / f_{i}$$

## TABLE VII

# ACCEPTABLE PWR FUEL DESIGN, DNBR LIMITS

FUEL DESIGN	APPLICABLE TEST SERIES	DNBR LIMIT
17 x 17 R GRID 14' LENGTH	A-1, A-2, A-5, A-18	
17 x 17 R GRID	A-1, A-2, A-5, A-18	
12' LENGTH	A-3, A-4, A-19	> 1.17
15 x 15 R GRID	A-6, A-7, A-8, A-9,	
12' LENGTH	A-10, A-11, A-12, A-13,	
	A-14, A-15, A-16, A-17 )	
15 x 15 L GRID	A-20, A-21, A-22, A-23, )	
12' LENGTH	A-24	
		1.37
14 x 14 L GRID		
12' LENGTH	. )	





Figure 2



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

JUN 2 9 1984

Mr. E. P. Rahe, Jr., Manager Nuclear Safety Department Water Reactor Divisions Westinghouse Electric Corporation P. O. Box 355 Pittsburg, Pennsylvania 15230

Dear Mr. Rahe:

Fastanium. As shaded

SUBJECT: ACCEPTANCE FOR REFERENCING OF LICENSING TOPICAL REPORT -WCAP-8762(P)/WCAP-8763(NP), SUPPLEMENT 1, "BASIS FOR THE APPLICABILITY OF THE WRB-1 CORRELATION TO 15 x 15 OFA AND 14 x 14 OFA FUEL"

We have completed our review of the subject topical report submitted November 18, 1983, by Westinghouse Electric Corporation. We find the report to be acceptable for referencing in license applications to the extent specified and under the limitations delineated in the report and the associated NRC evaluation, which is enclosed. The evaluation defines the basis for acceptance of the report.

We do not intend to repeat our review of the matters described in the report and found acceptable when the report appears as a reference in license applications, except to assure that the material presented in applicable to the specific plant involved. Our acceptance applies only to the matters described in the report.

In accordance with procedures established in NUREG-0390, it is requested that Westinghouse publish accepted versions of this report, proprietary and non-proprietary, within three months of receipt of this letter. The accepted versions shall incorporate this letter and the enclosed evaluation between the title page and the abstract. The accepted versions shall include an A (designating accepted) following the report identification symbol.

Should our criteria or regulations change such that our conclusions as to the acceptability of the report are invalidated, Westinghouse and/or the applicants referencing the topical report will be expected to revise and resubmit their respective documentation, or submit justification for the continued effective applicability of the topical report without revision of their respective documentation.

Sincerely,

ecil O. Shamas

Cecil O. Thomas, Chief Standardization and Special Projects Branch Division of Licensing

### ENCLOSURE

### WCAP-8762(P)/WCAP-8763(NP)

### SER ON THE APPLICABILITY OF WRB-1 TO WESTINGHOUSE 14X14 AND 15X15

### 1. INTRODUCTION AND BACKGROUND

The Westinghouse rod bundle critical heat flux (CHF) correlation, WRB-1, has prevously been approved (Ref. 1,2) for application to the 15x15 and 17x17 standard low parasitic (LOPAR) fuel assemblies and 17x17 optimized fuel assemblies (OFA). The approved minimum departure from nucleate boiling ratios (DNBR) are 1.17 for the standard R-type mixing vane grid assembly and the 17x17 OFA, and 1.37 for the standard L-Grid assembly. By letter dated November 18, 1983 (Ref. 3), Westinghouse submitted Supplement 1 to WCAP-8762, "Basis for the Applicability of the WRB-1 correlation to 15x15 and 14x14 OFA Fuel," to appTy for the extension of the application of WRB-1 to the 14x14 and 15x15 OFA with a DNBR limit of 1.17.

The differences between the OFA and standard LOPAR fuel are the fuel pin diameters and the mixing vane spacer grid designs. The 17x17 OFA has a pin outer diameter of 0.36 inches versus 0.374 inches for the standard 17x17 fuel; the 14x14 OFA and 15x15 OFA have pin diameters of 0.40 inches and 0.422 inches, respectively, compared to 0.422 inches for both 14x14 and 15x15 standard fuel. The OFA spacer grid has thicker and higher straps made of Zircaloy having different mechanical properties than the Inconel straps used in the standard grids. Although the OFA grid dimensions are different than the standard LOPAR grid, Westinghouse stated that there is no significant departure from the type-R grid characteristics.

The WRB-1 correlation as described in WCAP-8762 (Ref. 4) was orginally approved for application to the 17x17 and 15x15 standard fuel assemblies based on the available CHF test data representative of standard fuel.

In order to extend the application of WRB-1 to the 17x17 OFA, Westinghouse in its submittal WCAP-9401 (Ref. 5) provided additional CHF test data from a test assembly representative of the 17x17 OFA. To justify that the DNBR limit of 1.17 is applicable to the 17x17 OFA, a statistical analysis was performed to show that the OFA data belong to the same population as the standard R-grid data. The result of this analysis showed that the OFA data were within the tolerance limits of the means of the measured to predicted CHF ratios (M/P) of the comparable standard R-grid data. The analysis of variances showed that the null hypothesis, that the variances of the M/P ratios of the OFA typical cell and standard R-grid typical cell are equal, would not be rejected at a 5 percent significance level. For the OFA thimble cell data, a similar hypothesis would be rejected at a 5 percent significance level. However, since the rejected OFA data had a lower standard deviation, it was shown that a DNBR limit of 1.17 would be conservative when applied to the rejected data. Based on this analysis, WRB-1 was found acceptable for application to the 17x17 OFA with the same DNBR limit of 1.17.

The extension of the WRB-1 applicability to the 14x14 and 15x15 OFA will be evaluated and discussed in the following section.

### 2. STAFF EVALUATION

In order to justify the extension of the applicability of WRB-1 to the 14x14 and 15x15 OFA, Westinghouse provided additional CHF test data from the test bundle representative of the 14x14 OFA. Westinghouse maintains that the same DNBR limit of 1.17 for the standard R-grid fuel is also applicable to the 14x14 and 15x15 OFAs. To justify this assertion, it must be shown that the 14x14 OFA data belong to the same population which was used to determine the limit, or that 1.17 was a conservative limit relative to any limit based on the OFA data. In addition, since there is no CHF data representative of the 15x15 OFA, it is necessary that the 15x15 OFA geometry is within the WRB-1 applicability range.

- 2 -
In order to show that the 14x14 OFA test data belong to the same population as the standard fuel data, Westinghouse has performed a statistical analysis of the measured to predicted CHF ratios from the 14x14 OFA test data and the comparable standard R-grid data with fuel OD of 0.422 inches. The analysis consists of a F-test for equality of population variances and a t-test for equality of population means. The results show that both null hypotheses of equal variances and means of the 14x14 OFA and the comparable standard R-grid data distributions cannot be rejected at a 5 percent significance level. In this analysis, Westinghouse has combined the 2 sets of standard R-grid data having 0.422 inches pin diameter and 26 inches grid spacing into one group and therefore the tests of variances and means are simply two group analyses between the standard and OFA data. The st ff has performed a one way analysis of variances for the equality of means test as an independent check. In this calculation, the standard R-grid data are not combined into one group. The result of this staff analysis of variance also shows that the null hypothesis of equal means cannot be rejected at 5 percent significance level. Therefore, the 14x14 OFA CHF data can be incorporated into the total R-grid population. Using the mean and standard deviation of the (M/P) ratios corresponding to the combined total data, the derived one-sided tolerance minimum DNBR limit would be 1.163 with 95 percent probability at a 95 percent confidence level of avoiding DNB. In addition, the 95/95 DNBR limit derived from the 14x14 OFA data alone would be 1.122. These DNBR limits are below the proposed 1.17. Therefore, the staff concludes that WRB-1 is applicable to the 14x14 OFA with a DNBR limit of 1.17.

The 15x15 OFA design is virtually identical to the 15x15 R-grid design except for the spacer grid dimensions. In order to minimize the effect of the grid dimensional changes on DNB performance, Westinghouse stated that special care was taken in the OFA grid design to preserve the important mixing vane characteristics, flow area ratio, and the dimple and spring arrangement used for maintaining the grid-to-rod contact. The

- 3 -

success of the use of this scaling technique in the OFA grid design has been demonstrated by the fact that WRB-1 predicts both 17x17 and 14x14 OFA CHF data well without any modification to the correlation. Repeatability studies performed as described in WCAP-9401 have shown that the WRB-1 correlation's prediction capability is essentially identical for both OFA and standard fuel geometry, indicating no additional component of variance is introduced by the grid dimensional change. In other words, the correlation correctly accounts for the equivalent diameter effects and the scaling approach for the grid dimensional changes.

Since the 15x15 OFA diameter, rod pitch, heated length and grid spacing are within the WRB-1 applicability range and the success of the scaling technique in the OFA mixing vane grid design has been proved by the similar 14x14 and 17x17 OFA grid design, we conclude that WRB-1 is also applicable to the 15x15 OFA with a DNBR limit of 1.17.

## 3. REGULATORY POSITION

The staff has reviewed Supplement 1 to WCAP-8762. We find that the WRB-1 correlation is acceptable for application to both 14x14 OFA and 15x15 OFA with a minimum DNBR limit of 1.17. This acceptability is subject to other restrictions which were imposed in the staff safety evaluation reports (Refs. 1 and 2) on WCAP-8762 and WCAP-9401.

REFERENCES

- Memorandum from D. F. Ross, Jr. (NRC) to D. B. Vassallo (NRC), "Topical Report Evaluation for WCAP-8762," April 10, 1978.
- Letter from R. L. Tedesco (NRC) to T. M. Anderson (Westinghouse), "Acceptance for Referencing Topical Report WCAP-9401(P)/WCAP-9402 (NP)," May 7, 1981.
- Letter from E. P. Rahe, Jr. (Westinghouse) to C. O. Thomas (NRC), "Basis for Applicability of the WRB-1 CHF Correlation to 15x15 OFA and 14x14 OFA Fuel, Supplement 1, WCAP-8762," NS-EPR-2854, November 18, 1983.
- 4. F. E. Motley, et al, "New Westinghouse Correlation WRB-1 For Predicting Critical Heat Flux In Rod Bundles With Mixing Vane Grids," Westinghouse Topical Report WCAP-8762, July 1976.
- M. D. Beaumont and J. Skaritka, "Verification Testing and Analyses of the 17x17 Optimized Fuel Assembly," WCAP-9401, March 1979.

### TABLE OF CONTENTS

ection	Title	Page
1	INTRODUCTION	1-1
2	ORIGIN OF THE CORRELATION	2-1
3	STATISTICS	3-1
	3-1. Sources of Data	3-1
	3-2. Test Section Characteristics	3-1
	3-3. Statistical Results	3-6
	3-4. Prediction of CHF Location	3-6
	3-5. Data Plots	3-7
	3-6. Design Criterion	3-7
4	CONCLUSIONS	4-1
	APPENDIX	A-1 through A-55

# APPENDIX B - NRC CORRESPONDENCE

- B.1 Letter from J. F. Stolz to C. Eicheldinger, September 28, 1977, request for additional information
- B.2 Letter from C. Eicheldinger to J. F. Stolz, October 24, 1977, response to request for additional information on WCAP 8762 and WCAP 8763

B.3 Supplement 1 to WCAP-8763

Se

# LIST OF ILLUSTRATIONS

Figure	Title	Page
2.1	Typical Fits of the Form $q''CHF = A - BX_{LOC}$ with Westinghouse Mixing Vane Grid Data	2-2
3-1	8 ft. and 14 ft. Heater Rods Axial Heat Flux Distributions	3-4
3.2	Cross Sections of CHF Test Sections	3-5
3.3 .	Measured vs Predicted Critical Heat Flux	3-8
3-4	Measured-to-Predicted Critical Heat Flux vs Local Quality	3-9
3-5	Measured-to-Predicted Critical Heat Flux vs Local Mass Velocity	3-10
3-6	Measured-to-Predicted Critical Heat Flux vs Pressure	3-11

۷

10 mm

# LIST OF TABLES

Table	Title	Page
3-1	WRB-1 CHF Correlation - Statistical Results	3-2
3-2	Accuracy of CHF Location Predictions	3-6

# ACKNOWLEDGMENT

The authors wish to thank Mr. Jeffry Hoffman who developed the flexible and sophisticated computer techniques used in developing this correlation.

# ABSTRACT

A new critical heat flux (CHF) correlation, based on local fluid conditions, has been developed from Westinghouse rod bundle data. This correlation applies to both 0.422 inch and 0.374 inch rod O. D., geometries. It accounts for typical cell and thimble cell effects, uniform and non-uniform heat flux profiles, variations in rod heated length and in grid spacing. The applicable range of variables is:

Pressure	1440 ≤ P ≤ 2490 psia
Local Mass Velocity	$0.9 \le G_{loc}/10^6 \le 3.7 \text{ lb/ft}^2$ -hr
Local Quality	$-0.2 \le X_{loc} \le 0.3$
Heated Length, Inlet to CHF Location	$L_{h} \leq 14$ feet
Grid Spacing	$13 \leq g_{sp} \leq 32$ inches
Equivalent Hydraulic Diameter	$0.37 \le d_e \le 0.60$ inches
Equivalent Heated Hydraulic Diameter	$0.46 \le d_h \le 0.58$ inches

The correlation predicts CHF for 1147 data points with a sample mean and standard deviation of measured-to-predicted heat flux ratio of 1.0043 and 0.0873, respectively.

It was concluded that to meet the reactor design criterion the minimum DNBR should be 1.17.

The new CHF correlation in the above range of applicability is intended to supercede correlations presently in use for Westinghouse cores employing the "L" and "R" - grid fuel assembly designs.

The name WRB-1 (for "Westinghouse Rod Bundle") has been selected for this new correlation.

# SECTION 1 INTRODUCTION

The W-3 correlation, and several modifications of it, are presently used for all Westinghouse CHF calculations. The W-3 was originally developed from single tube data,<sup>[1]</sup> but was subsequently modified to apply to the 0.422 inch O. D. rod "R"-grid,<sup>[2]</sup> and "L"-grid,<sup>[3]</sup> as well as the 0.374 inch O. D.,<sup>[4,5]</sup> rod bundle data. These modifications to the W-3 correlation have been demonstrated to be adequate for reactor rod bundle design.

However, it has been felt that a new correlation could be developed based exclusively on the large bank of mixing vane grid rod bundle CHF data (over 1100 points) that Westinghouse has collected in recent years. Such a new correlation would, ideally, represent these data with better accuracy over a wider range of variables. It is the purpose of this report to describe the development of such a correlation, which has been named the WRB-1 correlation.

<sup>1.</sup> L. S. Tong, "Boiling Crisis and Critical Heat Flux", TID-25887, 1972.

<sup>2,</sup> F. E. Motley, F. F. Cadek, "DNB Test Results for New Mixing Vane Grids (R), WCAP-7958-A, January, 1975.

F. E. Motley, F. F. Cadek, "Application of Modified Spacer Factor to L Grid Typical and Cold Wall Cell DNB", WCAP-8030-A, October, 1972.

<sup>4.</sup> F. E. Motley, A. H. Wenzel, F. F. Cadek, "Critical Heat Flux Testing of 17 x 17 Fuel Assembly Geometry with 22 inch Grid Specing", WCAP-8537, May, 1975.

K. W. Hill, F. E. Motley, F. F. Cadek, A. H. Wenzel, "Effect of 17 x 17 Fuel Assembly Geometry on DNB", WCAP-8297-A, February, 1975.

# SECTION 2 ORIGIN OF THE CORRELATION

The development of the correlation started by considering data from individual test geometries one at a time to establish the basic relationships between the flow parameters. Different test geometries were then added, one by one, in an orderly fashion to identify and correlate the effects of test section length, grid spacing,  $D_e$ ,  $D_h$ , and grid type. The details of this step-by-step process are as follows:

1) Basic Form of the Correlation

The development of the new CHF correlation was based on the evaluation of local fluid conditions as determined by the THINC sub-channel computer code. Inspection of the data from the 0.374 inch rod O. D. uniformly heated tests indicated that there exists a linear relationship between CHF heat flux and local quality  $(X_{LOC})$ :

This relationship is entirely empirical, but it has been observed by many different experimentors, as discussed in reference.<sup>[1]</sup> It applies quite well to Westinghouse mixing vane grid data.

2) Identification of Parameter Dependence of Empirical Functions A and B

Figure 2-1 shows a large number of lines plotted on the  $q''_{CHF}$  versus  $X_{LOC}$  plane; each line is from a linear regression fit of several runs carried out with the same test section conditions of constant pressure and flow. Inspection of figure 2-1, and of other similar plots for other tesc geometries, shows similar trends with respect to the functional variations of the "constants" A and B. After extensive trial and error fitting, it was concluded that:

$$A = A(P, GLOC, L_H, g_{SP}, d_q)$$

 $B = B(P, G_{LOC}, L_H)$ 

where:

P = pressure (psia)

t. P. G. Barnett, "An investigation into the Validity of Certain Hypotheset Implied by Various Burnout Correlations", AEEW-R214, June, 1963.

FITS ARE FROM 14 FT. 0.374 INCH ROD 0.D., UNIFORM, TYPICAL CELL TEST SECTIONS WITH 22 INCH GRID SPACING

SYMBOL	PRESSURE PSIA	GLOC LB 106' HR-FT <sup>2</sup>
A	1500	2.5
В	1500	3.5
C	1800	1.5
D	1800	2.5
Ε	1800	3.5
F	2100	1.5
G	2100	2.5
H	2100	3.5
1	2400	1.5
J	2400	3.5



Figure 2-1. Typical Fits of the Form  $Q''_{CHF} = A - BX_{LOC}$ with Westinghouse Mixing Vane Grid Data

GLOC = local mass velocity (lb/ft<sup>2</sup>-hr)

 $L_{H}$  = heated length, inlet to CHF location (feet)

- gsp = grid spacing (inches)
- d<sub>n</sub> = distance from last grid to CHF site (inches)
- 3)

Basic Form of Correlation Based on 0.374 Inch Rod O. D. Uniformly Heated Typical Cell Data

In the development of the correlation, the initial formulation of the A and B functions was based first only on four sets of 0.374 inch rod O. D. axially uniform heat flux typical cell data. This resulted in an evaluation of A and B which applied to uniformly heated, typical cell data, and included heated length, grid spacing, and distance from the last grid to the site of CHF.

In the evaluation of the coefficients, the conditions at the actual measured CHF location for each uniform heat flux point were used. In cases where CHF was indicated at two elevations, conditions at both elevations were included. An extensive discussion of this approach is given in reference.<sup>[1]</sup>

The new form of the correlation contains the distance from the last grid to the CHF site as a parameter. The addition of this parameter to the correlation enables it to provide about 93 percent agreement between the measured and predicted CHF elevation. This will be discussed in more detail in section 3-4.

## 4) Confirmation of the Existing Non-Uniform F-factor

Once a form was developed which represented the uniformly heated data, the CHF correlation was applied to the 0.374 inch rod O. D. non-uniform typical cell data, using the non-uniform F-factor.<sup>[2]</sup> The derivation given in that reference is from theoretical considerations, and is thus an analytical form, except for a single sonstant" which must be evaluated utilizing the test data. The formulation of this constant (actually a function of local conditions) is given in reference.<sup>[2]</sup> Comparison with non-uniform data indicated that no modification to either the constant or the form of the F-factor was necessary for the present application.

<sup>1.</sup> F. E. Motley, A. H. Wenzel, F. F. Cadek, "Critical Heat Flux Testing of 17 x 17 Fuel Assembly Geometry with 22 inch Grid Spacing", WCAP-8537, May, 1975.

<sup>2.</sup> L. S. Tong, "Boiling Crisis and Critical Heat Flux", TID-25887, 1972.

## 5) Extension of Correlation to Other Rod Bundle Geometries

With the confirmation that the form of the F-factor of reference<sup>[1]</sup> was satisfactory when used with the new form of the correlation, the new correlation was then extended to the large body of Westinghouse data taken with 0.422 inch rod O. D. non-uniform axial heat flux test sections. This extension required the addition of several new constants to the correlation in order to account for the differences in test section geometry. These geometry effects are expressed by terms incorporating  $D_e$  and  $D_h$  (hydraulic and heated hydraulic equivalent diameters). The much wider range of grid spacing available with this 0.422 inch data necessitated a modification in the form of the grid spacing term.

Once the geometry differences had been accounted for with typical cell data, the new correlation was then extended to thimble cell data. This resulted in further modification of the  $D_e$  and  $D_h$  terms so that the revised form could apply to both typical and thimble cell geometries.

#### 6) Formulation of Performance Factor (PF)

The above formulation fit the data well, but it required a performance factor (PF) to yield the proper trend with  $D_e$  and  $D_h$  in going from the 0.422 inch rod O. D. to the 0.374 inch rod O. D. data. This allowed the correlation to simulate the slight change in the geometry of the mixing vane between the 0.422 inch and the 0.374 inch O. D. rod bundle geometry.

In order to assure the proper  $D_e$  trend independent of the performance factor, an additional set of 0.500 inch O. D. rod data with mixing vanes scaled from the 0.422 inch mixing vane shape was added to the total data set.

# 7) Final Form of Correlation

The final form of WRB-1 correlation, which meets all the criteria discussed above, is given on the following page.

1. L. S. Tong, "Boiling Crisis and Critical Heat Flux", TID-25887, 1972.

# WRB-1 CHF CORRELATION



## RANGE OF VARIABLES

Pressure	1440 ≤ P ≤ 2490 psia
Local Mass Velocity	$0.9 \le G_{loc}/10^6 \le 3.7 \text{ lb/ft}^2 \text{-hr}$
Local Quality	$-0.2 \le X_{10C} \le 0.3$
Heated Length, Inlet to CHF Location	$L_h \le 14$ feet
Grid Spacing	$13 \leq g_{sp} \leq 32$ inches
Equivalent Hydraulic Diameter	$0.37 \leq d_e \leq 0.60$ inches
Equivalent Heated Hydraulic Diameter	$0.46 \le d_h \le 0.58$ inches

# SECTION 3 STATISTICS

## 3-1. SOURCES OF DATA

Westinghouse, over a period of about six years, has collected a large body of rod bundle CHF data - over 1100 runs - using full-scale, electrically-heated rod bundle test sections. All of these tests were carried out at the Columbia University Heat Transfer Laboratory. A complete description of the Columbia University test facilities, and of the general procedures followed in conducting these tests, is given in reference.<sup>[1]</sup>

Table 3-1 summarizes the various bodies of data used in developing the WRB-1 correlation. Most, but not all, of these data sets have been published previously; the appropriate references are given in table 3-1. However, all the data - whether previously published or not - are given in the appendix of this report.<sup>[2]</sup>

# 3-2. TEST SECTION CHARACTERISTICS

The references given in table 3-1 contain detailed descriptions of the various test sections used to obtain these data, but a brief summary of their pertinent characteristics is given below for convenience.

All of the test sections were either 8 or 14 feet in heated length. The axial heat flux profiles were either uniform or non-uniform; the non-uniform test sections had either a cosine or a usinu axial heat flux profile. Figure 3-1 shows the shapes of the various axial heat flux profiles that have been tested.

Figure 3-2 is a sketch of the various test geometry cross sections from which the data were obtained.

These test sections were all in the form of rectangular array rod bundles;  $5 \times 5$  for the 0.374 inch rod O. D. test sections, all of which used "R" type grids: and  $4 \times 4$  for the 0.422 inch rod O. D. test sections, which used either "R" or "L" grids.<sup>[3]</sup> The test sections simulated

K. W. Hill, F. E. Motley, F. F. Cadek, A. H. Wenzel, "Effect of 17 x 17 Fuel Assembly Geometry on DNB", WCAP-8297-A, February, 1975.

<sup>2.</sup> It should be noted that many of the previously reported sets contain substantially more data points than have been reported before. This is because in the past data with qualities above the W-3 quality limit, usually taken to be 15 percent, were eliminated.

The 0.500 inch rod O. D. data points included in this study were taken with a 3 x 3 test section which was otherwise similar to other typical cell "L" grid rod bundles.

# TABLE 3-1

# WRB-1 CHF CORRELATION - STATISTICAL RESULTS

R	od O. D. Inch	L <sub>H</sub> ft	9sp Inch	Heat Flux Profile	[a] Configuration	N	(M) AVG	Standard Deviation, S	Reference	Appendix Table
"R"	0 374	14	22	UNIF	TYP - 5X5	71	0.9964	0.0655	[1]	A- 1
Grid	0.374	14	26	UNIF	<b>TYP - 5X5</b>	73	1.0041	0.0805	[2]	A- 2
unu	0.374	8	22	UNIF	<b>TYP - 5X5</b>	67	1.0502	0.1020	[1]	A- 3
	0.374	8	26	UNIF	<b>TYP - 5X5</b>	78	1.0136	0.0848	[2]	A- 4
	0.374	14	22	COSINE	<b>TYP - 5X5</b>	74	1.0022	0.0852	[1]	A- 5
	0.422	8	20	COSINE	TYP - 4X4	33	1.0042	0.0528	[3]	A- 6
	0.422	8	20	USINU	TYP - 4X4	33	0.9937	0.0649	[3]	A- 7
	0.422	8	26	USINU	TYP - 4X4	36	0.9846	0.0922	[3]	A- 8
	0.422	14	26	USINU	TYP - 4X4	35	1.0584	0.0816	[4],[3]	A- 9
	0.422	14	20	USINU	TYP - 4X4	36	1.0100	0.09.5	[b]	A-10
	0.422	14	13	USINU	TYP - 4X4	38	0.9737	0.0781	[b]	A-11
	0.422	14	32	USINU	TYP - 4X4	38	1.0238	0.0752	(3)	A-12
	0.422	8	32	USINU	TYP - 4X4	31	0.9913	0.0724	[3]	A-13
	0.422	14	26	USINU	TYP - 4X4	71	1.0466	0.0829	[4]	A-14
	0.422	14	26	UNIF	TYP - 4X4	42	0.9321	0.0595	[2]	A-15
	0.422	14	26	USINU	TH - 4X4	39	1.0141	0.0579	[5]	A-16
	0.422	14	32	USINU	TH - 4X4	37	0.9728	0.0887	[5]	A-17
	0.374	14	22	COSINE	TH - 5X5	70	1.0002	0.0796	[1]	A-18
	0.374	8	26	UNIF	TH - 5X5	68	1.0303	0.1048	[2]	A-19
	0.422	8	26	COSINE	TYP - 4X4	36	0.8826	0.0369	,6]	A-20
Grid	0.422	14	26	USINU	TYP - 4X4	41	1.0743	0.0740	[7]	A-21
Griu	0.422	8	20	USINU	TYP - 4X4	29	0.9379	0.0733	[6]	A-22
	0.422	14	26	USINU	TH - 4X4	38	0.9998	0.0728	[7]	A-23
	0.500	14	20	USINU	TYP - 3X3	33	0.9934	0.0581	[6]	A-24
				ATA		1147	1 0043	0.0873		

All DATA

b. Not Previously Published

TH - Thimble Cell

a. TYP - Typical Cell

#### TABLE 3-1 (cont)

#### WRB-1 CHF CORRELATION - STATISTICAL RESULTS

- Motley, F. E., Wenzel, A. H., and Cadek, F. F., "Critical Heat Flux Testing of 17 x 17 Fuel Assembly Geometry with 22-Inch Grid Spacing," WCAP-8537, May, 1975.
- Hill, K. W., Motley, F. E., Cadek, F. F., and Wenzel, A. H., "Effect of 17 x 17 Fuel Assembly Geometry on DNB", WCAP-8297-A, February, 1975.
- 3. Motley, F. E., and Cadek, F. F., "DNB Test Results for New Mixing Vane Grids (R)," WCAP-7958-A, January, 1975.
- 4. Hill, K. W., Motley, F. E., and Cadek, F. F., "Evaluation of DNB Test Repeatability," WCAP-8201, July, 1973.
- Motley, F. E., and Cadek, F. F., "DNB Test Results for R Grid Thimble Cold Wall Cells, WCAP-7958-A1-A, January, 1975.

3.3

.

- Rosal, E. R., Cermak, J. O., and Tong, L. S., "Rod Bundle Axial Nonuniform Heat Flux DNB Tests and Data," WCAP-7411, December, 1969.
- Motley, F. E., and Cadek, F. F., "Application of Modified Spacer Factor to L-Grid Typical and Cold Wall Cell DNB," WCAP-8030, October, 1972.





10.235-2

3.4

10.235-3







4



Figure 3-2. Cross-Sections of CHF Test Sections

either a typical cell (all rods heated) or a coldwall cell (i.e., one interior rod unheated, simulating a control rod thimble tube).

## 3-3. Statistical Results

Table 3-1 gives the results of applying the WRB-1 correlation to each of the various rod bundle sets, in the form of an average measured-to-predicted critical heat flux ratio,  $(M/P)_{AVG}$  and sample standard deviation, s, for each data set. The individual M/P's were evaluated at the point of minimum DNBR, which is defined as:

# DNBR = (q"CHF)PRED/(q"CHF)MEAS

## 3-4. Prediction of CHF Location

An unusual feature of the new CHF correlation is the incorporation of a grid spacing term  $g_{SP}$ , and of a term which represents the distance to the point of CHF from the last mixing vane grid,  $d_g$ . The inclusion of these terms permits a more accurate prediction of the CHF location (the position of minimum predicted-to-measured heat flux ratio). The accuracy of these predicted locations is given in the following table.

## TABLE 3-2

# ACCURACY OF CHF LOCATION PREDICTIONS

Data Group	Predictions <sup>[a]</sup>
All Uniform	92.7%
All Non-uniform	75.8%
All	81.7%

a. Based on a 4 percent band for agreement in M/P. This means that if the minimum DNBR location and the measured location are within 4 percent in the value of M/P, they are considered to be in agreement. The 4 percent bandwidth is based on the repeatability study reported in reference. [?] which showed that 4 percent is the standard deviation for repeatability of Westinghouse CHF tests.

1. K. W. Hill, F. E. Motley, "Evaluation of DNB Test Repeatability", WCAP-8201, July, 1973.

The accuracy of these predictions is most significant with respect to the uniform heat flux data. For the non-uniform data, the exact axial location of CHF is not significant in terms of predictive capability of rod bundle or reactor core power level at CHF. This is discussed in detail in<sup>[1]</sup>.

#### 3-5. Data Plots

Figures 3-3 through 3-6 show the results of applying this correlation to all of the data. Figure 3-3 shows measured critical heat flux plotted against predicted for the 1147 data points. Figures 3-4, 3-5, and 3-6 show M/P (measured-to-predicted heat flux ratio) plotted against fluid parameters - pressure, flow and quality. The low scatter (s = 0.0873) in the data and the absence of any significant trend with the fluid parameters indicates that the W.RB-1 correlation accounts quite well for the behavior of these fluid parameters.

#### 3-6. Design Criterion

For the design of Westinghouse reactor cores, the chosen criterion is that CHF will not occur at a 95 percent probability with a 95 percent confidence level. In order to meet this criterion, a limiting value of DNBR is determined by the method of Owen.<sup>[2]</sup> Owen has prepared tables which give values of  $k_p$  such that at least a proportion P of the population is greater than  $(\frac{M}{P})_{AVG} - k_p s$  with confidence  $\gamma$  where  $(\frac{M}{P})_{AVG}$  and s are the sample mean and standard deviation, respectively. When this method was carried out using all 1147 data points, the results indicate that a reactor core designed using the *WRB-1* correlation could operate with a minimum DNBR of 1.17 and satisfy the design criterion.

<sup>1.</sup> F. E. Motley, A. H. Wenzel, F. F. Cadek, "Critical Heat Flux Teating of 17 x 17 Fuel Assembly Geometry with 22 inch Grid Spacing", WCAP-8537, May, 1975.

<sup>2.</sup> D. B. Owen, "Factors for One-Sided Tolerance Limits and for Variable Sampling Plans", SCR-607, March, 1963.



Figure 3-3. Measured versus Predicted Critical Heat Flux - WRB-1 Correlation



Figure 3-4. Measured-to-Predicted Critical Heat Flux versus Local Quality - WRB-1 Correlation



Figure 3-5. Measured-to-Predicted Critical Heat Flux versus Local Mass Velocity - WRB-1 Correlation

Figure 3-6. Measured-to-Predicted Critical Heat Flux versus Pressure - WRB-1 Correlation



PRESSURE (PSIA)

# SECTION 4 CONCLUSIONS

The WRB-1 CHF correlation described in this report fits over 1100 rod bundle data points well, with no modification of the non-uniform F-factor. A significant improvement in the accuracy of CHF prediction has been obtained, with a minimum DNBR of 1.17 required to meet the reactor design criterion.

APPENDIX

# WESTINGHOUSE ROD BUNDLE CHF DATA SUMMARY

			1 1 1 1	VELOCITY IXIOCO IDM/HD-SOFTI	1 F)	IPSIA)	R114
. 8841 . 8160 . 9332 . 9946 . 9645 1.0316 1.1251 . 9387 . 9387 . 9368 . 6887 . 6957 . 9368 . 6887 . 69442 . 8914 . 9437	and the second se	***********	*******	**************	• • • • • • • • • •		
. 8160 . 9332 . 9946 . 9645 1.0316 1.1251 . 9387 . 9128 . 4507 . 9368 . 4887 . 9368 . 4887 . 9442 . 8914 . 9437	4841					<b>—</b>	4170
. 9332 .9946 .9645 1.0316 1.1251 .9387 .9128 .9387 .9128 .9507 .9368 .9367 .9368 .9367 .9368 .9367 .9442 .8914 .9437	1160						1 127
	1332					1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1 709
	9946						117.99
1.0316 1.1251 .9387 .9129 .9507 .9369 .6887 .6942 .8914 .9437	9645						11000
1.1251 .9387 .9124 .4507 .9368 .9368 .9887 .9462 .8914 .9437	0316						1.1.01
.9387 .9129 .9507 .9369 .9369 .9369 .9369 .9487 .9442 .8914 .9437	1251					1	1402
.9128 .9507 .9368 .9387 .9442 .8914 .9437	9387						1 803
. 4507 . 9369 . 8887 . 9442 . 8914 . 9437	9128						1 904 '
.9368 .6887 .9442 .8914 .9437	4507						11405
. 9887 .9442 .8914 .9437	9369					1000	ALH M.
.9442 .8914 .9437	AA87						1937
.8914 .9437	442					1	41.4.38
.9437	8914					1.00	41 4.13
	9437					1	
.9322	9322						41 # 11
.9736 (b	9736					1 - C - C	11112
.9527	9527						21213
1.2112	1119					1.	41914
1.0602	0602					[1] A.	41515
1.0560	0560						wiels
1.0324	0324						41.17
.1962	1962						PININ
1.0201	0201						41119
1.0817	0817						H1830
1.0149	0149						w1821
.8948	8948					Carlos Contra	41322
.9781	9781						41975
.9730	9730						-11/6
.9541	9541						#1425

# TABLE A-1 TEST PESILITS - 14 FORT .374 INCH ON UNIFORM TEST SECTION TYPICAL CELL

.

.

.

RUD 0.0. = . 374 11 MIXING VANE GRIDE (P) 22 1" CONFING INVER 200/01/100 000 00000 = 1.1705

. . . .

.

NULLUS 1531 Netsimi UJ HJNI 5/1" 1043 51 - 51 01550 1531 (100) 1-8 3181

 HNET 14LET 14LET MASS LOCEL LOCAL HOTTELUX
 ALET 14LET MASS LOCEL LOCAL HOTTELUX
 ALET 14LET VELOCITY
 ALET 14LET 14LET 14LET 14LET
 ALET 14LET 14LET 14LET
 ALET 14LET 14LET 14LET
 ALET 14LET 14LET
 ALET 14LET 14LET 14LET
 ALET 14LET
 ALET 14LET 14LET
 ALET 14LET
 AL :

									(p,c)								٦
00001	. 9320	10001	1.0192	5460.1	1.0562	1.0401	2466.	1740.	\$6.99	1,0032	1.0122	1.0112	. 9839	3582	1.0503	1250-1	1.0200
41825 41827	#1829	1841#	w1833 w1934	#1835	1831	use 14	w1840	2561#	w1043	4961m	41 194C	wides utaco	w1 654	1541#	41857	w1854	#1853

RED 0.0. \* .314 191 41X165 VARS SOLOS 101 22 10 COARTHG 194468 000/04150 506 57455 = 1.1765

# TABLE A-1 (cont) TEST PESINTS - 14 FORT . 374 19CH OD UNIFORM TEST SECTION TYPICEL FELL

	INLET	THEFT	INLET MACS	Incal	100.41	HFAT FLUX		FIFVATI	UV. EBUN INI LA
0 (JM	PEFSSIPF	TEMP	VELOCITY	QUALITY	1X1076 A	TU/HP-SCET)	(MFAS/	0050	V(HES)
*1 .	(PSIA)	1 F) (	XIGES LAW/HO-SOFT	1 21		**********			*****************
W1 85+	<b></b>						.9946		
41057	1						1.0728	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	다는 ' 전격입 것' 문서' 없습니.
W1037							1.1632		
W1030		1.00				1.	.9737		
w1840							.9631		
41000							1.0194		
41001							1.1088		(b,c
M1002							1.0666		
W1 003							1.0483		
#1404						N	.9450		
41402						A REAL PROPERTY.			

A-4

10.

.

.

L = 14 FT DE = .4635 IN 9 9005 1008 16 8005 858 200 0.0. = .374 10 MIXING VANE COIDS (E1 22 IN SPACING INNER ROD/DUTER ROD POWES = 1.1765 TABLE A-2 TEST ASSUMTS - 14 5717 .374 IVEN INISITATEST TEST STORE

 
 IVLFT
 \*\*\*\*\*\*\*\*\*\* \*.Jh

																1P											٦	
1.1532	1896.	1600.1	. 9306	1.0262	1661.1	0660*1	1*0*10	.916.	6664°		1 1010	9446	84.98	1.3316	1.0010	1110	.8559	1.0740	1.0734	1.1832	1.0010	1.0008	1.0834	1.1016	1.090.1	1.0034	6986.	1
***In	*1445	1441		D++ 13	1441M	41451	w1452	41453	41434	CC41#	41456	w1451	#145B	41459	#140U	witch	41462	*1403	*0*15	CO*1#	1400			04 14 7	. 11414		61419	

0-10 0.0. = .314 1N w1x1NG VANG 52105 151 26 14 5045146 1N469 400/00156 2010 0-460 = 1.1765

40.	INLET PFESSURE (PSIA)	INLET INL TEMP VE ( F) (X10F6 )	T MASS L DCITY QU RM/HQ-SQFT)	0 CAL 1411 TY 1 1 KJ	LOCAL HEAT FL X10F6 RTU/HR-S MEAC. PRET	UX SCFT1 (45) D. P3(	כן רעו הן הזרה,	(1)10455) (1)10455) 4585.	110:01
*******	*********	*************	**************	••••••					
	_					.98	8		
31414						. 915	in l		
41470						1.102	22		
WIGHT						1.07	32		
414/8	and the second second					1.098	15		
W1414	Contraction of the					1.65	14		
w1430						1.190	6		
w1471						.93	10		
W1492	1.000					1.24	8		이 동네는 말 날 것 ?
w1433						-84	8		
41484 .						.900	22		
W1.436						. 20	12		(b.c)
W1497	1 A					981	5		10.0
W1488						.97	29		
41439	1.0						04		
W1490						1.02	18		
W1491						1.00	50		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
W1492						1.03	76		
W1493						.97	20		
W1592						97	20		1.5.1.5.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1
#1503	1.						50		CONTRACTOR (1997)
41574						1 1 03	0.4		and the property
#1505						1.00	62		
w1505						1.00	02		
¥1527	18 St. 19 (19)					1.05	00		2015 101
41 508	1.					. 40	21		
41509						.70	26		Same and the second
#1525									(a) (b) (b) (b) (b) (b) (b) (b) (b) (b) (b
41520						1	02		
W1527	- 10 M M					1.11	a.		
	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1						os L		

.

\*

.

TABLE A-2 (cont) TEST DESULTS - 14 FINT .374 INCH AN INTENSA TEST CONTINUE TYPICAL CELL

.

TABLE A-2 (cont) rest presents -. 14 FOAT ... 374 THEM OF IMPERIAN TEST SERVICE

 INF
 INF</th

.9198	1.1058	1.0464	1.0351	.9434	CR60 1	.4246	1.1012	5946 ·
				-	-			٦
								1

( ), d

9114 40.	INLET PRESSURE (PSTA)	INLET TEMP	INLET MASS VELOCITY IXIOF6 LAM/HQ-SQETI	LOCAL QUALITY (1)	LOCAL HEAT FLUX (X10F6 RTU/HR-SOFT) MFAS. PRTD.	INFAS/ DOFN1	CLEVATION FROM INLET (INCHES) PRED. MEAS.	
W1720 W1721 W1722 W1723 W1724 W1725 W1724 W1725 W1726 W1727 W1726 W1727 W1726 W1731 W1732 W1733 W1735 W1736 W1735 W1736 W1737 W1738 W1739 W1740 W1741 W1741 W1742 W1743 W1745 K1745 W1745 K1746						.9663 1.0167 1.0557 1.1062 .9413 1.0489 1.0825 1.0931 .9012 1.0408 1.0667 1.1772 .9163 1.1544 1.1934 1.2171 1.0525 1.1052 1.1052 1.1052 1.1052 1.1041 1.1197 1.1942 1.2192 1.1696 1.1575 1.0946		(b,c)
w1747 w1748 w1749	L					1.0946 1.0939 1.0725	L	

- 41 -

14

#### INTERPA TEST SECTION TEST RESULTS - 8 FORT .374 INCH NO TYPICAL CELL TABLE A-3

9 0005 1008 16 0005 854

INNER PODIOITER FOD POHED = 1.1765

140

 $\mathbf{\hat{x}}$ 

TABLE A-3 (cont) TTST 2 SIN, TS - B STAT . 314 1'IGH CA INIFAGA TTST SECTION

 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1
 10/1

	ت	7
1.1406 1.1508 1.01588 1.01588 1.01589 1.0559	0068. 11011 11011 121111 121111 1211111 121111 121111 12111111 1211111 1211111 121111111	1:0111
1		

P(N N.D. - .314 11. 41 XING VANG SATES (P1 22 11. SPATING 11445 POD/THEE SOD PINED = 1.1765

L = 8 FT PF = .4635 T4 9 8705 1005 16 8705 855 TABLE A-3 (cont) TEST RESULTS - & FOOT .374 INCH ON UNIFORM TEST SECTION TYPICAL CELL

.

9114 NO.	INLET PPESSUPE (PSTA)	INL FT TEMP	1NL CT MASS VELOCITY (X10°6 LPM/HE-SOFT)	LOCAL VIIIAUQ (1)	INCAL HEAT FLIX (X10F6 RTU/HD-SQFT) MEAS. PPED.	(MEAS/ DBFC)	FLFV411	15 500 101 101 101 101 101 101 101 101 1	
********	**********	*******	*****************						
	_					1-0082			
41779						1.0833		1 1 1 1 1 1 1 1	
W1190						1.0320			
¥1791	1.					.9113		and the second second	(h.c)
w178?						9435	1000	12.201	10.01
W1793						0734	G		
W1 784						1 0346		10 C 10 C	
W1785						1.0340		_	

A-10

L = 8 FT DF = .4635 IN 9 PODS 1004 16 FODS 854 POD 0.0. = .374 TH MIXING VANE SEINS (C) 22 IN SPACING INNEE POD/DUTEP 200 POWER = 1.1765
	דויד המשי ואוי וושריידגו אדמג.	0361.		INCAL HEAT FLUX IXIOTO RTU/HO-SJET) MEAS. POCO.	LOCAL QUALITY (8)	INI ET MASS VELOCITY 106 LAM/H2-SOFTI	INL ET TENP ( C)	INLET POF SCIDE (PSIA)	2(1") NI .
-		-	1 0109					·····	
			.9432	and the second state of the					11559
		a fair and a	.9175						00611
100			- 9447						1001
5.000			.8746						11502
		1.	.9115	and the second					11503
			.9816	and the second second second				1000	11565
1			.9377						11566
			.8985					1.000	11507
			9941						1 568
			.9705						11569
		1.	1.0648					1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	1570
			.9143						11571
1.1			.9521					1.	41572
			.9620						W1573
		and the second	1.0700						41574
			1.0580					- 16 - Friter	41575
1 12		100 100	1. 3097						41576
1 10			1.0354						W1577
			1.9798						41578
			1.0940						41579
			1.0057						W1590
			.9277	and the second				1.	W1591
		1.0	84.04					1.0	w1592
			1 0121						W15d3
		1.	1.0476					(1) 1 (1) (2)	W1584
			8302					* I	W1535
			8240					A DOWNER OF	W1586
		1.1.1.1.1.1.1.1.1	.9814						N1281
_		L		the second s					M1283

TABLE A-4 TEST PESULTS - 8 FORT .374 INCH OD WHEDAN TEST PESULTS - 9 FORT OF TYPICAL (FIL

L = 8 FT NF = .4635 IN 9 RONS 1006 16 PONS 958 400 0.0. = .374 10 MIXING VATE GRIDE 101 26 11 CONTING INMER EDD/ 1176 200 DOWER = 1.1765

.

. .

.

2.12	INLET PRESSIRE (PSTAT	TNLET TEND ( F)	TALET MASS VELOCITY (X1056 LAM/HQ-SOF	LOCAL QUALITY	INCAL HEAT FLUX (XLOF6 PTU/HO-SOFT) HEAS, DED.	(MENS)	porn.	11, FOIN 11	
*******	**********	*******	**************						
						.9003			
M1244						1.1037	1.1.1.1.1.1.1		
MIDAU					이 같은 것 같은 것은 것은 것 같아요.	.1785			
M1241						.9431			
M1242						1.0252			1.1.1
MI 243						1.0533			
W1244	1					1.0363			The second second
W1242	1.				and the second second second second	1.1053	1.1.1.1.1.1.1.1		10 M M M
M1296						.9872			N.C. 1977. 1
41241						1.0663	- 1 C C C C C C C C C C C C C C C C C C		1.10
M1238						1.0948			1.190.000
M1233						1.1292			
M1000	1.10.00					1.0597			1 16
w1631						.9795			(0,0
A1 9 US						.9882			
W1033					The second s	1-1941			
W16.04						1.0398	1. 1. L. L.		1.
W1 675	Contraction of the second					1.0453			10.1
W1536						1-0206	1		1
w1007						1.0789			
MILOA	1 K. 1994					1.0617			
¥16.39					사람은 것을 감독하는 것이 같아요.	1-0546			
#1610						9764			
W1611						9599			
w1012	10 Mar 11 (1979)					1-0044			1
w1613	10.000					1.0822			
WI014	1.1.1.1.1.1.1.1					9509			
41615						9441	2012-01-0		10 A
41616						1.0615	and the second		
#1617	1.1					1 0769			1.1.1
						1.0101			

.

# TABLE A-4 (cont) TEST RESULTS - 8 FORT .374 INCH CO UNTERPRITEST SECTION TYP ICAL FELL

.

A-12

9 5005 1008 16 2005 858

Actass 1531 Kacaladi TABLE A-4 (cont) TEST GESULTS - HEADT . 374 INCH OF TABLE A-4 (cont) ΝΗΕΤ ΙΝΕΓ ΓΑΓΕΥ ΑΚS LOCAL LOFAL HEAT FLUX NUL PRESSIDE TEMP VELOCITY UJALITY IXIOF6 ΒΤΟ/ΟΡ-5Ω5T | UTAS/ 1100 - 110 - 110 - 110 - 110 - 110 - 110 - 110 - 110 - 110 - 110 - 100 - 110 - 100 -(p,c) 8800.1. 5195.1. 5170.1. 517 41619 41625 41625 41626 41626 41627 41637 41637 41637 41637 41637 41637 41637 41637 41637 41637

ord C.D. = .314 HU WIXING VANE COINC FF1 26 HU SPACING INVER CONFUTE FOR PISES = 1.1765

t = 8 FT nE = .4615 IV 9 ends 100t 16 ands 85t

int fr	(p. c)	
11111 453		
(4FAS/ parn)	9555 9441 9441 9441 9461 9468 9151 9151 9151 9152 9152 9152 9152 9519 9519	20110
LDCAL HFAT FL'IX (X10°6 RTU/HD - 50F'1 HFAC PPED.	]	-1 = 33464 June 3140 - 28162 61 53 14 - 14
LUCAL DUJALITY [5]		00 0.0 0.0 =
1 105 - 04/ AL 1 0201X1 AL 1 04 134 SSW 14 141		8 T -
INL CT TF4P ( F) (		14 FT = .4635 RODS 100
INLET PRF SSUGE (PSIA)		- JC
-Uk Mi-o	MI979 MI979 MI981 MI981 MI985 MI985 MI985 MI986 MI986 MI998 MI999 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI9900 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990 MI990	

TABLE A-5 (cont) TFAT DEFUT - 14 FART .374 TVFH AN NANIMIERAM TEST STETAM

.

.

TABLE A-5 (cont) TEST DESINTS - 14 FONT .374 INCH FOR NONIMIENDER TEST SECTION

(p,c) 1.0922 1.0011 -

QUD 0.0. = .314 IN IXING VANE GUIDS (#) 22 IN SPACING INNEP 400/01158 PDD POWEP = 1.1165

L = 14 FT DE = .4635 IN 9 #05 1008 16 #05 858

4/1.       (P S1A)       (F)       (X10F6 LRM/HD-SQFT)       (Z)       MFAS.       PDFD.       DDFD)       DDFD.       4EAS.         42039	1	UN FROM THEFT	=11A1.10h	(MEAC/	LICAL HEAT FLIX X10F6 BTU/HR-SOFT)	QUALITY	VELOCITY	INL FT TEMP	PRESSURE	DIN
#2039     .9205       #2040     1.0574       #2041     1.0612       #2042     1.0612       #2043     1.0027       #2044     1.1015       #2045     1.1015       #2046     9537       #2047     1.0929       #2048     1.0155       #2049     1.0144       #2049     9308       #2051     1.0667       #2052     1.0610		HEAS.	0010.	PAFNI	MFAS. PRED.	(2)	6 LAM/HR-SOFT)	( F) (X10	(PSIA)	·113 .
#2039     .9205       #2040     1.0574       #2041     1.0612       #2042     1.1042       #2043     1.1027       #2044     1.1015       #2045     1.1015       #2046     .9537       #2047     1.0929       #2048     1.0929       #2049     1.0144       #2049     .9308       #2051     1.0610				********	***************	********	*************	**********	**********	******
#2039     .9205       #2040     1.0574       #2041     1.0574       #2042     1.1042       #2043     1.0027       #2044     1.1015       #2045     1.1015       #2046     9537       #2047     1.0929       #2048     1.0929       #2049     1.0144       #2049     1.0188       #2050     .9308       #2051     1.0610		-	-							
12040     1.0574       12041     1.0612       12042     1.0622       12043     1.0027       12044     1.1772       12045     1.1015       12046     9537       12047     1.0129       12048     1.0144       12049     1.0188       12049     1.1088       12050     .9308       12051     1.0610				.9205					10000	12039
12041     1.0612       12042     1.1042       12043     1.0027       12044     1.1772       12045     1.1015       12046     9537       12047     1.0929       12048     1.0144       12049     1.0144       12049     1.0188       12051     9308       12052     1.0567				1.0574					1.1.1.1.1.1.1.1.1	12040
1.1042       1.0027       1.0027       1.1072       1.1015       1.1015       1.1015       1.0929       1.0144       1.1088       1.1088       1.1088       1.1080       1.2051       1.2052				1.0612						120+1
1.0027       12043       12044       12045       12046       12046       12046       12046       12046       12047       12048       12049       12049       12049       12050       12051       12052			Contraction of the second	1.1042						2042
1.1772         12044         1.1015         12046         12046         12046         12047         12048         12049         12049         12049         12049         12049         12050         12051         12052		State of the second	1	1.0027						2043
1     1015       12045     .9537       12046     .9537       12047     1.0929       12048     1.0144       12049     1.0144       12049     .9308       12051     .9308       12052     1.0610				1.1772					1	12045
12045     .9537       12046     .9537       12047     1.0929       12048     1.0144       12049     .9308       12051     .9308       12052     1.0610				1.1015					1.1.4.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1	2044
12046     1.0929       12047     1.0144       12049     1.0144       12049     1.0188       12050     .9308       12051     1.0567       12052     1.0610			1. 1. 1. 1. 1. 1. 1.	0517					13 N. & Law (1)	12045
12047     1.0429       12046     1.0144       12049     1.1088       12050     9308       12051     1.0567       12052     1.0610	(b.c)		a start of the start of the							12046
12049     1.0144       12049     1.1088       12050     .9308       12051     1.0567       12052     1.0610				1.0424						12047
12049 12059 12051 12051 12052 1.0610				1.0144						12048
42050 42051 42052				1.1088						12049
1.0567 1.0610				.9308						12:150
1.0610				1.0567						12051
				1.0610						12052
			L						-	42032
사람은 집에 친구 가격에 가려가 잘 못 하는 것을 가지 않는 것이 같은 것이 같은 것을 하는 것을 다 가지 않는 것을 것이다. 나는 것을 것이 같은 것을 하는 것을 했다. 말										

### TABLE A-5 (cont) TEST DESULTS - 14 FORT .374 INCH OR NONUNIFORM TEST SECTION TYPICAL FEL

L = 14 FT DF = .4635 IN 9 PODS 100% 16 PODS 85% ROD  $\Omega_*D_* = .374$  TM MIXING VANE GETOS (P1 22 TM SDAFING INNEP DOD/DUTER DOD POWES = 1.1765

A-16

1

TABLE A-6 YEST SESTATS - B FONT .422 THEN PONUMIENTH TEST SETTING

2.44	434	130	616	169	000	255	040	124	454	1067	187	156	663	265	1834	1440	 1921	1111	1420	1444	1044
		· · · ·	6.	0-1	•	1.0		1.0	¢.	1.0	1.0		1.0	1.0	1.0		 		1.0	1.1	1.1

PON 0.0. - . . 422 14 MIXING VANE 54105 151 20 14 5747146 183418 PODJUHIEE FOD PARE = 1.3470

L = 8 FT DF = .5074 FM 4 0005 1000 12 0005 220

ICHES)	ELC VATI 34 6	INFAS/	INCAL HEAT FLUX	LACAL	INEFT MASS	FT INL FT	••••••••
 MFAS.		PPF())	MFAS. POFD.	( 2)	IXINTA LAM/HE-SOFTI	SUPE TEMP	NO.
٦ <sub>(b,c)</sub>	Г	1.0457	Г				W-506
1		.9801					8-577

TABLE A-6 (cont) TEST POSULTS - 8 FOOT .422 INCH OD NONUNTEROM TEST SECTION TYPICAL PEL

16

L = 8 FT DE = .5074 IN 4 PODS 1008 12 RODS 928 POD D.D. = .422 IN MIXING VANE SPIDE (P) 20 19 CONTING INNED PODUPITER FOD POWED = 1.9870 TABLE A-7 TEST RESULTS - 8 FONT .422 THCH ON NUNIMIFNEW TEST SECTION

	(p.c	
FLCVATION CRO	I	
(4FAS/ PHERI		961.5
LOCAL HEAT FLUX IXIOTO NTU/HO-SOFTI MEAS. PRED.		-422 IN
1111		u -u 00
INLET MASS VELOCITY IX1066 LBM/HP-SQFTI		a
14.11		. 8 .1
INLET PRE SSURE (PSIA)	L	
С. с.	110-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1	

L = 8 FT DF = .5074 IN 4 RODS 100X 12 4005 831

TABLE A-7 (cont) TEST RESULTS - 8 FOOT .422 INCH OD NONUNIFORM TEST SECTION TYPICAL CELL

	INLET	INLET	THEFT MASS	LOCAL	LOCAL HEAT FLUX		ri cvatin (IA	ICHES)
NC.	(PSIA)	1 -1	IXLOSE LAM/HA-SOFTI	( 6)	MFAS. PPED.			NFA 5.
	_					-		7
						1.00	S 11 1 1 1	(b.c)
1-540							ALC: NOT A	

L = 8 FT DF = .5074 TN 4 PODS 100% 12 PODS ROD 0.0. = .422 IN MIXING VANE GEIDS (9) 20 IN SPACING INVSP ROD/OUTEP POD POWEP = 1.2048

	INCHESI PPED. MEAS.	1 (NE/5/ DRFr)	LINEAL HEAT FLUX (XIOF6 RTU/HP-SOFT) HEAS, POED.	S LOCAL QUALITY -SQFTI (1)	THLET MASS VELOCITY IXIOE6 LAM/HR-SQFT	NLFT INLFT ESSURE TEMP PSIAI (F)	9.14 1 <sup>6</sup> .
-				••••••	••••••		
		.8834	and the second				4-550
		.9422					-551
	and the second states of the second	.8921	States and the second second second				- 552
0.000		.9564					1-553
		. 9063					1-554
1.1.1		.9711					- 555
1.11.11.1		. 9630					1-550
11 12 11		.9153					1-557
		.9459					- 558
		.9160					4-559
		.9116					-560
		.9184					1-561
		. 9268					1-562
		.8539					1-563
		.9223					4-564
		.9030					4-565
		.9231					- 566
		. 9526	the second second second				4-567
		.9595					- 568
		-8990	the state of the second se				4-569
		.9425	and the second second second				4-570
		.9871					4-571
	에 가슴 옷이 가지 못했다.	1.0397					W-572
1.1.1.1.1		1.1082					W-573
		1.1132					4-576
1 - G - C - A		1.0879					H-575
		1.1169					4-576
		1.0034	CONTRACTOR OF A				H-577
		1.0150					4-578
	the second second second second second	1.0950					4-579
	Las					and the second se	

### TABLE A-8 TEST RESULTS - 8 FOOT .422 INCH OD NONHINIFORM TEST SECTION TYPICAL CELL

L = 8 FT DE = .5074 14 4 RODS 100% 12 PODS 83% 900 0.0. \* .422 IN MIXING VANE GRIDS (P) 26 IN SPACING INNEP RODZOUTSP ROD POWEP = 1.2048

A-21

10

1

12				*** ******************						
	9.UN ND.	INLET PRESSURF (PSIA)	INLET TEMP ( F)	INLET MASS VFLOCITY (X10F6 LBM/H9-SQFT)	LOCAL QUALITY (1)	LOCAL HEAT FLUX (XLOF6 RTU/NR-SOFT) MEAS. PRED.	(MFAS/ PRFP)	ELEVATION FROM (INCHES) PRED. MEAS	• INLET 5.	
	H-580 H-581 H-582 H-583 H-583 H-585 H-586						1.0018 .9641 .9730 1.0020 1.2047 1.2699	Γ	-	(b,c)
		Second Second				the second se		Laure .	the second se	

## TABLE A-8 (cont) TEST RESULTS - 8 FOOT .422 INCH ON NONUNIES H TEST SECTION TYPICAL CELL

.

***************************************	***************************************
L = 0 FT	ROD 0.D. = .422 IN

.

.

DE = .5074 IN 4 8005 1004 12 8005 83%

1.1.1

ROD 0.D. = .422 IN MIXING VANE GRIDS (P) 26 IN SPACING INNER ROD/OUTER ROD POWER = 1.2048

÷

.

	ELEVATION FROM INLET (INCHES) PRED. 4FAS.	) (4F45/ P9FD)	LOCAL HEAT FLUX (X1056 BTU/HB-SOFT) MFAS. POFD.	LOCAL QUALITY (\$)	INLET MASS VELOCITY (X10F6 LBM/HR-SQFT)	INLET INL PRESSURE TEM (PS1A) ( F	P1"1 NO.
7	-			*******	** ** ** *** ***************	**************	••••••
1.000		1.0894				<b>F</b>	4.610
1000		1.1149					- + 20
10.000		.9677					- 620
1.5		1.1242					H-622
The second		1.0794				The second second	-622
1000		1.1024				and the second second	4-626
		1.1060				The Contraction of the second	1-624
		1.1298					4-625
		1.1758					H-020
		1.0736				1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	H-628
		1.1506					H=620
1 .	and the second second second	1.0164					014-1
(		1.0434					W-631
		.9565				The second second	W-031
		1.0358					310-1
		1.1163				- Martin Carlo and Carlo a	H-635
1		1.1360				Collection and the	W-034
		1.0954					W-033
		1.0846				The second second	W-030
		1.1762					W-638
1		1.1102					010-W
		1.0533					4-660
		1.0841					W-640
		1.0199					W-642
1 2 2 3		1.0258					H-643
		1.0070					4-645
		. 9985				1. Sec.	4-044
	Part of the second second	.9850					W-045
		.8233					H-040
	and the second second	1.0919					W-041
		Contraction of the	Sector Se				H-048

## TABLE A-9 TEST RESULTS - 14 FORT -422 INCH OF NONUNIEDON TEST SECTION TYPICAL CELL

3

.

L = 14 FT DE = .5074 TN 4 PODS 100% 12 PODS 85%

.

A-23

1

ROD 0.D. = .422 TH MIXING VANE GAIDS (P) 26 TH SPATING INNEP POD/DUTEP POD POWER = 1.1765 TABLE A-9 (cont) TEST RESULTS - 14 FJJT .422 TVCH M MMMIPHECI & TCT SCTTON

	(9.6)
מסנט" אבענ" (ואנאנג) פֿר מעון או און	
(MEAS /	1.0543 1.0012 .8902 .9450
L NC AL HE FT FL UX [X10F6 aTU/HP-50F7] HF AS. POFD.	<b></b>
LOCAL UNLI TY (12)	
INLET 4455 VELOTITY X10°6 L34/HP-SQFT)	
INLFT TENP I FJ	
I'VLET PRESSIRE [PSIA]	L
	н-650 н-656 н-656 н-651 н-651 н-653

400 -... = .422 IN MIXI'S VANE GRIDE (0) 26 14 CONCINE HIXI'S VANE GRIDE (0) 26 14 105 L = 14 FT 7F = .5074 TM 4 RMS 1008 4 RMS 858

	(p.c)
ELEVATIN: FRAM INLET (INCHES) PDFD, WEAS,	
145A5/ 22471	1.0338 .9940 .9113 .9113 .9113 .9113 .9113 .0946 .0955 .0955 .0950 .1015 .10500 .1117
LOCAL HEAT FLUX (XIOF6 RTU/HP-SQFT) MFAS. PDED.	
121 121	
INI CT MASS VELOCITY X1056 L9M/HR-50FT1	
TENP TENP	
PFF SSURE PFF SSURE (PS1 A1	L
NU.	W = 554 W = 554 W = 554 W = 559 W = 559 W = 559 W = 560 W = 56

400 0.0. = .422 14 41X1KC VANE GPIOS 181 20 11: SPAFING 11445 000/01158 000 00056 = 1.1765

L = 14 FT DE = .5074 IN 4 enn5 1001 12 RDD5 851

TABLE A-10 TEST GESULTS - 14 FONT .422 INCH OD NOMINITORN TEST SETTION TYPICAL CFLL







ROD 0.0. = .422 1W MIXING VANE GRIDS (8) 20 1º CPACING INNEP ROD POWER = 1.1765

٠

.

L = 14 FT DF = .5074 IN 4 RNDS 1005 12 R0DS 855

TABLE A-11 TEST RESILTS - 14 FINT 422 IVCH ON NONUNIFORM TEST SECTION TYPECAL CELL

	(p.c)	
FLEVATION FROM INLET LINCHES PAFD. MEAS.		
INFAS/	1,1715 1,0810 96976 1,0280 9876 9876 9876 9876 9978 9978 99787 99587 99515 99515 99515 99515 99515 99515 99515 99553 99553 99553 1,00354 1,00354 1,00354 1,00354 1,01352 99553 1,01352 1,01552	541 2416
LPCAL HEAT FLUX (X10F6 87U/Ha-5057) HTAS. PPFD.	]	-422 IN E GATOS (01 13 IV 504 DUTEP OOD PIME0 = 1.1
LDCAL QUALITY (1)		00 0.0
141.ET MASS VELOFITY (XICF& L9M/HR-SQFT)		4 1 M
TEMP TEMP		14 FT * 507 * 507 * 005 10
14: FT PBF 55URF [PS1A]	L]	- <sup>66</sup>
kun Yn.	100 100 100 100 100 100 100 100	

9UN ND.	INLET PRESSURF (PSIA)	INLET TEMP ( F)	INCET MASS VELCEITY IX1056 LAM/HR-SOF	LOCAL QUALITY T) (8)	L DF AL 1 X10F6 MFAS	NEAT FLUX TU/HP-SOFT) PRFO.	MEAS/ PREDI	ELE ANTI	N FROM THEFT	
	_					**********	********		*******	
H- 720							.9397			
4-721						1.0.0	1.0614			
1-722							1.0396			
-723	100 100 10						. 9067			10000
1-724							1.0779			
-725	Charles and					10.00 A 10.00	1.0674			1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1
-726	1 1					1 . TO 10	.8568			
1-727							8715	A COLORED		

TABLE A-11 (cont) TEST RESULTS - 14 FOOT .422 INCH OD NONIMIESPA TEST SECTION TYPICAL CELL

L = 14 FT DE = .5074 IN 4 PODS 1003 12 RODS 85\$ POD 0.0. = .422 IN MIXING VANE GPIDS (P) 13 IN SPACING INNER ROD/OUTER POD POWER = 1.1765 TABLE A-12 TEST RESULTS - 14 FOOT .422 INCH OD NONIMIFORM TEST SECTION TYPEFAL CELL

 INLET
 <th



6114 40.	INLET PRESSURE (PSIA)	TEMP	1 NLET MACS VFLOF 1 TY (X10F6 1 PM/HP-COFT)	LOCAL DUALITY (I)	LOFAL HEAT FLUX (X10F6 ATU/H9-50F*) MEAS. DEF.	(MEAC) PFFD1	CLEVATION (14	ICHES) WERS.	INLET
	*********	******	******************						
- 758	[					1. 9335			
- 759						.9740		1.0	
- 760						.9116		1.000	
- 761						.9543			
-752						.9521		121111	(h.c)
763	and the second					.9744			(0,0)
766						.8778		1	
						1.0482			

TABLE A-12 (cont) TEST RECHETS - 14 FOOT .422 INCH OF PONINIEDIN TEST SECTION TYPICAL FELL

L = 14 FT DE = .5074 IN 4 RDCS 100% 12 FODS 85% .

ROD D.D. = .422 TM MIXING VANE GPIDS (P) 32 IN SPACING INMEE POD/DUITEP ROD POWER = 1.1765 TABLE A-13 TEST RESULTS - 8 FORT .422 INCH TO MUNIFORM TEST SECTION TYPICAL FELL

INLET IM. FT INLET MASS LOCAL LOCAL HEAT FLUX ELEVATION FAIM INLET AUN PPESSURE TEMP VELOCITY QUALITY (XLOF6 NTU/HH-50FT) (4FAS/ 114C4F5) AON. (PSIA) (F) (XLOE6 L9M/HH-50FT) (T) MEAS. PPED. PPED. 4FFD) PAFD. 4FS.





PRO 0.0. = .422 IN MIXING VANE GAINS (0) 32 IV CPATING INNEP R/D/(N)TER COD PANER = 1.2043

L = 8 FT DF = \$5074 IN 4 RDDS 1005 12 PDDS 831



RID 0.0. = .422 IN 41X14C VANG 58105 101 26 111 5945146 118958 010/00768 010 50450 = 1.1765

> L = 14 FT DF : .5074 14 4 MD5 1005 12 MD5 855

> > \*\*\*

100

.

, , 1000



1.00

Stree of St

-

-

4

1

1

)

Sec. 1

-0

.

20 × 1-1

\$ -

100

A.s

E.

1

-----

र्थः क्रि. मा

· 14. \*\*

đ 8

TABLE A-14 (cont) IFST OF SIL TS - 14 FINT .422 THEM OF MEMBINIFER TEST SETTING TABLE A-14 (cont)

	(p.c)	
ст. с.		
145A57	1.1531 1.1531 1.1945 1.0700 1.0700 1.0700 1.0700 1.0707 1.0107 1.2110 1.2110 1.2110 1.2110 1.2110 1.0107 1.0107 1.0107 1.013955 1.013955 1.013955 1.0139555 1.	1165
LPCAL HEFT ELUX (X1056 RTU/HO-50FT) WEAS. FOED.		422 IN 16 -59105 181 26 14 504 1011168 000 00469 = 1.
1511 0.101174		ANN D.D
X10-0 Law/MC-50FT		ž
1N2 5.		14 FT = -5074 RADS 100 P105 85
INLET PVF SSIDF (PSIA)		ст 26 12
- Jh	MI 207 MI 207 MI 207 MI 207 MI 210 MI 210 MI 211 MI 215 MI 217 MI 217 MI 217 MI 217 MI 225 MI	6 9 9 9 6 6 8 8 8 8 8 8 8 8 8 8 8 8 8 8

TABLE A-14 (cont) TEST OFSILTS - 14 FTT 422 INFH IN NUMBERPH TEST SECTION



L = 14 FT PF = .5014 FN 4 9705 1007 4 9705 855

TABLE A-15 TEST BESINTS - 14 FONT -422 INCH ON INVERSA TEST SECTION

 
 Print
 INLET
 INLET

 PHET
 INLET
 INLET
 INLET
 INLET
 INLET
 INLET
 INLET

 PHESSIDE
 TEMP
 VELOCITY
 QUALITY
 (XIOE6 RTC/HD-SOFT)
 (YIOCHES)

 NC.
 (PSIA)
 (F)
 (XIOE6 LBM/HD-SOFT)
 (T)
 VESSIDE
 \* (p,c) 9731 97358 9958 9912 9946 9499 9499 9499 9328 9328 9328 9328 .9458 411395 411395 411399 411493 411493 411493 411493 411419 411413 411413 411413 411413 411413 411413 411413 41416 11414 1418 41419 12414 1420 WI 391 WI 372 WI 372

RID (1.0. - .4.22 IN 41X1NG VANE GATOS (P) 26 IN SPAFING INNEP POD/JIFF BOD PJMEP - 1.1765

L = 14 FT DE = .5074 'N 4 8005 1004 12 8005 858

TABLE A-15 (cont)	TEST RESULTS	- 14 FONT	.422 INCH PP	UNIFOPH TEST	SECTION
			TYPICAL CELL		

2114 ND.	INLET PRESSURE (PSTA)	INLET TEMP (F) (	INLET MASS VELOCITY KIOF6 LBM/HP-SQFT	LOCAL QUALITY (1)	LDCAL IXIOF6 P MEAS.	HEAT FLUX TU/HR-SOFT } PRED.	(MFAS/ PPFD)	ELEVATION PRED.	N FROM INT ACHES . MERS .	
W1422 W1423 W1424 W1425 W1426 W1427 W1428 W1429 W1430 W1431 W1433							.8258 .9178 .9148 .8805 .8217 .9613 1.0043 .9823 .9912 .9445 .9372 .9334			(b,c

L = 14 FT ROD 0.D. = .422 IN DE = .5074 IN MIXING VANE GRIDS (P) 26 IM SPACING 4 RODS 1002 INNER ROD/JUTER POD POWER = 1.1765 12 RODS 858

• UN NA.	IMLET PRESSURE (PSIA)	TEMP	INLET MASS VELOCITY XIGE6 LBM/HR-SOFT	LOCAL QUALITY (X)	LOCAL HEAT FLUX (X10E6 ATU/HE-SOFT) MEAS. PED.	(MFAS/ PRED)	ELEVATION FROM THEFT (INCHES) PPED. MEAS.	
	<u> </u>				-		-	
1097						.9533	이 지수는 것이 같아. 이 가지 않는 것이	
1098	10 State 1 State 1					1.0216		
1099	1 - C. S.					. 9769		
1100						.9145		
1191						1 45 20		
1102	and the second					1.0053		
1103						1.0452		
1105						.9729		
1106						1.0914		
1107						1.0283		
1108					the second second second second	1.0932		
1109	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					.9775		
1110					Contraction of the second second	1.0226		
1111						1.0549	이 가지 않는 것 같이 있는 것 같이 같이 했다.	
1112						1.0332		
11113						.9305		
41114						.9592	집 집에 있는 것이 안 집에서 있다.	
11115						1.1163		
1116						.9491		
11117	1					1.0565		
1119	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1					1.1209		
41119						.9297		
11120	1.1.1.1.1.1.1.1					1.0535		
11121						1.0931		
1122	1					1.0857		
11123						.9895		
11126						1.0096		
11122						1.0156		
11120	L						L	
•••••	••••••	= 14 FT	••••••	RND 0.0.	422 IN	•••••		(b)
	0E 3	* .4080 RODS 100 RODS 85	1N 2	INNER ROD	OUTEP POR POWER = 1.	1765		

TABLE A-16 TEST SESULTS - 14 FORT .422 INCH CD NONUNTEDEM TEST SECTION COLD WALL CELL





A-39

UD 0.0. = .422 th MIXING VANG GEIDE FET 26 IN CONCING MIXING VANG GEIDE FET 26 IN CONCING

t = 14 FT 7F = -4080 tN 3 8005 1002 12 8005 852

V PP	PESSUPE	INLET TEMD	INLET MASS	LOCAL QUALITY	LOCAL HEAT FLUX (X10F6 PTU/HP-SOFT) MEAS. PRED.	MEAS/	FLEVATION FROM INLET (11/045) POFD. MEAC.	
	*********		***********		********************	********	***********************	*****
-	_				-		F	-
40						0350		
41						. 4350	김 승규는 것 같은 것 않는 것 같아요?	
142						. 1085		
43						. 9321		
44						. 4425		
45						.0839		
46						. 4303		
147						1.0393		
48						1.0105		
149						1.0802	이 나는 것 같은 것 같은 것이 많은 것을 했어.	
150							김 의원을 위한 것 같이 많은 것이 같이 많이 했다.	
151						.9214	A STORE ALL AND DELTA	
152						. 9483		
153						. 9926		
154						.8245	날 것 같은 그 같은 것 같아? 것 같아?	
155						.9121		
156						1.0095		
157						1.0477		
358 .						1.0549		
359						.9799		
160						.7870		
161						. 9389		
362						. 4378		
363						. 9357		
364						1.0144		
865						1.1151		
866						.8241		
867						. 4245		
868						1.0217		
						1.0115		1. Hach

. . . .

TABLE A-17 (cont) TEST RESULTE - 14 FOOT . 422 INCH OD NONINTEDEN TEST SECTION COLD WALL CFL

	INLET	INL ET	INLEY MASS	LOCAL	1.9CAL N	FAT FLUX		FLEVATI	TN FROM ( NL	
NO.	IPSTAT	1 F1 1X	10 4 L 8M/HP-SQ	FT) (1)	MEAS.	BBEU.	PREDI	beeD.	HEAS.	
	_									
W-8	10					1.11	1.0464			1. 1. 1. 1. 1.
W-8	12					States and	1.0880	10.00%		
W-8	73						. 9258			(b.c)
W-9	14						1-1342	1201000		
W-8	76						.9168	10.3		in the state

TABLE A-17 TEST RESULTS - 14 FOOT .422 INCH OD NONUNTERPH TEST SEFTION COLD WALL FELL

A-41

.

L = 14 FT DE = .4080 IN 3 RODS 1004 12 RODS 853

ROD 0.0. = .422 IN MIXING VANE GRIDS (R) 32 IN SPACING INNER ROD/OUTER FOD POWER = 1.1765

-

N1857         1.0124           N1857         1.0652           N1857         1.0701           N1870         1.0701           N1871         1.0701           N1872         .9909           N1874         .9909           N1875         .9853           N1876         .9553           N1877         .9553           N1876         .9574           N1877         .9574           N1879         .9574           N1879         .9574           N1879         .9574           N1879         .9574           N1879         .9574           N1879         .9943           N1879         .9943           N1879         .9943           N1883         .9909           N1883         .9909           N1892         .9909           N1893         .9909           N1894         .9909           N1895         .9909           N1896         .9909           N1896         .9909           N1897         .9474           N1899         .9277           N1891         .90576           N1	n. 1	INIET DEFSSIJDE (PSIA)	1NLF* TF4P ( F) (	THEFT MASS VELOCITY XLOFO LAM/HA-SOFT	DUALTTY 1 ( C)	LUCAL HEAT FLUX (XLOF6 ATU/HO-COFT) MAAS. DRED.	(MCAC) DDED)	ELLARITH LOUR HALF	' 
N1857       10124         W1859       1.0652         W1870       1.0701         W1470       1.0305         W1471       .9856         V1171       .9856         V1874       .9909         W1873       1.0492         W1874       .9553         ×1874       .9553         ×1874       .9574         W1873       .9574         W1874       .9574         W1873       .9574         W1874       .9574         W1873       .9574         W1874       .9574         W1873       .9674         W1873       .9674         W1873       .9943         W1874       .9943         W1892       .9909         W1893       .0614         W1894       .9019         W1895       .9019         W1896       .9277         W1897       .9475         W1891       .9277         W1892       .9277         W1893       .9277         W1894       .9277         W1891       .9485         W1892       .9277		_							
w1 554       1.0652         41859       1.0701         w1 371       .9355         w1 371       .99090         w1 373       1.0492         w1 374       .9553         w1 375       .83643         w1 376       .9573         w1 376       .9574         w1 376       .9574         w1 376       .9574         w1 377       .9574         w1 379       .9471         w1 379       .9471         w1 380       .9471         w1 381       .0072         w1 383       .9943         w1 384       .9943         w1 885       .9900         w1 886       .9943         w1 887       .1.0614         w1 896       .1.0774         w1 898       .9474         w1 899       .1.1773         w1 890       .9474         w1 891       .9277         w1 892       .9468         w1 894       .9277         w1 892       .9468         w1 894       .9277         w1 892       .9468         w1 894       .93576         w1 894 <t< td=""><td>857</td><td></td><td></td><td></td><td></td><td></td><td>1.0124</td><td></td><td></td></t<>	857						1.0124		
418.99       1.0701         M1470       1.0305         M1470       .8556         M1371       .9090         M173       1.0492         X1874       .9553         X1875       .8643         M1376       .8553         X1877       .9574         M1376       .9574         M1477       .9574         M1873       1.0628         M1874       .9574         M1873       .9471         M1874       .9574         M1873       .9471         M1874       .99471         M1883       .9909         M1884       .9909         M1883       .9909         M1884       .9909         M1883       .9909         M1884       .9909         M1883       .9909         M1884       .9909         M1885       .9909         M1886       .9909         M1887       .9474         M1889       .9474         M1891       .9277         M1892       .9465         M1891       .9355         M1892       .9465         <	969	1					1.0652		
k1 470       1.0305         k1 371       .9856         k1 371       .9909         k1 373       1.0492         k1 374       .9553         k1 375       .8943         k1 376       .8943         k1 376       .8943         k1 376       .9574         k1 376       .9574         k1 377       .9574         k1 379       .9471         k1 830       .9471         k1 831       .0072         k1 833       .1.0614         k1 833       .1.0948         k1 833       .1.0614         k1 834       .9909         k1 835       .9009         k1 836       .0072         k1 837       .9074         k1 838       .0074         k1 839       .0074         k1 839       .0074         k1 839       .1.173         k1 839       .0074         k1 839       .0076         k1 839       .0076         k1 839       .0076         k1 839       .00576         k1 839       .00576         k1 839       .9355         k1 8495       <	859	1 - F 22 1 3 3					1.0701		
#1371     .9856       41972     .9909       41972     .9909       #1874     .9553       #1874     .9553       #1376     .8943       #1376     .8543       #1473     .8953       #1473     .9574       #1873     1.0826       #1874     .9574       #1875     .9574       #1873     1.0826       #1874     .9471       #1875     .9471       #1890     .9471       #1891     .9943       #1892     .9943       #1893     .9909       #1894     .9909       #1895     .9909       #1896     1.1506       #1897     .9474       #1898     .9474       #1899     .9474       #1899     .9475       #1891     .9475       #1893     .9485       #1894     .9277       #1895     .9310	970	1.				A STATE AND A STATE OF A STATE	1.0305		
41972     .9909       41973     1.3492       41874     .9553       41874     .9553       41376     .8543       41376     .9574       41373     1.0828       41373     .9471       41830     .9471       41831     1.0072       41830     .9943       41831     1.0072       41833     .9943       41843     .9943       41892     .9943       41893     1.0614       41994     1.0948       41895     .9009       41895     1.1596       41895     1.0576       41891     .9277       41892     .9277       41893     .9277       41894     .9277       41895     .9356       41894     .9277       41892     .9356       41894     .9277       41892     .9356       41894     .9356	371	1.00				and the state of the state of the state	.9856		
#1873     1.0492       #1874     .9553       #1475     .8943       #1476     .8943       #1477     .8543       #1473     1.0826       #1879     .9471       #1810     .4547       #1831     1.0672       #1883     1.0614       #1895     .9943       #1896     1.1506       #1897     1.0374       #1898     .9474       #1899     1.0468       #1891     .9277       #1893     1.0576       #1894     1.0156       #1895     .9355	972						. 9909	이 것 같아? 그 것 같아요? 것이	
41874     .9553       41874     .8943       41376     .8543       41477     .9574       41873     .9574       41873     .9574       41873     .9471       41830     .9471       41831     1.0072       41843     .9943       41843     .9943       41843     .9943       41844     1.0948       41845     .9909       41846     .9910       41847     1.0374       41893     .9474       41893     .9474       41893     .9277       41893     .9277       41893     .9277       41893     .9277       41893     .9277       41893     .9277       41893     .9277       41893     .9277       41893     .9277       41893     .9358       41893     .93576       41893     .93576       41893     .93576       41895     .9358	1373	1.1.1.1.1.1.1.1.1					1.0492		
#1475     .8943       #1476     .8543       #1477     .9574       #1473     1.0826       #1473     .9574       #1473     .9574       #1473     .9574       #1473     .9574       #1473     .9574       #1473     .9574       #1870     .9471       #1891     .90471       #1892     .9943       #1893     1.0614       #1994     1.0948       #1895     .9009       #1896     1.1506       #1898     .90474       #1899     1.1773       #1890     .9277       #1891     .9277       #1892     .9277       #1893     1.0576       #1994     .935       #1996     .935	874						. 9553	the state of the second second second	
#1376     .8543       #1477     .9574       #1473     1.0826       #1473     .9574       #1473     1.0826       #1870     .9471       #1830     .9471       #1831     1.0072       #1892     .9943       #1893     1.0614       #1994     1.0948       #1895     .9209       #1896     1.0576       #1897     .9474       #1898     .9277       #1899     .9277       #1892     .9485       #1893     .0576       #1894     1.0576       #1895     .9935       #1896     .935	915						.8943	그는 아파 것 같다. 한 바람이	
w1477       .9574         w1873       1.0826         w1873       .9471         w1830       .9471         w1831       1.0072         w1832       .9943         w1833       1.0614         w1834       1.0948         w1835       .90943         w1846       1.0948         w1835       .9099         w1836       .90948         w1835       .9099         w1836       .9074         w1835       .9079         w1836       .9074         w1837       .9474         w1838       .9474         w1839       .9474         w1839       .9475         w1891       .9475         w1892       .9485         w1893       .9485         w1894       .9356	376					같은 문문에 관한 것을 많은 것 같아.	.8543		
N1873     1.0826       N1879     .9471       N1830     .8547       N1831     1.0072       N1892     .9943       N1893     1.0614       N1894     .9909       N1895     .9909       N1896     .1506       N1897     .9474       N1898     .9474       N1899     .10374       N1893     .9474       N1893     .9475       N1894     .9475       N1895     .9485       N1897     .9485       N1893     .9935       N1894     .9935       N1895     .9910	A77	1					.9574		
w1879       .9471         w1830       .4547         w1831       .9471         w1831       .9072         w1842       .9943         w1843       .0014         w1843       .0044         w1843       .90943         w1843       .9048         w1845       .9909         w1696       .1506         w1893       .9474         w1893       .9474         w1893       .9474         w1893       .9277         w1893       .9277         w1893       .9277         w1893       .9277         w1893       .9277         w1894       .9277         w1893       .9277         w1894       .9277         w1895       .935         w1896       .935	873						1.0829		
*1830     .8547       *1831     1.0072       *1842     .9943       *1843     1.0614       *1843     1.0614       *1844     1.0948       *1845     .9209       *1846     1.0374       *1847     .9474       *1848     .9474       *1848     .9474       *1849     .9474       *1899     1.1773       *1899     1.0488       *1891     .9277       *1892     .9485       *1893     1.0576       *1994     1.0156       *1895     .935       *1896     .935	879						.9471	이 없는 것 같은 그렇게 앉아 같은 것을	
41831       1.0072         41832       .9943         41833       1.0614         41843       1.0948         41845       .9909         41845       .9909         41845       .9909         41845       .9474         41849       .9474         41899       1.1773         41899       .9277         41891       .9277         41892       .9485         41893       1.0576         41894       1.0156         41895       .9255	830						.8547		
#1892     .9943       #1893     1.0614       #1994     1.0948       #1895     .9909       #1696     1.1506       #1897     1.0374       #1898     .9474       #1899     1.1773       #1890     1.0488       #1891     .9277       #1892     .9485       #1893     1.0576       #1894     1.0576       #1895     1.0156       #1896     .9257	831	1.					1.0072		
w1883     1.0614       w1994     1.0948       w1895     .9009       w1896     1.1506       w1898     .9474       w1899     1.1773       w1890     1.0488       w1891     .9277       w1892     .9285       w1893     1.0576       w1894     .9277       w1895     .9285       w1896     .9935	892						.9943		
110948       1895       1895       11896       11506       11506       110374       10374       10374       110374       110374       110374       110374       110374       110374       110374       110374       110374       110374       110374       110374       110374       110374       110374       11037 <td>883</td> <td>1.</td> <td></td> <td></td> <td></td> <td></td> <td>1.0614</td> <td></td> <td></td>	883	1.					1.0614		
#1895     .9909       #1696     1.1506       #1897     1.0374       #1898     .9474       #1899     1.1773       #1890     1.0488       #1891     .9277       #1892     .9485       #1893     1.0576       #1994     .935       #1896     .9510	994	1.					1.0948		
11096     1.1506       10374     1.0374       10374     .9474       10374     .9474       11773     1.0488       1037     .9277       10393     .9277       10393     .9285       11994     .935       11996     .935	895	1					.9909		
x1887     1.0374       x1893     .9474       x1893     1.1773       x1890     1.0488       x1831     .9277       x1893     .9485       x1893     1.0576       x1894     1.0156       x1895     .935       x1896     .9510	696						1.1506		
w1898     .9474       w1899     1.1773       w1890     1.0488       w1891     .9277       w1892     .9485       w1893     1.0576       w1895     1.0156       w1896     .9935	847						1.0374		
41899     1.1773       41890     1.0488       41891     .9277       41892     .9485       41893     1.0576       41894     .92935       41895     .9935       41896     .9510	899	1.					.9474		
(1890     1.0488       (18)1     .9277       (18)2     .9485       (18)3     1.0576       (13)4     1.0576       (13)4     .935       (18)5     .9510	899	1					1.1773		
•18/1     .9277       •18/1     .9485       •18/2     .9485       •18/3     1.0576       •13/4     1.0156       •18/5     .935       •18/6     .9277	890	1.					1.0488		
41892     .9485       41893     1.0576       41894     1.0156       41895     9935       41896     .9510	871	1.00					.9277		
(1893     1.0576       (1994     1.0156       (1895     .9935       (1896     .9510	892	1.32.94					.9485		
1994 1895 1896 1996	893	1.					1.0576	and the second second second	
•1845 •1896 •1996	994						1.0156		
.9510	845	193.53					. 9935		
	996						.9510		
······································			*******						

TABLE A-18 TEST DESULTS - 14 FORT .374 TACH OD PONUMICORM TEST SECTION CILD VALL FELL

8 9005 1008 16 8005 858

INNER RODINITER CON PONCE = 1.1765

2019	PRESSURE	TEMP	INC.L	MASS	QUALITY	LOCAL HEAT FLUX IXIGES RTU/HE-SOFTI		FLCVATION (1*)	FROM INIET
******	(PSIA)	1 51	######################################	M/HF - 5 OF* )		MFAS. PRCD.	por() )	P9-7.	WFA 5.
	_					-		_	_
41911							1.0187	1.1.1.1.1.1.1.1	
41835							.9718		
41830							.8875	1	
41900							1.0722	The state of the	
11991							. 9236		
41903						and the second	.9246		
41433							311		
41904							1.0208	and the second	
1995							1.0165		
41906	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1						.8614		이 같은 것 같은 것 같은 것 같아요.
41907	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1						.9041		
41976							.9047		
#1909							1.0250		
H1910	and the second						.8752		10.0
41411	and the latest						1.1195	10.00	(0,0)
41015	Contraction of the local sectors of the local secto						. 9186		
H1913	2 C C C C						.9492		
w1914							1.0954		and the second second second
41915							. 9789	1.1.1.1.1.1.1.1	
W1916	1.1						.9418		
w1917	1 C						.9739		
41413	1000						.8975		
41913							. 9905		
M1959							1.0101		
F1351	and the second second						. 9376		
M1955							1.1342		
M- 451							1.0338		
#1924							1.0538		1 200 C 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
41925							1.0015		
H1926							.9637		

TABLE A-18 (cont) TEST PESINTS - 14 FORT . 374 INCH ON NOMINIFROM TEST SECTION COLD WALL CELL

8

L 14 FT DE = .3713 14 a 90D5 1008 16 P0D5 858 NNER COD/ DITE COD DOMES - 1.1765

.

A-43

1

.

	INIET	INL FT	INTEL MACC	LOCAL	LACAL	HFL FILIX		FLEVATI	IN COUN IN	FT
2181	PRESSINE	TEMP	VICOLITY	QUALITY	1×10[6 P	TUTHO-SOFT )	(MEAC)	11	ALHECI	
nr.	(PSIA)	1 =1	IXINF6 I AM/HR-SOFTI	( 2)	Mr 1c.	ppen.	DOEUT	bocu.	WF 1 4.	
******	***********	******	****************	********	********	*********	*********	*********	*********	*******
1027	-					-	. 9551	-		7
11020	1 2 2 2 2 2 3					1.	1.0946	1.00		
1020							1.0372	1 1 1 1 1 1 1 1		1.1.1
41454							1 1155	1 1 1 1 1 1		1.1.1
11430							1.1333			
41331						1. S.	* 4845	1. 1. 1. 1. 1. 1. 1.		1 A
41932							1.0906			
41933							1.1037			
41934	1.1						1.1017			12.54 5.65
11016						1.5	1.0368			1.2.2.
1035							1.1502			
41 430							111212			

TABLE A-18 (cont) TEST PESINTE - 14 FORT - 374 INCH ON NONIPILECEN TEST CERTION

L = 14 FT ROD (P.D. = .374 IM DF = .3713 IN MIXING VANF GRIDS (P) 22 (M SPACING B RODS 100% INNER ROD/OUTER ROD FOWER = 1.1765

8 RODS 100%

5U%	INLET PLESSLET	INLE!	INLET MASS VELCCITY	LUCAL	LICAL HEAT FLUX	INFAS/	ELF VATI	HI FROM INLET	
	122141		1 X 1010 1 00/10 - 50/11	********		********	*********	***********	
					-		_	-	-
-1430						1.0572			10.00
41037						1.0034			1
41040						1.0390			
41-41						1.1091	1. 1. 1. 1. 1.		
41642						1.0520	1. 1. 1. 1. 1. 1.		1
alu41						1.0242			
#16.1m						1.0343	1.1.1.1.1.1.1		1
+1642						1.0511	1.1.1.1.1.1.1.1		
#1046						. 1829			
41641						.8428			
#10.4b						. 9432			
410.44						.9401			1
11000	1000					.8812	1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -		(b,0
wiast						.9131			
*1552						1.0570	1000		
*1031						- 4250			
w1024						1.1079			
W1652						1.0423			
00314						1.1792			
klust						1.1150			
*1658						1.0406			
41034						1.0540	1		
ALCER						1.0100			
M1001						.9438			1.
MICOL						.8189			
41663					and the second	.8958			
41604						1.1011			1
Altes	1				and the second	1.1481			1
41000						1.1130			
1001						.9943		Section 1.	1

#### 

L = E FT DE = .3713 IN d 40DS 1008 Ic x0ES 858 PCD 0.0. = .374 IF MIXING VANE GRIDS (NI 26 IN SPACING INNER FOD/OUTER MOD FINEF = 1.1 of

ант: Т. •	DELET PELSSUPP (PSIA)	INLFT TEMP (F)	INLET MASS VELCCITY IXIUSO LOM/HP-SQFT)	LUCAL QUALITY ( 8)	LUCAL HEAT FLUX (XLOEG BTU/HR-SGET) MEAS. PPED.	IMEAS/ PGEDI	CLEVATI IN FROM INLET (TYCHES) PRED. MEAS.	
								-
Lud						.9671		
100%	1.1.1.1.1.1.1.1					.8470		1
1110	10000					.9431		1. 1. 1. 1.
1671	10.00					.4219		1
1012	1.00					.9821		
1.13	1.					1.0/16		
1614						. 9159		1. 1. 1.
1015						.9239		
1611						. 4203		
1111	1. 1. 1. 1. 1. 1.					.9445		
1-13	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					.9238		1 2 4 4
1.1.1.						.9232		
los	1.					1.0509		
1631	1.1					1.1030		
1442						1.1079		
1433						1.0939		(b,c)
1624						1.0911		1.00
chalt						1.0340		
ludu						1.0440		- 10 - O.Z.
41CH7						1.0432		
1648						1.0344		
4634					and the second	1 1056		1.1
ele mi						1.2402		1
11041						1.1775		
11042	A DECEMBER OF					1.2518	the state of the state of the	1
1093	<ul> <li>IS State</li> </ul>				and the second second second second	1 217/		1
1214						1.1692		
1215	1.					1 0291		
9401+	1000					1.0971		
alust	The second second							

### TABLE A-19 (cont) TEST REBULTS - & FOUT .374 THCH DO INTEREM TEST SECTION CULD WALL CELL

L = E FT DE = .3713 IN 9 PORS 1004 10 PORS 854 REF C.C. = .374 IN MIXING VANE GRIDS (R) 26 IN SPACING INNER SOCIOUTER ROC POWER = 1.1765
	14117	INLET	INLET MASS	LOCAL	LUCAL HEAT FLUX	I INFAS/	ELEVATI	JN FR'M INLET	
1.	(PSIA)	1 = 1	IXIUFO LAMINE-SUFTI	( 2 )	MLAS. PPFD.	PREDI	PRED.	4EA5.	
1058						.9586			
cluve .	1.					.8670			
1 700					and the second	.9523	2.4		
1 / 31						: 1576	The second second	A CONTRACTOR OF A	
1 702						1.0604		No. 11 States	
1 7.34					a state and the state of the state	1.1518		and the second second	
						1.2537			
					Contraction of the second second	1.0199	1.1		
1133							_		

COLD WALL CFLL

TABLE A-19 (cont) TEST PESULTS - 8 FOCT . 374 INCH CD UNIFORM TEST SECTION

.

A-47

14.

L = E FT 0: = .3713 14 = FORS 1004 10 9075 d54 ACD C.D. = .374 IN MIXING 4442 GPTCS (F) 26 14 SEACING IMMER 400/OUTCE PCD PORSE = 1.1765

	INLEY	FLEVATION ERNA		LOCAL HEAT FLUX	LUCAL	INLET MASS	INL FT	INLET	
		IT AL MEST	(MEAS/	(X10:6 PTU/HR-SOFT)	QUALITY	VELICITY	TEMP	OPE SSURF	DIIA
		######################################	********	MF & S. PP=D.	(3)	IX10°6 LAM/HA-SOFTI	( = )	(PSTA)	30.
				_					
		1 75.0	.8658			2.548	516.7	1500.0	4-217
		1 75.0	. 9065		Alexander S. V	2.560	496.7	1500.0	4-218
		81.0	.9402			2.546	481.0	1500.0	1-219
		57.0	.1732			3.596	559.7	1530.0	4-220
		57.0	.8438			3.590	539.3	1530.0	1-221
		57.0	. 7847			3.543	580.7	1815.0	1-222
		57.0	.8912			3.677	560.0	1810.0	4-223
57.	63.0.	1 75.0.	.8772		1	2.561	583.0	2115.0	4-224
		57.0	.8960			2.553	565.3	2115.0	4-225
		75.0	.8857		1. A. A.	2.572	546.0	2113.1	4-226
		57.0	.8512		10 Y 17 18	3.097	599.0	2119.7	H-227
	75.0	57.0.	.9045	Service of the service of the	States in	3.058	583.7	2128.8	4-228
		1 75.0	.8859		10. L. 1997	3.104	559.3	21 37 . 7	H-229
		57.0	.8423		1.10.00	3.573	600.3	2100.0	4-230
		75.0	.9452		1.	3.584	585.3	2120.0	W-231
		75.0	.9396		1.	3.565	566.3	2110.0	W-232
	57.0.	63.0.	.9059			3.538	625.3	2420.0	W-233
		1 75.0	.8949		1.	3.611	602.5	2420.0	W-234
		1 75.0	.9017		26	3,589	583.7	2610.0	4-235
		75.0	.8867		1.1.1.1.1.1.1.1	3,027	624.3	24 30 . 0	W-236
		75.0	.8907		12.0	3.064	602.2	2420.0	H-237
		1 75.0	.8951			3.089	580.3	2427.5	W-238
		15.0	.8671			2.576	579.3	2410.0	W-239
		75.0	.8814			2.566	553.7	2410.0	W-240
		1 15.0	.8704	Contraction of the second second		2.562	537.0	2385.0	W-241
		1 75.0	.8580			2.090	558.3	2410.0	H-242
		1 75.0	.8727		60 C 10 C 10 C	2.059	541.0	2390.0	W-243
		75.0	. 8807			2.068	514-3	2418-8	W-266
		1 75.0	.9185		1.1	2.035	537.7	2119.5	W-245
		1 75.0	.9135		1.1.1.1.1.1.1.1.1	2.064	515.3	2109.5	4-246

# TEST RESULTS - R FORT . . 422 THCH ND NONUNTERRA TEST SECTION TYPICAL FELL TABLE A-20

L = 8 FT DF = .5074 IN 4 RODS 1008 12 PODS 948

000 0.0. = .422 IN MIXING VAN GOIDS (1) 26 IN SOACING INNER 000/017FE POD POWER = 1.0638

(b.c)

1-48

	INLET	INLET	THLET MASS	LOCAL	LOCAL HEAT FLUX		ELEVATION	EQUM THEFT
Paint	PEESSIRE	TEMP	VELOCITY	Y'T JAUG	IXINF6 ATII/HP-COFT)	IMENS/	. 1140	HESI
nn.	[A 12 4]	I FI	IXIOF6 LBM/HO-SOFTI	(8)	MEAS. DOED.	parni	open.	MENC.
	*********	********	******************	********	••••••			
	and the second			-		0142		75.0
W-247	2109.4	499.1	2.052		Children and the Local State of the			
W-248	1800.1	499.7	2.109	1		.8908		41.0
H-249	1819-6	471.7	2.019	1		. 8960		91.0
2-2-0	1617 4	670.3	1.549	Dell'street		. 9345		15.0
8-230	1717.44			1.000	And the second	8592		15.0
M-131	1507.4	952.0	1.540	Distance of the second		0164		at 0 7' 0
W-252	1507.0	415.3	1.563	L .		*4130		31.07
							12 - 22	

TABLE A-20 (cont) TEST RESULTS - & FOOT .422 INCH ON NONUNIFORM TEST SECTION TYPICAL FELL

A-49

L = 8 FT DF = .5074 IN 4 RIDS 1008 12 PODS 948 ROD 0.0. = .422 IM MIXING VANE GRIDS (1) 26 IM SPACING INNER END/DUTER POD POWER = 1.0038

MENC.	(1"[[ 44 5]	F6 ATU/HP-SOFT) (MEAS/ F45. DRED. PRED)	CITY QUALITY	TEMP VELO	INLET PPESSURF (PSIA)	9 HN NO.
		_				
		1.0514				W1056
		1.0067				1057
		.9946				1058
		.9733				11059
		1.0796				1060
		1.0014				1061
		1.0580				41062
		1.0341				W1063
		1.2050				41 064
	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1.1950				1065
		1.1848				1060
		1.1763				1067
		1.1010				1068
		1.1510				41069
		1.1725				11070
		1.1248				11071
		1.1409				41972
<ul> <li>A state of the sta</li></ul>		1.1463				+1073
		1.0524				1074
		1.1201				W1075
		1.1401				W1076
	a state of the second	1.0306				41077
		1.1434				41078
		1.1594				W1079
	A second s	1.0595				41050
		1.1307				W1081
		1.1510				W1082
States of the states of the		.9916	Contraction of the second second		3	H1083
	and the second second	1.0798				41094
		1.0894			5	W1095
		1.1510 .9916 1.0798 1.0894	800 C.D	- 14 FT		w1082 w1083 w1094 w1095

TABLE A-21 TEST PERULTS - 14 FONT .422 INCH ON NOPUNIFORM TEST SECTION TYPICAL FEL

TABLE A-21 (cont)	TEST RESULTS - 14 FANT	. 422 INCH OP MONINIFORM TEST SECTION	
		TYPICAL CELL	

	INLET	INLET	INTEL WVCE	LUCAL	10741	HEAT FEISX		FLEVATI	J. FRUM THIFT
c /1+1	PPFSCUPE	TEMP	VELOCITY	QUALT'Y	1 KI OF 6	ATU/HO-SCITI	I IME VEL	11	ALHES !
Au*	105141	1 = 1	1X10F6 LAM/HD-SQFT]	(1)	AL V.	. epen.	bec.1	PRFN.	MERC.
	**********	*******	****************	*******		**********	*********	********	********** ******
	<b></b>							<b></b>	
41097							9284	1.1	
-1088							95 30		
H1089	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1						1.0429		
W11-90	1					••••••••••••••••••••••••••••••••••••	1.0482		
W1091	1					1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1.0503	1.0	And the second second
w1092	1.000					10000	1-05:4	1.00	
W1093							1.0411		
21 394						1	1.0192		and the second second
41095						1.	1.0169	Contraction in the second	
W10 6							1.0439		
	L								
									(b,c)

A-51

L = 14 FY DF = .5074 IN 4 PODS 1008 12 PODS 858 900 0.9. = .422 14 MIXING VANE CRIDS IN 26 TH "PACING IMMER 4 30/447EP 200 POWER = 1.1765

		NLST	ELEVATION FROM I	INFAS/	LOCAL HEAT FLUX	LOCAL	INLET MASS	INLET	INLET	
			PRED. MEAS.	PPEDI	MEAS. PRED.	(2)	IXLOFA LAM/HR-SOFT)	I FI	IDCIAL	NO
*****	******	******	***************	*********		********	******************			
			69.0	.9872			2.501	520.0	1500.0	W-B
			59.0	1.0465			2.503	499.0	1500.0	W-9
			69.0	.9260			2.587	594.0	2166.3	W-10
			69.0	901			2.551	567.0	2115-1	H-11
			69.0	.9564		1 - 1 - 1 - C	2.541	577.0	2415-6	H-12
			69.0	. 9629		1	2.062	559.0	2410-8	W-13
			69.0	.8535		14 J. C. C. S.	3.427	560.0	1500.0	H-14
			69.0	.9199			3.550	579.0	1800.0	W-15
			69.0	1.0365			1.910	500.0	1819.9	W-16
			69.0	1506.		100 m m m	3.602	545.0	1500.0	H-17
			69.0	1.0952			2.479	482.0	1500.0	W-18
	30.80	81.0	90.0.	1.0852		- 10 C - 1	1.972	466.0	1530.0	W-19
			69.0	.8025			3.575	558.0	1532.0	W-53
			69.0	. 8969		1.1.1.1.1.1.1.1	3.617	560.0	1842.0	W-54
			69.0	.9911			2.033	481.5	1790.0	W-55
			69.0	.9465		1. State 1. State 1.	2.025	502.5	2112.0	W-56
			69.0	.9466		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	2.039	517.5	2118.0	H-57
			69.0	.9312			2.029	541.5	21 20.0	W-58
			69.0	.9453			2.529	545.0	21 28 .0	W-59
.0	90.0	81.0,	69.0.	. 9586		10 C 10 C	3.062	567.5	21 35 .0	W-60
			69.0	.8813		A. 1944.	3.072	581.0	21 50 .0	N-61
			69.0	.8646			3.044	601.5	2120.0	W-62
		81.0	75.0.	1.0113		1.1	3.578	566.0	21 30 - 0	H-63
			69.0	.8854		12.1	3.460	594.0	21 35-0	W-64
			69.0	.9291			3.572	577.5	2110.0	W-65
.0, 84.	90.0.	81.0.	75.0,	.9156		1.	3.095	580.0	2410-0	W-66
		90.0	75.0,	.8536		1.1.1.1.1.1.1.1.1	3.072	602.0	2425.0	8-67
			69.0	.8398	A REAL PROPERTY AND A REAL		3.050	623.0	2430-0	6A-W
.0.	90.0	81.0,	69.0.	.8380			3,561	627.0	2440-0	P-69

### Table A-22 TEST RESULTS - 8 FONT .422 INCH ON NONUNIFORM TEST SECTION TYPICAL CELL

L = 8 FT DE = .5074 IN 4 RODS 100% 12 RODS 83% ROD 0.0. = .422 IN MIXING VANE GRIDS (L) 20 IN SPACING INVER ROD/DUTER ROD POWER = 1.2048 (b,c)

.

A-52

 
 I'VET
 INLET
 I'VET
 UT
 LDCAL
 LDCAL
 MEA
 FI'VX
 CLEVATINE GROW INLET

 P/P1
 PRESSUPE
 TEMP
 VELOCITY
 Quality
 NI/HE-50FT
 (I'VEHES)

 V/L
 (PSIA)
 (F)
 IXL0F6
 I N/HE-50FT
 (I'VEHES)
 \* (p,c) .9864 .9866 .9568 .9568 .9569 .9550 .9550 .1.1124 1.11255 .9962 .9962 .9962 1.1356 1.0565 1.0966 1.1099 .9926 1.0640 .9182 .9182 .9182 .9185 .9185 .9185 1010.1 .96.34 .9655 1.0927 1.0489 1.0489 4-0 0.0. = .422 14 MIXING VANT SPIDT 111 26 14 SPACING HIVE 2002/01/150 500 01450 = 1.1705 [ L = 14 FT nE = .4080 \*4 3 PNDS 100 12 RNDS 85E 

TABLE A-23 TEST RESULTS - 14 FONT 422 INCH ON PONIMITOR TEST SECTION





(p,c)

\*\*\*\*\*\*\*\*\*\*\*\*\*\*\*\* 

L = 14 FT DE = .4030 IN 3 9705 1000 12 PPDS 958

POD 0.7. = .422 IN MIXING VANE COINS (1) 26 IN COACING INWES RID/INJER OFN DAMED = 1.1765

# TABLE A-24 TEST RESINTS - 14 FOOT .500 1424 IN UNUMEDAM TEST SECTION TYPICAL CFLI

*********************************	FLEVATION FROM INLET	(1MCH55)	DOFN. WAS.
		158341	pern1
	LOCAL HEAT FLIIX	IXIOF & FUIMO-SOFTI	HEAC. PRFD.
*********	LOCAL	GUALT TY	(1)
	THLET MASS	VFLOCITY	1×105- 484/40-50FT1
	19461	TENP	1 1 1
**********	INLFT	FRE SSURE	(PSIA)
*********		Puli B	. NN .

	٠	
	•	
	:	
	:	
	ε.	
	٠	
	2	
	:	
	2	
	5	
	÷	
	٠	
6	٠	
ţ.	•	
	:	
	:	
	1	
	5	
	÷	
	٠	
	•	f
1	:	1
	5	,
		ŧ
	۹.	ł
	•	5
	:	
	Ξ.	
ê		
	٠	
	٠	
	٠	
	2	
	:	
	Ξ.	
	٠	
	٠	t
5	:	ł
	2	ş
	:	
	٠	
	•	
é	Ξ.	
	Ξ.	
Ľ.	÷	
1	٠	
	٠	
	٠	
	:	
	Ξ.	
	÷	
	٠	
	٠	
2	:	
į.	Ξ.	
	÷	ł
		ş
	•	
•	1	
	•	
٠	:	
1	:	
	****	
	*****	
	******	
	*******	
	******	
	*********	
	*********	
	*********	
	*********	
	*********	
	**********	
	***********	
	*****	
	*****	
	*************	
	*****	
	******************	
	*****	
	******	
	******	
	******************	
	*********************	
	****************	
	**********	
	***********	
	***********	
	*******************	
	*******************	
	*********************	
	*******************	
	******************	
	************************	
	*********************************	
	**********************************	
	******************	
	******************	

	1.1.1	. 141	141	141.1	141.1	141.1	141.1	1.121	1 141.1. 121.0	1 141.1. 121.0	1.1.1	121-0	1.121	1.121	141.1	1.1.1	141-1	1.141	. 1.141	1.1.1	1.121	1.1.1	1.141	1.141	1.141	1.141	1.1.1	1.121
0146.	1016.	6126.	.9639	6156.	1.0144	1966.	1.0069	1110-1	1.0537	1.1073	1.0516	1.1062	6566*	1.0177	1.0129	1.0043	1.0623	08401	1.0485	\$766.	1186.	2866.	. 3675	1516.	\$\$16.	. 9330	1.0475	1.0115
						~										-												
1 CC.7 0.0	13.0 2.559	9.0 2.511	1.0 2.488	4.0 2.530	4.0 2.547	11.0 2.562	14.0 2.544	13.0 2.559	20.0 3.426	11.0 3.577	15.0 3.007	12.0 3.028	10.5 2.005	13.0 2.036	20.0 2.035	36.0 3.560	19.0 3.530	24.0 2.440	3.060	100.2 0.44	18.0 2.030	11.0 2.037	30.0 3.516	53.0 3.507	19.0 3.014	10.0 1.019	24.0 2.501	94.0 2.057
660"7 D'644 4"7661	1541.0 483.0 2.559	1840.4 519.0 2.511	1870.2 501.0 2.488	2121.9 564.0 2.530	2121.3 544.0 2.547	2421.3 581.0 2.562	24.20.4 564.0 2.544	2419.9 543.0 2.559	2400.0 620.0 3.426	2400.0 601.0 3.577	2400.0 605.0 3.007	2400.0 582.0 3.028	2414.9 560.5 2.005	2414.7 543.0 2.036	2414.1 520.0 2.035	2100.0 596.0 3.560	2100.0 579.0 1.530		2100.0 561.0 3.060	2115.8 544.0 2.001	2115.3 518.0 2.030	2115.1 501.0 2.037	1800.0 580.0 3.516	1800.0 563.0 3.507	1800.0 559.0 3.014	1800.0 540.0 1.019	2100.0 524.0 2.501	1816.6 494.0 2.057

(p,c)

L = 14 FT DF = ...6025 IV 9 RATYS 1008 TABLE A-24 (cont) TEST PESULTS - 14 FJOT .500 INCH ON MONIMIETEN VEST SECTION TYPETCAL SEL 
 NILFT
 INLET
 INLET
 NILET
 NILET

1.1 (1. 0)	1.1 (0.01
141	**
.8535	1.0250
Г	7
L	
3.471	3.525 2.035
541.0 3.471	\$14.0 3.525 482.0 2.035
1500.0 541.0 3.471	1500.0 514.0 3.525 1815.8 482.0 2.035

RID 0.0. = .500 IN WIXING VANG SPIDS (11 20 IN SPACING INNER ROD/UTER POD POWER = 1.0000

L = 14 FT 7F = .6025 TN 9 8775 1005



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SEP 2 8 1977,

Mr. C. Eicheldinger, Manager Nuclear Safety Department Westinghouse Electric Corporation P. O. Box 355 Pittsburgh, Pennsylvania 15230

Dear Mr. Eicheldinger:

SUBJECT: STAFF REVIEW OF WCAP-8762

Additional information is needed to complete our review of Westinghouse Electric Corporation report WCAP-8762 (Proprietary) entitled "New Westinghouse Correlation WRB-1 for Predicting Critical Heat Flux in Rod Bundles with Mixing Vane Grids". The required additional information is described in the enclosure.

Your response to these requests is needed by October 25, 1977 in order to complete our review as scheduled. If you cannot meet this schedule, please advise us within ten days after receipt of this letter so that we may revise our schedule.

If you have any questions about our request for additional information, please contact us.

Sincerely, luit. It

John F. Stolz, Chief Light Water Reactors Branch No. 1 Division of Project Management

Enclosure: Request for Additional Information

# ENCLOSURE

# REQUEST FOR ADDITIONAL INFORMATION ON WCAP-8762

- Provide a complete description of how the local conditions for the WRB-1 correlation were calculated in developing the correlation. The description should include a discussion of: the subchannel code used; subchannel modeling; axial nodalization; and input assumptions (such as Thermal Diffusion Coefficient, friction factors, spacer grid loss coefficient, treatment of mixing grids and non-mixing grids).
- 2. The inclusion of the d<sub>g</sub> term (distance from the last mixing vane grid) makes the WRB-1 correlation a stronger function of axial position than previous correlations. Provide a description of how the axial locations at which the correlation is evaluated are chosen for the CHF tests; that is, how the thermocouple locations are chosen and how the locations at which the correlation is evaluated will be chosen in the application of the correlation of the correlation are safety calculations.
- 3. What value of the performance factor (PF) is used for the 0.5 inch 0.D. Rods in the 3x3 CHF tests?
- Provide the correct value of the coefficient for the pressure squared term (B45) on page 2-5.
- 5. The Westinghouse topical report "Effects of Local Heat Flux Spikes on DNB in Non-Uniformly Heated Rod Bundles" (WCAP-8174-PA, Feb., 1975) adequately demonstrates that a special DNB heat flux spike factor need not be incorporated into the Westinghouse reactor design using Westinghouse type mixing vane grids when the W-3 CHF correlation is used. Provide a similar analysis to justify not including a special DNB heat flux spike when the WRB-1 correlation is used for reactor design.
- 6. To date the information presented to the staff on the effects of rod bowing on DNB has been based on a combination of CHF tests and calculation using the W-3 CHF correlation. Justify the use of this information with the WRB-1 correlation or provide information on changes in CHF and the equivalent change in FN when the WRB-1 correlation is applied.
- 7. Section 4 of WCAP-8762 proposes the use of a 1.17 Minimum DNBR for reactor design calculation. This value is based on 95% probability of not experiencing DNB at a 95% confidence level when all of the data are considered (i.e., 1147 data points). Since each reactor design contains only one heated length; one fuel rod size; one type of mixing vane grid, etc., the use of CHF data from CHF test on other geometries (i.e., other heated lengths, fuel rod sizes, etc.) must be justified. This justification must be based on the fact that the correlation, in combination with the subchannel code, correctly treats the physical phenomena associated with the purticular geometry change. For example, the treatment of different mixing grids is accomplished by using the appropriate loss coefficients in the subchannel calculation.

No empirical constants are required in the CHF correlation in order to fit the data. Therefore the data from the "R" grid and "L" grid CHF tests can be combined when computing the mean and standard deviation of the data and in establishing the correlation limit. However, the inclusion of the "Performance Factor" (a different value for the 5x5 type fuel and the 4x4 type fuel) in the WRB-1 correlation appears to be purely empirical. The requirement for a "Performance Factor" indicates that the CHF correlation and subchannel code are not representing all of the physical phenomena associated with the hydraulic diameter, rod size, pitch, change in mixing grid geometry, etc. Provide justification for the use of both the 5x5 and 4x4 test data in establishing the correlation limit.

If combination of the 5x5 type CHF data and the 4x4 type CHF data is not adequately justified, then the DNB limits must be established independently for 5x5 type fuel and 4x4 type fuel.

- The form of the WRB-1 correlation includes a "Performance Factor" which is required to make the correlation fit both the 5x5 CHF data and the 8. 4x4 data. The correlation indicates that the "Performance Factor" should be chosen based on the fuel rod outer diameter. This implies that the 5x5 "Performance Factor" also applies to 17x17 fuel since 17x17 fuel and the 5x5 test assembly both have rod diameters of 0.374 in. Similarly, the 4x4 "Performance Factor" would apply to 15x15 fuel. The 5x5 tests and the 4x4 tests differ in many areas, such as: rod diameter; pitch; equivalent diameter; equivalent heated diameter; mixing grid details; proximity of the CHF location to low power rods; proximity of the CHF location to the unheated walls; and proximity of the CHF location to the corner mixing vanes. A bias in CHF prediction or the subchannel conditions associated with one of these parameters could cause the difference in the 5x5 and 4x4 results. In order to apply the 5x5 and 4x4 data to 17x17 and 15x15 fuel assemblies, it is necessary to identify which of the differences between the 5x5 and the 4x4 tests causes the difference in the results (i.e., causes the need for the different "Performance Factors"). Therefore, provide a detailed discussion, including supporting calculations and test results, to justify the assumption that difference between the 5x5 and the 4x4 results is associated with difference in the rod diameter.
- 9. For test series A-3, WCAP-8762 indicates that for some cases the CHF location was measured at 84 inches from the test section inlet. WCAP-8536 which is referenced as the source of the information for test series A-3 shows the thermocouple location to be 85 inches from the inlet. Correct this discrepancy.
- Provide the grid locations and thermocouple locations for the test series A-10. This information is not presently available because these tests were not previously published.

11. The staff has been unable to verify the results of the A-10 test series. We believe that this is because the USINU power distribution presented in WCAP-8762 and in the referenced reports does not have sufficient detail to allow an accurate representation in the COBRA IV code. Provide a more detailed graphical or numerical representation of the power distribution for test series A-10.



Westinghouse Electric Corporation

Power Systems

Box 355 Pittsburgh Pennsylvania 15230 October 24, 1977

NS-CE-1581

Mr. John F. Stolz, Chief Light Water Reactors Branch No. 1 Division of Projects Management Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Reference: 1. Letter from J. F. Stolz to C. Eicheldinger, September 28, 1977. Subject: Request for additional information on WCAP-8762 (P) and WCAP-8763 (NP).

Dear Mr. Stolz:

Enclosed are:

- Twenty-five (25) copies of additional information on WCAP-8762 (Proprietary) as requested by Reference 1.
- Twenty (20) copies of additional information on WCAP-8763 (Non-Proprietary).

Both reports are entitled, "New Westinghouse Correlation WRB-1 for Predicting Critical Heat Flux In Rod Bundles With Mixing Vane Grids".

The information transmitted in this response is additional information to supplement Reference 1.

This submittal contains proprietary information. In conformance with the requirements of 10CFR 2.790, as amended, of the Commission's regulations, we are enclosing with this submittal, an application for withholding from public disclosure and an affidavit. The affidavit identifies the information sought to be withheld and sets forth the basis on which the information may be withheld from public disclosure by the Commission.

We expect that the non-proprietary version of this report, WCAP-8763, will be placed in the Public Document Room and identified as a Westinghouse Topical Report.

Correspondance with respect to the Westinghouse affidavit or application for withholding should be addressed to: R. A. Wiesemann, Manager, Licensing Programs, Westinghouse Electric Corporation, P. O. Box 355, Pittsburgh, Pennsylvania 15230.

Very truly yours.

AP:pj Enclosure B.2

C. Eicheldinger, Manager Nuclear Safety Department  Provide a complete description of how the local conditions for the WRB-1 correlation were calculated in developing the correlation. The description should include a discussion of: the subchannel code used; subchannel modeling; axial nodalization: and input assumptions (such as Thermal Diffusion Coefficient, friction factors, spacer grid loss.

# Answer

As in design, the THINC sub-channel code is used for the data reduction. The subchannel modeling is shown in the attached figure 1. The length of the axial nodes and other input variables are given in the attached table 1. The friction factors are calculated by the methods presented in Reference (2).





Figure 2 Cross-Sections of CHF Test Sections

10.235-3

	Rod O.D. Inch	L <sub>H</sub> ft	9 <sub>sp</sub> Inch	Heat Flux Profile	Configuration	Table Ref (1)	Axial Node Length in.	TDC	Grid La	side	t 1	W Grid	Grid	Loss Co	ef t	lon-HV Grid Thim.	Vane Design	Performance
"R"	0.374	14	22	UNIF	TYP-5X5	A- 1	3.36 [		Corner	3100	CETT	Len	corne	5100	Len		1	Г <u>7</u> +
Grid	0.374	14	26	UNIF	TYP-5x5	A- 2	3.36										,8	
	0.374	8	22	UNIF	TYP-5X5	A- 3	2										B	
	0.374	8	26	UNIF	TYP-5X5	A- 4	2										В	
	0.374	14	22	COSINE	TYP-5X5	A- 5	3.36										В	1.10 6.1
	0.422	8	20	COSINE	TYP-4X4	A- 6	3										В	
	0.422	8	20	USINU	TYP-4X4	A- 7	3										A	
	9.422	8	26	USINU	TYP-4X4	A- 8	3										A	
	0.422	14	26	USINU	TYP-4X4	A- 9	3.36										A	
	0.422	14	20	USINU	TYP-4X4	A-10	3.36										A	
	0.422	14	13	USINU	TYP-4X4	A-11	3.36										A	
	0.422	14	32	USINU	TYP-4X4	A-12	3.36									938 A.	A	
	0.422	8	32	USINU	TYP-4X4	A-13	3										A	
	0.422	14	26	USINU	TYP-4X4	A-14	3.36										A	
	0.422	14	26	UNIF	TYP-4X4	A-15	3.36										A	
	0.422	14	26	USINU	TH -4X4	A-16	3.36										A	
	0.422	14	32	USINU	TH -4%4	A-17	3.36										k	
	0.374	14	22	COSINE	TH -5X5	A-18	3.36										A	
	0.374	8	26	UNIF	TH -5X5	A-19	2										B	
																	В	1. 2. 2. 3
"L"																		
Grid	0.422	8	26	COSINE	TYP-4X4	A-20	3										A	
	0.422	14	26	USINU	TYP-4X4	A-21	3.36									1.	A	
	0.422	8	20	USINU	TYP-4X4	A-22	3										A	
	0.422	14	26	USINU	TH -4X4	A-23	3.36										A	
•	0.500	14	20	USINU	TYP-3X3	A-24	3.36										A	
					*TYP - Typ	ical Cell	-	(a.	c)							(a.c)		(a,c) .

.

TABLE 1. WRB-1 CHF CORRELATION - THINC ANALYSIS INPUTS

TH - Thimhle Cell

2. The inclusion of the d term (distance from the last mixing vane grid) makes the WRB-1 correlation a stronger function of axial position than previous correlations. Provide a description of how the axial locations at which the correlation is evaluated are chosen for the CHF tests; that is, how the thermocouple locations are chosen and how the locations at which the correlation is evaluated will be chosen in the application of the correlation of axial position of the correlation.

### Answer

The test results indicate that for uniform heat flux the CHF occurs at the exit, or the grid just upstream of the exit, while for non-uniform heat flux CHF almost invariably occurs just upstream of one or both of the last two mixing vane grids. For evaluation of the test results, the location most upstream of the exit at which a CHF signal was observed is treated as the CHF location. The thermocouple position is within a length step in which the fluid conditions are calculated; the fluid conditions calculated at the beginning of the length step in which CHF occurred are used in evaluation of the correlation. Because THINC is relatively insensitive to length steps, this is a reasonable assumption. Since this is in front of a grid, the distance from the last grid is set equal to the grid spacing. This is consistent with design use of the correlation where the elevation at the beginning of a length step containing a grid uses the grid spacing in the evaluation of the prediction of the CHF correlation. 3. What value of the performance factor (PF) is used for the 0.5 inch 0.D. Rods in the 3x3 CHF tests?

# Answer

[ ] (same as 0.422" 0.D. rods). This is duscussed further in the (a,c) answer to Question 7.

 Provide the correct value of the coefficient for the pressure squared term (B45) on page 2-5.

Answer

[ ] (a,c)

5. The Westinghouse topical report "Effects of Local Heat Flux Spikes on DNB in Non-Uniformly Heated Rod Bundles" (WCAP-8174-PA, Feb., 1975) adequately demonstrates that a special DNB heat flux spike factor need not be incorporated into the Westinghouse reactor design using Westinghouse type mixing vane grids when the W-3 CHF correlation is used. Provide a similar analysis to justify not including a special DNB heat flux spike when the WRB-1 correlation is used for reactor design.

### Answer

A perturbation effect parameter,  $\delta$ , (where "perturbation" refers to some small, local fuel abnormality such as a heat flux spike, a bowed rod, etc.) can be defined by:

$$\delta = 1 - \frac{\left(\frac{M}{p}\right)_2}{\left(\frac{M}{p}\right)_1} \equiv 1 - \frac{\frac{Q_2 \text{ meas}}{Q_2, \text{pred}}}{\frac{Q_1, \text{meas}}{Q_1, \text{meas}}}$$

- where: Q<sub>2</sub>,meas is the measured critical heat flux in the perturbed test section (test section 2)
  - Q1'meas is the measured critical heat flux in the un-perturbed test section (test section 1).
  - Q2'pred is the critical heat flux as predicted by a correlation, based on the un-perturbed geometry of test section 1.
  - Q1'pred is the critical heat flux as predicted by a correlation for test section 1.

It should be emphasized that the heat fluxes discussed above are for two separate test runs, the second of which, carried out with the perturbed test section, was a repeat of the first, i.e., the two runs were carried out at the same inlet conditions. The two runs thus constitute a matched pair. As a practical matter, however, the test inlet conditions cannot be matched exactly. The correlation predicted heat fluxes have been incorporated into the definition of  $\delta$  in order to correct for this slight disparity in inlet conditions. This can be seen by re-writing the definition of  $\delta$ :

$$\delta = 1 - \left(\frac{Q_2 \cdot meas}{Q_1 \cdot meas}\right) \left(\frac{Q_1 \cdot pred}{Q_2 \cdot pred}\right)$$

The ratio  $Q_1$ , pred  $Q_2$ , pred will thus always be close to unity since the correlation is evaluated for the same geometry in both cases, and for almost the same inlet conditions. This will be true even if the correlation predicted heat fluxes are substantially different from the measured.

Similarly, the value of  $Q_1$ , pred $Q_2$ , pred as predicted by one correlation can be only very slightly different from that predicted by another correlation. Thus, the effect of the correlation used will be very much second order.

It should be noted that in Reference(3) the staff approved the elimination of a power spike in a completitor's plant for application with the use of a CHF correlation other than the "R" Grid and without Westinghouse mixing vane grids. The above approval was based on tests conducted by Westinghouse. 6. To date the information presented to the staff on the effects of rod bowing on UNB has been based on a combination of CHF tests and calculation using the W-3 CHF correlation. Justify the use of this information with the WRB-1 correlation or provide information on changes in CHF and the equivalent change in F<sup>N</sup><sub>AH</sub> when the WRB-1 correlation is applied.

# Answer

As described in the answer to Question 5, the effect of using the WRB-1 versus the W-3 CHF correlation is negligible.

7. Section 4 of WCAP-8762 proposes the use of a 1.17 Minimum DNBR for reactor design calculation. This value is based on 95% probability of not experiencing DNB at a 95% confidence level when all of the data are considered (i.e., 1147 data points). Since each reactor design contains only one heated length; one fuel rod size; one type of mixing vane grid, etc., the use of CHF data from CHF test on other geometries (i.e., other heated lengths, fuel rod sizes, etc.) must be justified. This justification must be based on the fact that the correlation, in combination with the subchannel code, correctly treats the physical phenomena associated with the particular geometry change. For example, the treatment of different mixing grids is accomplished by using the appropriate loss coefficients in the subchannel calculation.

No empirical constants are required in the CHF correlation in order to fit the data. Therefore the data from the "R" grid and "L" grid CHF tests can be combined when computing the mean and standard deviation of the data and in establishing the correlation limit. However, the inclusion of the "Performance Factor" (a different value for the 5x5 type fuel and the 4x4 type fuei) in the WRB-1 correlation appears to be purely empirical. The requirement for a "Performance Factor" indicates that the CKF correlation and subchannel code are not representing all of the physical phenomena associated with the hydraulic diameter, rod size, pitch, change in mixing grid geometry, etc. Provide justification for the use of both the 5x5 and 4x4 test data in establishing the correlation limit.

If combination of the 5x5 type CHF data and the 4x4 type CHF data is not adequately justified, then the DNB limits must be established independently for 5x5 type fuel and 4x4 type fuel.

# Answer

The development of the WRB-1 correlation included all available data using mixing vane grids which are applicable to Westinghouse reactors. The test sections used to obtain these data were not designed to model any specific reactor core design but rather to provide a wide range of data parameters which more than cover reactor geometries and operating conditions. The WRB-1 properly accounts for the varied fluid properties and geometries encountered in twenty-four (24) different tests. This broad base for the correlation provides more versatility and justification for use of the correlation.

A subchannel code is used to determine the local fluid conditions in each subchannel at each axial elevation. The code can account for subchannel mixing and the loss coefficients of the grids. The bundle geometry change from 4x4 to 5x5 increases the number of subchannels but the solution technique of the code remains the same. The application of the THINC code to many different geometries has been extensively justified in the past; References (4, 5, 6, and 7).

As indicated in WCAP-8762, the "Performance Factor: is associated with the change in the geometry of the mixing vane grids which occurred when the rod C.D. was changed from .422" to .374". As it happens, this change also corresponds to the change from the 4x4 to 5x5 bundle. The change in geometry of the mixing vane is accounted for in the subchannel code by a change in the loss coefficients of the grid. (However, this does not fully reflect the effect of the vanes on the CHF performance of the grid. The vanes set up a swirling flow pattern around each rod. This swirl pattern delays CHF, so that the change in geometry in the mixing vane causes a change in the "Performance Factor". The swirl pattern effect is a localized phenomenon, and therefore, is independent of bundle size.) It is therefore concluded that the 4x4 and 5x5 type CHF data can be considered as part of the same population for determining CHF limits.

.

8. The form of the WRB-1 correlation includes a "Performance Factor" which is required to make the correlation fit both the 5x5 CHF data and the 4x4 data. The correlation indicates that the "Performance Factor" should be chosen based on the fuel rod outer diameter. This implies that the 5x5 "Performance Factor" also applies to 17x17 fuel since 17x17 fuel and the 5x5 test assembly both have rod diameters of 0.374 in. Similarly, the 4x4 "Performance Factor" would apply to 15x15 fuel. The 5x5 tests and the 4x4 tests differ in many areas, such as: rod diameter; pitch; equivalent diameter; equivalent heated diameter; mixing grid details; proximity of the CHF location to low power rods; proximity of the CHF location to the unheated walls; and proximity of the CHF location to the corner mixing vanes. A bias in CHF prediction or the subchannel conditions associated with one of these parameters could cause the difference in the 5x5 and 4x4 results. In order to apply the 5x5 and 4x4 data to 17x17 and 15x15 fuel assemblies, it is necessary to identify which of the differences between the 5x5 and the 4x4 tests causes the difference in the results (i.e., causes the need for the different "Performance Factors"). Therefore, provide a detailed discussion, inc' ding supporting calculations and test results, to justify the assumption that difference between the 5x5 and the 4x4 results is associated with difference in the rod diamecer.

### Answer

The identification of "Performance Factor" with a particular rod diameter was chosen as a convenient way of accounting for the change in the geometry of the mixing vane. It is not meant to imply that there is any relationship between rod diameter and "Performance Factor". Table 1 gives the vane designs for each test series. Vane design A is larger than vane design B. An appropriate method of comparing the vanes is to compare ]. This ratio is equal (a,c) [  $]^{a,c}$  for the type A vane and [  $]^{a,c}$  for the type B vane. A to [ ] is associated with the .422" rod (a,c) "Performance Factor value of [ because the mixing size (Vane A in Table 1) is comparable for all assem-] is associated with the .374" rod (a.c) bijes using this rod size and [ because the mixing vane size (Vane B) is comparable for all assemblies using this rod size. The change in mixing vane was not always accompanied by a rod diameter change. This is case for test A-24 where the rod O.D. was .500". The vanes were scaled to be equivalent to type A [ ]a.c so that the "Performance ] which is the same as for .422" O. D. rods. The results (a,c) Factor" is [ of this test are in good agreement with all the other tests.

The 5x5 test bundle has grids which are exact duplicates of the 17x17 fuel assembly grids. The 4x4 test bundle has a <sup>a,c</sup>[ ] which is equal to the 15x15 fuel assembly vane design. 9. For test series A-3, WCAP-8762 indicates that for some cases, the CHF location was measured at 84 inches from the test section inlet. WCAP-8536 which is referenced as the source of the information for test series A-3 shows the thermocouple location to be 85 inches from the inlet. Correct this discrepancy.

# Answer

The thermocouple was located at 85 inches from the inlet in test series A-3 while the measured location was indicated as 84 inches. This discrepancy is the result of the axial nodalization used in the data analysis. The length step containing the T/C location (85 in.) is treated as having CHF occurring at the beginning of the length step. This is consistent with the design procedure as outlined in the answer to question 2.

 Provide the grid locations and thermocouple locations for the test series A-10. This information is not presently available because these tests were not previously published.

# Answer

Figure 2 gives the locations of the grids and thermocouples for test series A-10.



11. The staff has been unable to verify the results of the A-10 test series. We believe that this is because the USINU power distribution presented in WCAP-8762 and in the referenced reports does not have sufficient detail to allow an accurate representation in the COBRA IV code. Provide a more detailed graphical or numerical representation of the power distribution for test series A-10.

# Answer

The axial heat flux profiles for test series A-10 are the same as for test series A-9, A-11, A-12, A-14, A-16 and A-17. Figure 3 is a plot of this profile.



10

\*

# REFERENCES

- Motley, F. E., Hill, K. W., Cadek, F. F., Shefcheck, J., "New Westinghouse Correlation WRB-1 for Predicting Critical Heat Flux in Rod Bundles with Mixing Vane Grids," WCAP-8762, (Westinghouse proprietary), July 1976.
- Novendstern, E. H. and Sandberg, R. O., "Single Phase, Local Boiling and Bulk Boiling Pressure Drop Correlations", WCAP-2850-L, April 1966 (Westinghouse Proprietary).
- Docket No. 50-255, Amendment 21 to Provisional Operating License DPR-20, United States Nuclear Regulatory Commission, April 29, 1976
- H. Chelemer, J. Weisman and L. S. Tong, "Subchannel Thermal Analysis of Rod Bundle Core," WCAP-7015, Revision 1, January, 1969.
- J. Shefcheck, "Application of the THINC Program to PWR Design," WCAP-7359-L, August, 1969, (Westinghouse Proprietary), and WCAP-7838, January, 1972.
- L. E. Hochreiter, H. Chelemer and P. T. Chu, "THINC-IV An Improved Program for Thermal-Hydraulic Analysis of Rod Bundle Core," WCAP-7956, June, 1973.
- L. E. Hochreiter, "Application of the THINC IV Program to PWR Design," WCAP-8054, October, 1973, (Westinghouse Proprietary), and WCAP-8195, October, 1973.



Westinghouse Electric Corporation Water Reactor Divisions Box 355 Pittsburgh Pennsylvania 15230 November 18, 1983

NS-EPR-2854

Dr. Cecil O. Thomas, Chief Special Projects Branch Division of Project Management U.S. Nuclear Regulatory Commission Phillips Building 7920 Norfolk Avenue Bethesda, Maryland 20014

SUBJECT: Basis for the Applicability of the WRB-1 CHF Correlation to 15x15 OFA and 14x14 OFA Fuel, Supplement 1, WCAP-8762 (Proprietary)

REFERENCE: "New Westinghouse Correlation WRB-1 for Predicting CHF in Rod Bundles with Mixing Vanes," WCAP-8762 (Proprietary)

Dear Dr. Thomas:

Enclosed are twenty-five (25) copies of, "Basis for Applicability of the WRB-1 CHF Correlation to 15x15 OFA and 14x14 OFA Fuel," Supplement 1 to WCAP-8762 (Proprietary).

Also enclosed are:

- Fifteen (15) copies of, "Basis for Applicability of the WRB-1 CHF Correlation to 15x15 OFA and 14x14 OFA Fuel," Supplement 1 to WCAP-8763 (Non-Proprietary).
- 2. One (1) copy of Application for Withholding (Non-Proprietary).
- One (1) copy of Affidavit (Non-Proprietary).

This information is provided to gain generic approval for using the WRB-1 CHF Correlation to evaluate 15x15 OFA and 14x14 OFA fuel designs. In this regard we anticipate a Supplement to the SER for WCAPs 8762 and 8763.

Expedited NRC review and approval is requested to support near term OFA reload applications.

This submittal contains proprietary information of Westinghouse Electric Corporation. In conformance with the requirements of 10CFR2.790, as amended, of the Commission's regulations, we are enclosing with this submittal an application for withholding from public disclosure and a copy of an affidavit. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission. Dr. C. O. Thomas Page Two

Correspondence with respect to the afficient or the application for withholding chould reference AW-83-101 and should be addressed to R. A. Wiesemann, Manager of Regulatory and Legislative Affairs, Westinghouse Electric Corporation, F.O. Box 355, Fittsburgh, Pennsylvania 15230.

Very truly yours,

1 m

2 E.P. Rahe, Jr., Manager Nuclear Safety Department

JWM/kk Enclosures

cc: Mr. Carl H. Berlinger, Chief Core Performance Branch Division of Systems Integration

> Mr. Laurence E. Phillips Core Performance Branch

# SUPPLEMENT 1 TO WCAP-8763

Basis for the Applicability of the WRB-1 Correlation to 15x15 OFA and 14x14 OFA Fuel.

Section	Title		
Α.	15x15	OFA	Fuel
в.	14x14	OFA	Fue

 $X = Q_{1}$
## A. 15x15 OFA FUEL

#### INTRODUCTION

The WRB-1 CHF correlation is based entirely on rod bundle data and has been shown to provide a significant improvement in DNB predictive capability for Westinghouse fuel designs with type "R" mixing vane grids. The NRC has recognized this increased accuracy and concurred that a 95/95 limit DNBR of 1.17 is appropriate for 12 ft and 14 ft 17x17 standard and optimized fuel assemblies, and 12 ft 15x15 standard fuel assemblies with the type "R" mixing vane grid (Ref. 1 and 2). Based on the semi-empirical nature of the correlation, the NRC has imposed restrictions on its applicability to other PWR designs. Specifically, the Safety Evaluation Report stated that. "The correlation should not be applied to any PWR geometry which has not been specifically tested or which has not been bracketed by the test data. The important parameters to which this applies are: rod size, rod pitch, heated length, mixing vane design and grid spacing."

The 15x15 optimized design is virtually identical to the 15x15 R-grid design in that the [

-1-

(a,c)

As will be discussed below, similar scaling techniques have been used for designing the 17x17 OFA and 14x14 OFA grids, and DNB testing has shown that the WRB-1 correlation correctly predicts the performance of those designs without modifications.

## 17x17 OFA DNB TEST RESULTS

Geometrically the 17x17 OFA design differs from the standard 17x17 R-grid design in that:

- The fuel rod diameter was reduced from 0.374 inch to 0.360 inch.
- The Zircaloy type "R" grid is taller and has a thicker strap than the Inconel type "R" grid which has previously been DNB tested.

In order to minimize the effect of the grid dimensional changes on DNB performance, special care was taken to preserve the important type "R" mixing vane characteristics.

(a.c)

# ]\* DNB testing of

the 17x17 OFA geometry demonstrated the success of this scaling approach-the WRB-1 correlation predicted the data well without any modifications, using the same performance factor as was used for the 17x17 standard fuel. Repeatability studies (Ref. 3) have shown that the accuracy of the WRB-1 correlation is essentially identical for the 17x17 OFA and standard geometries, indicating that no additional component of variance is introduced by the grid dimensional changes. In other words, the correlation correctly accounted for the equivalent diameter effects and the scaling approach correctly accounted for the grid dimensional changes.

#### 14X14 OFA DNB TEST RESULTS

The 14x14 optimized geometry differs from the reference geometry in that:

- The fuel rod diameter has been reduced from 0.422 inch to 0.400 inch.
- The Zircaloy type "R" grid is taller and has a thicker strap than the Inconel type "R" grid which had previously been DNB tested.

A DNB test series of the 14x14 OFA typical cell geometry has been performed to verify that the WEB-1 correlation correctly predicts the effect on CHF of the equivalent diameter change, and that the grid scaling approach introduces no additional component of variance. The details of the 14x14 OFA test, including test section description, test procedures, data, and data evaluations are presented in Section B of this submittal.

The results indicate that the WRB-1 correlation predicts the 14x14 OFA data with essentially the same accuracy as for the geometry from which it was scaled. The average measured-to-predicted critical heat flux ratio for the data set is 1.0571 with a sample standard deviation of 0.0771. These values were compared to those from the 0.422 inch rod bundle tests with 26 inch grid spacing, the geometry from the original WRB-1 R-grid database which is closest to the 14x14 OFA geometry. As shown in Table 1 the agreement is excellent, indicating that the WRB-1 correlation correctly accounts for the geometry changes. Also given in Table 1 is a comparison of the 17x17 standard and OFA DNB statistics. It is apparent that the WRB-1 correlation's ability to predict CHF is essentially identical for standard and OFA fuel designs.

-3-

## STATISTICAL TESTS

T-tests and F-tests have been performed for each of these standard/OFA data set pairs in order to evaluate the effect of the geometry changes on the accuracy of the WRB-1 correlation. Table 2 shows the results of these tests. It can be seen that the hypothesis that the WRB-1 correlation predicts the DNB behavior of the OFA geometries with the same accuracy as the standard R-grid geometries cannot be rejected at a 5% significance level, with the exception of the 1  $f^{+}$  (b,c) comparison. For that comparison the OFA data had an appreciably lower variance. A smaller variance is indicative of better correlation accuracy, so failure of the F-test is no meason for concern. Therefore, the results of these tests indicate that no additional component of variance is introduced by the grid dimensional changes.

#### OTHER GRID SIMILARITIES

One difference between the 15x15 OFA design and the 14x14 and 17x17 OFA designs is that in the 14x14 and 17x17 cases, there was a rod diameter change from their respective standard designs as well as the change to a Zircaloy grid, while in the 15x15 case there was no rod diameter change. This has raised the NRC concern that there may be a different flow velocity effect in the grid of the 15x15 OFA design as compared to the 14x14 and 17x17 designs that were tested. Included in Table 1 for the various geometries is the ratio of the gridded flow area to the ungridded flow area. Ungridded flow area refers to the bundle flow area at an ungridded elevation. Gridded flow area is the projected flow area at a grid elevation, i.e. bundle flow area minus obstructions due to grid straps, springs, dimples, etc. The ratio of these two flow areas gives an indication of the velocity changes encountered by the fluid as it passes through a grid. As can be seen in Table 1, both the 14x14 and 17x17 OFA designs resulted in

# ]+

# CONCLUSIONS

[

Based on the similarity of the 15x15 OFA and R-grid geometries and the previous success of the scaling techniques employed in the Zircaloy grid design (as demonstrated by the 17x17 OFA and 14x14 OFA DNB test results), it is concluded that the use of the WRB-1 CHF correlation with a design limit of 1.17 for the 15x15 OFA design is appropriate and that no additional uncertainty is required.

#### REFERENCES

- Letter, D. F. Ross, Jr. (NRC) to D. B. Vassalo (NRC), Subject: Topical Report Evaluation for WCAP-8762, April 10, 1978.
- Letter, R. L. Tedesco (NRC) to T. M. Anderson (Westinghouse), Subject: Acceptance for Referencing Topical Report WCAP-9401 (P)/WCAP-9402 (NP), May 7, 1981.
- Beaumont, M. D., Skaritka, J., "Verification Testing and Analyses of the 17x17 Optimized Fuel Assembly," WCAP-9401, March 1979.

# STATISTICAL COMPARISON OF STANDARD AND OPTIMIZED FUEL CHF RESULTS USING THE WR8-1 CORRELATION

-7-

+b,c

# F-test and t-test Results for Standard/OFA

Data Set Pairs in Table 2

+b,C

## B. 14x14 OFA FUEL

#### INTRODUCTION

The 14x14 optimized geometry differs from the reference geometry in that:

- The fuel rod diameter has been reduced from 0.422 inch to 0.400 inch.
- The Zircaloy type "R" grid is taller and has a thicker strap than the Inconel type "R" grid which had previously been DNB tested.

In order to ensure that these changes do not affect DNB performance, special care was taken to preserve the important type "R" mixing vane characteristics. [

 $]^{\dagger}$  Similar scaling techniques have also been used in designing the 17x17 and 15x15 OFA grids.

(a,c)

#### CRITICAL HEAT FLUX TESTING

DNB testing of the 17x17 OFA geometry initially demonstrated the success of this scaling approach -- the WRB-1 correlation (Ref. 1) predicted the data well without any modifications, using the same performance factor as was used for the 17x17 standard fuel (Ref. 2).

These results indicate that the correlation correctly accounted for the equivalent diameter effects and the scaling approach correctly accounted for the grid dimensional changes.

A DNB test series of the 14x14 OFA typical cell geometry has been performed to verify that the WRB-1 correlation predicts the 14x14 OFA DNB performance with essentially the same accuracy as for the geometry from which it was scaled. As discussed below, the results of this test series provide further verification of the scaling techniques employed in the Zircaloy grid design.

#### TEST FACILITIES

The test facilities and testing procedures used for the 14x14 OFA DNB tests were the same as those described in References 3 and 4. The test section was similar to the 0.422 inch rod bundle described in Reference 3, except that the mixing vane grid dimensions were modified slightly in order to accommodate the new rod diameter and the change from Inconel to Zircaloy. The modified grid design has retained the type "R" grid features. Figure 1 shows a sketch of the 14x14 OFA typical cell test bundle cross section. The axial locations of the grids and thermocouples are shown in Figure 2, and Figure 3 shows the cosine axial power distribution used for the tests.

## 14x14 OFA DNB DATA EVALUATIONS

The data were reduced using the THINC subchannel code, in the same manner as described previously in References 3 and 4. The WRB-1 correlation of Reference 1 was used to predict the critical heat flux.

shown in Reference 2, this approach had previously worked quite well with the 17x17 OFA DNB data.

1 As

(a,b,c)

The results of the data reduction are shown in Table 1. The average measured-to-predicted critical heat flux ratio for the data set is 1.0571 with a sample standard deviation of 0.0771. These values were compared to those from the 0.422 inch rod bundle tests with 26 inch grid spacing, the geometry from the original WRB-1 R-grid database which is closest to the 14x14 OFA geometry. As shown in Table 2, the agreement is excellent, indicating that the WRB-1 correlation correctly accounts for the geometry changes and that the choice of performance factor is appropriate. Also given in Table 2 is a comparison of the 17x17 standard and OFA DNB statistics. It is apparent that the WRB-1 correlation's ability to predict CHF is essentially identical for standard and OFA fuel designs.

#### CRITERION FOR DESIGN

Because the 14x14 OFA data set is indistinguishable from the 0.422 inch rod data sets with the same grid spacing, this new set can be incorporated into the data base of the WRB-1 correlation of Reference 2. This is done in Table 3 which includes all the "R" grid data of Reference 2 plus the new data set of this study.

As shown in Table 3, this expanded "R" grid data base yields statistics for the WRB-1 correlation which are essentially the same as those given in Reference 2. When values of  $(M/P)_{avg}$  and sample standard deviation, S, are used to calculate the 95/95 value of DNBR using the method of Owen (Reference 5), the result is:

$$(DNBR)_{95/95} = \frac{1}{\binom{M}{p} - KS} = \frac{1}{1.0079 - 1.724(0.0859)}$$

where K is a statistical factor (Reference 5)

 $(DNBR)_{95/95} = 1.163$ 

This is essentially the same value (1.17) found for the "R" grid data of Reference 2. Hence, the design  $(DNBR)_{95/95} = 1.17$  recommended in Reference 2 is not changed by the incorporation of the new optimized fuel 14x14 data into the "R" grid data base of the WRB-1 correlation.

#### CONCLUSIONS

DNB testing of the 14x14 OFA typical cell geometry has shown that the WRB-1 correlation correctly accounts for the geometry changes from the reference design, using the same performance factor as used for the 0.422 inch rod data evaluations. The 14x14 OFA data can be added to the WRB-1 R-grid database without changing the DNBR limit of 1.17.

#### REFERENCES

- Motley, F. E., Hill, K. W., Cadek, F. F., Shefcheck, J., "New Westinghouse Correlation WRB-1 for Predicting Critical Heat Flux in Rod Bundles with Mixing Vane Grids," WCAP-8762, (Westinghouse Proprietary), July 1976.
- Beaumont, M. D., Skaritka, J., "Verification Testing and Analyses of the 17x17 Optimized Fuel Assembly," WCAP-9401, March 1979.
- K. W. Hill, F. E. Motley, F. F. Cadek, A. H. Wenzel, "Effect of 17x17 Fuel Assembly Geometry on DNB," WCAP-8926-P-A (Westinghouse Proprietary) and WCAP-8297-A (Non-proprietary), February 1975.
- F. E. Motley, A. H. Wenzel, F. F. Cadek, "Critical Heat Flux Testing of 17x17 Fuel Assembly Geometry with 22-Inch Grid Spacing," WCAP-8536, (Westinghouse Proprietary) and WCAP-8537 (Non-proprietary), May 1975.
- D. B. Owen, "Factors for One-Sided Tolerance Limits and for Variable Sampling Plans," SCR-607, March 1963.



## FIGURE 2

AXIAL GRID AND CHF DETECTOR LOCATIONS, 14X14 OPTIMIZED CHF TEST SECTION

+b,c

1. b.c Z, AXIAL DISTANCE FROM BEGINNING OF HEATED LENGTH (INCHES) -0"LOC /2" AVG. LOCAL-TO-AVERAGE HEAT FLUX RATIO

-16-

,

.

Figure 3 . Axial Heat Flux Distribution

RUN NG.	INLET PRESSURE (PSIA)	INL ET TEMP ( F) (	INLET MASS VELOCITY X10c6 L5R/HR-SQFT	LUCAL QUALITY ) (P)	LOCAL TEAT FLUX (X10E6 BTU/HR-SQFT MEAS.) PRED.	H/P I CHF (JRB-1 )	ELEVATION FROM INLEF (INCHES) PRED. MEAS.#b.
224.2	Г				1		Г
2263						1.0599	
244						1.1582	
245						1.0593	
246						1.1064	
247					and the second second second	1.1149	
248	States and States					1.1483	
249						1.0943	
250						1.1320	
251						1.1482	
252						1.1118	
253	ALC: NOT A					1 1026	
254						1.1030	
255						1.0903	[1월 2일 (1월 20] - 1월 24] (1월 11일) [1월 2일 (1월 20] (1
256						1.0939	
257						1 0783	이 것이 없는 것이 많이 많이 많이 했다.
258					같은 것 같은 것 같아요.	1 1018	
259						9514	김 씨는 것 같은 것 같은 것이 없는 것이 없다.
260					and the second second	1,1338	
201					사람님께요. 정말 가 잘 알 걸	1.0550	
202	10 C 10 C 10 C					.8592	
203						.9104	
265	2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					.9466	
266						1.0739	
267	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1					1.0461	
268					a sector de la Bada	.9942	영제 그는 것이 아파 가슴을 가지 않는 것
269	1.0				and the second	1.0154	
270						1.0146	
271						1.0065	The second second second
	L					9615	

TABLE 1 - CHF TEST RESULTS FOR 14×14 OFA TYPICAL CELL USING WRB-1 CORRELATION

1.2.4

5.0.8

## TABLE 1 (CONTINUED)

## CHF TEST RESULTS FOR 14x14 OFA TYPICAL CELL

RUN	INL ET PRESSURE	INLET TEAP	INLET PASS VELOCITY	LOCAL	LOCAL HE	AT FLUX /HR-SQFT	N/P CHF	ELEVATION IINC	FRON INLE
N.J.	[PSIA]	( F)	(X1026 LBM/HR-SQFT)	(?)	MEASol	PRED.	(WRB-1 ;	PRED.	MEAS.I
	Г								**************************************
2272							1.1481	E .	
2273	1						1.0612		
2214	1.						.9741	and the second	
2319	24 1 1 1 1 1 1 1						. 9314		
2312						1.1.1.1.1.1.1	1.0735		
2310							1.1411		
<311	L						1.1465	Contraction of the second	

-18-

***************************************		
L = 14 FT DE = .5840 IN 4 RODS 1001 12 RODS 851	RUD U.D. =[ ] + 4,C LIRC SPRING MV GRIDS 26 IN SPACING LINCK RUD/DUTER RUD POWER = 1.1765	

STATISTICAL COMPARISON OF STANDARD AND OPTIMIZED FUEL CHF RESULTS USING THE WRB-1 CORRELATION

+b,c

# WRB-1 CHF CORRELATION - STATISTICAL RESULTS USING ALL "R" GRID DATA, INCLUDING NEW CPTIMIZED 14x14 DATA

Rod 0.D. Inch	L <sub>H</sub> <u>ft</u>	g <sub>sp</sub> Inch	Heat Flux Profile	<u>Configuration</u> (a)	N	(M) avg	Sample Standard Deviation,S	Reference
0.374	14	22	UNIF	TYP - 5x5	71	0.9964	0.0655	(2)
0.374	14	26	UNIF	TYP - 5x5	73	1.0041	0.0805	5. 14 1
0.374	8	22	UNIF	TYP - 5x5	67	1.0502	0.1020	
0.374	8	26	UNIF	TYP - 5x5	78	1.0136	0.0848	2.14.5 (2.5.4)
0.374	14	22	COSINE	TYP - 5x5	74	1.0022	0.0852	
0.422	8	20	COSINE	TYP - $4x4$	33	1.0042	0.0528	
0.422	8	20	USINU	TYP - $4x4$	33	0.9937	0.0649	
0.422	8	26	USINU	TYP - $4x4$	36	0.9846	0.0922	
0.422	14	26	USINU	TYP - $4x4$	35	1.0584	0.0816	3. 3. 1. 1. 1.
122	14	20	USINU	TYP - $4x4$	36	1.0100	0.0915	
0.422	14	13	USINU	TYP - 4x4	38	0.9737	0.0781	
0.422	14	32	USINU	TYP - $4x4$	38	1.0238	0.0752	
0.422	8	32	USINU	TYP - $4x4$	31	0.9913	0.0724	
0.422	14	26	USINU	TYP - $4x4$	71	1.0466	0.0829	
0.422	14	26	UNIF	TYP - $4x4$	42	0.9321	0.0595	
0.422	14	26	USINU	TH - 4x4	39	1.0141	0.0579	
0=422	14	32	USINU	TH - 4x4	37	0.9738	0.0887	
0.374	14	22	COSINE	TH - 5x5	70	1.0002	0.0796	
0.374	8	26	UNIF	TH - 5x5	68	1.0303	0.1048	1
0.360	14	20	COSINE	TYP - 5x5	63	0.9918	0.0970	
0.360	,14	20	COSINE	TH - 5x5	38	0.9755	0.0504	5
[ ]	HO14)	26	COSINE	TYP - $4x4$	37	1.0571	0.0771	This study

ALL DATA<sup>+</sup> 1180 1.0079 0.0859

.

+Results use all "R" grid data, including new optimized 14x14 data

\*TYP - Typical Cell TH - Thimble Cell