

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342.3840

Corbin A. McNeill, Jr.
Resident Manager



October 21, 1984
JAFP-84-0979

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing

Subject: James A. FitzPatrick Nuclear Power Plant (JAFNPP)
Docket No. 50-333
Recirculation System Weld Joints

Dear Sir:

A thorough in-service inspection program has recently been completed of the recirculation and associated stainless steel piping systems at JAFNPP. IGSCC-like indications were found in six 12-inch diameter recirculation riser welds and four 28-inch diameter welds. Attachment 1 provides a weld-by-weld summary of these indications including sizes and corrective actions taken.

To facilitate further discussion, it should be noted that each weld is identified by four sets of numbers. The first set is the pipe diameter, the second two sets identify the system, and the last is the individual weld number. The system number has been omitted, since all the welds under discussion are in the recirculation system.

Five of the welds were repaired by full structural weld overlay repairs, in which the design basis was to assume no structural credit for any remaining pipe wall over the entire length of the observed indication. It is also noteworthy that the overlay designs included thermal expansion stress as a primary stress to account for possible low toughness material effects, and that the first layer of weld overlay material has been discounted in determining overlay thickness to account for possible crack propagation into diluted ferrite weld metal. These conservatisms were applied in addition to the standard weld overlay practices of controlling weldment ferrite and carbon levels and applying the overlays with low heat input and water in the pipe. Design and application of the weld overlays applied at FitzPatrick exceed the standard practices used in the large majority of weld overlays applied in U.S. BWRs in terms of their ability to restore design basis structural margins to the welds and to arrest any future IGSCC propagation in the weldment.

8410250103 841021
PDR ADOCK 05000333
Q PDR

A047
11

U.S. Nuclear Regulatory Commission
Attention: Mr. D. B. Vassallo
Subject: Recirculation System Weld Joints

October 21, 1984
JAFP-84-0979
Page -2-

Five welds with indications were evaluated in accordance with ASME Section XI, IWB-3640 and the recommendations of NRC Generic Letter 84-11. In all cases, the indications are shown to be acceptable for a period in excess of the time to the next scheduled plant outage, in the as-welded condition. In addition, each weld was also treated by IHSI, which should inhibit further IGSCC propagation in these welds thus increasing their acceptability for continued operation by an even larger margin. It is noteworthy that the evaluations of these welds also included thermal expansion stress as a primary stress in determining maximum allowable flaw size to account for possible low toughness material effects. One final point of significance is that IHSI was performed on a large percentage of the remaining uncracked welds, thus greatly reducing the probability of future IGSCC in these welds. Considering the above factors, the New York Power Authority considers the results of the inspections and the corrective actions taken adequate to justify continued operation until the 1986 refueling outage at which time the relevant welds will be reevaluated.

Attachments 2 through 6 to this letter transmit fracture mechanics evaluation of ultrasonic indications for welds 28-53, 28-113, 28-112, 12-4, and 12-17. These indications were found by Ebasco personnel using 45° and 60° angles of shear waves at 2-1/4 MHz. The sizing was performed by KWU/UTL personnel using various techniques including:

- ID mode conversion - creeping wave
- SLIC 40-dual element multiple angle
- 45°, 4 MHz
- 60°, 4 MHz
- SUSI, dual element focused beam
- crack tip diffraction, 45°, 4 MHz
- head wave, creeping wave on ID

Attachment 7 is a summary of recirculation system weld inspections as of this date.

Attachment 8 provides weld overlay reports.

Attachment 9 provides weld overlay thicknesses.

Attachment 10 provides ultrasonic test data and polar plots for the riser and safe-end welds plus weld 12-02-2-70.

Attachment 11 provides simplified isometric drawings of the James A. FitzPatrick recirculation system.

If you have any questions, please contact Mr. J. A. Gray, Jr.

Very truly yours,

W. J. ... By direction for
CORBIN A. McNEILL, JR.

CAM:SMT:lar

Attachments

U.S. Nuclear Regulatory Commission
Attention: Mr. D. B. Vassallo
Subject: Recirculation System Weld Joints

October 21, 1984
JAFP-84-0979
Page -3-

cc: J. P. Bayne - WPO (w/attachments)
R. Burns - WPO (w/o attachments)
J. Gray - WPO (w/attachments)
S. M. Toth - WPO (w/attachments)
D. Sancic - WPO (w/attachments)
T. Dougherty - WPO (w/o attachments)
P. C. Riccardella - SI (w/attachments)
R. Patch - JAF (w/attachments)
Document Control Center - JAF (w/attachments)
R. J. Converse - JAF (w/o attachments)

Dr. Thomas E. Murley, Regional Administrator
U.S. N.R.C. Region I
631 Park Avenue
King of Prussia, PA 19406

L. Doerflein, NRC Resident Inspector

Attachment 1
JAFF-84-0979
October 21, 1984

Weld Summary

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333

WELD SUMMARY

JAMES A. FITZPATRICK - RESULTS OF IGSCC INSPECTIONS

Weld No.	Loop	Weld Location	Crack Type	Length	Thru Wall	Depth Var.	IHSI	Discovery Method	Previous Inspection	Corrective Action	Remarks
12-4	A	Pipe to sweep-o-let	C	1.0%	No	7.5%	Yes	UT-Pre & Post IHSI	6/83	IHSI & Analysis	
12-12	A	Pipe to safe end	C	100%	Yes	Avg. 50% Max. 100% Min. < 5%	Yes	PT, Visual, UT, Post IHSI	9/84	Weld Overlay	See Note 1
12-17	A	Pipe to safe end	C	4.0% 3.0%	No	Max. 10%	Yes	UT, Post IHSI	12/81 9/84	None	Indications 90% apart
12-23	A	Pipe to safe end	C	100% int.	No	Avg. 40% Max. 75% Min. < 5%	Yes	UT, Post IHSI	6/83 9/84	Weld Overlay	See Note 1
12-64	B	Pipe to safe end	C	100% int.	Yes	Avg. 30% Max. 100% Min. < 5%	Yes	PT, Visual, UT, Post IHSI	9/84	Weld Overlay	See Note 1
12-69	B	Pipe to safe end	C	100%	Yes	Not appt 2	Yes	PT, Visual, UT, post IHSI	12/81 9/84	Weld Overlay	See Note 1
12-70	B	Elbow to pipe	C	12.6%	No	45%	Yes	UT, Pre-IHSI	12/81 9/84	Weld Overlay	
28-48	A	Pipe to safe end	C	1.1%	No	15%	Yes	UT, Pre-IHSI	3/84	IHSI & Analysis	
28-53	A	Elbow to valve	C	.3%	No	5%	Yes	UT, Pre-IHSI	6/83 9/84	IHSI & Analysis	
28-112	B	Elbow to valve	C	.6%	No	17%	Yes	UT, Pre-IHSI	6/83 9/84	IHSI & Analysis	
28-113	B	Valve to pipe	C	.5%	No	10%	Yes	UT, Pre-IHSI	6/83 9/84	IHSI & Analysis	

Note 1 - No pre-IHSI UT examination performed.

Attachment 2
JAFP-84-0979
October 21, 1984

Fracture Mechanics Evaluation of Ultrasonic Indication in
Recirculation System Weld Joint 28-113

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333

The applied stresses (pressure + DW + thermal + seismic) were also used, in conjunction with ASME Section XI, Article IWB-3640, to determine allowable indication size. This result is illustrated in Figure 3. In accordance with the requirements of NRC Generic Letter 84-11, a maximum allowable crack size of 2/3 of the IWB-3640 limit is used to allow for uncertainty in crack depth sizing. Referring to Figure 3, it is seen that this limit is not predicted to be exceeded for greater than 36 months in the subject weld, even considering as/welded residual stress conditions. If IHSI residual stress benefits are accounted for, the flaw will remain at its present size, and thus satisfy the allowable flaw size limit by a large margin for the balance of plant life.

On the basis of the above evaluation, it is concluded that continued operation of this weld, considering the observed indication, will not lead to a reduction in plant safety margins, or a plant operational concern. The application of IHSI to the joint further reinforces this conclusion.

Very truly yours,




P. C. Riccardella

/dlh

Enclosures



Figure 1. Stress Intensity factor versus Crack Depth for J. A. Fitzpatrick Recirculation System - Weld 28-113



Stress Corrosion Crack Growth

Figure 2. Predicted Stress Corrosion Crack Growth for Observed Ultrasonic Flaw Indication - Weld 28-113.

CRACK GROWTH (mm)






Figure 3. Comparison of Predicted Crack Growth with Allowable Flaw Size Limits - Weld 28-113



Attachment 3
JAFP-84-0979
October 21, 1984

Fracture Mechanics Evaluation of Ultrasonic Indication in
Recirculation System Weld Joint 28-112

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333



STRUCTURAL INTEGRITY ASSOCIATES

3150 ALMADEN EXPWY. SUITE 226 • SAN JOSE, CA 95118 • (408) 978-8200

ASSOCIATES

J.F. COPELAND
T.L. GERBER
A.J. GIANNUZZI
A.N. MUCCIARDI
P.C. RICCARDELLA

DSR # 2163
OF PAGES 5

October 3, 1984
PCR-84-056A

Mr. David Sancic
New York State Power Authority
P. O. Box 41
Lycoming, NY 13093

Subject: Fracture Mechanics Evaluation of Ultrasonic Indication in Weld Joint 28-112 in J. A. Fitzpatrick Recirculation System

- References:
1. GE Report 22A2622, Rev. 1, "Design Report, Recirculation System for James A. Fitzpatrick Nuclear Power Station, ANSIB31.1 Calculations," Dec. 6, 1976.
 2. EPRI Report NP-2662-LD, "Computational Residual Stress Analysis for Induction Heating of Welded BWR Pipes," EPRI Project T113-8, Final Report, Dec. 1982.

Dear Dave:

This letter summarizes our evaluation of the subject U.T. indication per your request. Input to the evaluation was as follows:

Indication Length - 0.5 inch
Indication Depth - 0.221 inch

Pipe O.D. - 28.363 inch
Pipe I.D. - 25.867 inch
Pipe Wall Thickness - 1.248 inch

Applied Stresses (From Ref. 1, Node 175)
Pressure + DW + Thermal - 6899 PSI
Pressure + DW + Thermal + Seismic - 7935 PSI

Residual Stresses
Pre-IHSI Standard Distributions
Post-IHSI From Reference 2


Figure 1 provides applied stress intensity factor versus crack depth data for three load cases used in the evaluation. Assuming the indication to be IGSCC, these stress intensity curves were used to perform IGSCC crack growth estimates for both as-welded and post-IHSI residual stress conditions. The resulting crack growth prediction is illustrated in Figure 2 for the as-welded case. The post-IHSI case is also shown, and results in no predicted crack growth for the balance of plant life.

RECEIVED
OCT 4 5 55 PM '84

The applied stresses (pressure + DW + thermal + seismic) were also used, in conjunction with ASME Section XI, Article IWB-3640, to determine allowable indication size. This result is illustrated in Figure 3. In accordance with the requirements of NRC Generic Letter 84-11, a maximum allowable crack size of 2/3 of the IWB-3640 limit is used to allow for uncertainty in crack depth sizing. Referring to Figure 3, it is seen that this limit is not predicted to be exceeded for greater than 36 months in the subject weld, even considering as/welded residual stress conditions. If IHSI residual stress benefits are accounted for, the flaw will remain at its present size, and thus satisfy the allowable flaw size limit by a large margin for the balance of plant life.

On the basis of the above evaluation, it is concluded that continued operation of this weld, considering the observed indication, will not lead to a reduction in plant safety margins, or a plant operational concern. The application of IHSI to the joint further reinforces this conclusion.

Very truly yours,



P. C. Riccardella

/dlh

Enclosures



NO. 5011Z101001




Figure 1. Stress Intensity Factor Versus Crack Depth for J. A. Fitzpatrick Recirculation System Weld 28-112

Figure 2. Predicted Stress Corrosion Crack Growth for Observed Ultrasonic Flaw Indication






Figure 3. Comparison of Predicted Crack Growth With Allowable Flaw Size Limits - Weld 28-112



Attachment 4
JAFF-84-0979
October 21, 1984

Fracture Mechanics Evaluation of Ultrasonic Indication in
Recirculation System Weld Joint 12-4

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333



STRUCTURAL INTEGRITY ASSOCIATES

3150 ALMADEN EXPWY. SUITE 226 • SAN JOSE, CA 95118 • (408) 978-8200

ASSOCIATES

J.F. COPELAND
T.L. GERBER
A.J. GIANNUZZI
A.N. MUCCIARDI
P.C. RICCARDELLA

DSR# 2159
OF PAGES 5

October 3, 1984
PCR-84-055A

Mr. David Sancic
New York State Power Authority
P. O. Box 41
Lycoming, NY 13093

Subject: Fracture Mechanics Evaluation of Ultrasonic Indication in Weld Joint 12-4 in J. A. Fitzpatrick Recirculation System

- References:
1. GE Report 22A2622, Rev. 1, "Design Report, Recirculation System for James A. Fitzpatrick Nuclear Power Station, ANSIB31.1 Calculations," Dec. 6, 1976.
 2. EPRI Report NP-2662-LD, "Computational Residual Stress Analysis for Induction Heating of Welded BWR Pipes," EPRI Project T113-8, Final Report, Dec. 1982.

Dear Dave:

This letter summarizes our evaluation of the subject U.T. indication per your request. Input to the evaluation was as follows:

Indication Length - 0.4 inch
Indication Depth - 0.046 inch

Pipe O.D. - 12.662 inch
Pipe I.D. - 11.442 inch
Pipe Wall Thickness - 0.61 inch

Applied Stresses (From Ref. 1, Node 258)
Pressure + DW + Thermal - 14030 PSI
Pressure + DW + Thermal + Seismic - 17245 PSI

Residual Stresses
Pre-IHSI Standard Distributions
Post-IHSI From Reference 2

Figure 1 provides applied stress intensity factor versus crack depth data for three load cases used in the evaluation. Assuming the indication to be IGSCC, these stress intensity curves were used to perform IGSCC crack growth estimates for both as-welded and post-IHSI residual stress conditions. The resulting crack growth prediction is illustrated in Figure 2 for the as-welded case. The post-IHSI case is also shown, and results in no predicted crack growth for the balance of plant life.


RECEIVED
OCT 11 1984
5 56 PM '84

The allowable end-of-cycle flaw size was determined in accordance with ASME Section XI, Article IWB-3640, and is illustrated in Figure 3 in terms of allowable flaw depth versus length. Note that although not required by IWB-3640, thermal expansion stresses have been included in the evaluation to account for possible effects of low toughness weldment material. In accordance with the requirements of NRC Generic letter 84-11, a maximum allowable flaw size of 2/3 of the IWB-3640 limit (shown as a dashed line in Figure 3) is used to allow for uncertainty in flaw depth sizing.

Referring to Figure 3, it is seen that the 2/3 of IWB-3640 limit is exceeded in approximately nine months in the as-welded case, but is satisfied by a large margin in the post-IHSI case, since no crack propagation is predicted. To add further assurance in the post-IHSI case, the IGSCC crack growth analysis has been repeated assuming various initial crack depths ranging upward from the observed crack depth. No crack propagation is predicted in the post-IHSI condition for initial crack depths up to .488 inches, or 80% of the pipe wall. It is also noteworthy that, given the relatively short length of the observed indication (5% of circumference), it would not lead to any reduction in piping system safety margins, even if the above crack growth or initial flaw size estimates are significantly in error. Leak before break is clearly the expected, hypothetical failure mode for this indication.

On the basis of the above evaluation, it is concluded that continued operation of the plant with this weld, considering the observed indication and the IHSI treatment which has been applied, will not lead to a reduction in plant safety margins, or a plant operational concern.

Very truly yours,



P. C. Riccardella


/dlh

Enclosures



STRUCTURAL
INTEGRITY ASSOCIATION

Figure 1. Stress Intensity Factor versus Crack Depth for J. A. Fitzpatrick Recirculation System Weld 12-4.



Stress Corrosion Crack Growth

CORROSION QUALITY # 101 (IN)





Figure 2. Predicted Stress Corrosion Crack Growth for Observed Ultrasonic Flaw Indication.


Figure 3. Comparison of Predicted Crack Growth with Allowable Flaw Size Limits - Weld 12-4.



Attachment 5
JAFF-84-0979
October 21, 1984

Fracture Mechanics Evaluation of Ultrasonic Indication in
Recirculation System Weld Joint 28-53

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket 50-333



STRUCTURAL INTEGRITY ASSOCIATES

3150 ALMADEN EXPWY. SUITE 226 • SAN JOSE, CA 95118 • (408) 275-8200

ASSOCIATES

J.F. COPELAND
T.L. GERBER
A.J. GIANNUZZI
A.N. MUCCIARDI
P.C. RICCARDELLA

October 10, 1984
PCR-84-057A

Mr. David Sancic
James A. Fitzpatrick
Nuclear Power Plant
Lake Road East
Town of Scriba
Oswego, NY 13093

Subject: Fracture Mechanics Evaluation of Ultrasonic Indication in Weld Joint 28-53 in J. A. Fitzpatrick Recirculation System

- References:
1. GE Report 22A2622, Rev. 1, "Design Report, Recirculation System for James A. Fitzpatrick Nuclear Power Station, ANSIB31.1 Calculations," Dec. 6, 1976.
 2. EPRI Report NP-2662-LD, "Computational Residual Stress Analysis for Induction Heating of Welded BWR Pipes," EPRI Project T113-8, Final Report, Dec. 1982.

This letter summarizes our evaluation of the subject U.T. indication per your request. Input to the evaluation was as follows:

Indication Length - 0.28 inch
Indication Depth - 0.069 inch

Pipe O.D. - 28.363 inch
Pipe I.D. - 25.867 inch
Pipe Wall Thickness - 1.248 inch

Applied Stresses (From Ref. 1, Node 331)
Pressure + DW + Thermal - 6985 PSI
Pressure + DW + Thermal + Seismic - 8213 PSI


Residual Stresses
Pre-IHSI Standard Distributions
Post-IHSI From Reference 2

Figure 1 provides applied stress intensity factor versus crack depth data for three load cases used in the evaluation. Assuming the indication to be IGSCC, these stress intensity curves were used to perform IGSCC crack growth estimates for both as-welded and post-IHSI residual stress conditions. The resulting crack growth prediction is illustrated in Figure 2 for the as-welded case. The post-IHSI case is also shown, and results in no predicted crack growth for the balance of plant life.

The applied stresses (pressure + DW + thermal + seismic) were also used, in conjunction with ASME Section XI, Article IWB-3640, to determine allowable indication size. This result is illustrated in Figure 3. In accordance with the requirements of NRC Generic Letter 84-11, a maximum allowable crack size of 2/3 of the IWB-3640 limit is used to allow for uncertainty in crack depth sizing. Referring to Figure 3, it is seen that this limit is not predicted to be exceeded for greater than 36 months in the subject weld, even considering as-welded residual stress conditions. If IHSI residual stress benefits are accounted for, the flaw will remain at its present size, and thus satisfy the allowable flaw size limit by a large margin for the balance of plant life.

On the basis of the above evaluation, it is concluded that continued operation of this weld, considering the observed indication, will not lead to a reduction in plant safety margins, or a plant operational concern.

Figure 1. Stress Intensity Factor versus Crack Depth for J. A. Fitzpatrick Recirculation System-Weld 28-53.



Y \ 10 \ 20 \ 30 \ 40 \ 50 \ 60 \ 70 \ 80 \ 90 \ 100

Figure 2. Predicted Stress Corrosion Crack Growth for Observed Ultrasonic Flaw Indication - Weld 28-53





Figure 3. Comparison of Predicted Crack Growth with Allowable Flaw Size Limits - Weld 28-53.



Attachment 6
JAFF-84-0979
October 21, 1984

Fracture Mechanics Evaluation of Ultrasonic Indication in
Recirculation System Weld Joint 12-17

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333



STRUCTURAL INTEGRITY ASSOCIATES

3150 ALMADEN EXPWY. SUITE 226 • SAN JOSE, CA 95118 • (408) 979-6200

ASSOCIATES

J.F. COPELAND
T.L. GERBER
A.J. GIANNUZZI
A.N. MUCCIAROLI
P.C. RICCARDIELLA

October 18, 1984
PCR-84-062

TELECOPY (315) 342-3840
Ext. 292, 3 min.

Mr. David Sancic
New York State Power Authority
P. O. Box 41
Lycoming, NY 13093

Subject: Fracture Mechanics Evaluation of Ultrasonic Indication in Weld Joint 12-17 in J. A. Fitzpatrick Recirculation System

- References:
1. GE Report 22A2622, Rev. 1, "Design Report, Recirculation System for James A. Fitzpatrick Nuclear Power Station, ANSIB31.1 Calculations," Dec. 6, 1976.
 2. EPRI Report NP-2662-LD, "Computational Residual Stress Analysis for Induction Heating of Welded BWR Pipes," EPRI Project T113-8, Final Report, Dec. 1982.

Dear Dave:

This letter summarizes our evaluation of the subject U.T. indication per your request. Input to the evaluation was as follows:

Indication Length - 2.90 inch
Indication Depth - 0.061 inch

Pipe O.D. - 12.662 inch
Pipe I.D. - 11.442 inch
Pipe Wall Thickness - 0.61 inch

Applied Stresses (From Ref. 1, Node 178)
Pressure + DW + Thermal - 17988 PSI

Residual Stresses
Pre-IHSI Standard Distributions
Post-IHSI From Reference 2

Figure 1 provides applied stress intensity factor versus crack depth data for three load cases used in the evaluation. Assuming the indication to be IGSCC, these stress intensity curves were used to perform IGSCC crack growth estimates for both as-welded and post-IHSI residual stress conditions. The resulting crack growth prediction is illustrated in Figure 2 for the as-welded case. The post-IHSI case is also shown, and results in no predicted crack growth for the balance of plant life.

The allowable end-of-cycle flaw size was determined in accordance with ASME Section XI, Article IWB-3640, and is illustrated in Figure 3 in terms of allowable flaw depth versus length. Note that although not required by IWB-3640, thermal expansion stresses have been included in the evaluation to account for possible effects of low toughness weldment material. In accordance with the requirements of NRC Generic letter 84-11, a maximum allowable flaw size of 2/3 of the IWB-3640 limit (shown as a dashed line in Figure 3) is used to allow for uncertainty in flaw depth sizing.

Referring to Figure 3, it is seen that the 2/3 of IWB-3640 limit is exceeded fairly shortly in the as-welded case, but is satisfied indefinitely in the post-IHSI case, since no crack propagation is predicted. To add further assurance in the post-IHSI case, the IGSCC crack growth analysis has been repeated assuming various initial flaw sizes ranging from the observed UT depth. No crack propagation is predicted in the post-IHSI condition for initial crack depths up to 0.439 inches, or 72% of the pipe wall. It is also noteworthy that, given the relatively short length of the observed indication (8% of circumference), it would not lead to rupture of the pipe joint even if the above crack growth or initial flaw size estimates are significantly in error. Leak before break is clearly the expected, hypothetical failure mode for this indication.

On the basis of the above evaluation, it is concluded that continued operation of the plant with this weld, considering the observed indication and the IHSI treatment which has been applied, will not lead to a reduction in plant safety margins, or a plant operational concern.

Very truly yours,

P. C. Riccardella for PCR
P. C. Riccardella

/dlh

Enclosures




Figure 1. Stress Intensity Factor Versus Crack Depth for J. A. Fitzpatrick Recirculation System Weld 12-17.




Figure 2. Predicted Stress Corrosion Crack Growth for Observed Ultrasonic Flow Evaluation





Figure 3. Comparison of Predicted Crack Growth With Allowable Flaw Size Limits - Weld 12-17.



Attachment 7
JAFP-84-0979
October 21, 1984

Summary of Recirculation System
Weld Ultrasonic Inspections (UT)

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333

<u>Pipe Diameter</u>	<u>Total Welds</u>	<u>UT Inspections Completed*</u>
12"	40	40
22"	16	16
28"	41	39**


*All UT utilized procedures and personnel certified in accordance with the requirements of IEB 83-02 and Generic Letter 84-11.

**Two 28" welds were not subjected to UT because of their location under pipe whip restraints.

Attachment 8
JAFF-84-0979
October 21, 1984

Weld Overlay Reports

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333



STRUCTURAL INTEGRITY ASSOCIATES

3150 ALMADEN EXPWY. SUITE 226 • SAN JOSE, CA 95118 • (408) 978-8200

ASSOCIATES

J.F. COPELAND
T.L. GERBER
A.J. GIANNUZZI
A.N. MUCCIARDI
P.C. RICCARDILLA

Mr. David Sancic
New York State Power Authority
P. O. Box 41
Lycoming, NY 13093

October 12, 1984
PCR-84-060

Subject: Weld Overlay Design for J. A. Fitzpatrick Recirculation Weld 12-70

Dear Dave:

Attached per your request today are detailed design calculations for the weld overlay for the subject weld. This design is a full structural overlay, which assumes that the observed crack is completely through the original pipe wall, over the entire observed length. (Actually, the recommended overlay thickness is adequate for through wall crack lengths up to 40% of the circumference. Lengths beyond this would require a somewhat thicker overlay).

Other recommendations regarding this overlay design are as follows:

- As-deposited weld overlay ferrite levels should be measured after each layer, and should be a minimum of 10 FN. The weld overlay material should also be specified to a maximum carbon level of 0.02%. This will ensure no propagation of the observed IGSCC into the weld overlay.
- The minimum overlay thickness should be measured after the first PT clear layer. This allows for the possibility of some propagation of the observed IGSCC into the ferrite diluted first layer.
- The welding should be performed using a controlled heat input process (<40 KJ/in) with water in the pipe to minimize any further sensitization of the underlying piping material, and to ensure a favorable residual stress pattern.
- The as-installed design should be subjected to a thorough preservice baseline examination, including ultrasonic examination of the weld overlay material and its bond to the pipe, and best possible examination of the underlying weldment to define the existing indication.

The proposed design, implemented as outlined above, will produce a sound, long-term repair of the observed indication which ensures that current design basis safety margins are maintained in the joint.

Very truly yours,

Peter C. Riccardella

PASNY-01

Weld Overlay Design for Weld Joint 12-70

I. Weld #: 12-70 (pipe to elbow)

Node #: 65

II. Flaw Configuration

$$l = 4.75''$$

$$\left. \begin{array}{l} a/t = 45\% \\ t = .69'' \end{array} \right\} a = .3105''$$

Circumferential Crack

III

$$OD = 12.662'' \quad R_m = \frac{12.662 - .69}{2} = 5.986''$$
$$t = 0.69'' \quad 2\pi R_m = 37.61''$$

IV Applied Stress (Ref. 1)

$$I = 1.0 \quad \text{axial stress}$$
$$S_m = 16.95 \text{ ksi}$$

	σ_a	σ_a/S_m
Pre. + DW	5.924	.35
Pre + DW + Seis	7.347	.43
Exp.	4.198	.25
Pre + DW + Exp.	9.632	.57
Pre + DW + Seis + Exp.	10.843	.64

hoop stress

$$\text{design pressure} = 1.274 \text{ ksi}$$

$$\sigma_h = \frac{PR}{t} = \frac{1.274 \times (12.662 - .69)/2}{.69} = 11.05 \text{ ksi}$$

$$\sigma_h/S_m = .65$$

Prepared by:	<u>Walter Eno</u>	10-12-84
Checked by:	<u>WEE</u>	10/12/84
File No.	PASNY-01-200	
Page	1	of 5

V. Weld Overlay Sizing

- circumferential crack

$$a/t = .45$$

$$l/2\pi R_m = .13$$

$$\Rightarrow \text{overlay thickness} = 0.23''$$

- axial crack

$$a/t = 0.1$$

$$l = 1''$$

$$l/\sqrt{Rt} = .5$$

} hypothetical crack

$$\Rightarrow \text{overlay thickness} = 0.23''$$

- $\sqrt{Rt} = 2.03''$

$$1.5\sqrt{Rt} = 3.05'' \leftarrow \text{min. wol length}$$

Prepared by:	<u>Ag-for Eup</u>	<u>10-12-84</u>
Checked by:	<u>RLB</u>	<u>10/12/84</u>
File No.	<u>PASNY-01-200</u>	
Page	<u>2</u>	of <u>5</u>

Weld 12-70

0417757

TABLE 01 (CONTINUED)

GENERAL ELECTRIC COMPANY
BOILING WATER REACTOR SYSTEMS DEPARTMENT

SPEC NO. 22A2522

REV. NO. 7
PAGE NO. 92

FITZPATRICK RECIRC DISCHARGE LINE & RISERS AND HEATER

JOINT NO.	TYPE	OD	ID	T	INERTIA	Z
05 [x1,000]	B, WELD L/W/LW	12.062	11.442	0.610	420.5	80.423
			MA	MB	MC	
	EXPANSION	MOMENTS=	220040,	-120815,	120147,	
	DEADLOAD	MOMENTS=	15484,	2573,	-5901,	
	PRIMARY SEISMIC	MOMENTS=	15531,	53152,	85309,	
	SECONDARY SEISMIC	MOMENTS=	0,	0,	0,	
						STRESS RATIO
A, PRIMARY STRESS INTENSITIES						
	DEADLOAD + PRESSURE					= 5924, 0.373
	DEADLOAD + PRESSURE + SEISMIC					= 7547, 0.385
B, SECONDARY STRESS RANGE						
	EXPANSION					= 4198, 0.193
	EXPANSION + SECONDARY SEISMIC					= 4198, 0.193
C, PRIMARY PLUS SECONDARY STRESS RANGE						
	DEADLOAD + PRESSURE + EXPANSION					= 9032, 0.185
	DEADLOAD + PRESSURE + SEISMIC + THERMAL + EXPANSION					= 10843, 0.208
D, RARE EVENTS - PRIMARY STRESS LIMIT						
	ALLOWABLE STRESS =		19080,			
	ELECTRIC EVALUATED PRIMARY STRESSES AS SHOWN BELOW					STRESS RATIO
	EMERGENCY CONDITIONS 10E-1 > P > 10E-1					
	DEADLOAD + PRESSURE + DOUBLE PRIMARY SEISMIC					= 8505, 0.297
	DEADLOAD + MAX. PRESSURE + PRIMARY SEISMIC					= 8505, 0.297
	FULLY LOADED CONDITIONS 10E-3 > P > 10E-6					
	DEADLOAD + MAX. PRESSURE + DOUBLE PRIMARY SEISMIC					= 10029, 0.263

Prepared by: Chas. H. Eno 10-12-84
 Checked by: W. L. 70/12/84
 File No. PASNY-01-200
 Page 3 of 5

Prepared by: Chang Hui Jun 10-12-84
 Checked by: W. B. C. 10/12/84
 File No. PASNY-01-200
 Page 4 of 5

STRUCTURAL INTEGRITY ASSOCIATES
 WELD OVERLAY SIZING

OVERLAY SIZING FOR CIRCUMFERENTIAL CRACK:-

PASNY-01. WELD 12-70, WELD OVERLAY DESIGN

WALL THICKNESS=0.6900
 LOAD FACTOR= 1.00
 STRESS RATIO=0.640


	L/CIRCUMFERENCE						
	0.0	0.1	0.2	0.3	0.4	0.5-->	1.0
FINAL A/T	0.7500	0.7500	0.7500	0.7500	0.7500	0.7041	
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2300	0.2300	0.2900	

CRITICAL FLAW SIZE FOR AXIAL CRACK:


PASNY-01. WELD OVERLAY DESIGN

WALL THICKNESS=0.6900
 LOAD FACTOR= 1.00
 STRESS RATIO=0.650

	L/SQRT(RT)						
	0.0	0.5	1.0	2.0	3.0	4.0	5.0
FINAL A/T	0.7500	0.7500	0.7500	0.7275	0.6938	0.6685	0.6558
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2584	0.3045	0.3422	0.3622
	L/SQRT(RT)						
	6.0	7.0	8.0	9.0	10.0	11.0	>12.0
FINAL A/T	0.6494	0.6431	0.6367	0.6309	0.6207	0.6207	0.1000
OVERLAY THICKNESS	0.3725	0.3830	0.3937	0.4037	0.4216	0.4216	6.2100



DATE	10-12-84
BY	J. L. G.
PROJECT	PASNY-01-200
PAGE	5 of 5



STRUCTURAL INTEGRITY ASSOCIATES

3150 ALMADEN EXPWY. SUITE 226 • SAN JOSE, CA 95118 • (408) 978-8200

ASSOCIATES

J.F. COPELAND
T.L. GERBER
A.J. GIANNUZZI
A.N. MUCCIARDI
P.C. RICCARDELLA

October 16, 1984
PCR-84-061

Mr. David Sancic
New York State Power Authority
P.O. Box 41
Lycoming, N.Y. 13093

Subject: Weld Overlay Designs for J.A. FitzPatrick Recirculation
Welds 12-12, 12-23, 12-64, and 12-69

Dear Dave:

Attached per your request today are detailed design calculations for the weld overlays for the subject welds. The designs are full structural overlays, which assume that the observed cracks are completely through the original pipe wall, over the entire observed length.

Other recommendations regarding the overlay designs are as follows:

As-deposited weld overlay ferrite levels should be measured after each layer, and should be a minimum of 10 FN. The weld overlay material should also be specified to a maximum carbon level of 0.02%. This will ensure no propagation of the observed IGSCC into the weld overlay.

The minimum overlay thickness should be measured after the first PT clear layer. This allows for the possibility of some propagation of the observed IGSCC into the ferrite diluted first layer.

The welding should be performed using a controlled heat input process (≤ 40 KJ/in) with water in the pipe to minimize any further sensitization of the underlying piping material, and to ensure a favorable residual stress pattern.


The as-installed des'gns should be subjected to a thorough preservice baseline examination, including ultrasonic examination of the weld overlay material and its bond to the pipe, and best possible examination of the underlying weldment to define the existing indications.

-2-

October 16, 1984
PCR-84-061

The proposed designs, implemented as outlined above, will produce sound, long term repairs, of the observed indications, which ensure that current design basis safety margins are maintained in the joints.

Very truly yours,



Peter C. Riccardella

/rp

STRUCTURAL INTEGRITY ASSOCIATES
WELD OVERLAY SIZING

OVERLAY SIZING FOR CIRCUMFERENTIAL CRACK:-

TITLE: PASNY-01, WELDS 12-12 AND 12-64 WELD OVERLAY DESIGN

WALL THICKNESS= 0.6900
STRESS RATIO= 1.130
LOAD FACTOR= 1.000

	L/CIRCUM						
	.0	.1	.2	.3	.4	.5->1.0	
FINAL A/T	0.7500	0.7500	0.7500	0.7422	0.6919	0.5938	
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2397	0.3073	0.4721	

CRITICAL FLAW SIZE FOR AXIAL CRACK:

TITLE: PASNY-01, WELDS 12-12 AND 12-64 WELD OVERLAY DESIGN

WALL THICKNESS= 0.6900
STRESS RATIO= 0.650
LOAD FACTOR= 1.000

	L/SQRT(RT)						
	.0	.5	1.0	2.0	3.0	4.0	5.0
FINAL A/T	0.7500	0.7500	0.7500	0.7275	0.6938	0.6685	0.6558
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2584	0.3045	0.3422	0.3622

	6.0	7.0	8.0	9.0	10.0	11.0	>12.0
FINAL A/T	0.6494	0.6431	0.6367	0.6309	0.6207	0.6207	0.1000
OVERLAY THICKNESS	0.3725	0.3830	0.3937	0.4037	0.4216	0.4216	6.2100

Prepared by:	<u>Anthony Kuo</u>	<u>10-12-84</u>
Checked by:	<u>[Signature]</u>	<u>10/16/84</u>
File No.	<u>PASNY-01-200</u>	
Page	<u>1</u>	of <u>8</u>

Weld 12-12

0417757

TABLE 01 (CONTINUED)

GENERAL ELECTRIC COMPANY
BOILING WATER REACTOR SYSTEMS DEPARTMENT

SPEC NO. 22A2022

REV. NO. 1
PAGE NO. 159

FIZPATRICK RECIRC DISCHARGE LINE B RISERS AND HEADER

JOINT NO.	TYPE	OO	ID	T	INERTIA	Z
198	NOZZLE (RPV)	12,662	11,442	0,610	420,5	66,423
I=1,000						
			MA	MB	MC	
	EXPANSION	MOMENTS=	-300834,	268376,	398047,	
	DEADLOAD	MOMENTS=	-17042,	-106225,	-18871,	
	PRIMARY SEISMIC	MOMENTS=	25530,	86039,	409530,	
	SECONDARY SEISMIC	MOMENTS=	0,	0,	0,	
					STRESS	RATIO
A, PRIMARY STRESS INTENSITIES						
	DEADLOAD + PRESSURE				= 7316,	0,460
	DEADLOAD + PRESSURE + SEISMIC				= 12770,	0,669
B, SECONDARY STRESS RANGE						
	EXPANSION				= 8529,	0,310
	EXPANSION + SECONDARY SEISMIC				= 8529,	0,310
C, PRIMARY PLUS SECONDARY STRESS RANGE						
	DEADLOAD + PRESSURE + EXPANSION				= 13511,	0,260
	DEADLOAD + PRESSURE + SEISMIC + THERMAL + EXPANSION				= 19151,	0,368
D, RARE EVENTS-PRIMARY STRESS LIMIT						
	ALLOWABLE STRESS =				19080,	
	ELESTIC EVALUATED PRIMARY STRESSES AS SHOWN BELOW				STRESS	RATIO
	EMERGENCY CONDITIONS 10E=1>P40>10E=3					
	DEADLOAD + PRESSURE + DOUBLE PRIMARY SEISMIC				13929,	0,487
	DEADLOAD + MAX. PRESSURE + PRIMARY SEISMIC				13929,	0,487
	FAULTED CONDITIONS 10E=3>P40>10E=6					
	DEADLOAD + MAX. PRESSURE + DOUBLE PRIMARY SEISMIC				20162,	0,528

Prepared by:	<i>Chm-ypu</i> END 10-12-84
Checked by:	<i>W/L</i> 10/16/84
File No:	PASNY-01-200
Page	2 of 8

Weld 12-64

0417757

TABLE D1 (CONTINUED)

GENERAL ELECTRIC COMPANY
BOILING WATER REACTOR SYSTEMS DEPARTMENT

SPEC NO. 22A2522

REV. NO. 1

PAGE NO. 75

FITZPATRICK RECIRC DISCHARGE LINE A RISERS AND HEADER

JOINT NO.	TYPE	OD	ID	T	INERTIA	Z	
28	NOZZLE (RPV)	12.062	11.042	0.010	820.5	66.423	
[x1,000]							
			MA	MB	MC		
	EXPANSION	MOMENTS	355702,	-359108,	450827,		
	DEADLOAD	MOMENTS	-15195,	12879,	-22452,		
	PRIMARY SEISMIC	MOMENTS	17547,	69677,	267870,		
	SECONDARY SEISMIC	MOMENTS	0,	0,	0,		
						STRESS RATIO	
A.	PRIMARY STRESS INTENSITIES						
	DEADLOAD + PRESSURE					=	6124, 0.385
	DEADLOAD + PRESSURE + SEISMIC					=	10243, 0.537
B.	SECONDARY STRESS RANGE						
	EXPANSION					=	10259, 0.373
	EXPANSION + SECONDARY SEISMIC					=	10259, 0.373
C.	PRIMARY PLUS SECONDARY STRESS RANGE						
	DEADLOAD + PRESSURE + EXPANSION					=	15482, 0.297
	DEADLOAD + PRESSURE + SEISMIC + THERMAL + EXPANSION					=	19091, 0.367
D.	WAVE EVENTS-PRIMARY STRESS LIMIT						
	ALLOWABLE STRESS =					19080,	
	ELASTIC EVALUATED PRIMARY STRESSES AS SHOWN BELOW					STRESS	RATIO
	EMERGENCY CONDITIONS 10E-1 > P40 > 10E-3						
	DEADLOAD + PRESSURE + DOUBLE PRIMARY SEISMIC					11400,	0.398
	DEADLOAD + MAX. PRESSURE + PRIMARY SEISMIC					11400,	0.398
	FAULTED CONDITIONS 10E-3 > P40 > 10E-6						
	DEADLOAD + MAX. PRESSURE + DOUBLE PRIMARY SEISMIC					15575,	0.408

Prepared by: Chm - G. E. King 10-2-84
 Checked by: W. L. King 10/16/84
 File No. PASNY-01-200
 Page 3 of 8

STRUCTURAL INTEGRITY ASSOCIATES
WELD OVERLAY SIZING

OVERLAY SIZING FOR CIRCUMFERENTIAL CRACK:-

TITLE: PASNY-01, WELD 12-69 WELD OVERLAY DESIGN

WALL THICKNESS= 0.6900
STRESS RATIO= 0.850
LOAD FACTOR= 1.000

	L/CIRCUM						
	.0	.1	.2	.3	.4	.5->1.0	
FINAL A/T	0.7500	0.7500	0.7500	0.7500	0.7500	0.6523	
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2300	0.2300	0.3677	

CRITICAL FLAW SIZE FOR AXIAL CRACK:

TITLE: PASNY-01, WELD 12-69 WELD OVERLAY DESIGN

WALL THICKNESS= 0.6900
STRESS RATIO= 0.650
LOAD FACTOR= 1.000

	L/SQRT(RT)						
	.0	.5	1.0	2.0	3.0	4.0	5.0
FINAL A/T	0.7500	0.7500	0.7500	0.7275	0.6938	0.6685	0.6558
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2584	0.3045	0.3422	0.3622
	6.0	7.0	8.0	9.0	10.0	11.0	>12.0
FINAL A/T	0.6494	0.6431	0.6367	0.6309	0.6207	0.6207	0.1000
OVERLAY THICKNESS	0.3725	0.3830	0.3937	0.4037	0.4216	0.4216	6.2100

Prepared by:	<i>Am Jhu Kuo</i> 10-12-84
Checked by:	<i>W. L. Ch</i> 10/16/84
File No.	PASNY-01-200
Page	4 of 8

Weld 12-69

041757

TABLE 01 (CONTINUED)

GENERAL ELECTRIC COMPANY
BOILING WATER REACTOR SYSTEMS DEPARTMENT

SPEC NO. 22A2622

REV. NO. 1
PAGE NO. 91

FITZPATRICK RECING DISCHARGE LINE A RISERS AND HEADER

JOINT NO.	TYPE	OD	ID	T	INERTIA	Z
06	NOZZLE (RPV)	12.262	11.492	2.210	429.5	66.423
181,300						
			MA	MB	MC	
	EXPANSION	MOMENTS	220697,	-151025,	261787,	
	DEADLOAD	MOMENTS	-15488,	98579,	-39906,	
	PRIMARY SEISMIC	MOMENTS	15552,	74985,	295210,	
	SECONDARY SEISMIC	MOMENTS	0,	0,	0,	
						STRESS RATIO
A. PRIMARY STRESS INTENSITIES						
DEADLOAD + PRESSURE						= 7290, 0.458
DEADLOAD + PRESSURE + SEISMIC						= 11573, 0.596
B. SECONDARY STRESS RANGE						
EXPANSION						= 5038, 0.205
EXPANSION + SECONDARY SEISMIC						= 5038, 0.205
C. PRIMARY PLUS SECONDARY STRESS RANGE						
DEADLOAD + PRESSURE + EXPANSION						= 10291, 0.198
DEADLOAD + PRESSURE + SEISMIC + THERMAL + EXPANSION						= 14353, 0.276
D. RARE EVENTS-PRIMARY STRESS LIMIT						
ALLOWABLE STRESS = 19080,						
ELASTIC EVALUATED PRIMARY STRESSES AS SHOWN BELOW						STRESS RATIO
EMERGENCY SITUATIONS 10E-12 10E-10E-3						
DEADLOAD + PRESSURE + DOUBLE PRIMARY SEISMIC						12550, 0.438
DEADLOAD + MAX. PRESSURE + PRIMARY SEISMIC						12550, 0.438
FACTORED CONDITIONS 10E-12 10E-10E-3						
DEADLOAD + MAX. PRESSURE + DOUBLE PRIMARY SEISMIC						17054, 0.447

Prepared by: CLJ/SLD 10-12-84
 Checked by: SLD 10/16/84
 File No. PASNY-01-200
 Page 5 of 8

STRUCTURAL INTEGRITY ASSOCIATES
WELD OVERLAY SIZING

OVERLAY SIZING FOR CIRCUMFERENTIAL CRACK:-

FITZPATRICK WELD 12-23

WALL THICKNESS=0.6900
LOAD FACTOR= 1.00
STRESS RATIO=1.310

	L/CIRCUMFERENCE						
	0.0	0.1	0.2	0.3	0.4	0.5-->1.0	
FINAL A/T	0.7500	0.7500	0.7500	0.7056	0.6421	0.5615	
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2879	0.3846	0.5388	

CRITICAL FLAW SIZE FOR AXIAL CRACK:

FITZPATRICK WELD 12-23

WALL THICKNESS=0.6900
LOAD FACTOR= 1.00
STRESS RATIO=0.650

	L/SQRT(RT)						
	0.0	0.5	1.0	2.0	3.0	4.0	5.0
FINAL A/T	0.7500	0.7500	0.7500	0.7275	0.6938	0.6685	0.6558
OVERLAY THICKNESS	0.2300	0.2300	0.2300	0.2584	0.3045	0.3422	0.3622
	6.0	7.0	8.0	9.0	10.0	11.0	>12.0
FINAL A/T	0.6494	0.6431	0.6367	0.6309	0.6207	0.6207	0.1000
OVERLAY THICKNESS	0.3725	0.3830	0.3937	0.4037	0.4216	0.4216	6.2100

WELD 12-23

0417757

TABLE 01 (CONTINUED)


GENERAL ELECTRIC COMPANY
BOILING WATER REACTOR SYSTEMS DEPARTMENT

SPEC NO. 22A2622

REV. NO. 1
PAGE NO. 169

FITZPATRICK RECIRC DISCHARGE LINE B RISERS AND HEADER

JOINT NO.	TYPE	OO	ID	T	INERTIA	Z
218	NOZZLE (RPV)	12.862	11.482	0.610	820.5	66.423
I=1,000						
			MA	MB	MC	
EXPANSION	MOMENTS=		-390477,	364011,	480409,	
DEADLOAD	MOMENTS=		-16958,	-114609,	21767,	
PRIMARY SEISMIC	MOMENTS=		15350,	34575,	474620,	
SECONDARY SEISMIC	MOMENTS=		0,	0,	0,	
						STRESS RATIO
A. PRIMARY STRESS INTENSITIES						
DEADLOAD + PRESSURE						= 7447, 0.468
DEADLOAD + PRESSURE + SEISMIC						= 13490, 0.707
B. SECONDARY STRESS RANGE						
EXPANSION						= 10818, 0.394
EXPANSION + SECONDARY SEISMIC						= 10818, 0.394
C. PRIMARY PLUS SECONDARY STRESS RANGE						
DEADLOAD + PRESSURE + EXPANSION						= 18111, 0.310
DEADLOAD + PRESSURE + SEISMIC + THERMAL + EXPANSION						= 22260, 0.428
D. RARE EVENTS-PRIMARY STRESS LIMIT						
ALLOWABLE STRESS =						19060,
ELASTIC EVALUATED PRIMARY STRESSES AS SHOWN BELOW						STRESS RATIO
EMERGENCY CONDITIONS 10E-1 > P > 10E-3						
DEADLOAD + PRESSURE + DOUBLE PRIMARY SEISMIC						14648, 0.512
DEADLOAD + MAX. PRESSURE + PRIMARY SEISMIC						14648, 0.512
FAULTED CONDITIONS 10E-3 > P > 10E-6						
DEADLOAD + MAX. PRESSURE + DOUBLE PRIMARY SEISMIC						21725, 0.566



WELD NO.	t"
12-12	0.47
12-23	0.54
12-64	0.47
12-69	0.23 - 0.37*

* RANGE - ACTUAL THICKNESS
PENDING FINAL UT LENGTH
DETERMINATION.

Prepared by: *[Signature]*
 Checked by: *[Signature]*
 File No. PASNY-01-200
 Page 8 of 8

Attachment 9
JAFF-84-0979
October 21, 1984

Weld Overlay Thicknesses

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333

<u>Weld No.</u>	<u>Length</u>	<u>Thickness**</u>
12-70	3.01"	0.23"
12-12	3.01"	0.47"
12-64	3.01"	0.47"
12-23	3.01"	0.54"
12-69	3.01"	0.23" - 0.37"*

*Ranges - Actual size will be determined after UT evaluation of indication length.

**After the first clean PT.

Attachment 10
JAFF-84-0979
October 21, 1984

Ultrasonic Data and Polar Plots
For All Riser to Safe-End Welds Plus Weld 12-02-2-70

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333

Weld 12-02-2-1

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J.A. Fitzpatrick
DATA SHEET NO. JAF-192/A DATE 10-17-84
PROCEDURE JAF-UTS Ad 1-2 REV 3

COMPONENT OR SYSTEM Recirculation Loop PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 122°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 120°F

SCAN COVERAGE


WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT
Manufacturer Aerotech
Style GAMMA
Serial No. E14112
Size 0.5" DIA Frequency 2.25 MHz
Angle 62° Mode SHEAR
Couplant ULTRABEL II Batch No. 8439

INSTRUMENT
Manufacturer KRAUTKRAMER BRANSON Model USL-38
Serial No. 210571 Cable Length 6'
Frequency 2.5 MHz Reject OFF
Rep Rate N/A Damping OFF
dB Gain - Coarse 20 Fine 34
Primary Reference Response Amplitude % Full Screen Height 80% FSH

DAC PLOT - TIME 1530 AM (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1910	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)
1. [Signature] TC-IA LEVEL III
2. [Signature] TC-IA LEVEL I
REVIEWED BY [Signature] DATE 10/17/84

ADDITIONAL REMARKS

[Signature] NIPAA 10/17/84

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

SHEET 2 OF
 ITEM IDENTIFICATION 12-02-2-1
 CALIBRATION DATA SHEET NO. JAF-092/A

SCAN DIRECTION		DATA TABULATION										STRAIGHT BEAM (CAL ON BACK REFLECTION)				
		SEARCH UNIT		EXIT POINT LOCATION		SWEAP READING		MAXIMUM AMPLITUDE		50% DAC OR HALF MAXIMUM AMPLITUDE				INDICATION AMPLITUDE (% FSH)		BACK REFLECTION AMPLITUDE (% FSH)
ST. BEAM	CIRCUMFERENTIAL	CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD £)	SWEAP READING	MAX % DAC	EXAM. ON WELD) SIDE OF WELD	INDICATION NO.	INDICATION NO.	AXIAL	AXIAL	MINIMUM SWEEP READING	S.U. POSITION	MAXIMUM SWEEP READING	S.U. POSITION	INDICATION AMPLITUDE (% FSH)	BACK REFLECTION AMPLITUDE (% FSH)
N/A	N/A	1/2 CW	1.4"	5.9	100	PIPE	1	1	✓	✓	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	38 1/4 CW	0.6"	2.8	34	PIPE	2	2	✓	✓	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	39 1/2	0.6"	3.6	38	PIPE	3	3	✓	✓	N/A	N/A	N/A	N/A	N/A	N/A
(The remainder of the table is crossed out with a large X)																

INDICATION NO.	LOCATION OF INDICATION		LENGTH	DEPTH (IF PLANAR)	% I	DISTANCE FROM SURFACE	WIDTH (IF LAMINAR)	COMMENTS
	CIRC	AXIAL						
1	✓	N/A	*	N/A				60°
2	✓	N/A	*	N/A				* Intermittent indications in base material 360° around the Axial measurements from Top of weld.
3	✓	N/A	*	N/A				

RESULTS

EXAMINER(S)
 1. [Signature] TC-1A LEVEL III
 2. [Signature] TC-1A LEVEL I
 REVIEWED BY [Signature] DATE 10/17/84

CONTINUATION ATTACHED - Yes No

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 3

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NYPA

PROJECT J.A. FITZPATRICK

DATA SHEET # JAF-692/A

SUBJECT 12-02-2-1 RECIRCULATION SYSTEM Loop "A"





UNITED STATES TESTING COMPANY, INC.

12-02-2-1

101 16 1 84
Date


RADIOGRAPHIC EXAMINATION REPORT

Customer NYPA
 Location JAFNPP
 Purchase order no. NYO 82-246
 Work request no. N/A
 Welder I. D. W 4+7

R. T. Procedure/Rev. REACTOR CONTROLS INC RTI
 Specimen Description WELD
 Material Type S/S
 Dia./Thickness 12.750 / .668
 Specimen I. D. RECIRC WELD 15" B

Procedure Data

Gamma	X-Ray	Penetrometer Designation	<u>15F</u>
Source Type <u>IR¹⁹²</u>	Machine Mfg. <u>A</u>	Required Sensitivity/Essential Hole	<u>2/4T</u>
Curies <u>70</u>	Kilovoltage	Shim Thickness	<u>.093</u>
Physical Size <u>1/8 X 1/8</u>	Milliamperage <u>N</u>	Pb Screens: Front <u>.010</u>	Back <u>.010</u>
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance	<u>12.750</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness	<u>.010</u>
Film Size <u>4 1/2 X 17</u>	Total No. Film <u>8</u>	Exposure Time	<u>6 M.</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrometer	Weld		
5B	0-10				✓	✓	✓	✓	✓	ARTIFACTS	2.55	2.3-2.6	✓	
	10-20					✓	✓			ARTIFACTS	2.45	2.4-2.5	✓	
	20-30					✓	✓			ARTIFACTS	2.6	2.6-2.7	✓	
	30-0				✓		✓		✓	ARTIFACTS	2.5	2.2-2.6	✓	

Acceptance Criteria: Code/Addenda/Class- ASME III 68

Remarks:

Radiographed By: _____ Interpreted By: R Koontz, I. 10/16/84
 Customer Review: Chubb II 10/17/84
 Name Level Date

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J. A. Fitzpatrick
 DATA SHEET NO. JAF-R2/A DATE 10/1/84
 PROCEDURE JAF-UT-5 / 1/100/142 REV 3

COMPONENT OR SYSTEM RECIRC LOOP A PIPE OD (IF APPLICABLE) 12"
 ITEM IDENTIFICATION NO(S), LISTED ON REVERSE SIDE - COMPONENT TEMP 120°F
 CALIBRATION BLOCK NO. 17-A376 THICKNESS .66 TEMP 110°F


SCAN COVERAGE

WHAZ 0° BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT		INSTRUMENT	
Manufacturer	<u>NOFEL</u>	Manufacturer	<u>KRAUTKRAMER</u>
Style	<u>ZT-2</u>	Model	<u>USK-7</u>
Serial No.	<u>15462</u>	Serial No.	<u>22276-1539</u>
Size	<u>.50"</u>	Frequency	<u>BB</u>
Angle	<u>43°</u>	Rep Rate	<u>N/A</u>
Mode	<u>SHEAR</u>	dB Gain - Coarse	<u>20</u>
Couplant	<u>UTRAGEL II</u>	Batch No.	<u>8439</u>
		Primary Reference Response Amplitude % Full Screen Height	<u>88%</u>
		Reject	<u>MIN</u>
		Damping	<u>N/A</u>
		Fine	<u>20</u>

DAC PLOT - TIME 800 AM PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP ± 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
<u>1145</u>	<input checked="" type="checkbox"/>	<u>N/A</u>	<input checked="" type="checkbox"/>	<u>N/A</u>

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

2.5

EXAMINER
 1. [Signature] TC.IA LEVEL II
 2. [Signature] TC.IA LEVEL I
 REVIEWED BY [Signature] DATE 10/1/84

ADDITIONAL REMARKS
ID 3.6
3/4 2.6
1/4 4.6

[Signature] NPPA [Signature]
12/19/84

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

SHEET 2 OF 4
 ITEM IDENTIFICATION 12-02-2-1
 CALIBRATION DATA SHEET NO. JAF-102/A

DATA TABULATION

ST. BEAM	SCAN DIRECTION		INDICATION NO.	EXAM. ON WELD	MAX % DAC	SWEEP READING	EXIT POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE				STRAIGHT BEAM	
	CIRCUMFERENTIAL	AXIAL					CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD)	MINIMUM SWEEP READING	S.U. POSITION	MAXIMUM SWEEP READING	S.U. POSITION	INDICATION AMPLITUDE (% FBH)	BACK REFLECTION AMPLITUDE (% FBH)
	✓		1	EIBON SIDE	60	3.8	16" CW	.8	3.8	BV	4.2	1.0		
	✓		2	EIBON SIDE	100	3.7	1" CW	.65						
	✓		3	EIBON SIDE	100	3.8	1" CCW	.7						

INDICATION NO.	LOCATION OF INDICATION		LENGTH	DEPTH (IF PLANAR)	WIDTH (IF LAMINAR)		COMMENTS
	CIRC	AXIAL			DISTANCE FROM SURFACE	WIDTH	
1	✓	n/a	1.2				30 to 40% 5 to 6 1/2" IN TOLERANCE 360°, 100% OF DAC
2	✓	n/a	.5				
3	✓	n/a	.5				

RESULTS

EXAMINERS

- John R. Longgo TC-1A LEVEL II
- John R. Longgo TC-1A LEVEL I

CONTINUATION ATTACHED - Yes No

REVIEWED BY John R. Longgo III

DATE

10/17/84

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

CHKD. BY _____ DATE _____

CLIENT NVPA

PROJECT J.A. Fitzpatrick


SUBJECT 12-02-2-1

SHEET 3 OF 4

OFS NO. _____ DEPT. NO. _____

REC'D. Sys. Loop "A"


Data Sheet # JAF-102



EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING

B d e f d

WELD THICKNESS DATA SHEET



Transducer Size .50 Weld No. 12-02-2-1 System/Area REPAIR - SAFE-ENDS

Examiner J. Langis Level II Date 10-13-81



REPORT OF UT INSPECTION

PAGE 1 OF 6

REPORT NO. JAF 102084-1

CLIENT New York Power Authority

DATE 10-19-84

LOCATION James A. Fitzpatrick

WELD IDENTIFICATION NO. 12-02-2-1 DRAWING NO. N.A.

TYPE OF WELDING PIPE TO SAFE END MATERIAL: BASE SS WELD SS

SIZE OF PIPE 12" O.D. INCHES WALL THICKNESS _____ INCHES

SURFACE CONDITION OF PIPE ground OF WELD GROUND

WELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 126 °F

METHOD OF EXAMINATION: AUTOMATIC / MANUAL / SEMI-AUTO YES (ROBB)

UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes

form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60	RTU SEL 70	SRI SLIC 40	SUSI SUS 423	KK MWB 70
SERIAL NO.	#7	V#2	V#2	80-580		2002	
TRANSDUCER SIZE (MM) (←INCHES→)	8x9	8x9	8x9	2x7x15	2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	65°/32°	44°	57°	70°		52°	
EXIT POINT (MM) (←INCHES→)	12/10	13	13	9		13	
REMARKS:	mode-conversion	shear	shear	high-long-mode	long-shear	shear	shear

AUTOMATIC MANUAL

EQUIPMENT MODEL NO.

SERIAL NUMBER

CALIBRATION DATE

CABLE TYPE

CABLE LENGTH

	KK USK 7
	27274-2613
	09-10-84
	TRIAXIAL
	50 meter

COUPLING ULTRAGEL II

MFG. TECHNICARE-ECHO, Inc.

B. ACCT. NO. # 8413

PERSONNEL PERFORMING EXAMINATION :

NAME <u>M. DALICHOW</u>	LEVEL <u>I</u>	SIGNATURE <u>[Signature]</u>
NAME <u>L. SCHWANKE</u>	LEVEL <u>I</u>	SIGNATURE <u>[Signature]</u>
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF 102084-1
 DATE 10-19-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	40	35	31	25	20	15	10	-

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 \pm 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-2	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1776-091084



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A376-.66

DRAWING NUMBER N.A.

MATERIAL S.S. 304


REFERENCE REFLECTORS Back Wall

REFERENCE REFLECTORS Edge

REFERENCE REFLECTORS 10% notch 1-D.

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM)(INCHES)

RECHECK DATA

CAL. BLOCK ✓ S/N ✓ REF. REFL. ✓ TEMP. ✓ °F

REF. BLOCK 12-A376-.66 S/N N.A. REF. REFL. 10% notch 1-D. TEMP. 115 °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
<u>M. Dalichow</u>	<u>09:00</u>	<u>46 d.B 80% FSH</u>	<u>3.7</u>
<u>M. Dalichow</u>	<u>13:00</u>	<u>46 d.B 80% FSH</u>	<u>3.7</u>

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 6
 REPORT NO. JAF 102084-1
 DATE 10-19-84




DAC DATA

PROBE NO.	REFERENCE REFLECTOR	METAL PATH (MM) (IN)	AMPLITUDE (DB)	CALIBRATION BLOCK NO.	REMARKS
1	10% notch I.D.	37	46	12-A376-.66	SE2
	Edge	39	40	.	SE2
	Back Wall	34	46	.	SE1
2	10% notch I.D.	22	24	12-A376-.66	1/2-V-PATH
	10% notch O.D.	46	26	.	3/2-V-PATH
	10% notch 1 1/2 rods	68	30	.	3/2-V-PATH
3	10% notch I.D.	30	40	12-A376-.66	1/2-V-PATH
4	90% notch	2.5 depth fr. O.D.	60	EDM-CAL-25mm	PA 14 mm
	80% notch	5.0 " "	62	.	PA 18 mm
	70% notch	7.5 " "	64	.	PA 23 mm
	60% notch	10.0 " "	66	.	PA 25 mm
5					
6	20% notch	5mm depth fr. I.D.	70	EDM-CAL-25mm	SPOT-Calibration



REFERENCE POINT LOCATION TOP OF THE PIPE
INSPECTED AREA FROM CW 856-0-13 MM

EXAM NO.	PROBE NO.	IND NO.	Y LINEAR EXTEND FROM REFERENCE			X LINEAR EXTEND FROM WELD CT LINE			Z DEPTH POS. FROM SURFACE % OF 'T'	EVALUATION % OF 'T'	ECHO HEIGHT DIFF. dB	METAL PATH MM
			START	AT MAX	END	START	AT MAX	END				
1	1	1	856	1001	13	÷	-12	÷	÷	-10	39	
1	1	1	856	1001	13	÷	-12	÷	÷	-12	45	
1	2	1	856	1001	13	÷	-12	÷	÷	-16	27	
7	3	1	856	1001	13	÷	-12	÷	÷	-8	32	
			856	÷	13	÷	IRREGULAR GEOMETRY - COUNTER BORE					



EXAMINER DALICHOW / SCHWANKE LEVEL II
 SIGNATURE [Signature]
 AUTHORIZED INSPECTOR [Signature] (IF REQUIRED)
 CLIENT AT. WPAFF 102084 (IF REQUIRED)

T-INSPECTION -IGSCC-


Field Identification No 12-02-2-1

Signal No INDICATION NO 1

Coordinate from reference point "Y" CW 1001


Probes Used	Probe No.	Signal No.
Wall Thickness	MSEB 4-H	÷
Root Center	MSEB 4-H	÷
Other Data	1	1, 2
	2	3
	3	4

INSPECTION CONTOUR



INSPECTOR DALKHOW, SCHWANKE Level II







DATE 10-19-84



Report No. JAF 102084-1 page 6 of 6

Weld 12-02-2-7

IMAGE EVALUATION
TEST TARGET (MT-3)



EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA

PROJECT JA FITZPATRICK
DATA SHEET NO. JAF-096/A DATE 10-12-89
PROCEDURE JAF-UT-5 AM102 REV 3

COMPONENT OR SYSTEM RECONSTRUCTION 345' Long A' PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 127°F
CALIBRATION BLOCK NO. 12-B326 THICKNESS .66" TEMP 105°F


SCAN COVERAGE

WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT		INSTRUMENT	
Manufacturer <u>HB BRISTOL</u>	Manufacturer <u>GEORGE-BAIRD</u>	Model <u>USL-3B</u>	
Style <u>Gamma</u>	Serial No. <u>210571</u>	Cable Length <u>6'</u>	
Serial No. <u>E1442</u>	Frequency <u>2.25 MHz</u>	Reject <u>NA</u>	
Size <u>50° Ø</u>	Rep Rate <u>NA</u>	Damping <u>NA</u>	
Frequency <u>2.25 MHz</u>	dB Gain - Coarse <u>20</u>	Fine <u>20</u>	
Angle <u>62 1/2°</u>	Mode <u>SHEAR</u>	Primary Reference Response Amplitude % Full Screen Height <u>80%</u>	
Couplant <u>ULTRACAL 2</u>	Batch No. <u>8439</u>		

DAC PLOT - TIME 1:35 AM, PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
<u>2030</u>	<input checked="" type="checkbox"/>	<u>NA</u>	<input checked="" type="checkbox"/>	<u>NA</u>

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)
 1. [Signature] TC-IA LEVEL III
 2. John R. [Signature] TC-IA LEVEL I
 REVIEWED BY [Signature] DATE 10/17

ADDITIONAL REMARKS

3/4T - 3.4 @ 80% @ 54db
ID. - 5.2
1117

[Signature] 10/17/89

FIELD OR COMPONENT IDENTIFICATION

RECORDABLE INDICATION

COMMENTS OR REFERENCE TO INDICATION DATA SHEET (IDS)*

YES

NO

12-02-2-7

✓

N/A

See Indication Data Sheet

* Comments may include geometric reflectors, areas of inaccessibility, surface condition, etc. . . Also include the location of these conditions.

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

SHEET 2 OF 4

ITEM IDENTIFICATION 12-02-2-1

CALIBRATION DATA SHEET NO. JHF-C96/A

DATA TABULATION

ST. BEAM	SCAN DIRECTION		INDICATION NO.	EXAM. ON (ADJ WELD) SIDE OF WELD	MAX % DAC	SWEEP READING	SEARCH UNIT EXIT POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE				STRAIGHT BEAM (CAL ON BACK REFLECTION)	
	CIRCUMFERENTIAL	AXIAL					CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD C)	MINIMUM		MAXIMUM		INDICATION AMPLITUDE (% FSH)	BACK REFLECTION AMPLITUDE (% FSH)
									SWEEP READING	S.U. POSITION	SWEEP READING	S.U. POSITION		
		✓	1	ELBOW	50	4.2	38.5 CW	.8						
		✓	2		100	4.2	38.5 CW	.7						
		✓	3		25	3.0	15.5 CW	.44						
		✓	4		25	3.0	1.25 CW	.44						

RESULTS	INDICATION NO.	LOCATION OF INDICATION		LENGTH	% I		WIDTH (IF LAMINAR)	COMMENTS
		CIRC	AXIAL		DEPTH (IF PLANAR)	DISTANCE FROM SURFACE		
								60°
								MULTIPLE SIGNALS - ALL MEASUREMENTS TAKEN FROM TOE OF WELD TO INDEX POINT. I.E.T.C. WITHIN 360°.

EXAMINER(S)

[Signature] TC-IA LEVEL III
 2. *[Signature]* TC-IA LEVEL I

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF _____

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NYPA

PROJECT JA FITZPATRICK

Data Sheet # JPF-046/A

SUBJECT 12-02-2-7 "A" Loop RECIRCULATION SYS.



12-02-2-7



UNITED STATES TESTING COMPANY, INC.

12-02-2-7


10/16/84
Date

RADIOGRAPHIC EXAMINATION REPORT

Customer <u>NYPA</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS INC RT 1</u>
Location <u>JAFNPP</u>	Specimen Description <u>WELD</u>
Purchase order no. <u>NYO 82-246</u>	Material Type <u>S/S</u>
Work request no. <u>N/A</u>	Dia./Thickness <u>12.750 / .688</u>
Welder I. D. <u>7</u>	Specimen I. D. <u>RECIRC WELD 19B</u>

Procedure Data

Gamma	X-Ray	Penetrometer Designation <u>15F</u>
Source Type <u>IR¹⁹²</u>	Machine Mfg. <u>N/A</u>	Required Sensitivity/Essential Hole <u>2-4T</u>
Curies <u>70</u>	Kilovoltage	Shim Thickness <u>.093</u>
Physical Size <u>1/8 x 1/8</u>	Milliamperage	Pb Screens: Front <u>.010</u> Back <u>.010</u>
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance <u>12 3/4"</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u> <u>RI 1</u>	Geometric Unsharpness <u>.010</u>
Film Size <u>4 1/2 x 17</u>	Total No. Film <u>8</u> <u>RI 2</u>	Exposure Time <u>6 MIN</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrometer	Weld		
19B	0-10					✓		✓	✓	ARTIFACTS	2.3	2.1-2.3	✓	
	10-20			X					✓	ARTIFACTS	2.4	2.0-2.3		X
	20-30					✓		✓	✓	ARTIFACTS	2.4	2.05-2.4	✓	
	30-0						✓	✓	✓	ARTIFACTS	2.5	2.3-2.5	✓	
19BRI	10-20					✓				ARTIFACTS	2.3	2.3-2.4	✓	

Acceptance Criteria: Code/Addenda/Class - ASME III 68

Remarks: COUNTER BORE ≈ 3/4" from C of WELD

Radiographed By:

Interpreted by:

Customer Review

RKOONT II 10-16-84
Date

[Signature] III
Name Level

10-17-84
Date



REPORT OF UT INSPECTION

PAGE 1 OF 6
 REPORT NO. JAF102084-2
 DATE 10-19-84

CLIENT New York Power Authority
 LOCATION James A. Fitzpatrick

WELD IDENTIFICATION NO. 12-02-2-7 DRAWING NO. N.A.
 TYPE OF WELDING PIPE TO SAFE END MATERIAL: BASE SS WELD SS
 SIZE OF PIPE 12 O.D. INCHES WALL THICKNESS _____ INCHES
 SURFACE CONDITION OF PIPE ground OF WELD GROUND
 WELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 127 °F
 METHOD OF EXAMINATION: AUTOMATIC - MANUAL YES SEMI-AUTO -
 UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes
 form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60	KK MWB 60	SBI SLIC 40	SUSI SUS 423	KK MWB 70
SERIAL NO.	1.03	V#3	V#3	R415-1			
TRANSDUCER SIZE (MM) (_____)	8x9	8x9	8x9	8x9	2x 9.5	9.5	8x9
FREQUENCY MHz	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	68°/32°	44°	57°	56°			
EXIT POINT (MM) (_____)	12/10	13	13	13			
REMARKS:	mode-conversion	shear	shear	shear	long-shear	shear	shear

	AUTOMATIC	MANUAL
EQUIPMENT MODEL NO.		KK USK 7
SERIAL NUMBER		27274-2606
CALIBRATION DATE		08-23-84
CABLE TYPE		coaxial
CABLE LENGTH		1.5 meter

COUPLING ULTRAGEL II
 MFG. TECHNICARE-ECHO, Inc.
 B. ACCT. NO. # 8443

PERSONNEL PERFORMING EXAMINATION :

NAME M. DALICHOW LEVEL II SIGNATURE [Signature]
 NAME U. SCHWANKE LEVEL II SIGNATURE [Signature]
 NAME _____ LEVEL _____ SIGNATURE _____
 NAME _____ LEVEL _____ SIGNATURE _____
 NAME _____ LEVEL _____ SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF 102084-2
 DATE 10-19-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	40	34	30	25	20	15	10	7

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 \pm 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1763-82384



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A.376-.66

DRAWING NUMBER N.A.

MATERIAL SS 304


REFERENCE REFLECTORS 10% notch I.D.

REFERENCE REFLECTORS Edge I.D.

REFERENCE REFLECTORS BACK WALL

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM)(INCHES)

RECHECK DATA

CAL. BLOCK 7 S/N 7 REF. REFL. 7 TEMP. 7 °F

REF. BLOCK 12-A.376-.66 S/N N.A. REF. REFL. 10% notch I.D. TEMP. 115 °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
<u>M. Dalichow</u>		<u>SE 2 48 dB 80% FSH</u>	<u>3.6</u>
<u>M. Dalichow</u>		<u>SE 2 48 dB 80% FSH</u>	<u>3.6</u>

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 4

REPORT NO. JAF 102084-2

DATE 10-19-84



DAC DATA


PROBE NO.	REFERENCE REFLECTOR	METAL (MM) PATH (+/-)	AMPLITUDE (DB)	CALIBRATION BLOCK NO.	REMARKS
1	10% notch I.D.	36	48	12-A376-.66	.5E2
	Edge I.D.	37	42	"	.5E2
	Back Wall	34	48	"	.5E1
2	10% notch I.D.	22	26	12-A.376-.66	1/2 node
	10% notch O.D.	45	32	"	2/2 node
	10% notch I.D.	69	34	"	3/2 node
3	10% notch I.D.	28	40	12-A376-.66	1/2 node
4	10% notch I.D.	33	44	12-A376-.66	1/2 node
5					
6					



REFERENCE POINT LOCATION TOP OF THE PIPE
INSPECTED AREA CW 810-0-45

EXAM NO.	PROBE NO.	IND NO.	REFLECTOR POSITION/MM				Z DEPTH POS. FROM SURFACE % OF 'T.	EVALUATION % OF 'T.	ECHO HEIGHT DIFF. db	METAL PATH MM	
			Y LINEAR EXTEND FROM REFERENCE CW	X LINEAR EXTEND FROM WELD CT LINE	AT MAX	END					
1	1	1	810	35	904	-15	÷	÷	-18	39	
1	1	1	810	35	904	-15	÷	÷	-20	44	
1	2	1	÷	÷	904	-15	÷	÷	-16	24	
1	3	1	÷	÷	904	-15	÷	÷	-14	28	
1	3	1	÷	÷	904	-11	÷	÷	-6	32	
1	4	1	÷	÷	904	-3	÷	÷	-22	31	
			ALL INDICATIONS ID - GEOMETRY								

INTERMITTENT
 SCRATCH
 COUNTER-BORE
 FUSION-LINE




EXAMINER DALICHOW / SCHWABE LEVEL I
 SIGNATURE [Signature]
 AUTHORIZED INSPECTOR [Signature]
 CLIENT [Signature] (IF REQUIRED)
 (IF REQUIRED)

DATA STANDARD REPORT OF INDICATION NUMBER 1

SIGNAL NO.	PROBE NO.	ANGLE OF INCIDENT	EXAM NO.	EXIT X	POINT Y	GAIN DB 100% DAC	METAL PATH	REMARKS
1	1	32°	1	25	904	64	39	SHEAR DIRECT SCRATCH
2	1	32°	1	31	904	66	44	SE 2 SCRATCH
3	2	44°	1	30	904	42	24	SCRATCH
4	3	57°	1	36	904	46	32	COUNTER BORE
5	3	57°	1	37	904	54	28	SCRATCH
6	4	56°	1	29	904	62	31	FUSION LINE

DEGREES	
0	360
LOCATION OF DEFECT ONE CIRCUMFERENCE OF PIPE	



EXAMINER DALICHOW/SCHWANIK LEVEL II
 LEVEL III
 REVIEWED BY William E. Dotts DATE 10-20-84
 AUTHORIZED INSPECTOR _____


* THE ABOVE GRAPH REPRESENTS THE POSITION OF THE DEFECT IN RELATIONSHIP TO THE WELD CENTERLINE.



INSPECTION - IGSCC -
 Id Identification No 12-02-2-7
 gnat No INDICATION NO 1
 ordinate from reference point "Y" CW 904

Probes Used	Probe No.	Signal No.
Wall Thickness	KSK	÷
Root Center	KSK	÷
Other Data	1	1,2
	2	3
	3	4,5
	4	6

INSPECTION CONTOUR



INSPECTOR DALCHOW / SCHWANKE level

DATE 10-19-84

Report No. JAF 102084-2 page 6 of 6

Weld 12-02-2-12

ULTRASONIC DATA SHEET

UNIT: *THUMP*

SYSTEM: *02-2 / Reirs*

COMPONENT: *pipng welds*

DESCRIPTION: *Pipe to SHC and - Top of Riser*

WELD ID: *12-02-2-12*

PROCEDURE: *QAI - 9.0 + Add.*

MATERIAL: *SS*

THICKNESS: *0.70"*

TEST SURFACE: *00*

INSTRUMENT(S): *48-38*

CAL-BLOCK(S): *500 CAL. 54272*

CRYSTAL: *53475*

CRYSTAL: *84-88*

CRYSTAL:

NODE: *5/2*

BEAM DIRECTION: *THRU / 10K/1*

NO. POSITIONS: *41*

ANGLE: *45°*

ANGLE: *73°*

ANGLE:

DISTANCE: *10"*

#1 REF: *Top of Pipe*

TIME START: *1100*

TIME START: *1100*

TIME START: *1100*

COUPLANT: *ULTRASEL 72*

COUPLANT BATCH NO.: *8443*

TIME STOP: *1100*

TIME STOP: *1100*

TIME STOP:

CAL. SHEET: *79E-EVAL-008 5-009*

DATE: *10/15/89*

DATE: *10/15/89*

DATE:

PERFORMED BY: *George Nicks*

ID#: *5-1765*

LEVEL: *III*

DATE:

PERFORMED BY: *[Signature]*

ID#: *24*

LEVEL: *1/4*

DATE:

PERFORMED BY: *[Signature]*

ID#: *24*

LEVEL: *1/4*

DATE:

PERFORMED BY: *[Signature]*

ID#: *24*

LEVEL: *1/4*

DATE:

POSITION

LAMINATION (ONLY)

LEN.

LEN.

MAX. SIGNAL (% OF DAC)

DEPTH (IN)

20 TO 20

50 TO 50

100 TO 100

BEAM DIRECTION

ANGLE (DEG)

CRYSTAL

DISTANCE

FROM

SURFACE

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

DISTANCE FROM SURFACE IN.

POSITION (IN.)

NO

YES (IF SO WHY)

LIMITED SCAN

REMARKS

one they - wall 360° INTERAMB.

REVIEWED BY:

LEVEL:

DATE REVIEWED:

FIGURE NO.:

SK-JAF-82-002

WRED NO.:

DATA SHEET NO.:

CALIBRATION SHEET

HEET NO: JAF-EML-005

TIME: 1100 HR

DATE: 10/15/84

INIT: <u>JAFAPP</u>	SYSTEM: <u>02-2/Reinc.</u>	COMPONENT: <u>piping welds</u>
XAMINER: <u>George Seckler</u>	ID#: <u>5-1765</u>	LEVEL: <u>III</u>
XAMINER: <u>[Signature]</u>	ID#: <u>[Signature]</u>	LEVEL: <u>IV</u>
		COUPLANT: <u>ULTRAGEL II</u>
		COUPLANT ID#: <u>8443</u>

INSTRUMENT

D#: 210586

LINEARITY CHECK YES NO

REJECT: 0.35 %DB

MAT'L. CAL.: 182

DELAY: 678

PULSE ENERGY: S.F.D.

COARSE GAIN IN DB: 40

FINE GAIN IN DB: 12

FINE GAIN: 10 %

SCREEN RANGE: 2.5

SCREEN DEPTH: 1.0 IN.

TAR } OPERATION

NORMAL }

FREQUENCY: 5 MHZ

NORMAL } DISPLAY

RF }

REP. RATE: 1K

ZERO CONTROL: 0 0

DAMPING: off *

GAIN: _____

PLY: _____ } DAC

SLP: _____ }

POLARITY: _____

WIDTH: _____ } GATE %

DELAY: _____

NORMAL } ECHO START

FIRST ECHO }

CALIBRATION BLOCK

ID#: CTD-A376-75

LENGTH: _____ IN.

OD: _____ IN.

THICKNESS: _____ IN.

CRYSTAL

ID#: 53475

TYPE: AWB

FREQ: 4 MHZ

SIZE: 8x8mm

ACTUAL A: 45°

CALIBRATION BLOCK SIMULATOR

SERIAL NO. _____ SCREEN RANGE _____ IN.

SIGNAL AMP _____ % SCREEN READING _____ IN.

COURSE GAIN DB N FINE GAIN DB _____

SYSTEM CALIBRATION

ANGLE 45° NODE shear

SEARCH UNIT CABLE

TYPE AWG/STP LENGTH 6'

CAL. BLOCK TEMP. _____ F°

CAL. BLOCK SIMULATOR TEMP. N/A F°

(REQUIRED SUMMER 73 FOR VESSELS
REQUIRED WINTER 75 FOR PIPING)

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES
<u>10" 18-NODE</u>	<u>100 + %</u>	<u>50% = 10 IN.</u>
<u>15" 18-NODE</u>	<u>100 + %</u>	<u>60% = 15 IN.</u>
<u>20" 18-NODE</u>	<u>100 + %</u>	<u>40% = 20 IN.</u>
<u>25" 18-NODE</u>	<u>100 + %</u>	<u>40% = 25 IN.</u>
<u>30" 18-NODE</u>	<u>100 + %</u>	<u>30% = 30 IN.</u>
<u>35" 18-NODE</u>	<u>100 + %</u>	<u>25% = 35 IN.</u>
TOP NOTCH	%	IN
OPPOSITE NOTCH	<u>N/A</u> %	<u>N/A</u> IN.
BKR - CB*	<u>N/A</u> %	<u>N/A</u> IN.
BKR - P*	%	IN.

FIGURE NO(S), EXAMINED

<u>12-02-2-12</u>		
<u>12-02-2-17</u>		
<u>12-02-2-23</u>		
<u>12-02-2-64</u>		
<u>12-02-2-58</u>		
<u>12-02-2-75</u>		
<u>12-02-2-81</u>		

CALIBRATION CONFIRMATION

TIME	1400 HRS.		HRS.		HRS.		HRS.		HRS.		HRS.	
BLOCK SIM.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
BACK REFL.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
15" 18-NODE	100 %	60 IN.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
25" 18-NODE	100 %	60 IN.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
35" 18-NODE	100 %	35 IN.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
INITIALS	<u>[Signature]</u>											

HEET NO: JAF-EVAL-009

CALIBRATION SHEET

TIME: 1100 HR

DATE: 10/15/84

INIT: JAFNPP SYSTEM: 02-2/RECIRC. COMPONENT: PIPING welds
 XAMINER: George Seabrook ID#: 5-1765 LEVEL: III COUPLANT: ULTRATEL II
 XAMINER: N/A ID#: N/A LEVEL: N/A COUPLANT ID#: 8443

INSTRUMENT
 D#: 210568
 LINEARITY CHECK YES NO
 REJECT: off %DB
 MAT'L. CAL: 966
 DELAY: 682
 PULSE ENERGY: 0.7
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 22
 FINE GAIN: 15 %
 SCREEN RANGE: 0.5
 SCREEN DEPTH: 1.0 IN.
 T&R } OPERATION
] NORMAL }
 FREQUENCY: 2.5 MHZ
] NORMAL } DISPLAY
] RF }
 REP. RATE: 1K
 ZERO CONTROL: 0 0
 DAMPING: OFF
 GAIN: _____
 GATE: _____
 POLARITY: _____
 WIDTH: _____ %
 DELAY: _____
] NORMAL } ECHO START
] FIRST ECHO }

CALIBRATION BLOCK
 ID#: RTD-A376-.75
 LENGTH: 12 IN
 OD: 1.25 IN
 THICKNESS: .75 IN

CRYSTAL
 ID#: 84-88
 TYPE: RTD
 FREQ: 2 MHZ
 SIZE: 6X13 mm
 ACTUAL A: 7.3

CALIBRATION BLOCK SIMULATOR
 SERIAL NO. _____ SCREEN RANGE _____ IN.
 SIGNAL AMP _____ % SCREEN READING _____ IN.
 COURSE GAIN DB _____ FINE GAIN DB _____

SYSTEM CALIBRATION
 ANGLE 73° NODE Longitudinal

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES ± 0.01
1 LB NODE	100 %	0.3 SD. IN.
2 LB NODE	90 %	0.4 SD. IN.
3 LB NODE	70 %	0.5 SD. IN.
4 LB NODE	55 %	0.6 SD. IN.
5 LB NODE	40 %	0.7 SD. IN.
6 LB NODE	30 %	0.8 SD. IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR. CB*	%	IN.
BKR. P*	%	IN.

SEARCH UNIT CABLE
 TYPE DUAL LENGTH 6'
 CAL. BLOCK TEMP. _____ F°
 CAL. BLOCK SIMULATOR TEMP. _____ F°
 (REQUIRED SUMMER 75 FOR VESSELS
 REQUIRED WINTER 75 FOR PIPING)

FIGURE NO(S), EXAMINED

12-02-2-12		
12-02-2-17		
12-02-2-23		
12-02-2-64		
12-02-2-58		
12-02-2-75	N	N
12-02-2-81	A	A
N/A		

CALIBRATION CONFIRMATION

	TIME	1700 HRS.	HRS.	HRS.	HRS.	HRS.	HRS.	HRS.	HRS.	
BLOCK SIM.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
BACK REFL.	%	IN.	%	IN.	%	IN.	%	IN.	%	IN.
1 LB NODE	100 %	0.3 SD. IN.	%	IN.	%	IN.	%	IN.	%	IN.
3 LB NODE	80 %	0.5 SD. IN.	%	IN.	%	IN.	%	IN.	%	IN.
5 LB NODE	50 %	0.7 SD. IN.	%	IN.	%	IN.	%	IN.	%	IN.
INITIALS	Seabrook									

Ultrasonic Inspection Report

Page 1 of 3
No. JAF 10 1384-3
Date 10/13/84

Client: PASNY

Location: J. A. FITZPATRICK N.P.P.

System: Recirculation line

Weld Identification No.: 12-02-2-12

Inspected Area: whole circumference from pipe side, length evaluation of crack indications

Position of Weld Contour: NO WELD CONTOUR DONE

Reference Point Location: Top of pipe

Conclusion of Examination Results:

The found crack indications can be detected over the whole circumference (360 degrees) with short interruptions. Within these interruptions echo amplitudes do not drop below 20% DAC evaluated with SE II (mode conversion).
100% DAC = 10% ID NOTCH + 14dB

DR. SEYDEL/E Seydel

Responsible Inspector _____ Level _____ Signature: _____

William E. Stettin LEVEL II



UNITED STATES TESTING COMPANY, INC.

12-02-2-12

10/16/84
Date


RADIOGRAPHIC EXAMINATION REPORT

Customer NYPA
 Location JAFNPP
 Purchase order no. NYO 82-246
 Work request no. N/A
 Welder I. D. 7

R. T. Procedure/Rev REACTOR CONTROLS INC RTI
 Specimen Description WELD
 Material Type S/S
 Dia./Thickness 12.750 / .688
 Specimen I. D. RECIRC WELD 21B

Procedure Data

Gamma	X-Ray	Penetrameter Designation	<u>15F</u>
Source Type <u>IR¹⁹²</u>	Machine Mfg. <u>A</u>	Required Sensitivity/Essential Hole	<u>2/4T</u>
Curies <u>70</u>	Kilovoltage	Shim Thickness	<u>.093</u>
Physical Size <u>1/8 X 1/8</u>	Milliamperage	Pb Screens: Front <u>.010</u> Back <u>.010</u>	
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance	<u>12 3/4"</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness	<u>.010</u>
Film Size <u>4 1/2 X 17</u>	Total No. Film <u>8</u>	Exposure Time	<u>6 MIN</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrometer	Weld		
21B	0-10				✓	✓	✓	✓		ARTIFACTS	2.8	2.8-2.9	✓	
	10-20			1/4" X	✓	✓				"	2.8	2.7-2.9		✓
	20-30									"	2.8	2.6-2.9	✓	
	30-0									"	2.85	2.7-3.0	✓	

Acceptance Criteria: Code/Addenda/Class - ASME III 68

Remarks: COUNT BORE ≈ 3/4" from Q of weld

Radiographed By:

Interpreted By:

Customer Review

RKoynt II 10-16-84
Date

[Signature] III 10-17-84
Name Level Date

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J.A. Fitzpatrick
DATA SHEET NO. JAF-091/A DATE 10-13-54
PROCEDURE JAF-UTS-444/12 REV 3

COMPONENT OR SYSTEM Recirculation Loop "A" PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S), LISTED ON REVERSE SIDE - COMPONENT TEMP 122°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 120°F

SCAN COVERAGE

WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA


SEARCH UNIT

Manufacturer Aerotech
Style Gamma
Serial No. E14112
Size 0.5" Dia Frequency 2.25 MHz
Angle 62° Mode Shear
Couplant Ultragel II Batch No. 8439

INSTRUMENT

Manufacturer Krautkramer Branson Model USL-38
Serial No. 210571 Cable Length 6'
Frequency 2.5 MHz Reject OFF
Rep Rate N/A Damping OFF
dB Gain - Coarse 20 Fine 34
Primary Reference Response Amplitude % Full Screen Height 80% FSH

DAC PLOT - TIME 1530 AM, (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1910	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)

1. Thomas P. Rubin TC-1A LEVEL III
2. Robert B. Bump TC-1A LEVEL I
REVIEWED BY Arthur Smith II DATE 10/17/54

ADDITIONAL REMARKS

Supv. Subj. NPA III
10/17/54

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

SHEET 2 OF 4
 ITEM IDENTIFICATION 13-02-2-1
 CALIBRATION DATA SHEET NO. JAF-0914

DATA TABULATION

SCAN DIRECTION	INDICATION NO.	EXAM. ON (ADJ WELD) SIDE OF WELD	MAX % DAC	SWEEP READING	SEARCH POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE			STRAIGHT BEAM (CAL ON BACK REFLECTION)		
					EXIT POINT LOCATION (CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE) WELD %)	AXIAL (DISTANCE FROM WELD %)	MINIMUM SWEEP READING	S.U. POSITION	MAXIMUM SWEEP READING	S.U. POSITION	INDICATION AMPLITUDE (% FSH)	BACK REFLECTIVE AMPLITUDE (% FSH)
	1	ELBOW	50	3.2	0	.7						
	2	ELBOW	40	3.7	4CW	.7						
	3	ELBOW	25	4.6	7 5/8 CW	.8						
	4	ELBOW	25	4.4	8 1/2 CW	.85						
	5	ELBOW	30	4.8	4CW	1.0						
	6	ELBOW	25	3.5	2CW	.7						
	7	ELBOW	20	2.4	1 1/2 CW	.6						
	8	ELBOW	15	3.0	40CW	.6						
	9	ELBOW	40	3.8	3 3/8 CW	.6						
	10	ELBOW	30	2.2	35CW	.6						
	11	ELBOW	20	2.0	3 1/2 CW	.6						

NOTE: 25° TOWERS 0°

INDICATION NO.	LOCATION OF INDICATION		LENGTH	% I		WIDTH (IF LAMINAR)	COMMENTS
	CIRC	AXIAL		DEPTH (IF PLANAR)	DISTANCE FROM SURFACE		
						60°	ALL MEASUREMENTS TAKEN FROM TOE OF WELD TO INDEX POINT. Intermittent 360° in sections in base material

RESULTS

EXAMINER(S)

1. *Robert Bandy* TC-1A LEVEL III
 2. *Steve Smith III* TC-1A LEVEL I
 REVIEWED BY *Steve Smith III* DATE *10/1/84*

CONTINUATION ATTACHED - Yes No

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 4

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NYPA


PROJECT JA FITZPATRICK

Data Sheet # JAF-091A

SUBJECT 12-02-2-12 "A" Loop RECIRCULATION SYSTEM



WELD THICKNESS DATA SHEET



Transducer Size .50 Weld No. 12-02-2-12 System/Area REAR SAFE-END

Examiner [Signature] Level II Date 10-13-84

[Signature]

Weld 12-02-2-12

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
0.00	0.4000	0.3000	0.700
0.25	0.4000	0.3000	0.700
0.50	0.4000	0.3000	0.700
0.75	0.4000	0.3000	0.700
1.00	0.4000	0.3000	0.700
1.25	0.4000	0.3000	0.700
1.50	0.4000	0.3000	0.700
1.75	0.4000	0.3000	0.700
2.00	0.4000	0.3000	0.700
2.25	0.3500	0.3500	0.700
2.50	0.3000	0.4000	0.700
2.75	0.2500	0.4500	0.700
3.00	0.2000	0.5000	0.700
3.25	0.1330	0.5670	0.700
3.50	0.0660	0.6340	0.700
3.75	0.0000	0.7000	0.700
4.00	0.0500	0.6500	0.700
4.25	0.0625	0.6375	0.700
4.50	0.0750	0.6250	0.700
4.75	0.0875	0.6125	0.700
5.00	0.1000	0.6000	0.700
5.25	0.1500	0.5500	0.700
5.50	0.2000	0.5000	0.700
5.75	0.2500	0.4500	0.700
6.00	0.3000	0.4000	0.700
6.25	0.3250	0.3750	0.700
6.50	0.3500	0.3500	0.700
6.75	0.3750	0.3250	0.700
7.00	0.4000	0.3000	0.700
7.25	0.4250	0.2750	0.700
7.50	0.4500	0.2500	0.700
7.75	0.4750	0.2250	0.700
8.00	0.5000	0.2000	0.700
8.25	0.4625	0.2375	0.700
8.50	0.4250	0.2750	0.700
8.75	0.3875	0.3125	0.700
9.00	0.3500	0.3500	0.700
9.25	0.3125	0.3875	0.700
9.50	0.2750	0.4250	0.700
9.75	0.2375	0.4625	0.700
10.00	0.2000	0.5000	0.700
10.25	0.1875	0.5125	0.700
10.50	0.1750	0.5250	0.700
10.75	0.1625	0.5375	0.700
11.00	0.1500	0.5500	0.700
11.25	0.1250	0.5750	0.700
11.50	0.1000	0.6000	0.700
11.75	0.0750	0.6250	0.700
12.00	0.0500	0.6500	0.700
12.25	0.0575	0.6425	0.700

Weld 12-02-2-12

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
12.50	0.0650	0.6350	0.700
12.75	0.0725	0.6275	0.700
13.00	0.0800	0.6200	0.700
13.25	0.1100	0.5900	0.700
13.50	0.1400	0.5600	0.700
13.75	0.1700	0.5300	0.700
14.00	0.2000	0.5000	0.700
14.25	0.1625	0.5375	0.700
14.50	0.1250	0.5750	0.700
14.75	0.0875	0.6125	0.700
15.00	0.0500	0.6500	0.700
15.25	0.0750	0.6250	0.700
15.50	0.1000	0.6000	0.700
15.75	0.1250	0.5750	0.700
16.00	0.1500	0.5500	0.700
16.25	0.4000	0.3000	0.700
16.50	0.6500	0.0500	0.700
16.75	0.6500	0.0500	0.700
17.00	0.6500	0.0500	0.700
17.25	0.6500	0.0500	0.700
17.50	0.6500	0.0500	0.700
17.75	0.6500	0.0500	0.700
18.00	0.6500	0.0500	0.700
18.25	0.6500	0.0500	0.700
18.50	0.6500	0.0500	0.700
18.75	0.6500	0.0500	0.700
19.00	0.6500	0.0500	0.700
19.25	0.6500	0.0500	0.700
19.50	0.6500	0.0500	0.700
19.75	0.6500	0.0500	0.700
20.00	0.6500	0.0500	0.700
20.25	0.6500	0.0500	0.700
20.50	0.6500	0.0500	0.700
20.75	0.6500	0.0500	0.700
21.00	0.6500	0.0500	0.700
21.25	0.6500	0.0500	0.700
21.50	0.6500	0.0500	0.700
21.75	0.6500	0.0500	0.700
22.00	0.5000	0.2000	0.700
22.25	0.4500	0.2500	0.700
22.50	0.4000	0.3000	0.700
22.75	0.3500	0.3500	0.700
23.00	0.3000	0.4000	0.700
23.25	0.3000	0.4000	0.700
23.50	0.3000	0.4000	0.700
23.75	0.3000	0.4000	0.700
24.00	0.3000	0.4000	0.700
24.25	0.3000	0.4000	0.700
24.50	0.3000	0.4000	0.700
24.75	0.3000	0.4000	0.700

Weld 12-02-2-12

Reference Distance (Inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
25.00	0.3000	0.4000	0.700
25.25	0.3125	0.3875	0.700
25.50	0.3250	0.3750	0.700
25.75	0.3375	0.3625	0.700
26.00	0.3500	0.3500	0.700
26.25	0.3627	0.3373	0.700
26.50	0.3750	0.3250	0.700
26.75	0.3875	0.3125	0.700
27.00	0.4000	0.3000	0.700
27.25	0.4000	0.3000	0.700
27.50	0.4000	0.3000	0.700
27.75	0.4000	0.3000	0.700
28.00	0.4000	0.3000	0.700
28.25	0.4000	0.3000	0.700
28.50	0.4000	0.3000	0.700
28.75	0.4000	0.3000	0.700
29.00	0.4000	0.3000	0.700
29.25	0.4250	0.2750	0.700
29.50	0.4500	0.2500	0.700
29.75	0.4750	0.2250	0.700
30.00	0.5000	0.2000	0.700
30.25	0.4750	0.2250	0.700
30.50	0.4500	0.2500	0.700
30.75	0.4250	0.2750	0.700
31.00	0.4000	0.3000	0.700
31.25	0.3750	0.3250	0.700
31.50	0.3500	0.3500	0.700
31.75	0.3250	0.3750	0.700
32.00	0.3000	0.4000	0.700
32.25	0.3250	0.3750	0.700
32.50	0.3500	0.3500	0.700
32.75	0.3750	0.3250	0.700
33.00	0.4000	0.3000	0.700
33.25	0.4000	0.3000	0.700
33.50	0.4000	0.3000	0.700
33.75	0.4000	0.3000	0.700
34.00	0.4000	0.3000	0.700
34.25	0.4000	0.3000	0.700
34.50	0.4000	0.3000	0.700
34.75	0.4000	0.3000	0.700
35.00	0.4000	0.3000	0.700
35.25	0.4000	0.3000	0.700
35.50	0.4000	0.3000	0.700
35.75	0.4000	0.3000	0.700
36.00	0.4000	0.3000	0.700
36.25	0.4000	0.3000	0.700
36.50	0.4000	0.3000	0.700
36.75	0.4000	0.3000	0.700
37.00	0.4000	0.3000	0.700
37.25	0.4125	0.2875	0.700

Weld 12-02-2-12

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
37.50	0.4250	0.2750	0.700
37.75	0.4375	0.2625	0.700
38.00	0.4500	0.2500	0.700
38.25	0.4375	0.2625	0.700
38.50	0.4250	0.2750	0.700
38.75	0.4125	0.2875	0.700
39.00	0.4000	0.3000	0.700
39.25	0.4250	0.2750	0.700
39.50	0.4500	0.2500	0.700
39.75	0.4750	0.2250	0.700
40.00	0.5000	0.2000	0.700
40.25	0.4750	0.2250	0.700
40.50	0.4500	0.2500	0.700
40.75	0.4250	0.2750	0.700
41.00	0.4000	0.3000	0.700

Weld 12-02-2-17

HEET NO. JAF-PM-005 DATE: 10/15/84
 UNLBRATION SHELL TIME: 1100 HR
 INIT: JAFUP SYSTEM: 02-2/Raise COMPONENT: Piping welds
 EXAMINER: George Seckler ID# 51765 COUPLANT: AL79AG-6-2
 EXAMINER: AK ID# 14 COUPLANT ID#: 5443

INSTRUMENT: 210586 CALIBRATION BLOCK SIMULATOR
 LINEARITY CHECK YES NO SERIAL NO. _____ SCREEN RANGE _____
 REJECT: 0.5% % DB SIGNAL AMP _____ % SCREEN READING _____
 MAT'L. CAL: 182 COURSE GAIN DB 12 FINE GAIN DB _____
 DELAY: 678 SEARCH UNIT CABLE TYPE AWG 18 LENGTH 6'
 PULSE ENERGY: S.F.D. CAL. BLOCK TEMP. _____ F°
 COARSE GAIN V4 DB: 40 CAL. BLOCK SIMULATOR TEMP. _____ F°
 FINE GAIN IN DB: 12 (REQUIRED SUMMER 73 FOR VESSELS
 FINE GAIN: 10 % REQUIRED WINTER 76 FOR PIPING)

SYSTEM CALIBRATION ANGLE 45 ° NODE SCANS
 REFLECTOR AMPLITUDE % OF FULL SCREEN SCREEN READING IN INCHES

10" 18-NODE	100 ± %	50% ± 0.10 IN.
15" 18-NODE	100 ± %	60% ± 0.15 IN.
20" 18-NODE	100 ± %	40% ± 0.20 IN.
25" 18-NODE	100 ± %	40% ± 0.25 IN.
30" 18-NODE	100 ± %	30% ± 0.30 IN.
35" 18-NODE	100 ± %	25% ± 0.35 IN.

 TOP NOTCH _____ IN
 OPPOSITE NOTCH _____ IN
 BKR - CB _____ IN
 BKR - P _____ IN

FIGURE NO(S). EXAMINED

<u>12-02-2-12</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-17</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-23</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-64</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-58</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-75</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-81</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>

 CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	15" 18-NODE	25" 18-NODE	35" 18-NODE	INITIALS	HRS.	IN.	HRS.	IN.	HRS.	IN.	HRS.	IN.
<u>1400</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>

INSTRUMENT: 210586 CALIBRATION BLOCK SIMULATOR
 LINEARITY CHECK YES NO SERIAL NO. _____ SCREEN RANGE _____
 REJECT: 0.5% % DB SIGNAL AMP _____ % SCREEN READING _____
 MAT'L. CAL: 182 COURSE GAIN DB 12 FINE GAIN DB _____
 DELAY: 678 SEARCH UNIT CABLE TYPE AWG 18 LENGTH 6'
 PULSE ENERGY: S.F.D. CAL. BLOCK TEMP. _____ F°
 COARSE GAIN V4 DB: 40 CAL. BLOCK SIMULATOR TEMP. _____ F°
 FINE GAIN IN DB: 12 (REQUIRED SUMMER 73 FOR VESSELS
 FINE GAIN: 10 % REQUIRED WINTER 76 FOR PIPING)

FIGURE NO(S). EXAMINED

<u>12-02-2-12</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-17</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-23</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-64</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-58</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-75</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>
<u>12-02-2-81</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>

 CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	15" 18-NODE	25" 18-NODE	35" 18-NODE	INITIALS	HRS.	IN.	HRS.	IN.	HRS.	IN.	HRS.	IN.
<u>1400</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>	<u>AK</u>

DATE: 10/15/84

COMPONENT: PIPELINE WELDS

COUPLANT: GUTTERGLASS J

COUPLANT ID #: 8443

CALIBRATION BLOCK SIMULATOR

SERIAL NO. _____ SCREEN RANGE _____ IN.

SIGNAL AMP _____ % SCREEN READING _____ IN.

COURSE GAIN DB _____ FINE GAIN DB _____

SEARCH UNIT CABLE

TYPE DARK LENGTH 6'

CAL. BLOCK TEMP. _____ F°

CAL. BLOCK SIMULATOR TEMP. _____ F°

(REQUIRED SUMMER 73 FOR VESSEL, REQUIRED WINTER 75 FOR PIPING)

FIGURE NO(S), EXAMINED

12-02-2-12

12-02-2-17

14-02-2-13

11-02-2-64

12-02-2-58

12-02-2-75

12-02-2-81

N/A

N/A

N/A

N/A

N/A

N/A

N/A

CALIBRATION SHEET

TIME: 1100

SYSTEM: 02-2/BGR/KC

LEVEL: 500

LEVEL: 4

CRYSTAL

ID# 84-88

TYPE RTD

FREQ 2 MHZ

SIZE 6 X 13

ACTUAL 4

73

CALIBRATION BLOCK

ID# 870-A376-75

LENGTH: 12 IN

OD: 1.25 IN

THICKNESS: .75 IN

ANGLE 23°

MODE Large

INDICAL

SYSTEM CALIBRATION

REFLECTOR

AMPLITUDE % OF FULL SCREEN

SCREEN READING IN INCHES

1 LB NODE 100% 0.3 SD. IN.

2 LB NODE 90% 0.4 SD. IN.

3 LB NODE 70% 0.5 SD. IN.

4 LB NODE 55% 0.6 SD. IN.

SET NO: JAF-81-001

IT: JAFULLP

AMINER: George Sanders

AMINER: N/A

INSTRUMENT

210568

NEARITY CHECK YES NO

EJECT: OFF %DB

ATL. CAL: 866

ELAY: 882

ULSE ENERGY: 0.1

COURSE GAIN IN DB: 40

FINE GAIN IN DB: 22

THE GAIN: 15%

SCREEN RANGE: 0.5 IN.

SCREEN DEPTH: 6.0

FOR OPERATION

NORMAL RF DISPLAY

FREQUENCY: 2.5 MHZ

REP. RATE: 1K

ZERO CONTROL: 0

DAMPING: OFF

GAIN: _____ DAC _____

POLARITY: _____ GATE _____ %

WIDTH: _____

DELAY: _____

NORMAL ECHO START


FIRST ECHO

CALIBRATION CONFIRMATION

TIME	BKR CB (BACK REFLECTION FROM CAL. BLOCK)		BKR P (BACK REFLECTION FROM PART)		DATE REVIEWED	
	HRS.	%	HRS.	%	DATE	REVIEWED
BLOCK SIM.	1700	%	IN.	%		
BACK REFL.	%	IN.	IN.	%		
1 LB-NODE	100%	0.3 SD. IN.	IN.	%		
3 LB-NODE	80%	0.5 SD. IN.	IN.	%		
5 LB-NODE	50%	0.7 SD. IN.	IN.	%		
INITIALS	[Signature]		[Signature]			

8K-JAF-81-011

0.00 4.00 8.00 12.00 16.00 20.00 24.00 28.00 32.00 36.00 40.00
Standard Reference Distance (mm)



WORLD NATIONALITY... SOUL PIOT

Weld 12-02-2-17

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
0.00	0.6500	0.0500	0.700
0.25	0.6375	0.0625	0.700
0.50	0.6250	0.0750	0.700
0.75	0.6125	0.0875	0.700
1.00	0.6000	0.1000	0.700
1.25	0.5950	0.1050	0.700
1.50	0.5900	0.1100	0.700
1.75	0.5850	0.1150	0.700
2.00	0.5800	0.1200	0.700
2.25	0.5850	0.1150	0.700
2.50	0.5900	0.1100	0.700
2.75	0.5950	0.1050	0.700
3.00	0.6000	0.1000	0.700
3.25	0.6125	0.0875	0.700
3.50	0.6250	0.0750	0.700
3.75	0.6375	0.0625	0.700
4.00	0.6500	0.0500	0.700
4.25	0.6500	0.0500	0.700
4.50	0.6500	0.0500	0.700
4.75	0.6500	0.0500	0.700
5.00	0.6500	0.0500	0.700
5.25	0.6500	0.0500	0.700
5.50	0.6500	0.0500	0.700
5.75	0.6500	0.0500	0.700
6.00	0.6500	0.0500	0.700
6.25	0.6500	0.0500	0.700
6.50	0.6500	0.0500	0.700
6.75	0.6500	0.0500	0.700
7.00	0.6500	0.0500	0.700
7.25	0.6500	0.0500	0.700
7.50	0.6500	0.0500	0.700
7.75	0.6500	0.0500	0.700
8.00	0.6500	0.0500	0.700
8.25	0.6500	0.0500	0.700
8.50	0.6500	0.0500	0.700
8.75	0.6500	0.0500	0.700
9.00	0.6500	0.0500	0.700
9.25	0.6500	0.0500	0.700
9.50	0.6500	0.0500	0.700
9.75	0.6500	0.0500	0.700
10.00	0.6500	0.0500	0.700
10.25	0.6500	0.0500	0.700
10.50	0.6500	0.0500	0.700
10.75	0.6500	0.0500	0.700
11.00	0.6500	0.0500	0.700
11.25	0.6375	0.0625	0.700
11.50	0.6250	0.0750	0.700
11.75	0.6125	0.0875	0.700
12.00	0.6000	0.1000	0.700
12.25	0.5950	0.1050	0.700

Weld 12-02-2-17

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
12.50	0.5900	0.1100	0.700
12.75	0.5850	0.1150	0.700
13.00	0.5800	0.1200	0.700
13.25	0.5900	0.1100	0.700
13.50	0.6000	0.1000	0.700
13.75	0.6100	0.0900	0.700
14.00	0.6200	0.0800	0.700
14.25	0.6275	0.0725	0.700
14.50	0.6350	0.0650	0.700
14.75	0.6425	0.0575	0.700
15.00	0.6500	0.0500	0.700
15.25	0.6500	0.0500	0.700
15.50	0.6500	0.0500	0.700
15.75	0.6500	0.0500	0.700
16.00	0.6500	0.0500	0.700
16.25	0.6500	0.0500	0.700
16.50	0.6500	0.0500	0.700
16.75	0.6500	0.0500	0.700
17.00	0.6500	0.0500	0.700
17.25	0.6500	0.0500	0.700
17.50	0.6500	0.0500	0.700
17.75	0.6500	0.0500	0.700
18.00	0.6500	0.0500	0.700
18.25	0.6500	0.0500	0.700
18.50	0.6500	0.0500	0.700
18.75	0.6500	0.0500	0.700
19.00	0.6500	0.0500	0.700
19.25	0.6500	0.0500	0.700
19.50	0.6500	0.0500	0.700
19.75	0.6500	0.0500	0.700
20.00	0.6500	0.0500	0.700
20.25	0.6500	0.0500	0.700
20.50	0.6500	0.0500	0.700
20.75	0.6500	0.0500	0.700
21.00	0.6500	0.0500	0.700
21.25	0.6500	0.0500	0.700
21.50	0.6500	0.0500	0.700
21.75	0.6500	0.0500	0.700
22.00	0.6500	0.0500	0.700
22.25	0.6500	0.0500	0.700
22.50	0.6500	0.0500	0.700
22.75	0.6500	0.0500	0.700
23.00	0.6500	0.0500	0.700
23.25	0.6500	0.0500	0.700
23.50	0.6500	0.0500	0.700
23.75	0.6500	0.0500	0.700
24.00	0.6500	0.0500	0.700
24.25	0.6500	0.0500	0.700
24.50	0.6500	0.0500	0.700
24.75	0.6500	0.0500	0.700

Weld 12-02-2-17

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
25.00	0.6500	0.0500	0.700
25.25	0.6500	0.0500	0.700
25.50	0.6500	0.0500	0.700
25.75	0.6500	0.0500	0.700
26.00	0.6500	0.0500	0.700
26.25	0.6500	0.0500	0.700
26.50	0.6500	0.0500	0.700
26.75	0.6500	0.0500	0.700
27.00	0.6500	0.0500	0.700
27.25	0.6500	0.0500	0.700
27.50	0.6500	0.0500	0.700
27.75	0.6500	0.0500	0.700
28.00	0.6500	0.0500	0.700
28.25	0.6500	0.0500	0.700
28.50	0.6500	0.0500	0.700
28.75	0.6500	0.0500	0.700
29.00	0.6500	0.0500	0.700
29.25	0.6500	0.0500	0.700
29.50	0.6500	0.0500	0.700
29.75	0.6500	0.0500	0.700
30.00	0.6500	0.0500	0.700
30.25	0.6500	0.0500	0.700
30.50	0.6500	0.0500	0.700
30.75	0.6500	0.0500	0.700
31.00	0.6500	0.0500	0.700
31.25	0.6500	0.0500	0.700
31.50	0.6500	0.0500	0.700
31.75	0.6500	0.0500	0.700
32.00	0.6500	0.0500	0.700
32.25	0.6500	0.0500	0.700
32.50	0.6500	0.0500	0.700
32.75	0.6500	0.0500	0.700
33.00	0.6500	0.0500	0.700
33.25	0.6500	0.0500	0.700
33.50	0.6500	0.0500	0.700
33.75	0.6500	0.0500	0.700
34.00	0.6500	0.0500	0.700
34.25	0.6500	0.0500	0.700
34.50	0.6500	0.0500	0.700
34.75	0.6500	0.0500	0.700
35.00	0.6500	0.0500	0.700
35.25	0.6500	0.0500	0.700
35.50	0.6500	0.0500	0.700
35.75	0.6500	0.0500	0.700
36.00	0.6500	0.0500	0.700
36.25	0.6500	0.0500	0.700
36.50	0.6500	0.0500	0.700
36.75	0.6500	0.0500	0.700
37.00	0.6500	0.0500	0.700
37.25	0.6500	0.0500	0.700

Weld 12-02-2-17

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
37.50	0.6500	0.0500	0.700
37.75	0.6500	0.0500	0.700
38.00	0.6500	0.0500	0.700
38.25	0.6500	0.0500	0.700
38.50	0.6500	0.0500	0.700
38.75	0.6500	0.0500	0.700
39.00	0.6500	0.0500	0.700
39.25	0.6500	0.0500	0.700
39.50	0.6500	0.0500	0.700
39.75	0.6500	0.0500	0.700
40.00	0.6500	0.0500	0.700
40.25	0.6500	0.0500	0.700
40.50	0.6500	0.0500	0.700
40.75	0.6500	0.0500	0.700
41.00	0.6500	0.0500	0.700



REPORT OF UT INSPECTION

PAGE 1 OF 6
REPORT NO. JAF101684-
DATE 10-16-84

CLIENT New York Power Authority
LOCATION James A. Fitzpatrick

WELD IDENTIFICATION NO. 12-02-2-17 DRAWING NO. N.17.
TYPE OF WELDING PIPE TO SAFE END MATERIAL: BASE SS WELD SS
SIZE OF PIPE 12" O.D. INCHES WALL THICKNESS _____ INCHES
SURFACE CONDITION OF PIPE ground OF WELD ground
WELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 125 °C
METHOD OF EXAMINATION: AUTOMATIC ÷ MANUAL X SEMI-AUTO ÷
UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes
form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60		SBI SLIC 40	SUSI SUS 428	KK MWB 70
SERIAL NO.	1.03	V#3	V#3				
TRANSDUCER SIZE (MM) (INCHES)	8x9	8x9	8x9		2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	61°/32°	44°	57°				
EXIT POINT (MM) (INCHES)	12/10	13	13				
REMARKS:	mode-conversion	shear	shear		long-shear	shear	shear

EQUIPMENT MODEL NO.
SERIAL NUMBER
CALIBRATION DATE
CABLE TYPE
CABLE LENGTH

AUTOMATIC	MANUAL
	KK USK 7
	27274-2606
	08-23-84
	COAXIAL
	2m

COUPLING ULTRAGEL II
MFG. TECHNICARE-ECHO, Inc
B. ACCT. NO. # 8443

PERSONNEL PERFORMING EXAMINATION :

NAME <u>U. SCHWANKE</u>	LEVEL <u>II</u>	SIGNATURE <u>[Signature]</u>
NAME <u>H.-P. THEELEN</u>	LEVEL <u>II</u>	SIGNATURE <u>[Signature]</u>
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF101684-3
 DATE 10-16-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	40	34	30	25	20	15	10	÷

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 ± 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1763-8284



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A 376-.66

DRAWING NUMBER n.a.

MATERIAL SS 304


REFERENCE REFLECTORS 10% NOTCH ID

REFERENCE REFLECTORS EDGE ID

REFERENCE REFLECTORS BACKWALL

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM)(INCHES)

RECHECK DATA

CAL. BLOCK ÷ S/N ÷ REF. REFL. ÷ TEMP. ÷ °F

REF. BLOCK 12 A 376-.66 S/N ÷ REF. REFL. 10% 74 ID TEMP. 115 °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
<u>U. SCHWANKE</u>	<u>13:30</u>	<u>SE 2 48 dB 80% FSH</u>	<u>3.6</u>
<u>U. SCHWANKE</u>	<u>17:00</u>	<u>SE 2 48 dB 80% FSH</u>	<u>7.2</u>

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 6
 REPORT NO. JAF101684-3
 DATE 10-16-84




DAC DATA

PROBE NO.	REFERENCE REFLECTOR	METAL PATH (MM)	AMPLITUDE (DB)	CALIBRATION BLOCK NO.	REMARKS
1	10% NOTCH ID	36	48	12-A376-.66	SE 2
	EDGE ID	37	42	-4-	SE 2
	BACKWALL	34	48	-4-	SE 1
2	10% NOTCH ID	22	26	12-A376-.66	1/2 V-PATH
	10% NOTCH OD	45	32	-4-	2/2 V-PATH
	10% NOTCH ID	69	34	-4-	3/2 V-PATH
3	10% NOTCH ID	28	40	12-A376-.66	1/2 V-PATH
4					
5					
6					



REFERENCE POINT LOCATION Top of Pipe & WCL

EXAM NO.	PROBE NO.	IND NO.	REFLECTOR POSITION/MM				Z DEPTH POS. FROM SURFACE % OF 'T'	EVALUATION % OF 'T'		ECHO HEIGHT DIFF. dB	METAL PATH MM
			Y LINEAR EXTEND FROM REFERENCE CW	X LINEAR EXTEND FROM WELD CT LINE	CLASS	SIZ.		START	END		
1	1	1	START 275	END 315	AT MAX 10	-	<10%	-	-16	42	



EXAMINER SCHWANKE LEVEL I
 SIGNATURE [Signature]
 AUTHORIZED INSPECTOR [Signature]
 CLIENT [Signature] (IF REQUIRED) [Signature] (IF REQUIRED)




UT-INSPECTION - IGSCC -
 Weld Identification No. 12-02-2-17
 Ind. Section No. 1
 Coordinate from reference point "y" 280 mm CW

Probes Used	Probe No.	Signal No.
Wall Thickness	MSEB 4H	
Root Center	MSEB 4H	
Other Data	1	1, 2
	2	3
	3	4

INSPECTION CONTOUR

MM ← 0 → MM
 WCL



+120 +110 100 +90 +80 +70 +60 +50 +40 +30 +20 +10 0 -10 -20 -30 -40 -50 -60 -70 -80 -90 -100 -110 -120

76 72 69 64 60 56 52 48 44 40 36 32 28 24 20 16 12 8 4 0 -4 -6 -8 -12 -16 -20 -24 -28 -32 -36 -40 -44 -48 -52 -56 -60 -64 -68 -72

INSPECTOR H. SCHWANKE Level I

DATE 10-16-84

WCL
 INCHES
 1/16"



UNITED STATES TESTING COMPANY, INC.

12-02-2-17


10/16/84
Date

RADIOGRAPHIC EXAMINATION REPORT

Customer <u>NYPA</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS INC. RT1</u>
Location <u>JAFNPP</u>	Specimen Description <u>WELD</u>
Purchase order no. <u>NYO 82-246</u>	Material Type <u>S/S</u>
Work request no. <u>N/A</u>	Dia./Thickness <u>12.750 / .668</u>
Welder I. D. <u>7+8</u>	Specimen I. D. <u>RECIRC WELD 17B</u>

Procedure Data

Gamma	X-Ray <u>IA</u>	Penetrameter Designation <u>15 F</u>
Source Type <u>IR¹⁹²</u>	Machine Mfg. <u>IA</u>	Required Sensitivity/Essential Hole <u>2/4T</u>
Curies <u>9.5</u>	Kilovoltage	Shim Thickness <u>.063</u>
Physical Size <u>1/8 X 1/8</u>	Milliamperage	Pb Screens: Front <u>.010</u> Back <u>.010</u>
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance <u>12 3/4</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness <u>.010</u>
Film Size <u>4 1/2 X 17</u>	Total No. Film <u>8</u>	Exposure Time <u>4 1/2 MIN</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrometer	Weld		
17B	0-10					✓		✓	✓	ARTIFACTS	2.65	2.3-2.5	✓	
	10-20					✓		✓	✓	ARTIFACTS	2.77	2.7-3.0	✓	
	20-30				✓	✓		✓	✓	ARTIFACTS	2.66	2.5-2.7	✓	
	30-0						✓	✓	✓	ARTIFACTS	2.7	2.4-2.7	✓	

Acceptance Criteria: Code/Addenda/Class - ASME III 68

Remarks: COUNTER BORE ≈ 3/4" FROM C of WELD

Radiographed By:

Interpreted By:

Customer Review

R. Krom II 10-16-84
Date

ML II 10-17-84
Name Level Date

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT JA FITZPATRICK
DATA SHEET NO. JAF-095/A DATE 10-12-84
PROCEDURE JAF-UT-5 ADD 1/2 REV 3

COMPONENT OR SYSTEM "A" LOOP RECIRCULATION PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 127°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 105°F

SCAN COVERAGE


WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT
Manufacturer KB AEROTECH
Style GAMMA
Serial No. E14H2
Size 0.50" Frequency 2.25 MHz
Angle 62.5° Mode SHEAR
Couplant ULTRAGEL II Batch No. 8439

INSTRUMENT
Manufacturer KRAUTKRAMER-BRANSON Model USL-38
Serial No. 210571 Cable Length 6'
Frequency 2.25 MHz Reject NA
Rep Rate NA Damping NA
dB Gain - Coarse 20 Fine 34
Primary Reference Response Amplitude % Full Screen Height 80%

DAC PLOT - TIME 1635 AM, (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
<u>2030</u>	<input checked="" type="checkbox"/>	<u>NA</u>	<input checked="" type="checkbox"/>	<u>NA</u>
	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)

Thomas P. [Signature] TC-1A LEVEL III
2. John W. [Signature] TC-1A LEVEL I
REVIEWED BY [Signature] DATE 10/17

ADDITIONAL REMARKS

3/4 T-3.9 @ 80% @ 54 dB
ID -52 @ 2 1/2" SCREEN

[Signature] 10/17/84

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 4

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NYPA

PROJECT JA. FITZPATRICK

Data Sheet # JAF-095/H

SUBJECT 12-02-2-17 RECIRCULATION SYSTEM "A" LOOP



12-02-2-17

Weld 12-02-2-23

SHEET NO. JAF-81-005 DATE: 10/15/84
 INIT: JAFsupp COMPONENT: Piping, welds
 EXAMINER: George Sedore COUPLANT: ACRAGEL II
 EXAMINER: af COUPLANT ID #: 5443
 SYSTEM: 02-2/Rain LEVEL: III
 ID #: 51765 LEVEL: 1A

CALIBRATION BLOCK ID #: CTD-A376-25 SERIAL NO. _____
 LENGTH: _____ IN. TYPE: CRYSTAL SCREEN RANGE _____
 OD: _____ IN. SIZE: 2mm MHZ _____
 THICKNESS: _____ IN. ACTUAL: 45.0 FINE GAIN DB _____
 REJECT: ATS %DB _____
 MAT'L. CAL.: 182
 DELAY: 678
 PULSE ENERGY: S.F.A.
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 12
 FINE GAIN: 10 %
 SCREEN RANGE: 2.5
 SCREEN DEPTH: 1.0 IN.

SYSTEM CALIBRATION
 ANGLE 45 ° NODE schems
 SEARCH UNIT CABLE TYPE Buchter LENGTH 6'
 CAL. BLOCK TEMP. _____ F°
 CAL. BLOCK SIMULATOR TEMP. 1A F°
 (REQUIRED SUMMER 75 FOR VESSELS
 REQUIRED WINTER 75 FOR PIPING)

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES
<u>10" 18-NODE</u>	<u>100+</u> %	<u>50% ± 10</u> IN.
<u>15" 18-NODE</u>	<u>100+</u> %	<u>60% ± 15</u> IN.
<u>20" 18-NODE</u>	<u>100+</u> %	<u>40% ± 20</u> IN.
<u>25" 18-NODE</u>	<u>100+</u> %	<u>40% ± 25</u> IN.
<u>30" 18-NODE</u>	<u>100+</u> %	<u>30% ± 30</u> IN.
<u>35" 18-NODE</u>	<u>100+</u> %	<u>25% ± 35</u> IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR. CB	%	IN.
BKR. P	%	IN.

FIGURE NO(S), EXAMINED

<u>12-02-2-12</u>	<u>12-02-2-17</u>	<u>12-02-2-23</u>	<u>12-02-2-64</u>	<u>12-02-2-58</u>	<u>12-02-2-75</u>	<u>12-02-2-81</u>
<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>

CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	15" 18-NODE	25" 18-NODE	35" 18-NODE	INITIALS
<u>1400</u>	%	%	100%	100%	100%	<u>af</u>
	IN.	IN.	IN.	IN.	IN.	
	%	%	%	%	%	
	IN.	IN.	IN.	IN.	IN.	
	%	%	%	%	%	
	IN.	IN.	IN.	IN.	IN.	
	%	%	%	%	%	
	IN.	IN.	IN.	IN.	IN.	
	%	%	%	%	%	
	IN.	IN.	IN.	IN.	IN.	


*BKR CB (BACK REFLECTION FROM CAL. BLOCK) *BKR P (BACK REFLECTION FROM PART)
 REVIEWED BY _____ LEVEL _____ DATE REVIEWED _____
 SK-JAF-81-011

CALIBRATION SHEET

EET NO. JAF 81-009

DATE: 10/15/84

IT: JAFUFP
 AMINER: George Sander
 AMINER: *[Signature]*
 SYSTEM: 02-2/REGIRS
 ID#: S-1765
 ID#: *[Signature]*
 LEVEL: 50
 LEVEL: 74
 COMPONENT: PIPE WELDS
 COUPLANT: ALTAARCEL II
 COUPLANT ID#: 8443

INSTRUMENT: 210588
 NEARITY CHECK: YES NO
 EJECT: OFF
 ATT. CAL: 965
 ELAY: 082
 ULSE ENERGY: 0.7
 COURSE GAIN IN DB: 40
 FINE GAIN IN DB: 22
 INE GAIN: 15
 SCREEN RANGE: 0.5
 SCREEN DEPTH: 6.0
 OPERATION: NORMAL
 FREQUENCY: 2.5 MHz
 DISPLAY: 
 REP. RATE: 18
 ZERO CONTROL: 0
 DAMPING: OFF
 GAIN: _____
 DLY: _____
 SLP: _____
 POLARITY: _____
 WIDTH: _____
 DELAY: _____
 ECHO START: _____
 FIRST ECHO: _____

CRYSTAL: 84-88
 ID#: R70-A376-15
 TYPE: R70
 FREQ: 2 MHz
 SIZE: 6 X 13 MM
 ACTUAL: 73
 THICKNESS: 75
 CALIBRATION BLOCK SIMULATOR
 SERIAL NO.: _____
 SCREEN RANGE: _____ IN.
 SIGNAL AMP: _____ % SCREEN READING
 COURSE GAIN DB: _____
 FINE GAIN DB: _____

SYSTEM CALIBRATION
 ANGLE 73 ° NODE Large Technical

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES	IN.
0.1 1B-NODE	100 %	0.3 SP. IN.	
0.2 1B-NODE	90 %	0.4 SP. IN.	
0.3 1B-NODE	70 %	0.5 SP. IN.	
0.4 1B-NODE	55 %	0.6 SP. IN.	
0.5 1B-NODE	40 %	0.7 SP. IN.	
0.6 1B-NODE	30 %	0.8 SP. IN.	
TOP NOTCH	%		
OPPOSITE NOTCH	%		
BKR. CB	%		
BKR. P	%		

SEARCH UNIT CABLE
 TYPE: DIAL
 LENGTH: 6'
 CAL. BLOCK TEMP. F°
 CAL. BLOCK SIMULATOR TEMP. F°
 (REQUIRED SUMMER 78 FOR VESSELS
 REQUIRED WINTER 75 FOR PIPING)

FIGURE NO(S), EXAMINED

12-02-2-12							
12-02-2-17							
12-02-2-23							
12-02-2-67							
12-02-2-58							
12-02-2-75							
12-02-2-87							

CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	1B-NODE	3B-NODE	5B-NODE	INITIALS	HRS.	HRS.	HRS.	HRS.	HRS.	HR
1700	%	%	100 %	80 %	50 %	<i>[Signature]</i>	IN.	IN.	IN.	IN.	IN.	%
	%	%	100 %	80 %	50 %		IN.	IN.	IN.	IN.	IN.	%
	%	%	100 %	80 %	50 %		IN.	IN.	IN.	IN.	IN.	%
	%	%	100 %	80 %	50 %		IN.	IN.	IN.	IN.	IN.	%
	%	%	100 %	80 %	50 %		IN.	IN.	IN.	IN.	IN.	%



REPORT OF UT INSPECTION

PAGE 1 OF 0REPORT NO. JAF 101584-1CLIENT New York Power AuthorityDATE 10-13-84LOCATION James A. FitzpatrickWELD IDENTIFICATION NO. 12-02-2-23 DRAWING NO. N.A.TYPE OF WELDING PIPE TO SAFEND MATERIAL: BASE SS WELD SSSIZE OF PIPE 12" O.D. INCHES WALL THICKNESS .65 INCHESSURFACE CONDITION OF PIPE ground OF WELD groundWELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 100 °FMETHOD OF EXAMINATION: AUTOMATIC - MANUAL X SEMI-AUTO -UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes

form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 46	KK MWB 60	RTD SEL 70	SRI SLIC 40	SUSI SUS 428	KK MWB 70
SERIAL NO.	# 7		V # 2	80-580			
TRANSDUCER SIZE (MM) (+INCHES)	8x9	8x9	8x9	2x7x15	2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	60°/32°		57°	70			
EXIT POINT (MM) (+INCHES)	12/10		13	9			
REMARKS:	mode-conversion	shear	shear	high-long-mode	long-shear	shear	shear

EQUIPMENT MODEL NO.

SERIAL NUMBER

CALIBRATION DATE

CABLE TYPE

CABLE LENGTH

AUTOMATIC

MANUAL

	KK USK 7
	27274-2613
	09-10-84
	coaxial
	2w

COUPLING ULTRAGEL IIMFG. TECHNICARE-ECHO, Inc.B. ACCT. NO. # 8330

PERSONNEL PERFORMING EXAMINATION:

NAME M. DALICHOV LEVEL II SIGNATURE [Signature]NAME U. Horsthemke LEVEL I SIGNATURE [Signature]

NAME _____ LEVEL _____ SIGNATURE _____

NAME _____ LEVEL _____ SIGNATURE _____

NAME _____ LEVEL _____ SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF 101584-1
 DATE 10-13-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	40	35	30	25	20	15	10	÷

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 ± 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	40%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1776-091084



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A376-.66

DRAWING NUMBER n.a.

MATERIAL SS 304


REFERENCE REFLECTORS 10% NOTCH ID

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM) (INCHES)

RECHECK DATA

CAL. BLOCK 12-A 376-.66 S/N ✓ REF. REFL. 10% NOTCH ID TEMP. 110 °F

REF. BLOCK ✓ S/N ✓ REF. REFL. ✓ TEMP. ✓ °F

THERMOMETER SERIAL NO. UTL 010


NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
<u>JALICHOW</u>	<u>16:00</u>	<u>SE 2 46 dB 80% FSH</u>	<u>3.7</u>
<u>JALICHOW</u>	<u>19:30</u>	<u>SE 7 46 dB 80% FSH</u>	<u>3.7</u>



REFERENCE POINT LOCATION TOP OF THE PIPE

EXAM NO.	PROBE NO.	IND NO.	Y LINEAR EXTEND FROM REFERENCE			X LINEAR EXTEND FROM WELD CT LINE			Z DEPTH POS. FROM SURFACE % OF 'T'			EVALUATION % OF 'T'		ECLD HEIGHT DIFF. dB	METAL PATH MM
			START	AT MAX	END	START	AT MAX	END	START	END	CLASS	SIZ.			
1	1	1	0	20	60	±	-15	÷	÷	÷	>50%	÷	-6	42	
1	3	1	0	20	40	±	-15	÷	÷	÷	>50%	÷	±0	28	
1	4	1	5	20	40	±	-19	÷	÷	÷	75%	÷	÷	DEPTH 4 mm to 16.0D	
1	1	1	15	20	55	±	-18	÷	÷	÷	>50%	÷	-8	40	
7	1	1	÷	20	÷	BUTTED UP	-21	÷	÷	÷	>50%	÷	-6	42	
			SKEW ANGLE EXAM 7			10°	70 WCL								

SE2
SE1
SE2





EXAMINER DALCHOW / HORSTHEMKE LEVEL II
 SIGNATURE [Signature]
 AUTHORIZED INSPECTOR [Signature] (IF REQUIRED)
 CLIENT [Signature] (IF REQUIRED)



DATA STANDARD REPORT OF INDICATION NUMBER 1

SIGNAL NO.	PROBE NO.	ANGLE OF INCIDENT	EXAM NO.	EXIT X	POINT Y	GAIN DB 100% DAC	METAL PATH	REMARKS
1	1	32°	1	30	20	52	42	SE2
2	1	32°-70-70	1	41	20	54	40	SE1 } 75% CRACK
3	3	56°	1	38	20	40	28	
4	4	70°	1	34	20	68	4 mm J57TH 2D	



EXAMINER JALICHOW/MORITHEKUS LEVEL II
 LAJEC III
 REVIEWED BY William E. Duff DATE 10-15-84
 AUTHORIZED INSPECTOR _____


* THE ABOVE GRAPH REPRESENTS THE POSITION OF THE DEFECT IN RELATIONSHIP TO THE WELD CENTERLINE.




INSPECTION -IGSCC-
 Weld Identification No 12-02-2-23
 Indication No INDICATION NR 1
 Coordinate from reference point "Y" 20 mm CW

Probes Used	Probe No.	Signal No.
Wall Thickness	MSEB 4H	÷
Root Center	MSEB 4H	÷
Other Data	1	1, 2
	3	3
	4	4

INSPECTION CONTOUR



INSPECTOR DALICHOW / Horstheuer Level II
 DATE 10-13-84



Report No. JAF 10584-1 page 6 of 6

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 CALIBRATION DATA

PROJECT JAF, ISI OUTAGE
 DATA SHEET NO. JAF-085/A DATE 10/12/84
 PROCEDURE JAF UTS Add 1 & 2 REV 3

COMPONENT OR SYSTEM Recirculation System Loop "A" PIPE OD (IF APPLICABLE) 12"
 ITEM IDENTIFICATION NO(S), LISTED ON REVERSE SIDE - COMPONENT TEMP 120°F
 CALIBRATION BLOCK NO. R-A376 THICKNESS .66 TEMP 110°F

SCAN COVERAGE

$\frac{1}{8}$ ° WHAZ $\frac{1}{8}$ ° BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA


SEARCH UNIT
 Manufacturer NORTEC
 Style ZT-2
 Serial No. 15462
 Size .50" Frequency 2.25 MHZ
 Angle 43° Mode SHEAR

INSTRUMENT
 Manufacturer KRAUT KRAMER Model USK-7
 Serial No. 27276-1534 Cable Length 6'
 Frequency BB Reject min
 Rep Rate N/A Damping N/A
 dB Gain - Coarse 20 Fine 20

Couplant ULTRAGE II Batch No. 8439

Primary Reference Response Amplitude % Full Screen Height 80%

DAC PLOT - TIME 8:00 AM, PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1145	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)
 1. [Signature] TC-1A LEVEL II
[Signature] TC-1A LEVEL I
 REVIEWED BY [Signature] DATE 10/17/84

ADDITIONAL REMARKS ID. 3.6
3/4T - 2.6 80%
1/4T - 4.6 62%

[Signature] 10/17/84 4 T&P 10-15-1056

EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
INDICATION DATA

SHEET 2 OF 4

ITEM IDENTIFICATION 12-02-2-23

CALIBRATION DATA SHEET NO. JAF-085/A

DATA TABULATION

ST. BEAM	DIRECTION	INDICATION NO.		EXAM. ON (ADJ WELD) SIDE OF WELD	MAX % DAC	SWEEP READING	SEARCH POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE			STRAIGHT BEAM (CAL ON BACK REFLECTION)	
		CIRCUMFERENTIAL	AXIAL				CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD ξ)	SWEAP READING	MINIMUM S.U. POSITION	S.U. POSITION	INDICATION AMPLITUDE (% FSH)	BACK REFLECTION AMPLITUDE (% FSH)
		✓	1	PIPE SIDE	100	3.4	2" CW	.8	3.2	.65	4.0	1.0	Also TRANSVERSE 70% DAC
		✓	2	PIPE SIDE	100	4.2	3 1/2" CW	.7	4.2	.7	4.6	1.2	
		✓	3	PIPE SIDE	60	3.7	2 1/2" CW	.9	3.4	.7	4.2	1.1	

INDICATION NO.	LOCATION OF INDICATION		LENGTH	DEPTH (IF PLANAR)	% I	DISTANCE FROM SURFACE	WIDTH (IF LAMINAR)	COMMENTS
	CIRC	AXIAL						
								90-12-N 43° 42 63 1/2° PERMITTED 360°

RESULTS

EXAMINER J. J. Canygo TC-1A LEVEL II

REVIEWED BY John R. O'Neil TC-1A LEVEL F

DATE 10/17/84

CONTINUATION ATTACHED - Yes No

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 4

CHKD. BY _____ DATE _____

OFS NO. _____ DEPT. NO. _____


CLIENT NYPA

PROJECT J.A. Fitzpatrick

Data Sheet # JAF-085/A

SUBJECT 12-02-2-23

"A" Loop RECIRCULATION SYSTEM




12-02-2-23

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING

WELD THICKNESS DATA SHEET

Data Sheet # JAF-C85/A



Transducer Size .50 Weld No. 12-02-2-23 System/Area REGIAC SAFE-ENDS

Examiner J. Conroy Level II Date 10-13-84

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J.A. Fitzpatrick
DATA SHEET NO. JAF-C86/A DATE 10-16-8
PROCEDURE JAF-UT-5 Add 1+2 REV 3

COMPONENT OR SYSTEM Recirculation Loop "A" PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 115°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 120°F

SCAN COVERAGE

WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT

Manufacturer KB AEGOTECH
Style GAMMA
Serial No. E14112
Size 0.5" DIA Frequency 2.25 MHz
Angle 62° Mode SHEAR


INSTRUMENT

Manufacturer KRAUTKRAMER BRANSON Model USL-38
Serial No. 210571 Cable Length 6'
Frequency 2.5 MHz Reject OFF
Rep Rate N/A Damping OFF
dB Gain - Coarse 20 Fine 34

Couplant ULTRAGEL II Batch No. 8439

Primary Reference Response Amplitude % Full Screen Height 80% FSH

DAC PLOT - TIME 1200 AM PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1335	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)

1. Thomas P. [Signature] TC-1A LEVEL III
2. Robert [Signature] TC-1A LEVEL I
REVIEWED BY [Signature] DATE 10/17/8

ADDITIONAL REMARKS

George J. [Signature] N48A III 10/17/8

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

TCF 10-16-84
 SHEET 2 OF 4

ITEM IDENTIFICATION 12-02-2-23

CALIBRATION DATA SHEET NO. JAF-086/A

DATA TABULATION

ST. BEAM	SCAN DIRECTION		INDI- CA- TION NO.	EXAM. ON (ADJ WELD) SIDE OF WELD	MAX % DAC	SWEEP READING	SEARCH UNIT EXIT POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE				STRAIGHT BEAM (CAL ON BACK REFLECTION)	
	CIR- CUM- FEREN- TIAL	AXIAL					CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD ET)	MINIMUM		MAXIMUM		INDICATION AMPLITUDE (% FSH)	BACK REFLECTION AMPLITUDE (% FSH)
									SWEEP READING	S.U. POSITION	SWEEP READING	S.U. POSITION		
	✓		1	Pipe	44	1.6	0°	0.65"						
	✓		2		62	3.8	4" cw	0.65"						
	✓		3		21	3.4	5" cw	0.65"						
	✓		4		31	3.2	6" cw	0.65"						
	✓		5		25	3.8	9" cw	0.65"						
	✓		6		19	3.0	10" cw	0.65"						
	✓		7		38	4.0	12" cw	0.65"						
	✓		8		31	2.8	13" cw	0.65"						
	✓		9		31	3.8	15" cw	0.65"						
	✓		10		25	4.0	16" cw	0.65"						
	✓		11		25	3.8	17" cw	0.65"						
	✓		12		19	4.0	20" cw	0.65"						
	✓		13		25	2.6	26" cw	0.65"						

RESULTS	INDICA- TION NO.	LOCATION OF INDICATION		LENGTH	%I		WIDTH (IF LAMINAR)	COMMENTS
		CIRC	AXIAL		DEPTH (IF PLANAR)	DISTANCE FROM SURFACE		
								Multiple Signals 360° Intermittent around pipe.

* NOTE: MEASUREMENTS TAKEN FROM TOE OF WELD.

CONTINUATION ATTACHED - Yes No

EXAMINER(S)

1. *[Signature]* TC-1A LEVEL III
 2. *[Signature]* TC-1A LEVEL I
 al-101

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

SHEET 3 OF 4
 ITEM IDENTIFICATION [Z-PZ-2-2-1]
 CALIBRATION DATA SHEET NO. ZAF-086/A

DATA TABULATION

SCAN DIRECTION	ST. BEAM CIRCUMFERENTIAL	AXIAL	INDICATION NO.	EXAM. ON WELD SIDE (ADJ)	MAX % DAC	SWEEP READING	SEARCH POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE		STRAIGHT BEAM	
							CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD)	MINIMUM SWEEP READING	S.U. POSITION	MAXIMUM SWEEP READING	S.U. POSITION
	✓		14	PIPE	21	3.0	27 1/2" CW	0.65"				
	✓		15		21	3.2	31 1/2" CW	0.65"				
	✓		16		31	4.0	32 1/2" CW	0.65"				
	✓		17		28	3.0	34" CW	0.65"				
	✓		18		21	3.5	35" CW	0.65"				
	✓		19		25	3.2	36" CW	0.65"				
	✓		20		25	2.8	37" CW	0.65"				
	✓		21		19	3.4	38" CW	0.65"				
	✓		22		25	3.3	39 1/2" CW	0.65"				
	✓		23		62	2.0	1" CW	0.65"				

INDICATION NO.	LOCATION OF INDICATION		LENGTH	DEPTH (IF PLANAR)	DISTANCE FROM SURFACE	WIDTH (IF LAMINAR)	COMMENTS
	CIRC	AXIAL					
							Multiple Signals 360° Intensity level
							Pipe.

RESULTS

* NOTE: MEASUREMENTS TAKEN FROM TOE OF WELD.

EXAMINER(S)

1. [Signature]

2. [Signature]

REVIEWED BY [Signature] DATE 10/17/84

TC-1A LEVEL III

TC-1A LEVEL I

CONTINUATION ATTACHED - Yes No

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 4 OF 4

CHKD. BY JIP DATE 10-16-84

OFS NO. _____ DEPT. NO. _____


CLIENT NYP&A

PROJECT FITE 151


Data Sheet # JAF-086/A

SUBJECT _____

12-02-2-23




12-02-2-23



12-02-2-23

WIND ZONE 1-2-3-4-5-6-7-8-9-10-11-12-13-14-15-16-17-18-19-20-21-22-23-24-25-26-27-28-29-30-31-32-33-34-35-36-37-38-39-40-41-42-43-44-45-46-47-48-49-50-51-52-53-54-55-56-57-58-59-60-61-62-63-64-65-66-67-68-69-70-71-72-73-74-75-76-77-78-79-80-81-82-83-84-85-86-87-88-89-90-91-92-93-94-95-96-97-98-99-100



0.00 4.00 8.00 12.00 16.00 20.00 24.00 28.00 32.00 36.00 40.00
Circumferential Reference Distance (in)

Weld 12-02-2-23

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
0.00	0.2000	0.5100	0.660
0.25	0.2000	0.5100	0.660
0.50	0.2000	0.5100	0.660
0.75	0.2000	0.5100	0.660
1.00	0.2000	0.5100	0.660
1.25	0.2250	0.4850	0.660
1.50	0.2500	0.4600	0.660
1.75	0.2750	0.4350	0.660
2.00	0.3000	0.4100	0.660
2.25	0.3250	0.3850	0.660
2.50	0.3500	0.3600	0.660
2.75	0.3750	0.3350	0.660
3.00	0.4000	0.3100	0.660
3.25	0.4125	0.2975	0.660
3.50	0.4250	0.2850	0.660
3.75	0.4375	0.2725	0.660
4.00	0.4500	0.2600	0.660
4.25	0.4000	0.3100	0.660
4.50	0.3500	0.3600	0.660
4.75	0.3000	0.4100	0.660
5.00	0.2500	0.4600	0.660
5.25	0.2625	0.4475	0.660
5.50	0.2750	0.4350	0.660
5.75	0.2875	0.4225	0.660
6.00	0.3000	0.4100	0.660
6.25	0.3250	0.3850	0.660
6.50	0.3500	0.3600	0.660
6.75	0.3750	0.3350	0.660
7.00	0.4000	0.3100	0.660
7.25	0.4625	0.2475	0.660
7.50	0.5250	0.1850	0.660
7.75	0.5875	0.1225	0.660
8.00	0.6500	0.0600	0.660
8.25	0.6000	0.1100	0.660
8.50	0.5500	0.1600	0.660
8.75	0.5000	0.2100	0.660
9.00	0.4500	0.2600	0.660
9.25	0.4250	0.2850	0.660
9.50	0.4000	0.3100	0.660
9.75	0.3750	0.3350	0.660
10.00	0.3500	0.3600	0.660
10.25	0.4250	0.2850	0.660
10.50	0.5000	0.2100	0.660
10.75	0.5750	0.1350	0.660
11.00	0.6500	0.0600	0.660
11.25	0.6050	0.1050	0.660
11.50	0.5600	0.1500	0.660
11.75	0.5150	0.1950	0.660
12.00	0.4700	0.2400	0.660
12.25	0.4350	0.2750	0.660

Weld 12-02-2-23

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
12.50	0.4000	0.3100	0.660
12.75	0.3650	0.3450	0.660
13.00	0.3300	0.3800	0.660
13.25	0.4100	0.3000	0.660
13.50	0.4900	0.2200	0.660
13.75	0.5700	0.1400	0.660
14.00	0.6500	0.0600	0.660
14.25	0.6000	0.1100	0.660
14.50	0.5500	0.1600	0.660
14.75	0.5000	0.2100	0.660
15.00	0.4500	0.2600	0.660
15.25	0.4550	0.2550	0.660
15.50	0.4600	0.2500	0.660
15.75	0.4650	0.2450	0.660
16.00	0.4700	0.2400	0.660
16.25	0.4650	0.2450	0.660
16.50	0.4600	0.2500	0.660
16.75	0.4550	0.2550	0.660
17.00	0.4500	0.2600	0.660
17.25	0.5000	0.2100	0.660
17.50	0.5500	0.1600	0.660
17.75	0.6000	0.1100	0.660
18.00	0.6500	0.0600	0.660
18.25	0.6125	0.0975	0.660
18.50	0.5750	0.1350	0.660
18.75	0.5375	0.1725	0.660
19.00	0.5000	0.2100	0.660
19.25	0.4925	0.2175	0.660
19.50	0.4850	0.2250	0.660
19.75	0.4775	0.2325	0.660
20.00	0.4700	0.2400	0.660
20.25	0.4900	0.2200	0.660
20.50	0.5100	0.2000	0.660
20.75	0.5300	0.1800	0.660
21.00	0.5500	0.1600	0.660
21.25	0.5750	0.1350	0.660
21.50	0.6000	0.1100	0.660
21.75	0.6250	0.0850	0.660
22.00	0.6500	0.0600	0.660
22.25	0.6500	0.0600	0.660
22.50	0.6500	0.0600	0.660
22.75	0.6500	0.0600	0.660
23.00	0.6500	0.0600	0.660
23.25	0.6500	0.0600	0.660
23.50	0.6500	0.0600	0.660
23.75	0.6500	0.0600	0.660
24.00	0.6500	0.0600	0.660
24.25	0.5875	0.1225	0.660
24.50	0.5250	0.1850	0.660
24.75	0.4625	0.2475	0.660

Weld 12-02-2-23

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
25.00	0.4000	0.3100	0.660
25.25	0.3775	0.3325	0.660
25.50	0.3550	0.3550	0.660
25.75	0.3325	0.3775	0.660
26.00	0.3100	0.4000	0.660
26.25	0.3200	0.3900	0.660
26.50	0.3300	0.3800	0.660
26.75	0.3400	0.3700	0.660
27.00	0.3500	0.3600	0.660
27.25	0.3625	0.3475	0.660
27.50	0.3750	0.3350	0.660
27.75	0.3875	0.3225	0.660
28.00	0.4000	0.3100	0.660
28.25	0.4625	0.2475	0.660
28.50	0.5250	0.1850	0.660
28.75	0.5875	0.1225	0.660
29.00	0.6500	0.0600	0.660
29.25	0.6500	0.0600	0.660
29.50	0.6500	0.0600	0.660
29.75	0.6500	0.0600	0.660
30.00	0.6500	0.0600	0.660
30.25	0.5825	0.1275	0.660
30.50	0.5150	0.1950	0.660
30.75	0.4475	0.2625	0.660
31.00	0.3800	0.3300	0.660
31.25	0.4025	0.3075	0.660
31.50	0.4250	0.2850	0.660
31.75	0.4475	0.2625	0.660
32.00	0.4700	0.2400	0.660
32.25	0.4525	0.2575	0.660
32.50	0.4350	0.2750	0.660
32.75	0.4175	0.2925	0.660
33.00	0.4000	0.3100	0.660
33.25	0.3875	0.3225	0.660
33.50	0.3750	0.3350	0.660
33.75	0.3625	0.3475	0.660
34.00	0.3500	0.3600	0.660
34.25	0.3650	0.3450	0.660
34.50	0.3800	0.3300	0.660
34.75	0.3950	0.3150	0.660
35.00	0.4100	0.3000	0.660
35.25	0.4075	0.3025	0.660
35.50	0.4050	0.3050	0.660
35.75	0.4025	0.3075	0.660
36.00	0.4000	0.3100	0.660
36.25	0.3250	0.3850	0.660
36.50	0.2500	0.4600	0.660
36.75	0.1750	0.5350	0.660
37.00	0.1000	0.6100	0.660
37.25	0.1250	0.5850	0.660

Weld 12-02-2-23

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
37.50	0.1500	0.5600	0.660
37.75	0.1750	0.5350	0.660
38.00	0.2000	0.5100	0.660
38.25	0.2250	0.4850	0.660
38.50	0.2500	0.4600	0.660
38.75	0.2750	0.4350	0.660
39.00	0.3000	0.4100	0.660
39.25	0.2750	0.4350	0.660
39.50	0.2500	0.4600	0.660
39.75	0.2250	0.4850	0.660
40.00	0.2000	0.5100	0.660
40.25	0.2000	0.5100	0.660
40.50	0.2000	0.5100	0.660
40.75	0.2000	0.5100	0.660
41.00	0.2000	0.5100	0.660

Weld 12-02-2-58

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J.A. Fitzpatrick
DATA SHEET NO. JAF-092/A DATE 10-13-84
PROCEDURE JAF-UTS 84112 REV 3

COMPONENT OR SYSTEM Recirculation loop "B" PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S), LISTED ON REVERSE SIDE - COMPONENT TEMP 122°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 120°F

SCAN COVERAGE

WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT

Manufacturer Aerotech
Style Gamma
Serial No. E14112
Size 0.5" Dia. Frequency 2.25 MHz
Angle 62° Mode Shear


Couplant Ultracel II Batch No. 8439

INSTRUMENT

Manufacturer Kraut Kramer Banson Model USL-38
Serial No. 210571 Cable Length 6'
Frequency 2.5 MHz Reject OFF
Rep Rate N/A Damping OFF
dB Gain - Coarse 20 Fine 34

Primary Reference Response Amplitude % Full Screen Height 80% FSH

DAC PLOT - TIME 1530 AM, PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1910	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.


EXAMINER(S)

1. [Signature] TC-1A LEVEL III
2. [Signature] TC-1A LEVEL I
REVIEWED BY [Signature] DATE 10/17/84

ADDITIONAL REMARKS

[Signature] 10/17/84

WELD THICKNESS DATA SHEET



Transducer Size .50 Weld No. 12-02-2-58 System/Area REAR

Examiner [Signature] Level II Date 10-13-84

ULTRASONIC DATA SHEET

UNIT: *THRUPO* SYSTEM: *02-2 Recirc* COMPONENT: *Pipes weld*
DESCRIPTION: *Pipe - 6-5/8 in O.D. - Top of No. 2 "F"*

WELD ID: *12-02-2-58* PROCEDURE: *OMI-PO + Add.* MATERIAL: *SS* THICKNESS: *68* TEST SURFACE: *OD*
INSTRUMENT(S): *452-38* CAL-BLOCK(S): *(See cal. sheets)* CRYSTAL: *53425* CRYSTAL: *84-88* CRYSTAL:
NODE: *S&L* BEAM DIRECTION: *Trans. & Circ. 41* ANGLE: *45°* ANGLE: *73°* ANGLE:
DISTANCE: *10"* #1 REF: *Top of pipe* TIME START: *1100* TIME START: *1100* TIME START:
COUPLANT: *442855 II* COUPLANT BATCH NO.: *8443* TIME STOP: *1400* TIME STOP: *1400* TIME STOP:

CAL. SHEET: *STE - EML - 008 4009* DATE: *10/5/84* DATE: *10/5/84* DATE:
PERFORMED BY: *George Koller* ID#: *5-1765* LEVEL: *III* LEVEL: *III* LEVEL:
PERFORMED BY: *W* ID#: *24* LEVEL: *A* LEVEL: *A* LIMITED SCAN

POSITION	MAX. SIGNAL (% OF DAC)	DEPTH (IN.)	LAMINATION (ONLY)		BEAM DIRECTION	ANGLE (DEG)	CRYSTAL (INCHES)		SURFACE	DISTANCE FROM SURFACE IN.	POSITION (IN.)		DISTANCE FROM SURFACE IN.	POSITION (IN.)		REMARKS	
			LEN.	LEN.			A	B			1	2		A	B		
A			20 TO 20	50 TO 50			A	B			1	2				<i>NO RECORDED INDICATIONS - 360° Scans 10° Resolution - Air-CB.</i>	
B			100 TO 100														

SK-JAF-82-002

REVIEWED BY: LEVEL: DATE REVIEWED: FIGURE NO.: DATA SHEET NO.:

HEET NO: JAF-846-005

VALUATION WELD TIME: 1100 HR

DATE: 10/15/84

JNIT: JAFUPD SYSTEM: 02-2/Reinc COMPONENT: piping welds
 EXAMINER: George Seckler ID#: 51765 LEVEL: III COUPLANT: ULTRAGEL II
 EXAMINER: [Signature] ID#: [Signature] LEVEL: II COUPLANT ID#: 8443

INSTRUMENT ID#: 210586
 LINEARITY CHECK YES NO
 REJECT: 0.5 %DB
 MAT'L CAL: 182
 DELAY: 678
 PULSE ENERGY: S.F.A.
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 12
 FINE GAIN: 10 %
 SCREEN RANGE: 2.5
 SCREEN DEPTH: 1.0 IN.
 T & R } OPERATION
 NORMAL }
 FREQUENCY: 5 MHZ
 NORMAL } DISPLAY
 RF }
 REP. RATE: 15
 ZERO CONTROL: 0 0
 DAMPING: off
 GAIN: _____
 DLY: _____ } DAC
 SLP: _____ }
 POLARITY: _____ }
 WIDTH: _____ } GATE %
 DELAY: _____ }
 NORMAL } ECHO START
 FIRST ECHO }

CALIBRATION BLOCK ID#: CTD-A376-25
 LENGTH: _____ IN.
 OD: _____ IN.
 THICKNESS: _____ IN.
 CRYSTAL ID#: 53875
 TYPE: MUB
 FREQ: _____ MHZ
 SIZE: 4
 ACTUAL A: 45°

CALIBRATION BLOCK SIMULATOR
 SERIAL NO. _____ SCREEN RANGE _____
 SIGNAL AMP _____ % SCREEN READING _____
 COURSE GAIN DB _____ FINE GAIN DB _____

SYSTEM CALIBRATION
 ANGLE 45° NODE check

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES
10° 18-NODE	100+ %	50% = 10 IN.
15° 18-NODE	100+ %	60% = 15 IN.
20° 18-NODE	100+ %	40% = 20 IN.
25° 18-NODE	100+ %	40% = 25 IN.
30° 18-NODE	100+ %	30% = 30 IN.
35° 18-NODE	100+ %	25% = 35 IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR CB ^a	%	IN.
BKR P ^b	%	IN.

SEARCH UNIT CABLE TYPE 6' BUKHUT LENGTH 6'
 CAL. BLOCK TEMP. _____ F°
 CAL. BLOCK SIMULATOR TEMP. _____ F°
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 78 FOR PIPING)

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES
10° 18-NODE	100+ %	50% = 10 IN.
15° 18-NODE	100+ %	60% = 15 IN.
20° 18-NODE	100+ %	40% = 20 IN.
25° 18-NODE	100+ %	40% = 25 IN.
30° 18-NODE	100+ %	30% = 30 IN.
35° 18-NODE	100+ %	25% = 35 IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR CB ^a	%	IN.
BKR P ^b	%	IN.

FIGURE NO(S), EXAMINED
 12-02-2-12
 12-02-2-17
 12-02-2-23
 12-02-2-64
 12-02-2-58
 12-02-2-75
 12-02-2-81

CALIBRATION CONFIRMATION

TIME	1400 HRS.	HRS.	HRS.	HRS.	HRS.	HT
BLOCK SIM.	% IN.	% IN.	% IN.	% IN.	% IN.	%
BACK REFL.	% IN.	% IN.	% IN.	% IN.	% IN.	%
15° 18-NODE	100% IN.	% IN.	% IN.	% IN.	% IN.	%
25° 18-NODE	100% IN.	% IN.	% IN.	% IN.	% IN.	%
35° 18-NODE	100% IN.	% IN.	% IN.	% IN.	% IN.	%
INITIALS	[Signature]					

DATE: 10/15/84
 CALIBRATION SHEET
 TIME: 1:00 HR

COMPONENT: PIPE WELDS
 COUPLANT: ULTRAFLEX II
 COUPLANT ID#: 8443
 SYSTEM: 02-2/RECIRC
 LEVEL: 50Z
 LEVEL: 74

INSTRUMENT: 210568
 INEARTY CHECK: YES NO
 EJECT: OFF
 IATL CAL: 966
 ELAY: 082
 ULSE ENERGY: 0.7
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 22
 TIME GAIN: 15
 ISCREEN RANGE: 0.5
 ISCREEN DEPTH: 6.0
 IFR } OPERATION
 I NORMAL }
 FREQUENCY: 2.5 MHZ
 I NORMAL }
 I RF } DISPLAY
 REP. RATE: 18
 ZERO CONTROL: 0
 DAMPING: OFF

CRYSTAL: 8488
 ID#: 5-1765
 TYPE: RTD
 FREQ: 2 MHZ
 SIZE: 6 X 1.3 X 0.5
 ACTUAL Δ: 7.3
 CALIBRATION BLOCK
 ID#: 70-A376-15
 LENGTH: 12 IN
 OD: 1.25 IN
 THICKNESS: 0.75 IN

SYSTEM CALIBRATION
 ANGLE 73 ° NODE Large Technical

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES Δ
1 1B-NODE	100 %	0.3 SD. IN.
2 1B-NODE	90 %	0.4 SD. IN.
3 1B-NODE	70 %	0.5 SD. IN.
4 1B-NODE	55 %	0.6 SD. IN.
5 1B-NODE	40 %	0.7 SD. IN.
6 1B-NODE	30 %	0.8 SD. IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR. CB	%	IN.
BKR. P	%	IN.

SEARCH UNIT CABLE
 TYPE: DUAL
 LENGTH: 6'

CAL. BLOCK TEMP. F°
 CAL. BLOCK SIMULATOR TEMP. F°
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 75 FOR PIPING)

FIGURE NO(S) EXAMINED
 12-02-2-12
 12-02-2-17
 12-02-2-23
 12-02-2-64
 12-02-2-58
 12-02-2-75
 12-02-2-81

CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	1B-NODE	3 1B-NODE	5 1B-NODE	INITIALS	BKR CB (BACK REFLECTION FROM CAL. BLOCK)	BKR P (BACK REFLECTION FROM PART)	DATE REVIEWED
1700	%	%	100 %	80 %	50 %	Stall			SK-JAF-81-011



UNITED STATES TESTING COMPANY, INC.

12-02-2-58


10/17/84
Date

RADIOGRAPHIC EXAMINATION REPORT

Customer <u>NYPA</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS INC.</u>
Location <u>JAFNPP</u>	Specimen Description <u>WELD</u>
Purchase order no. <u>NVO 82-246</u>	Material Type <u>S/S</u>
Work request no. <u>N/A</u>	Dia./Thickness <u>12.75 / .688</u>
Welder I. D. <u>4+7</u>	Specimen I. D. <u>RECIRC WELD 15A</u>

Procedure Data

Gamma	X-Ray	Penetrameter Designation <u>15F</u>
Source Type <u>IR¹⁹²</u>	Machine Mfg. <u>A</u>	Required Sensitivity/Essential Hole <u>2-4T</u>
Curies <u>94</u>	Kilovoltage	Shim Thickness <u>.063</u>
Physical Size <u>4x1/8</u>	Milliamperage <u>N</u>	Pb Screens: Front <u>.010</u> Back <u>.010</u>
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance <u>12.75"</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness <u>.010</u>
Film Size <u>4 1/2 x 17</u>	Total No. Film <u>8</u>	Exposure Time <u>4 1/2 MIN.</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrameter	Weld		
15A	0-10					✓	✓	✓		ARTIFACTS	2.6	2.3-2.6	✓	
	10-20					✓		✓		" "	3.1	2.7-3.1	✓	
	20-30					✓		✓		" "	2.75	2.4-2.8	✓	
	30-0					✓	✓	✓		" "	2.8	2.35-2.9	✓	

Acceptance Criteria: Code/Addenda/Class- ASME III 68

Remarks:

Radiographed By:	Interpreted By: <u>R. Kowty II</u>	Customer Review
	Date <u>10-17-84</u>	Name <u>III</u> Level <u>III</u> Date <u>10-17-84</u>

Weld 12-02-2-64

ULTRASONIC DATA SHEET

UNIT: TRAPP SYSTEM: 02-2 Revis

COMPONENT: pipng wells

DESCRIPTION: pipe-6-8ft end on pipe "6" WELD ID: 12-02-2-64 PROCEDURE: QAT-P0 + Add. MATERIAL: SS THICKNESS: .66 TEST SURFACE: OD

INSTRUMENT(S): 45L-78 CAL-BLOCK(S): (See cal. charts) CRYSTAL: 53V75 ANGLE: 45° CRYSTAL: 84-8P ANGLE: 73° CRYSTAL:

NODE: 5 & L BEAM DIRECTION: Transverse #1 REF: Top of pipe NO POSITIONS: 41 TIME START: 1100 TIME STOP: 1400 TIME START: 1100 TIME STOP: 1400

DISTANCE: 1.0" COUPLANT: ULTRAGEL II COUPLANT BATCH NO.: 8443 DATE: 12/15/89 DATE: 12/15/89

CAL. SHEET: GAF-EVAL-008 & 009 PERFORMED BY: George Sutter ID#: 5-1365 LEVEL: III LIMITED SCAN

PERFORMED BY: George Sutter ID#: 5-1365 LEVEL: III NO YES (IF SO WHY)

A	B	MAX. SIGNAL (% OF DAC)	DEPTH (IN)	LENGTH (% DAC)		BEAM DIRECTION	ANGLE (DEG)	CRYSTAL DISTANCE (INCHES)		SURFACE	MINIMUM POSITION (IN.)		MAXIMUM POSITION (IN.)		REMARKS
				20 TO 20	50 TO 50			1	2		1	2			
															See attached charts & plot (18" scale) for values - Two thru-wall Ind. 360° Instrumentation.

REVIEWED BY: _____ LEVEL: _____ DATE REVIEWED: _____ FIGURE NO.: _____ DATA SHEET NO.: _____

HEET NO. JAF-RM-005

CALIBRATION SHEET
TIME: 1100

DATE: 10/15/84

JNIT: JAFNPP SYSTEM: 02-2/Rising COMPONENT: piping welds
 EXAMINER: George Seckler ID#: 51765 LEVEL: III COUPLANT: ALTRAGEL II
 EXAMINER: [Signature] ID#: [Signature] LEVEL: II COUPLANT ID#: 8443

INSTRUMENT
 ID#: 210586
 LINEARITY CHECK YES NO
 REJECT: OFF %DB
 MAT'L. CAL.: 182
 DELAY: 678
 PULSE ENERGY: S.F.D.
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 12
 FINE GAIN: 10 %
 SCREEN RANGE: 2.5
 SCREEN DEPTH: 1.0 IN.
 T & R } OPERATION
 NORMAL }
 FREQUENCY: 5 MHz
 NORMAL } DISPLAY
 RF }
 REP. RATE: 1K
 ZERO CONTROL: 0 0
 DAMPING: OFF
 GAIN: _____
 L.Y.: _____ DAC
 SLP: _____
 POLARITY: _____
 WIDTH: _____ GATE %
 DELAY: _____
 NORMAL } ECHO START
 FIRST ECHO }

CALIBRATION BLOCK
 ID#: CTD-A376-75
 LENGTH: _____ IN.
 OD: _____ IN.
 THICKNESS: _____ IN.

CRYSTAL
 ID#: 53975
 TYPE: RMB
 FREQ: 4 MHZ
 SIZE: PXPaa #
 ACTUAL A: 45°

CALIBRATION BLOCK SIMULATOR
 SERIAL NO. _____ SCREEN RANGE _____
 SIGNAL AMP _____ % SCREEN READING _____
 COURSE GAIN DB _____ FINE GAIN DB _____

SYSTEM CALIBRATION
 ANGLE 45° NODE check

SEARCH UNIT CABLE
 TYPE: [Signature] LENGTH: 6'
 CAL. BLOCK TEMP. _____ F°
 CAL. BLOCK SIMULATOR TEMP. _____ F°
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 75 FOR PIPING)

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES
10° 18-NODE	100+%	50% = 10 IN.
15° 18-NODE	100+%	60% = 15 IN.
20° 18-NODE	100+%	40% = 20 IN.
25° 18-NODE	100+%	40% = 25 IN.
30° 18-NODE	100+%	30% = 30 IN.
35° 18-NODE	100+%	25% = 35 IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR. CB	%	IN.
BKR. P	%	IN.

FIGURE NO(S) EXAMINED

12-02-2-12		
12-02-2-17		
12-02-2-23		
12-02-2-64		
12-02-2-58		
12-02-2-75		
12-02-2-81		

CALIBRATION CONFIRMATION

TIME	1100 HRS.	HRS.	HRS.	HRS.	HRS.	H
BLOCK SIM.	% IN.	% IN.	% IN.	% IN.	% IN.	%
BACK REFL.	% IN.	% IN.	% IN.	% IN.	% IN.	%
15° 18-NODE	100% IN.	% IN.	% IN.	% IN.	% IN.	%
25° 18-NODE	100% IN.	% IN.	% IN.	% IN.	% IN.	%
35° 18-NODE	100% IN.	% IN.	% IN.	% IN.	% IN.	%
INITIALS	[Signature]					

CALIBRATION SHEET

DATE: 10/15/84

EE: NO. JAF-81-008
 TIME: 1:00 PM

COMPONENT: PIPE WELDS
 COUPLANT: GUTRACEL II
 COUPLANT ID#: 8443

SYSTEM: 02-2/RECIRC.
 ID#: 5-1765
 ID#: 24

EXAMINER: George Sander
 AMINER: 24

CALIBRATION BLOCK SIMULATOR
 SERIAL NO. _____ SCREEN RANGE _____ IN.
 SIGNAL AMP _____ % SCREEN READING _____ IN.
 COURSE GAIN DB _____ FIRE GAIN DB _____

CALIBRATION BLOCK
 ID# A70-A376-15
 LENGTH: 12 IN.
 OD: 1.25 IN.
 THICKNESS: .75 IN.

INSTRUMENT
 # 210568
 INEARITY CHECK YES NO
 EJECT: OFF %DB _____
 INT'L. CAL: 966
 SLAY: 682
 ULSE ENERGY: 247
 COURSE GAIN IN DB: 40
 FINE GAIN IN DB: 22
 FINE GAIN: 15 %
 SCREEN RANGE: .5
 SCREEN DEPTH: 60 IN.

SEARCH UNIT CABLE
 TYPE: DIAL
 LENGTH: 6'
 CAL. BLOCK TEMP. _____ F°
 CAL. BLOCK SIMULATOR TEMP. _____ F°
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 70 FOR PIPING)

SYSTEM CALIBRATION
 ANGLE: 73 ° NODE: Longitudinal

OPERATION
 FREQUENCY: 2.5 MHZ
 RF: [] NORMAL [] DISPLAY
 REP. RATE: 1K
 ZERO CONTROL: 0 °
 DAMPING: OFF

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES 50
.1 18-NODE	100 %	.3 50. IN.
.2 18-NODE	90 %	.4 50. IN.
.3 18-NODE	70 %	.5 50. IN.
.4 18-NODE	55 %	.6 50. IN.
.5 18-NODE	40 %	.7 50. IN.
.6 18-NODE	30 %	.8 50. IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR. CB	%	IN.
BKR. P	%	IN.

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES 50
.1 18-NODE	100 %	.3 50. IN.
.2 18-NODE	90 %	.4 50. IN.
.3 18-NODE	70 %	.5 50. IN.
.4 18-NODE	55 %	.6 50. IN.
.5 18-NODE	40 %	.7 50. IN.
.6 18-NODE	30 %	.8 50. IN.
TOP NOTCH	%	IN.
OPPOSITE NOTCH	%	IN.
BKR. CB	%	IN.
BKR. P	%	IN.


FIGURE NO(S) EXAMINED
 12-02-2-12
 12-02-2-17
 12-02-2-23
 12-02-2-64
 12-02-2-58
 12-02-2-75
 12-02-2-87

CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	18-NODE	18-NODE	18-NODE	INITIALS
1900	%	%	100 %	80 %	50 %	ASL/MA
	%	%	3 50 IN.	5 50 IN.	7 50 IN.	

TIME	BLOCK SIM.	BACK REFL.	18-NODE	18-NODE	18-NODE	INITIALS
1900	%	%	100 %	80 %	50 %	ASL/MA
	%	%	3 50 IN.	5 50 IN.	7 50 IN.	

BKR CB (BACK REFLECTION FROM CAL. BLOCK) 8 BKR P (BACK REFLECTION FROM PART)
 BKR P (BACK REFLECTION FROM PART)
 DATE REVIEWED: SN-JAF-81-011



NONINION

Weld 12-02-2-64

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
0.00	0.1500	0.5100	0.660
0.25	0.1500	0.5100	0.660
0.50	0.1500	0.5100	0.660
0.75	0.1500	0.5100	0.660
1.00	0.1500	0.5100	0.660
1.25	0.1875	0.4725	0.660
1.50	0.2250	0.4350	0.660
1.75	0.2625	0.3975	0.660
2.00	0.3000	0.3600	0.660
2.25	0.2750	0.3850	0.660
2.50	0.2500	0.4100	0.660
2.75	0.2250	0.4350	0.660
3.00	0.2000	0.4600	0.660
3.25	0.1500	0.5100	0.660
3.50	0.1000	0.5600	0.660
3.75	0.0500	0.6100	0.660
4.00	0.0000	0.6600	0.660
4.25	0.0375	0.6225	0.660
4.50	0.0750	0.5850	0.660
4.75	0.1125	0.5475	0.660
5.00	0.1500	0.5100	0.660
5.25	0.1875	0.4725	0.660
5.50	0.2250	0.4350	0.660
5.75	0.2625	0.3975	0.660
6.00	0.3000	0.3600	0.660
6.25	0.3375	0.3225	0.660
6.50	0.3750	0.2850	0.660
6.75	0.4125	0.2475	0.660
7.00	0.4500	0.2100	0.660
7.25	0.4875	0.1725	0.660
7.50	0.5250	0.1350	0.660
7.75	0.5625	0.0975	0.660
8.00	0.6000	0.0600	0.660
8.25	0.5750	0.0850	0.660
8.50	0.5500	0.1100	0.660
8.75	0.5250	0.1350	0.660
9.00	0.5000	0.1600	0.660
9.25	0.4500	0.2100	0.660
9.50	0.4000	0.2600	0.660
9.75	0.3500	0.3100	0.660
10.00	0.3000	0.3600	0.660
10.25	0.2750	0.3850	0.660
10.50	0.2500	0.4100	0.660
10.75	0.2250	0.4350	0.660
11.00	0.2000	0.4600	0.660
11.25	0.2500	0.4100	0.660
11.50	0.3000	0.3600	0.660
11.75	0.3500	0.3100	0.660
12.00	0.4000	0.2600	0.660
12.25	0.3750	0.2850	0.660

Weld 12-02-2-64


Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
12.50	0.3500	0.3100	0.660
12.75	0.3250	0.3350	0.660
13.00	0.3000	0.3600	0.660
13.25	0.3500	0.3100	0.660
13.50	0.4000	0.2600	0.660
13.75	0.4500	0.2100	0.660
14.00	0.5000	0.1600	0.660
14.25	0.4950	0.1650	0.660
14.50	0.4900	0.1700	0.660
14.75	0.4850	0.1750	0.660
15.00	0.4800	0.1800	0.660
15.25	0.4850	0.1750	0.660
15.50	0.4900	0.1700	0.660
15.75	0.4950	0.1650	0.660
16.00	0.5000	0.1600	0.660
16.25	0.5250	0.1350	0.660
16.50	0.5500	0.1100	0.660
16.75	0.5750	0.0850	0.660
17.00	0.6000	0.0600	0.660
17.25	0.5550	0.1050	0.660
17.50	0.5100	0.1500	0.660
17.75	0.4650	0.1950	0.660
18.00	0.4200	0.2400	0.660
18.25	0.4400	0.2200	0.660
18.50	0.4600	0.2000	0.660
18.75	0.4800	0.1800	0.660
19.00	0.5000	0.1600	0.660
19.25	0.5250	0.1350	0.660
19.50	0.5500	0.1100	0.660
19.75	0.5750	0.0850	0.660
20.00	0.6000	0.0600	0.660
20.25	0.6000	0.0600	0.660
20.50	0.6000	0.0600	0.660
20.75	0.6000	0.0600	0.660
21.00	0.6000	0.0600	0.660
21.25	0.5750	0.0850	0.660
21.50	0.5500	0.1100	0.660
21.75	0.5250	0.1350	0.660
22.00	0.5000	0.1600	0.660
22.25	0.5000	0.1600	0.660
22.50	0.5000	0.1600	0.660
22.75	0.5000	0.1600	0.660
23.00	0.5000	0.1600	0.660
23.25	0.4750	0.1850	0.660
23.50	0.4500	0.2100	0.660
23.75	0.4250	0.2350	0.660
24.00	0.4000	0.2600	0.660
24.25	0.4250	0.2350	0.660
24.50	0.4500	0.2100	0.660
24.75	0.4750	0.1850	0.660

Weld 12-02-2-64

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
25.00	0.5000	0.1600	0.660
25.25	0.5250	0.1350	0.660
25.50	0.5500	0.1100	0.660
25.75	0.5750	0.0850	0.660
26.00	0.6000	0.0600	0.660
26.25	0.5250	0.1350	0.660
26.50	0.4500	0.2100	0.660
26.75	0.3750	0.2850	0.660
27.00	0.3000	0.3600	0.660
27.25	0.3250	0.3350	0.660
27.50	0.3500	0.3100	0.660
27.75	0.3750	0.2850	0.660
28.00	0.4000	0.2600	0.660
28.25	0.4000	0.2600	0.660
28.50	0.4000	0.2600	0.660
28.75	0.4000	0.2600	0.660
29.00	0.4000	0.2600	0.660
29.25	0.4500	0.2100	0.660
29.50	0.5000	0.1600	0.660
29.75	0.5500	0.1100	0.660
30.00	0.6000	0.0600	0.660
30.25	0.5750	0.0850	0.660
30.50	0.5500	0.1100	0.660
30.75	0.5250	0.1350	0.660
31.00	0.5000	0.1600	0.660
31.25	0.4300	0.2100	0.660
31.50	0.4000	0.2600	0.660
31.75	0.3500	0.3100	0.660
32.00	0.3000	0.3600	0.660
32.25	0.2750	0.3850	0.660
32.50	0.2500	0.4100	0.660
32.75	0.2250	0.4350	0.660
33.00	0.2000	0.4600	0.660
33.25	0.2250	0.4350	0.660
33.50	0.2500	0.4100	0.660
33.75	0.2750	0.3850	0.660
34.00	0.3000	0.3600	0.660
34.25	0.3000	0.3600	0.660
34.50	0.3000	0.3600	0.660
34.75	0.3000	0.3600	0.660
35.00	0.3000	0.3600	0.660
35.25	0.3250	0.3350	0.660
35.50	0.3500	0.3100	0.660
35.75	0.3750	0.2850	0.660
36.00	0.4000	0.2600	0.660
36.25	0.4250	0.2350	0.660
36.50	0.4500	0.2100	0.660
36.75	0.4750	0.1850	0.660
37.00	0.5000	0.1600	0.660
37.25	0.4750	0.1850	0.660

Weld 12-02-2-64

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
37.50	0.4500	0.2100	0.660
37.75	0.4250	0.2350	0.660
38.00	0.4000	0.2600	0.660
38.25	0.3500	0.3100	0.660
38.50	0.3000	0.3600	0.660
38.75	0.2500	0.4100	0.660
39.00	0.2000	0.4600	0.660
39.25	0.1500	0.5100	0.660
39.50	0.1000	0.5600	0.660
39.75	0.0500	0.6100	0.660
40.00	0.0000	0.6600	0.660
40.25	0.0375	0.6225	0.660
40.50	0.0750	0.5850	0.660
40.75	0.1125	0.5475	0.660
41.00	0.1500	0.5100	0.660



Ultrasonic Inspection Report

Page 1 of
No. JAF 1013 -2
Date 10/13/84

Client: PASNY

Location: J. A. FITZPATRICK N.P.P.

System: RECIRCULATION LINE Weld Identification No.: 12-02-2-64

Inspected Area: WHOLE CIRCUMFERENCE FROM PIPE SIDE ; LENGTH

EVALUATION OF CRACK INDICATIONS

Position of Weld Contour: _____

Reference Print Location: TOP OF PIPE

Conclusion of Examination Results:

THE CRACK INDICATIONS CAN BE DETECTED OVER THE WHOLE CIRCUMFERENCE (360 DEGREES) WITH SHORT INTERRUPTIONS. THE LENGTH OF THESE INTERRUPTIONS ARE NOT BIGGER THAN TWO INCHES. THE AMPLITUDES DO NOT DROP BELOW 20% DAC EVALUATED WITH SE II (MODE CONVERSION) WITHIN THESE INTERRUPTIONS
100% DAC = 10% ID NOTCH +14dB

DR. SEYDEL / II Seydel

Responsible Inspector _____ Level _____

Signature: _____

William E. Shultz LEVEL III

Kraftwerk Union AG

11.11 - HDA G.T. 10/17/84



UNITED STATES TESTING COMPANY, INC.

12-02-2-64

10/16/84


Date

RADIOGRAPHIC EXAMINATION REPORT

Customer <u>NYPA</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS INC RT-1</u>
Location <u>JAFNPP</u>	Specimen Description <u>WELD</u>
Purchase order no. <u>NYO 82-246</u>	Material Type <u>S/S</u>
Work request no. <u>N/A</u>	Dia./Thickness <u>12.75 / .688</u>
Welder I. D. <u>7</u>	Specimen I. D. <u>RECIRC WELD 19A</u>

Procedure Data

Gamma	X-Ray <u>IA</u>	Penetrameter Designation <u>15F</u>
Source Type <u>IR192</u>	Machine Mfg. <u>IA</u>	Required Sensitivity/Essential Hole <u>2/4T</u>
Curies <u>69</u>	Kilovoltage	Shim Thickness <u>.093</u>
Physical Size <u>1/8 X 1/8</u>	Milliamperage	Pb Screens: Front <u>.010</u> Back <u>.010</u>
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance <u>12 3/4"</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness <u>.010</u>
Film Size <u>4 1/2 X 17</u>	Total No. Film <u>8</u>	Exposure Time <u>6 MIN</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrameter	Weld		
19A	0-10							✓	✓	ARTIFACTS	2.8	2.3-2.7		
	10-20									"	2.5	2.3-2.5	✓	
	20-30					✓			✓	"	2.74	2.4-2.7	✓	
	30-0						✓	✓	✓	"	2.9	2.5-2.7		

Acceptance Criteria: Code/Addenda/Class-

Remarks: DENISTY 0-10 DOES NOT FALL WITHIN -15% + 30% OF PENETRAME DENISTY
 COUNTER BORE \approx 3/4 from Q of WELD
 NUMBER BAND MOVED DURING SHOOTING 0-1 BECAME 40-0

Radiographed By:

Interpreted By:

Customer Review

R. Koontz II 10/16/84

[Signature] III

10-17-84

Name Level Date

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J.A. FITZPATRICK

DATA SHEET NO. JAF-093/A DATE 10-12-84

PROCEDURE JAF-VT-5 Add 102 REV 3

COMPONENT OR SYSTEM RECIRCULATION SYS. Loop B PIPE OD (IF APPLICABLE) 12"
 ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 90-12-11-199°F 120°F
 CALIBRATION BLOCK NO. 12-A376 THICKNESS .66" TEMP 10-12-14-105°F 110°F

SCAN COVERAGE


° WHAZ ° BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT
 Manufacturer KB AEROTECH
 Style GAMMA
 Serial No. E14H2
 Size .50" Ø Frequency 2.25 MHz
 Angle 62 1/2° Mode SHEAR
 Couplant ULTRAGEL II Batch No. 8439

INSTRUMENT
 Manufacturer KRAUTKAMMER-BRANSON Model USL-3P
 Serial No. 210571 Cable Length 6'
 Frequency 2.25 MHz Reject N/A
 Rep Rate N/A Damping N/A
 dB Gain - Coarse 20 Fine 34
 Primary Reference Response
 Amplitude % Full Screen Height 80%

DAC PLOT - TIME 1635 AM, (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
2030	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)
 1. [Signature] TC-1A LEVEL III
 2. John R. O'Neil TC-1A LEVEL I
 REVIEWED BY Steve Smith III DATE 10/17/84

ADDITIONAL REMARKS

3/4T - 3.9 @ 80% @ 54db
 1D - 5.2 db.
 1 1/4T - 1.1 @ 60%

[Signature] 10/17/84

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
INDICATION DATA**

SHEET 2 OF 4

ITEM IDENTIFICATION 13-02-2-64

CALIBRATION DATA SHEET NO. JAF-093/A

DATA TABULATION

ST. BEAM	SCAN DIRECTION		INDICATION NO.	EXAM. ON (ADJ WELD) SIDE OF WELD	MAX % DAC	SWEEP READING	SEARCH POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE				STRAIGHT BEAM (CAL ON BACK REFLECTION)	
	CIRCUMFERENTIAL	AXIAL					CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD CL)	MINIMUM SWEEP READING	MINIMUM S.U. POSITION	MAXIMUM SWEEP READING	MAXIMUM S.U. POSITION	INDICATION AMPLITUDE (% FSH)	BACK REFLECTION AMPLITUDE (% FSH)
	✓		1	ELBOW SIDE	100*	4.7	2.4 CW	.75	3.2	BU	6.7	1.55	SKewed 20°	
	✓		2		75	4.4	1.2 CCW	1.1						

INDICATION NO.	LOCATION OF INDICATION		LENGTH	%I		WIDTH (IF LAMINAR)	COMMENTS
	CIRC	AXIAL		DEPTH (IF PLANAR)	DISTANCE FROM SURFACE		
						60°	INDICATION #1 FROM 1.0" - 5.75" CW
							MULTIPLE NON-RECORDABLE INDICATIONS 3600
							INTERVAL - ALL MEASUREMENTS TAKEN FROM
							TBE OF WELD TO INDEX POINT.

RESULTS

EXAMINER: [Signature] TC-1A LEVEL III
 REVIEWER: [Signature] TC-1A LEVEL II
 DATE: 10/17/84

CONTINUATION ATTACHED - Yes, No

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 4

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NEW YORK POWER AUTHORITY

PROJECT J.A. FITZPATRICK

Data Sheet # JAF-093/A

SUBJECT 12-02-2-1A4 RECIRCULATION SYSTEM "B" LOOP




E T'S ESTIMATED.

12-02-2-64

John R. O'Neil
LW. I

WELD THICKNESS DATA SHEET



Transducer Size .50 Weld No. 12-02-2-64 System/Area RECIRE

Examiner J. L. Ramirez Level II Date 10-13-84

John R. O'Neil
 Ins. I

Weld 12-02-2-69

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT J.A. FITZPATRICK
DATA SHEET NO. JAF-088/A DATE 10-12-84
PROCEDURE JAF-UT-5 Add 1+2 REV 3

COMPONENT OR SYSTEM RECIRCULATION SYSTEM Loop B PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 127°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS .66" TEMP 135°F

SCAN COVERAGE


OF WHAZ OF BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT
Manufacturer KA. AEROTECH
Style Gamma
Serial No. E14H2
Size .50" Ø Frequency 2.25 MHz
Angle 62 1/2° Mode SHEAR
Couplant ULTRAGEL II Batch No. 8439

INSTRUMENT
Manufacturer BRANTKRAMER-BRAWSON Model USL-3B
Serial No. 210571 Cable Length 16'
Frequency 2.25 MHz Reject N/A
Rep Rate N/A Damping N/A
dB Gain - Coarse 20 Fine 28 34
Primary Reference Response
Amplitude % Full Screen Height 80%

DAC PLOT - TIME 1635 AM (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
2030	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)
1. [Signature] TC-IA LEVEL II
2. John H. O'Leary TC-IA LEVEL I
REVIEWED BY [Signature] DATE 10/17

ADDITIONAL REMARKS

3/4 T - 3.4 @ 80% @ 54db
ID - 5.2

[Signature] NYPA 511
10/18/84

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 4

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NYPA

PROJECT JA FITZPATRICK

Data Sheet # JAF-028/A

SUBJECT 12-02-2-69 RECIRCULATION SYSTEM LOOP B





UNITED STATES TESTING COMPANY, INC.

12-02-7-69


101 17 184
Date

RADIOGRAPHIC EXAMINATION REPORT

Customer <u>NYP&</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS RT-1/1</u>
Location <u>JAFNPP</u>	Specimen Description <u>WELD</u>
Purchase order no. <u>NYO-82-246</u>	Material Type <u>S/S</u>
Work request no. <u>N/A</u>	Dia./Thickness <u>12.75 / .688</u>
Welder I. D. <u>7 + 4</u>	Specimen I. D. <u>RECIRC WELD 21A</u>

Procedure Data

Gamma	X-Ray	Penetrometer Designation <u>15F</u>
Source Type <u>IR 192</u>	Machine Mfg. <u>N/A</u>	Required Sensitivity/Essential Hole <u>2-4T</u>
Curies <u>84</u>	Kilovoltage	Shim Thickness <u>.063</u>
Physical Size <u>8X8</u>	Milliamperage <u>N/A</u>	Pb Screens: Front <u>.010</u> Back <u>.010</u>
Effective Size <u>.177</u>	Focal Spot Size	Source to Film Distance <u>12.75</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness <u>.010</u>
Film Size <u>4 1/2 X 17</u>	Total No. Film <u>8</u>	Exposure Time <u>5m.</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrometer	Weld		
21A	0-10				✓	✓	✓			ARTIFACTS	3.0	2.55-3.0	✓	
	10-20				✓	✓				" "	3.0	2.8-3.1	✓	
	20-30				✓	✓	✓	✓		" "	3.6	3.3-3.6	✓	
	30-0					✓	✓	✓		" "	2.9	2.4-3.1	✓	

Acceptance Criteria: Code/Addenda/Class-

ASME III 68

Remarks:

Radiographed By:

Interpreted By:

Customer Review

R Koontz II 10-17-84
Date

[Signature] III 10-17-84
Name Level Date



REPORT OF UT INSPECTION

PAGE 1 OF 4
REPORT NO. JAF 101984-
DATE 101884

CLIENT New York Power Authority
LOCATION James A. Fitzpatrick

WELD IDENTIFICATION NO. 12-02-2-69 DRAWING NO. N.A.
TYPE OF WELDING Pipe to Safe End MATERIAL: BASE SS WELD SS
SIZE OF PIPE 12" O.D. INCHES WALL THICKNESS 0.67 INCHES
SURFACE CONDITION OF PIPE ground OF WELD Ground
WELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 126 °
METHOD OF EXAMINATION: AUTOMATIC / MANUAL X SEMI-AUTO -
UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes
form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60		SBI SLIC 40	SUSA SUS 423	KK MWB 70
SERIAL NO.	1.03						
TRANSDUCER SIZE (MM) 4x4mm	8x9	8x9	8x9		2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	68°/32°						
EXIT POINT (MM) 4x4mm	12/10						
REMARKS:	mode-conversion	shear	shear		long-shear	shear	shear

	AUTOMATIC	MANUAL
EQUIPMENT MODEL NO.		KK USK 7
SERIAL NUMBER		27274-2606
CALIBRATION DATE		08-23-84
CABLE TYPE		Coax
CABLE LENGTH		2 meter

COUPLING ULTRAGEL II
MFG. TECHNICARE-ECHO, Inc
B. ACCT. NO. #8443

PERSONNEL PERFORMING EXAMINATION :

NAME <u>U. Schwanke</u>	LEVEL <u>I</u>	SIGNATURE <u>[Signature]</u>
NAME <u>H. P. Theelen</u>	LEVEL <u>I</u>	SIGNATURE <u>[Signature]</u>
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 4
 REPORT NO. JAF 101984-1
 DATE 10-19-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	40	34	30	25	20	15	10	~

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 \pm 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1763-82384



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A 376-.66

DRAWING NUMBER N.A.

MATERIAL SS 304


REFERENCE REFLECTORS 10% Notch ID

REFERENCE REFLECTORS Edge I.D

REFERENCE REFLECTORS Back wall

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM)(INCHES)

RECHECK DATA

CAL. BLOCK ~ S/N ~ REF. REFL. ~ TEMP. ~ °F

REF. BLOCK 12 A 376-.66 S/N ~ REF. REFL. 10% notch ID TEMP. 115 °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
<u>U. Schwanke</u>	<u>8:45</u>	<u>SE2 48 dB 80% FSH</u>	<u>3.6</u>
<u>U. Schwanke</u>	<u>10:05</u>	<u>SE2 48 dB 80% FSH</u>	<u>3.6</u>

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 4
 REPORT NO. JAF 101984-1
 DATE 10-18-84



DAC DATA

PROBE NO.	REFERENCE REFLECTOR	METAL PATH (MM)	AMPLITUDE (DB)	CALIBRATION BLOCK NO.	REMARKS
			80% FSH		
1	10% notch I.D.	36	48	12-A.376-.66	SE2
	Edge I.D.	37	42	"	SE2
	Backwall	34	48	"	SE1
2					
3					
4					
5					
6					




12-02-2-09
 Post IHSI

REFERENCE POINT LOCATION TOP OF THE PIPE

DETERMINATION OF CRACK LENGTH

EXAM NO.	PROBE NO.	IND NO.	REFLECTOR POSITION/MM				Z DEPTH POS. FROM SURFACE % OF 'T.		EVALUATION % OF 'T.	ECHO HEIGHT DIFF. dB	METAL PATH MM
			Y LINEAR EXTEND FROM REFERENCE	AT MAX	END	X LINEAR EXTEND FROM WELD CT LINE	START	END			
7	1	÷	0	0	0	15	35	70	÷	SE 2	42
1	1	÷	230	300	520	÷	÷	÷	÷	SE 2/SE 1	29 / 37
1	1	÷	775	800	800	÷	÷	÷	÷	SE 2/SE 1	35 / 36
1	1	÷	900	920	920	÷	÷	÷	÷	SE 2/SE 1	28 / 36
1	1	÷	560	570	570	÷	÷	÷	÷	SE 2/SE 1	35 / 37
1	1	÷	0	-	1035	INTERMITTENT		÷	÷	< 10	7-16



EXAMINER ICH WADDE / THEELEN LEVEL II
 SIGNATURE [Signature]

AUTHORIZED INSPECTOR _____ (IF REQUIRED)

CLIENT [Signature] JAF 101984 (IF REQUIRED)

Weld 12-02-2-69

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
0.00	0.0000	0.6700	0.670
0.25	0.1000	0.5700	0.670
0.50	0.2000	0.4700	0.670
0.75	0.3000	0.3700	0.670
1.00	0.4000	0.2700	0.670
1.25	0.4125	0.2575	0.670
1.50	0.4250	0.2450	0.670
1.75	0.4375	0.2325	0.670
2.00	0.4500	0.2200	0.670
2.25	0.4750	0.1950	0.670
2.50	0.5000	0.1700	0.670
2.75	0.5250	0.1450	0.670
3.00	0.5500	0.1200	0.670
3.25	0.5750	0.0950	0.670
3.50	0.6000	0.0700	0.670
3.75	0.6250	0.0450	0.670
4.00	0.6500	0.0200	0.670
4.25	0.6500	0.0200	0.670
4.50	0.6500	0.0200	0.670
4.75	0.6500	0.0200	0.670
5.00	0.6500	0.0200	0.670
5.25	0.6500	0.0200	0.670
5.50	0.6500	0.0200	0.670
5.75	0.6500	0.0200	0.670
6.00	0.6500	0.0200	0.670
6.25	0.6325	0.0375	0.670
6.50	0.6150	0.0550	0.670
6.75	0.5975	0.0725	0.670
7.00	0.5800	0.0900	0.670
7.25	0.5600	0.1100	0.670
7.50	0.5400	0.1300	0.670
7.75	0.5200	0.1500	0.670
8.00	0.5000	0.1700	0.670
8.25	0.4500	0.2200	0.670
8.50	0.4000	0.2700	0.670
8.75	0.3500	0.3200	0.670
9.00	0.3000	0.3700	0.670
9.25	0.3125	0.3575	0.670
9.50	0.3250	0.3450	0.670
9.75	0.3375	0.3325	0.670
10.00	0.3500	0.3200	0.670
10.25	0.3750	0.2950	0.670
10.50	0.4000	0.2700	0.670
10.75	0.4250	0.2450	0.670
11.00	0.4500	0.2200	0.670
11.25	0.4125	0.2575	0.670
11.50	0.3750	0.2950	0.670
11.75	0.3375	0.3325	0.670
12.00	0.3000	0.3700	0.670
12.25	0.3000	0.3700	0.670

Weld 12-02-2-69

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
12.50	0.3000	0.3700	0.670
12.75	0.3000	0.3700	0.670
13.00	0.3000	0.3700	0.670
13.25	0.3300	0.3400	0.670
13.50	0.3600	0.3100	0.670
13.75	0.3900	0.2800	0.670
14.00	0.4200	0.2500	0.670
14.25	0.4150	0.2550	0.670
14.50	0.4100	0.2600	0.670
14.75	0.4050	0.2650	0.670
15.00	0.4000	0.2700	0.670
15.25	0.3900	0.2800	0.670
15.50	0.3800	0.2900	0.670
15.75	0.3700	0.3000	0.670
16.00	0.3600	0.3100	0.670
16.25	0.3825	0.2875	0.670
16.50	0.4050	0.2650	0.670
16.75	0.4275	0.2425	0.670
17.00	0.4500	0.2200	0.670
17.25	0.4625	0.2075	0.670
17.50	0.4750	0.1950	0.670
17.75	0.4875	0.1825	0.670
18.00	0.5000	0.1700	0.670
18.25	0.5125	0.1575	0.670
18.50	0.5250	0.1450	0.670
18.75	0.5375	0.1325	0.670
19.00	0.5500	0.1200	0.670
19.25	0.5575	0.1125	0.670
19.50	0.5650	0.1050	0.670
19.75	0.5725	0.0975	0.670
20.00	0.5800	0.0900	0.670
20.25	0.5850	0.0850	0.670
20.50	0.5900	0.0800	0.670
20.75	0.5950	0.0750	0.670
21.00	0.6000	0.0700	0.670
21.25	0.6125	0.0575	0.670
21.50	0.6250	0.0450	0.670
21.75	0.6375	0.0325	0.670
22.00	0.6500	0.0200	0.670
22.25	0.6500	0.0200	0.670
22.50	0.6500	0.0200	0.670
22.75	0.6500	0.0200	0.670
23.00	0.6500	0.0200	0.670
23.25	0.6375	0.0325	0.670
23.50	0.6250	0.0450	0.670
23.75	0.6125	0.0575	0.670
24.00	0.6000	0.0700	0.670
24.25	0.6000	0.0700	0.670
24.50	0.6000	0.0700	0.670
24.75	0.6000	0.0700	0.670

Weld 12-02-2-69

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
25.00	0.6000	0.0700	0.670
25.25	0.6000	0.0700	0.670
25.50	0.6000	0.0700	0.670
25.75	0.6000	0.0700	0.670
26.00	0.6000	0.0700	0.670
26.25	0.6000	0.0700	0.670
26.50	0.6000	0.0700	0.670
26.75	0.6000	0.0700	0.670
27.00	0.6000	0.0700	0.670
27.25	0.6125	0.0575	0.670
27.50	0.6250	0.0450	0.670
27.75	0.6375	0.0325	0.670
28.00	0.6500	0.0200	0.670
28.25	0.6150	0.0550	0.670
28.50	0.5800	0.0900	0.670
28.75	0.5450	0.1250	0.670
29.00	0.5100	0.1600	0.670
29.25	0.3825	0.2875	0.670
29.50	0.2550	0.4150	0.670
29.75	0.1275	0.5425	0.670
30.00	0.0000	0.6700	0.670
30.25	0.1200	0.5500	0.670
30.50	0.2400	0.4300	0.670
30.75	0.3600	0.3100	0.670
31.00	0.4800	0.1900	0.670
31.25	0.4675	0.2025	0.670
31.50	0.4550	0.2150	0.670
31.75	0.4425	0.2275	0.670
32.00	0.4300	0.2400	0.670
32.25	0.4600	0.2100	0.670
32.50	0.4900	0.1800	0.670
32.75	0.5200	0.1500	0.670
33.00	0.5500	0.1200	0.670
33.25	0.5750	0.0950	0.670
33.50	0.6000	0.0700	0.670
33.75	0.6250	0.0450	0.670
34.00	0.6500	0.0200	0.670
34.25	0.6125	0.0575	0.670
34.50	0.5750	0.0950	0.670
34.75	0.5375	0.1325	0.670
35.00	0.5000	0.1700	0.670
35.25	0.4500	0.2200	0.670
35.50	0.4000	0.2700	0.670
35.75	0.3500	0.3200	0.670
36.00	0.3000	0.3700	0.670
36.25	0.3050	0.3650	0.670
36.50	0.3100	0.3600	0.670
36.75	0.3150	0.3550	0.670
37.00	0.3200	0.3500	0.670
37.25	0.3525	0.3175	0.670

Weld 12-02-2-69

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
37.50	0.3850	0.2850	0.670
37.75	0.4175	0.2525	0.670
38.00	0.4500	0.2200	0.670
38.25	0.4125	0.2575	0.670
38.50	0.3750	0.2950	0.670
38.75	0.3375	0.3325	0.670
39.00	0.3000	0.3700	0.670
39.25	0.2950	0.3750	0.670
39.50	0.2900	0.3800	0.670
39.75	0.2850	0.3850	0.670
40.00	0.2800	0.3900	0.670
40.25	0.2100	0.4600	0.670
40.50	0.1400	0.5300	0.670
40.75	0.0700	0.6000	0.670
41.00	0.0000	0.6700	0.670

Weld 12-02-2-75

EET NO: JAF-81-005
 DATE: 11/22/81
 TIME: 1100
 NR

MIT: JAFUPP
 COMPONENT: Piping, welds
 KAMINER: George Sedore
 COUPLANT: ACRAGECEL II
 KAMINER: [Signature]
 COUPLANT ID #: 5443

SYSTEM: 02-2/Rovine
 LEVEL: III
 ID #: 51765
 LEVEL: IV
 ID #: 278

CALIBRATION BLOCK
 ID #: CTD-1376-25
 LENGTH: IN. PL. MHZ
 OD: IN. PL. SIZE PXPear #1
 THICKNESS: IN. ACTUAL A. 45.0

CRYSTAL
 ID #: 53825
 TYPE: ALNB
 FREQ. MHZ
 SIZE PXPear #1
 ACTUAL A. 45.0

SYSTEM CALIBRATION
 ANGLE 45° MODE SCANS
 SEARCH UNIT CABLE
 TYPE: Buckeye LENGTH: 6'

CAL. BLOCK TEMP. F°
 CAL. BLOCK SIMULATOR TEMP. F°
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 76 FOR PIPING)

FIGURE NO(S). EXAMINED
 12-02-2-12
 12-02-2-17
 12-02-2-23
 12-02-2-64
 12-02-2-58
 12-02-2-75
 12-02-2-81

CALIBRATION CONFIRMATION
 HRS. IN. %
 HRS. IN. %
 HRS. IN. %
 HRS. IN. %
 HRS. IN. %
 HRS. IN. %

REVIEWED BY: [Signature]
 DATE REVIEWED: [Signature]
 SK-JAF-81-011

INSTRUMENT: 210586
 LINEARITY CHECK: YES NO
 REJECT: OFF %DB
 AAT'L CAL: 182
 DELAY: 678
 PULSE ENERGY: S.F.D.
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 12
 FINE GAIN: 10 %
 SCREEN RANGE: 2.5
 SCREEN DEPTH: 1.0 IN.
 T&R OPERATION
 NORMAL FREQUENCY: 5 MHZ
 REF: [Waveform] DISPLAY
 REP. RATE: 15
 ZERO CONTROL: 0 *
 DAMPING: OFF
 GAIN: [Waveform] DAC
 DLY: [Waveform] SLP: [Waveform] POLARITY: [Waveform] WIDTH: [Waveform] DELAY: [Waveform] ECHO START
 NORMAL FIRST ECHO

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES	HRS	IN.	%	HRS	IN.	%	HRS	IN.	%	HRS	IN.	%
10" 18-NODE	100+	50% ± 0.10 IN.	1400	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%
15" 18-NODE	100+	60% ± 0.15 IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%
20" 18-NODE	100+	40% ± 0.20 IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%
25" 18-NODE	100+	40% ± 0.25 IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%
30" 18-NODE	100+	30% ± 0.30 IN.	100	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%
35" 18-NODE	100+	25% ± 0.35 IN.	100	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%
TOP NOTCH	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%
OPPOSITE NOTCH	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%
BKR-CB	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%
BKR-P	%	IN.	%	IN.	%	%	IN.	%	%	IN.	%	%	IN.	%

INITIALS: [Signature]
 BKR CB (BACK REFLECTION FROM CAL. BLOCK) & BKR P (BACK REFLECTION FROM PART)
 REVIEWED BY: [Signature] LEVEL: [Signature]



REPORT OF UT INSPECTION

PAGE 1 OF 6
REPORT NO. JAF10/684-1
DATE 10-16-84

CLIENT New York Power Authority
LOCATION James A. Fitzpatrick

WELD IDENTIFICATION NO. 12-02-2-75 DRAWING NO. N.A.
TYPE OF WELDING PIPE TO SAFE END MATERIAL: BASE SS WELD SS
SIZE OF PIPE 12" O.D. INCHES WALL THICKNESS _____ INCHES
SURFACE CONDITION OF PIPE ground OF WELD ground
WELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 125 °F
METHOD OF EXAMINATION: AUTOMATIC ÷ MANUAL ÷ SEMI-AUTO ROBBY
UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes
form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60		SB SLIC40	SUS428	KK MWB 70
SERIAL NO.	V#7	V#2	V#2				
TRANSDUCER SIZE (MM) (+INCHES)	8x9	8x9	8x9		2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	68°/32°	44°	57°				
EXIT POINT (MM) (+INCHES)	12/10	13	13				
REMARKS:	mode-conversion	shear	shear		long-shear	shear	shear

EQUIPMENT MODEL NO.
SERIAL NUMBER
CALIBRATION DATE
CABLE TYPE
CABLE LENGTH

	AUTOMATIC	MANUAL
		UK USK 7
		27274-2613
		09-10-84
		TRIAXIAL
		50m

COUPLING ULTRAGEL II
MFG. TECHNICARE-ECHO, Inc.
B. ACCT. NO. # 8443

PERSONNEL PERFORMING EXAMINATION :

NAME <u>U. HORSTHEMKE</u>	LEVEL <u>II</u>	SIGNATURE <u>[Signature]</u>
NAME <u>U. SCHWANKE</u>	LEVEL <u>I</u>	SIGNATURE <u>[Signature]</u>
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF 10/684-1
 DATE 10-16-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	40	35	30	25	20	15	10	5

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 \pm 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1776-9/084



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A376-.66

DRAWING NUMBER n.a.

MATERIAL SS 304


REFERENCE REFLECTORS 10% NOTCH ID

REFERENCE REFLECTORS EDGE ID

REFERENCE REFLECTORS BACK WALL

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA PROBE NR. 1

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM) (INCHES)

RECHECK DATA

CAL. BLOCK ✓ S/N ✓ REF. REFL. ✓ TEMP. ✓ °F

REF. BLOCK 12-A376-.66 S/N ✓ REF. REFL. 10% NOTCH ID TEMP. 110 °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
<u>Horsthemke</u>	<u>10:00</u>	<u>SE 2 46dB 80% FSH</u>	<u>3.7</u>
<u>Horsthemke</u>	<u>13:30</u>	<u>SE 2 46dB 80% FSH</u>	<u>3.7</u>

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 6
 REPORT NO. JAF101684-1
 DATE 10-16-84



DAC DATA

PROBE NO.	REFERENCE REFLECTOR	METAL (MM) PATH (TH)	AMPLITUDE (DB) 80% FSH	CALIBRATION BLOCK NO.	REMARKS
1	10% NOTCH ID	37	46	12-A376-.66	SE 2
	EDGE ID	39	40	-4-	SE 2
	BACKWALL	34	46	-4-	SE 1
2	10% NOTCH ID	22	24	12-A376-.66	1/2 V-PATH
	10% NOTCH OD	46	26	-4-	2/2 V-PATH
	10% NOTCH ID	68	30	-4-	3/2 V-PATH
3	10% NOTCH ID	30	40	12-A376-.66	1/2 V-PATH
4					
5					
6					



UT-INSPECTION -IGSCC-

Weld Identification No 12-02-2-75


Signal No Indication No. 1

Coordinate from reference point "Y" 340mm

Probes Used	Probe No.	Signal No.
Wall Thickness	MSEB 4H	
Root Center	20,5 mm	
Other Data	1	1, 2
	2	3
	3	4, 5

INSPECTION CONTOUR

MM ← WCL → MM



INSPECTOR Schwanke, Horsthenke Level II

DATE 10.16.84

WCL
← INCHES →
1/16"

Report No. JAF 101684-1 page 6 of 6



UNITED STATES TESTING COMPANY, INC.


12-02-2-75

10/17/84
Date

RADIOGRAPHIC EXAMINATION REPORT

Customer: <u>NYP&</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS INC./RT1</u>
Location: <u>JAFNPP</u>	Specimen Description: <u>WELD</u>
Purchase order no.: <u>NYO 82 246</u>	Material Type: <u>S/S</u>
Work request no.:	Dia./Thickness: <u>12.750/.688</u>
Order I. D.: <u>7</u>	Specimen I. D.: <u>RECIRC WELD 17A</u>

Procedure Data			
Gamma	X-Ray <u>1A</u>	Penetrameter Designation <u>15F</u>	
Source Type <u>IR 192</u>	Machine Mfg.	Required Sensitivity/Essential Hole <u>2/4T</u>	
Series <u>36</u>	Kilovoltage	Shim Thickness <u>.093</u>	
Typical Size <u>1/8 x 3/32</u>	Milliamperage <u>N</u>	Pb Screens: Front <u>.010</u> Back <u>.010</u>	
Effective Size <u>.155</u>	Focal Spot Size	Source to Film Distance <u>12 3/4</u>	
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness	
Film Size <u>4 1/2 x 17</u>	Total No. Film <u>8</u>	Exposure Time	



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetrometer	Weld		
17A	0-10						✓	✓	✓	ARTIFACTS	3.3	2.75-3.1		
	10-20					✓				"	3.1	2.7-3.0	✓	
	20-30									"	3.25	2.6-3.1		
	30-0						✓	✓	✓	✓	"	3.5	2.8-3.3	

Acceptance Criteria: Code/Addenda/Class-

Remarks: FILM 0-10 DENSITIES DO NOT LIE WITHIN THE -15% +30%
 20-30 CALLED FOR BY UST-RT-EG REV1 AND ASME CODE
 30-0
 NO COPY OF RCI RT1 IS AVAILABLE AT THIS TIME

Radiographed By:

Interpreted By:

Customer Review

RK... II 10/17/84
Date

[Signature] III 10/17/84
Name Level Date

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT JAF Fitzpatrick
DATA SHEET NO. JAF-0901A DATE 10-13-84
PROCEDURE JAF-UT-5 NH112 REV 3

COMPONENT OR SYSTEM Recirculation Loop "B" PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S), LISTED ON REVERSE SIDE - COMPONENT TEMP 122°F
CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 120°F

SCAN COVERAGE


WHAZ BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT
Manufacturer Aerotech
Style Gamma
Serial No. E14112
Size 0.5" Dia Frequency 2.25 MHz
Angle 62° Mode Shear
Couplant Ultrasound II Batch No. 8439

INSTRUMENT
Manufacturer KrautKramer Branson Model USL-38
Serial No. 210571 Cable Length 6'
Frequency 2.5 MHz Reject OFF
Rep Rate N/A Damping OFF
dB Gain - Coarse 20 Fine 34
Primary Reference Response Amplitude % Full Screen Height 80%

DAC PLOT - TIME 1530 AM (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (3dB) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1910	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER(S)
1. [Signature] TC-IA LEVEL III
2. [Signature] TC-IA LEVEL I
REVIEWED BY [Signature] DATE 10/17/84

ADDITIONAL REMARKS

[Signature] NYPAA III
10/17/84

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 SERVICE INSPECTION
 INDICATION DATA

SHEET 2 OF 3
 ITEM IDENTIFICATION 12-02-Z-75
 CALIBRATION DATA SHEET NO. JAF-090/A

DATA TABULATION

ST. BEAM	SCAN DIRECTION		INDICATION NO.	EXAM. ON WELD SIDE	MAX % DAC	SWEEP READING	SEARCH POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE				STRAIGHT BEAM (CAL ON BACK REFLECTION)		
	CIRCUMFERENTIAL	AXIAL					CIRCUMFERENTIAL (DISTANCE C/W OR C/CW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD)	MINIMUM SWEEP READING	S.U. POSITION	MAXIMUM SWEEP READING	S.U. POSITION	INDICATION AMPLITUDE (% FSH)	BACK REFLECTION AMPLITUDE (% FSH)	
N/A	N/A	✓	1	PIPE	31	32	0° TD	0.6"	—	—	—	—	—	—	—
N/A	N/A	✓	2	PIPE	100	47	0° TD	0.7"	—	—	—	—	—	—	—
N/A	N/A	✓	3	PIPE	25	40	1" CW	0.6"	—	—	—	—	—	—	—
N/A	N/A	✓	4	PIPE	25	27	3 1/2" CW	0.6"	—	—	—	—	—	—	—
N/A	N/A	✓	5	PIPE	38	30	25" CW	0.6"	—	—	—	—	—	—	—
N/A	N/A	✓	6	PIPE	25	35	30 1/2" CW	0.6"	—	—	—	—	—	—	—
N/A	N/A	✓	7	PIPE	25	35	36" CW	0.6"	—	—	—	—	—	—	—
RESULTS															
INDICATION NO.		LOCATION OF INDICATION		LENGTH		DEPTH (IF PLANAR)		WIDTH (IF LAMINAR)		COMMENTS					
		CIRC AXIAL								60° Indications intermittent 360° base material (AMZ). * MEASUREMENTS TAKEN AT TOE OF WELD					

EXAMINER(S)
 1. Robert Briggs
 2. Robert Briggs
 REVIEWED BY Thurmond III

TC-1A LEVEL III
 TC-1A LEVEL I
 DATE 10/17/84

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 3

CHKD. BY _____ DATE _____

OFS NO. _____ DEPT. NO. _____


CLIENT NYPA

PROJECT JA. FITZPATRICK

Data Sheet # JAF-090/H

SUBJECT 12-02-2-75

RECIRCULATION SYSTEM Loop B



**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT JA. FITZPATRICK
 DATA SHEET NO. JAF-112/A DATE 10-18-82
 PROCEDURE JAF-UT-5 Add 1/2 REV 3

COMPONENT OR SYSTEM RECIRCULATION SYSTEM "B" LOOP PIPE OD (IF APPLICABLE) 12"
 ITEM IDENTIFICATION NO(S). LISTED ON REVERSE SIDE - COMPONENT TEMP 115°F
 CALIBRATION BLOCK NO. 12-A376 THICKNESS 0.66" TEMP 100°F

SCAN COVERAGE

0° WHAZ 0° BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA


SEARCH UNIT
 Manufacturer AEROTECH
 Style GAMMA
 Serial No. E14112
 Size 0.50" Frequency 2.25 MHZ
 Angle 61° Mode SHEAR

INSTRUMENT
 Manufacturer KRAUTKRAMER-BRANSON Model USL-38
 Serial No. 210571 Cable Length 6'
 Frequency 2.25 MHZ Reject OFF
 Rep Rate NA Damping OFF
 dB Gain - Coarse 40 Fine 12

Couplant ULTRAGEL II Batch No. 8439

Primary Reference Response Amplitude % Full Screen Height 80%

DAC PLOT - TIME 1600 AM, (PM)



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP + 10° OF INITIAL LOCATION	
	YES	NO	YES	NO
1715	 	1.9	 	1.2

NOTE: If response above is "NO" refer to Calibration section of procedure.

EXAMINER(S)
 1. Steve Smith TC-IA LEVEL
 2. John R. Ogilby TC-IA LEVEL
 REVIEWED BY Steve Smith DATE 10/18/82

ADDITIONAL REMARKS
34T-3.8 @ 80% @ 52dB
ID - 5.0
14T-6.6 @ 50%

Steve Smith NPPA-UT
10/19/82

SPRINK SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 CALIBRATION DATA

PROJECT JAF ISI Outage
 DATA SHEET NO. _____ DATE 10/12/04
 PROCEDURE INST. JAF UTS ^{add} 1.2 REV 3

COMPONENT OR SYSTEM Recirculation System Loop B PIPE OD (IF APPLICABLE) 12"
 IDENTIFICATION NO(S): LISTED ON REVERSE SIDE - COMPONENT TEMP 120°F EXAM. SURFACE 1/4 ID OD
 CALIBRATION BLOCK NO 12-A376 THICKNESS .66 TEMP 110°F

SCAN COVERAGE

1/4 WHAZ 1/4 BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA


SEARCH UNIT
 Manufacturer Nortec
 Style Z+-Z
 Serial No. 15462
 Size .50" Frequency 2.25 MHz
 Angle 43° Mode SHEAR

INSTRUMENT
 Manufacturer KRAUTKRAMER Model LASK 7
 Serial No. 27276-1534 Coaxial Cable Length 6'
 Frequency BB Reject min
 Rep Rate N/A Damping N/A
 dB Gain - Coarse 20 Fine 20

Couplant Ultragel II Batch No. 8439

Primary Reference Response
 Amplitude % Full Screen Height 80%

DAC PLOT - TIME 8:00 AM PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2dB) OF INITIAL AMPL		SWEEP ± 5% OF INITIAL LOCATION	
	YES	NO	YES	NO
1145	✓	N/A	✓	N/A

NOTE: If response above is "NO" refer to Calibration Check section of procedure.

EXAMINER BY [Signature]
 1. [Signature] TC-1A LEVEL II
 2. [Signature] TC-1A LEVEL I
 REVIEWED BY [Signature] DATE 10/12/04

ADDITIONAL REMARKS
ID 3.6
3/4 2.6 80%
1/4 4.6 62%

[Signature] USPA III
10/19/04

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 3

CHKD. BY _____ DATE _____

OFFS NO. _____ DEPT. NO. _____


CLIENT NYPA

PROJECT JA FITZPATRICK

Data Sheet # JAF-111/A

SUBJECT 12-22-2-88

REGULATION SYSTEM Loop 3



VALIDATION SHEET

DATE: 10/15/84

SHEET NO: JAF-EM-001

UNIT: JAFPP
 EXAMINER: George Seabra
 EXAMINER: *[Signature]*

SYSTEM: 02-2/Revis
 ID #: 5-1765
 ID #: *[Signature]*

COMPONENT: piping welds
 COUPLANT: ARRAGES II
 COUPLANT ID #: 8443

LEVEL: III
 LEVEL: *[Signature]*

INSTRUMENT: 210586
 LINEARITY CHECK: YES NO
 REJECT: *[Signature]* %DB

MAT'L CAL: 182
 DELAY: 678
 PULSE ENERGY: S.F.A.
 COARSE GAIN IN DB: 40
 FINE GAIN IN DB: 12

CRYSTAL: 53875
 ID #: 53875
 TYPE: MUB
 FREQ: 4
 SIZE: PXP
 ACTUAL Δ: 45.0

SEARCH UNIT CABLE: *[Signature]* LENGTH 6'
 TYPE: *[Signature]*

CAL. BLOCK TEMP: F° *[Signature]*
 CAL. BLOCK SIMULATOR TEMP: F° *[Signature]*
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 75 FOR PIPING)

SYSTEM CALIBRATION

ANGLE 45° NODE *[Signature]*

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES
10° 18-NODE	100 ± %	50% ± 0.10 IN.
15° 18-NODE	100 ± %	60% ± 0.15 IN.
20° 18-NODE	100 ± %	40% ± 0.20 IN.
25° 18-NODE	100 ± %	40% ± 0.25 IN.
30° 18-NODE	100 ± %	30% ± 0.30 IN.
35° 18-NODE	100 ± %	25% ± 0.35 IN.
TOP NOTCH	%	IN
OPPOSITE NOTCH	%	IN
BKR-CB	%	IN
BKR-P	%	IN

FIGURE NO(S), EXAMINED:
 12-02-2-12
 12-02-2-17
 12-02-2-23
 12-02-2-64
 12-02-2-58
 12-02-2-75
 12-02-2-81

CALIBRATION CONFIRMATION

TIME	1400 HRS.		HRS.		HRS.		HRS.	
	BLOCK SIM.	BACK REFL.	15° 18-NODE	25° 18-NODE	35° 18-NODE	INITIALS	BKR CB (BACK REFLECTION FROM CAL BLOCK)	BKR P (BACK REFLECTION FROM PART)
	%	IN.	%	IN.	%	IN.	%	IN.
	%	IN.	%	IN.	%	IN.	%	IN.
	100%	IN.	%	IN.	%	IN.	%	IN.
	100%	IN.	%	IN.	%	IN.	%	IN.
	100%	IN.	%	IN.	%	IN.	%	IN.
	INITIALS: <i>[Signature]</i>							

CALIBRATION SHEET

DATE: 10/15/84

SET NO.: JAF 5142-009
 IT: JAF SUPP

TIME: 1:00 PM

SYSTEM: 02-2/REGIRS.
 COMPONENT: PIPE WELDS
 COUPLANT: GUMMERS
 COUPLANT ID #: 8443

LEVEL: III
 LEVEL: II

CALIBRATION BLOCK SIMULATOR
 SERIAL NO. _____ SCREEN RANGE _____ IN.
 SIGNAL AMP _____ % SCREEN READING _____ IN.
 COURSE GAIN DB _____ FINE GAIN DB _____

CRYSTAL
 ID# 84-88
 TYPE RTD
 FREQ 2 MHZ
 SIZE 6 X 13 X 4 IN.
 ACTUAL Δ 73 °

CALIBRATION BLOCK
 ID# 570-A376-.15 IN.
 LENGTH: 12 IN.
 OD: 1.25 IN.
 THICKNESS: .75 IN.

SEARCH UNIT CABLE
 TYPE DABE LENGTH 6'
 CAL. BLOCK TEMP. F° N
 CAL. BLOCK SIMULATOR TEMP. F° N
 (REQUIRED SUMMER 73 FOR VESSELS
 REQUIRED WINTER 76 FOR PIPING)

SYSTEM CALIBRATION
 ANGLE 23 ° NODE Large Technical

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES Δ
.1 1B-NODE	100 %	.3 SD. IN.
.2 1B-NODE	90 %	.4 SD. IN.
.3 1B-NODE	70 %	.5 SD. IN.
.4 1B-NODE	55 %	.6 SD. IN.
.5 1B-NODE	40 %	.7 SD. IN.
.6 1B-NODE	30 %	.8 SD. IN.
TOP NOTCH	N/A	N/A
OPPOSITE NOTCH	N/A	N/A
BKR. CB	N/A	N/A
BKR. P	N/A	N/A

REFLECTOR	AMPLITUDE % OF FULL SCREEN	SCREEN READING IN INCHES Δ
12-02-2-12		
12-02-2-17		
12-02-2-23		
12-02-2-64		
12-02-2-58		
12-02-2-75		
12-02-2-81		

FIGURE NO(9), EXAMINED

CALIBRATION CONFIRMATION

TIME	BLOCK SIM.	BACK REFL.	1B-NODE	3B-NODE	5B-NODE	INITIALS
1:00	% IN.	% IN.	100% .3 SD. IN.	80% .5 SD. IN.	50% .7 SD. IN.	84-88
	% IN.	% IN.	% IN.	% IN.	% IN.	
	% IN.	% IN.	% IN.	% IN.	% IN.	
	% IN.	% IN.	% IN.	% IN.	% IN.	
	% IN.	% IN.	% IN.	% IN.	% IN.	

INSTRUMENT

210568
 NEARITY CHECK YES NO
 EJECT: OFF
 ATT. CAL: 966
 ELAY: 0822
 ULSE ENERGY: 0.7
 COURSE GAIN IN DB: 40
 FINE GAIN IN DB: 22
 FINE GAIN: 15 %
 GREEN RANGE: .5
 GREEN DEPTH: 60 IN.
 FOR OPERATION
] NORMAL } 2.5 MHZ
] RF }
 REP. RATE: 1K
 ZERO CONTROL: 0 *
 DAMPING: OFF

GAIN: _____
 DLY: _____
 SLP: _____
 POLARITY: _____
 WIDTH: _____
 DELAY: _____
 GATE: _____
 ECHO START
 FIRST ECHO

BKR CB (BACK REFLECTION FROM CAL. BLOCK) & BKR P (BACK REFLECTION FROM PART) DATE REVIEWED
 SK-JAF-81-011



REPORT OF UT INSPECTION

PAGE 1 OF 6
REPORT NO. JAF 10/684-2
DATE 10-16-84

CLIENT New York Power Authority
LOCATION James A. Fitzpatrick

WELD IDENTIFICATION NO. 12-02-2-81 DRAWING NO. N.A.
TYPE OF WELDING PIPE TO SAFE END MATERIAL: BASE SS WELD SS
SIZE OF PIPE 12" O.D. INCHES WALL THICKNESS _____ INCHES
SURFACE CONDITION OF PIPE ground OF WELD ground
WELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 125 °F
METHOD OF EXAMINATION: AUTOMATIC _____ MANUAL X SEMI-AUTO _____
UT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes
form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60	RTD SEL 70	SRI SLIC 40	SUS 423	KK MWB 70
SERIAL NO.	1.03	V#3	V#3	80-580	019		
TRANSDUCER SIZE (MM) (INCHES)	8x9	8x9	8x9	2(7x15)	2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	68°/32°	44°	57°	70°	E 40		
EXIT POINT (MM) (INCHES)	12/10	13	13	9	N.A.		
REMARKS:	mode-conversion	shear	shear	high-angle long	long-shear	shear	shear

EQUIPMENT MODEL NO.
SERIAL NUMBER
CALIBRATION DATE
CABLE TYPE
CABLE LENGTH

AUTOMATIC	MANUAL
	KK-USX 7
	27274-2606
	08-23-84
	COAXIAL
	2m

COUPLING ULTRAGEL II
MFG. TECHNICAPE-ECHO, Inc.
B. ACCT. NO. # 8443

PERSONNEL PERFORMING EXAMINATION:

NAME <u>M. DALICHOW</u>	LEVEL <u>II</u>	SIGNATURE <u>[Signature]</u>
NAME <u>U. SCHWANKE</u>	LEVEL <u>II</u>	SIGNATURE <u>[Signature]</u>
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____
NAME _____	LEVEL _____	SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF 101684-2
 DATE 10-16-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	30	45	40	34	30	25	20	15	10	÷

SIGNAL 2 SHALL EQUAL 30% OF SIGNAL 1 ± 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1763-92384



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A376-.66

DRAWING NUMBER n.s.

MATERIAL SS 304


REFERENCE REFLECTORS 10% NOTCH ID

REFERENCE REFLECTORS EDGE ID

REFERENCE REFLECTORS BACK WALL

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM) (INCHES)

RECHECK DATA

CAL. BLOCK ÷ S/N ± REF. REFL. ÷ TEMP. ÷ °F

REF. BLOCK 12-A376-.66 S/N ± REF. REFL. 10% NOTCH ID TEMP. 115 °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE)	SWEEP RANGE
M. DALICHOW	10:00	SE 2 48 dB 80% FSII	3.6
U. SCHWANKE	13:30	SE 2 48 dB 80% FSII	3.6
U. SCHWANKE	17:00	SE 2 UN DR 80% FSII	3.6

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 6
 REPORT NO. JAF 101684-2
 DATE 10-16-84



DAC DATA

PAGE NO.	REFERENCE REFLECTOR	METAL PATH (MM) (+/-)	AMPLITUDE (DB) 80% FSH	CALIBRATION BLOCK NO.	REMARKS
1	10% NOTCH ID	36	48	12-A376-.66	SE 2
	EDGE ID	37	42	-4-	SE 2
	BACKWALL	34	48	-4-	SE 1
2	10% NOTCH ID	22	26	12-A376-.66	1/2 V-PATH
	10% NOTCH OD	45	32	-4-	2/2 V-PATH
	10% NOTCH ID	69	34	-4-	3/2 V-PATH
3	10% NOTCH ID	28	40	12-A376-.66	1/2 V-PATH
4	90% NOTCH	2.5 DEPTH / r. OD	60	EDM-CAL-25mm	PA 14 mm
	80% NOTCH	5.0 -8-	62	-4-	PA 18 mm
	70% NOTCH	7.5 -4-	64	-4-	PA 23 mm
	60% NOTCH	100 -4-	66	-4-	PA 25 mm
5	20% NOTCH ID	20.0mm DEPTH / r. OD	70	EDM-CAL-25mm	CALCULATE FOR 17 mm WALL THICKNESS
6					




TOP OF PIPE

REFERENCE POINT LOCATION

EXAM NO.	PROBE SER. NO.	IND NO.	REFLECTOR POSITION/MM				Z DEPTH POS. FROM SURFACE % OF 'T'	EVALUATION % OF 'T'	ECHO HEIGHT db	METAL PATH MM	
			Y LINEAR EXTEND FROM REFERENCE	X LINEAR EXTEND FROM WELD CT LINE	START	END					
			START	END	AT MAX		START	END	CLASS	SIZ.	DAC/BW

No reportable indications (Geometry)



EXAMINER William Schubert
 SIGNATURE [Signature]
 AUTHORIZED INSPECTOR [Signature]
 CLIENT [Signature] (IF REQUIRED)
[Signature] (IF REQUIRED)




DATA STANDARD REPORT OF INDICATION NUMBER 1

SIGNAL NO.	PROBE NO.	ANGLE OF INCIDENT	EXAM NO.	EXIT X	POINT Y	GAIN DB 100% DAC	METAL PATH	REMARKS
1	1	68°/32°	1	31	280	64	40	} GEOMETRY
2	2	44°	1	33	280	50	24	
3	3	57°	1	30	280	58	35	ROOT

DEGREES
180 360

LOCATION OF DEFECT ON CIRCUMFERENCE OF PIPE



EXAMINER Jalichow / Schwanke LEVEL II
LEVEL III
REVIEWED BY William E. Shetter DATE 10-17-84
AUTHORIZED INSPECTOR _____

* THE ABOVE GRAPH REPRESENTS THE POSITION OF THE DEFECT IN RELATIONSHIP TO THE WELD CENTERLINE.




UT-INSPECTION -ICSCC-
 Weld Identification No. 12-02-2-8/
 -Signal No- Indication No. 1
 Coordinate from reference point "Y" 280 mm

Probes Used	Probe No.	Signal No.
Wall Thickness	ASEB4H	
Root Center	21 mm	
Other Data	1	1
	2	2
	3	3

INSPECTION CONTOUR

MM → 9 ← MM
 WCL



+120 +110 100 +90 +80 +70 +60 +50 +40 +30 +20 +10 0 -10 -20 -30 -40 -50 -60 -70 -80 -90 -100 -110 -120

INSPECTOR Dalchow / Schwanke Level II

DATE 10-16-84

Report No. JAF 10/684-2 page 6 of 6



UNITED STATES TESTING COMPANY, INC.

12-02-2-81

101 17 1 84
Date

RADIOGRAPHIC EXAMINATION REPORT

Customer <u>NYPA</u>	R. T. Procedure/Rev. <u>REACTOR CONTROLS INC RTI</u>
Location <u>JAFNPP</u>	Specimen Description <u>WELD</u>
Purchase order no. <u>NYO 82-246</u>	Material Type <u>S/S</u>
Work request no. <u>N/A</u>	Dia./Thickness <u>12.75 / .585</u>
Welder I. D. <u>7</u>	Specimen I. D. <u>RECIRC WELD 13A</u>

Procedure Data

Gamma	X-Ray	Penetrometer Designation <u>15F</u>
Source Type <u>1R 192</u>	Machine Mfg. <u>N/A</u>	Required Sensitivity/Essential Hole <u>2 / 4T</u>
Curie <u>44</u>	Kilovoltage <u>N/A</u>	Shim Thickness <u>.093</u>
Physical Size <u>1/8 X 3/32</u>	Milliamperage <u>N/A</u>	Pb Screens: Front <u>.010</u> Back <u>.010</u>
Effective Size <u>.155</u>	Focal Spot Size <u>N/A</u>	Source to Film Distance <u>12.75</u>
Film Type <u>KODAK M</u>	No. Exposures <u>4</u>	Geometric Unsharpness <u>.009</u>
Film Size <u>4 1/2 X 17</u>	Total No. Film <u>8</u>	Exposure Time <u>9M.</u>



Specimen I. D.	Film Increment Number	Cracks	Incomplete Penetration	Incomplete Fusion	Slag Inclusion	Porosity	Root Concavity/Convexity	Undercut	Tungsten Inclusion	Other	Density		Accept	Reject
											Penetra-meter	Weld		
15F	0-10				✓		✓	✓		ARTIFACTS	2.9	2.7-2.9	✓	
	10-20									" "	3.0	2.5-2.75	✓	
	20-30							✓	✓	" "	3.1	2.4-2.9		
	30-0							✓	✓	" "	3.1	2.5-2.8		

Acceptance Criteria: Code/Addenda/Class- ASME III 65

Remarks: FILM 20-30 DENSITIES DO NO LIE WITHIN -15% + 30% SPECIFIC
 30-0 BY UST-RT EG Rev 1
 NO COPY OF RCI RT 1 IS AVAILABLE

Radiographed By:

Interpreted By:

Customer Review

R. K. ... II 10-17-84
Date

[Signature] III 10-17-84
Name Level Date

Weld 12-02-2-70

**EBASCO SERVICES INCORPORATED
QUALITY ASSURANCE ENGINEERING
INSERVICE INSPECTION
CALIBRATION DATA**

PROJECT JAF
DATA SHEET NO. JAF-076/A DATE 10-11-1
PROCEDURE JAF-UT-5 A11 1.2 REV 3

COMPONENT OR SYSTEM REGIRC LOOP B PIPE OD (IF APPLICABLE) 12"
ITEM IDENTIFICATION NO(S), LISTED ON REVERSE SIDE - COMPONENT TEMP 125° F
CALIBRATION BLOCK NO. 12-9376 THICKNESS .66" TEMP 110° F


SCAN COVERAGE

WHAZ OF BASE MATERIAL AXIAL CIRCUMFERENTIAL

EQUIPMENT DATA

SEARCH UNIT		INSTRUMENT	
Manufacturer	<u>K.R. AEROTECH</u>	Manufacturer	<u>KRAUTKRAMER</u> Model <u>USK 6</u>
Style	<u>GAMMA</u>	Serial No.	<u>27593 - 3923</u> Cable Length <u>6'</u>
Serial No.	<u>K02119</u>	Frequency	<u>B.B.</u> Reject <u>MIN</u>
Size	<u>.50" φ</u> Frequency <u>2.25 MHz</u>	Rep Rate	<u>N/A</u> Damping <u>N/A</u>
Angle	<u>60°</u> Mode <u>SHEAR</u>	dB Gain - Coarse	<u>20</u> Fine <u>8</u>
Couplant <u>ULTRAGEL II</u> Batch No. <u>8439</u>		Primary Reference Response	<u>80% 3/4 T</u>
		Amplitude % Full Screen Height	

DAC PLOT - TIME 9:00 AM, PM



NOTE: When performing examinations where no DAC is required, indicate reference reflector location and amplitude above.

CALIBRATION CHECKS

TIME	AMPL ± 20% (2σ) OF INITIAL AMPL		SWEEP + 10% OF INITIAL LOCATION	
	YES	NO	YES	NO
1230	✓	NA	✓	NA
1600	✓	NA	✓	NA

NOTE: If response above is "NO" refer to Calibration Ch section of procedure.

EXAMINER(S)

1. [Signature] TC-1A LEVEL III
2. [Signature] TC-1A LEVEL I
REVIEWED BY [Signature] DATE 10/1

ADDITIONAL REMARKS

IO 5.2
3/4 4.0 @ 80%
1/4 6.6 @ 60%

[Signature] 10/1/01
[Signature] 10/1/01

EBASCO SERVICES INCORPORATED
 QUALITY ASSURANCE ENGINEERING
 INSERVICE INSPECTION
 INDICATION DATA

SHEET 2 OF 2
 ITEM IDENTIFICATION 62-02-2-7C
 REGR. SYS. LOOP 5
 CALIBRATION DATA SHEET NO. IME-076/A

DATA TABULATION

ST. BEAM	SCAN DIRECTION		INDI-CA-TION NO.	EXAM. ON (ADJ SIDE OF WELD)	MAX % DAC	SWEEP READING	SEARCH POINT LOCATION		50% DAC OR HALF MAXIMUM AMPLITUDE				STRAIGHT BEAM (CAL ON BACK REFLECTION)	
	CIR-CUM-FERENTIAL	AXIAL					CIRCUMFERENTIAL (DISTANCE CW OR CCW FROM REFERENCE LINE)	AXIAL (DISTANCE FROM WELD)	MINIMUM SWEEP READING	S.U. POSITION	MAXIMUM SWEEP READING	S.U. POSITION	INDICATION AMPLITUDE (% FSH)	BACK REFLECTIO AMPLITUDE (% FSH)
N/A	N/A	✓	1	PIPE	100	3.7	11" CW	.6"	3.5	.5	5.6	.98	N/A	N/A
N/A	N/A	✓	2	PIPE	50	4.4	83 1/2" CW	.7"	N/A	N/A	N/A	N/A	N/A	N/A

INDICA-TION NO.	LOCATION OF INDICATION		LENGTH	% I		WIDTH (IF LAMINARI)	COMMENTS
	CIRC	AXIAL		DEPTH (IF PLANAR)	DISTANCE FROM SURFACE		
1	✓	N/A	3/8"	N/A	39%	N/A	MULTIPLE INDICATIONS IN BASE MATERIAL WITH SHORT SOUND PATH. - ALL MEASUREMENTS TAKEN FROM TOE TO WELD POINT.

RESULTS

EXAMINER(S)

1. *[Signature]* TC-1A LEVEL III
 2. *[Signature]* TC-1A LEVEL I
 REVIEWED BY *[Signature]* DATE 10/12/04

CONTINUATION ATTACHED - Yes No

EBASCO SERVICES INCORPORATED

BY _____ DATE _____

SHEET 3 OF 3

CHKD. BY _____ DATE _____


OFS NO. _____ DEPT. NO. _____

CLIENT NEW YORK POWER AUTHORITY

PROJECT J.A. FITPATRICK

SUBJECT 12-02-2-70 RECIRCULATION SYSTEM Loop 'A'

Data Sheet JAF-076/A



12-02-2-70

CROWN WIDTH ~ 1.1"

John R. O'Neil
Sv. I



REPORT OF UT INSPECTION

PAGE 1 OF 6REPORT NO. JAF 10/284-1CLIENT New York Power AuthorityDATE 10-11-84LOCATION James A. FitzpatrickWELD IDENTIFICATION NO. 12-02-2-70 DRAWING NO. U.A.TYPE OF WELDING ELBOW TO PIPE MATERIAL: BASE SS WELD SSSIZE OF PIPE 12" O.D. INCHES WALL THICKNESS 0.68 INCHESSURFACE CONDITION OF PIPE ground OF WELD groundWELDING PROCEDURE OR WELD RECORD n.a. TEMPERATURE 124 °FMETHOD OF EXAMINATION: AUTOMATIC MANUAL SEMI-AUTO ROBBYUT. PROCEDURE NO. UTL - UT - S - 1 Rev. 0 DATE 11-15-83 CLIENT APPROVAL yes

form rev. 1 dated 4-17-84

	PROBE NO. 1	PROBE NO. 2	PROBE NO. 3	PROBE NO. 4	PROBE NO. 5	PROBE NO. 6	PROBE NO. 7
PROBE TYPE AND/OR MANUFACTURER	KK WSY 70	KK MWB 45	KK MWB 60	RDU SEL-70	SRI SLIC40	SUSI SUS423	KK MWB 70
SERIAL NO.	V#7	V#2	#2	80-580	019		V#2
TRANSDUCER SIZE (MM) (INCHES)	8x9	8x9	8x9	2x7x15	2x 9.5	9.5	8x9
FREQUENCY MHZ	2	2	2	4	5	5	2
ANGLE OF INCIDENCE	62°/30°	44°	57°	70°	±40		66°
EXIT POINT (MM) (INCHES)	12/10	13	13	9	-		13
REMARKS:	mode-conversion	shear	shear	high-long-mode	long-shear	shear	shear

AUTOMATIC MANUAL

EQUIPMENT MODEL NO.

SERIAL NUMBER

CALIBRATION DATE

CABLE TYPE

CABLE LENGTH

	KK US47
	27274-2613
	09-10-84
	Triaxial
	50m

COUPLING ULTRAGEL IIMFG. TECHNICARE-ECHO, Inc.B. ACCT. NO. # 8330

PERSONNEL PERFORMING EXAMINATION :

NAME U. HORSTHEMKE LEVEL I SIGNATURE [Signature]NAME H. DALICHOW LEVEL II SIGNATURE [Signature]

NAME _____ LEVEL _____ SIGNATURE _____

NAME _____ LEVEL _____ SIGNATURE _____

NAME _____ LEVEL _____ SIGNATURE _____

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 2 OF 6
 REPORT NO. JAF101284-1
 DATE 10-11-84

LINEARITY CHECK

VERTICAL

SIGNAL 1	100	90	80	70	60	50	40	30	20	10
SIGNAL 2	50	45	41	35	30	25	20	15	10	-

SIGNAL 2 SHALL EQUAL 50% OF SIGNAL 1 \pm 5% OF FULL SCALE

ATTENUATOR

TESTER GAIN	SET	-6	-12	SET	+12	SET	+6
SIGNAL AMP	80%	32-48	16-24	20%	64-96	40%	64-96
		40	20		80		80

DAILY LINEARITY CHECKS SATISFACTORY, REFER TO CAL. NO. 1776-091084



REFERENCE BLOCK DATA

SERIAL NUMBER 12-A376-.66

DRAWING NUMBER n.a.

MATERIAL SS 304


REFERENCE REFLECTORS 10% NOTCH ID

REFERENCE REFLECTORS EDGE ID

REFERENCE REFLECTORS BACK WALL

REFERENCE REFLECTORS _____

REFERENCE REFLECTORS _____



V-PATH DATA

PROBE NO.	PROBE NO.	METAL (MM) PATH (INCHES)	AMPLITUDE (dB)	PROJECTION DISTANCE (MM)(INCHES)

RECHECK DATA

CAL. BLOCK 12-A376-.66 S/N ✓ REF. REFL. 10% NOTCH TEMP. 118 °F

REF. BLOCK ✓ S/N ✓ REF. REFL. ✓ TEMP. ✓ °F

THERMOMETER SERIAL NO. UTL 010

NAME	TIME	DAC (RECORD AMPLITUDE) dB/FLH	SWEEP RANGE
<u>HORSTHEMUE</u>	<u>19:00</u>	<u>SE 2 10% NOTCH 46dB</u>	<u>3.7</u>
<u>DALKHOW</u>	<u>21:30</u>	<u>SE 2 10% NOTCH 46dB</u>	<u>3.7</u>

SYSTEM CALIBRATION VERIFICATION RECORD

PAGE 3 OF 6
 REPORT NO. JAF101284-1
 DATE 10-11-84



DAC DATA


PROBE NO.	REFERENCE REFLECTOR	METAL PATH (MM) (-132)	AMPLITUDE (DB)	CALIBRATION BLOCK NO.	REMARKS
1	10% NOTCH ID	37	46	12-A376-.66	SE 2
	10% NOTCH ID	40	66	-	SE 1
	EDGE ID	39	40	-	SE 2
	BACKWALL	34	46	-	SE 1
2	10% NOTCH ID	22	24	12-A376-.66	1/2 VEE-PATH
	10% NOTCH OD	46	26	-	3/2 VEE-PATH
	10% NOTCH ID	68	30	-	3/2 VEE-PATH
3	10% NOTCH ID	30	40	12-A376-.66	1/2 VEE-PATH
4	90% NOTCH	2.5 DEPTH OD	60	EDM-CAL	PA 14 mm
	80% NOTCH	5.0 DEPTH OD	62	-	PA 18 mm
	70% NOTCH	7.5 DEPTH OD	64	-	PA 23 mm
	60% NOTCH	10.0 DEPTH OD	66	-	PA 25 mm
5	20% NOTCH	20.0 DEPTH OD	70	EDM-CAL	CALCULATED FOR 17 mm WALL THICKNESS
7	10% NOTCH ID	56	60	12-A376-.66	1/2 VEE-PATH



REFERENCE POINT LOCATION

Top of Pipe

EXAM NO.	PROBE NO.	IND NO.	REFLECTOR POSITION/MM			Z DEPTH POS. FROM SURFACE % OF 'T'	EVALUATION % OF 'T'	ECHO HEIGHT DIFF. dB	METAL-PATH MM
			Y LINEAR EXTEND FROM REFERENCE	X LINEAR EXTEND FROM WELD CT LINE	AT MAX				
2	1	1	190	204	310	+	+	-8	41
2	1	1	200	204	274	÷	+	-12	38
2	2	1	190	204	310	÷	+	-12	24
2	3	1	190	204	310	÷	+	-6	31
2	7	1	÷	204	÷	÷	+	÷	26
2	4	1	÷	204	÷	÷	+	÷	10mm Depth Fr. OD
2	5	1	÷	204	÷	÷	+	÷	45% Thr. Wall



LEVEL II/II

EXAMINER Horsthemker Dalichow

SIGNATURE

AUTHORIZED INSPECTOR

CLIENT

(IF REQUIRED)


(IF REQUIRED)



DATA STANDARD REPORT OF INDICATION NUMBER: 1

SIGNAL NO.	PROBE NO.	ANGLE OF INCIDENT	EXAM NO.	EXIT X	POINT Y	GAIN DB 100% DAC	METAL PATH	REMARKS
1	1	68° / 32°	2	31	204	54	41	
2	1	v	2	38	204	58	38	
3	2	44°	2	32	204	36	24	
4	3	57°	2	41	204	46	31	
5	7	66°	2	26	204	70	26	
6	4	70°	2	40	204	72	10 mm Depth from OD	
7	5	E 40°	2	∞	204	74	45% Thr. Wall	

*G.P.	204 CW DIN	DEGREES		360
			180	
LOCATION OF DEFECT ON CIRCUMFERENCE OF PIPE				



EXAMINER Horsthemke Daxlichow LEVEL II / II
 REVIEWED BY William E. [Signature] DATE 10-12-84
 AUTHORIZED INSPECTOR _____

* THE ABOVE GRAPH REPRESENTS THE POSITION OF THE DEFECT IN RELATIONSHIP TO THE WELD CENTERLINE.




UT-INSPECTION -IGSCC-
 Weld Identification No. 12-02-2-7C
 Signal No. Indication No. 1
 Coordinate from reference point "V" 204mm ± 8"

Probes Used	Probe No.	Signal No.
Wall Thickness	MSEB4H	
Root Center	19.5 mm	
Other Data	1	1, 2
	2	3
	3	4
	4	6
	5	7, 5

INSPECTION CONTOUR

WCL → ● ← WCL
 ← → joint



INSPECTOR Horstheims, Dalchow Level II
 DATE 10.11.84

Report No. JAF 101284-1 page 6 of 6

Weld 12-02-2-70

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
0.00	0.6500	0.0600	0.710
0.25	0.6500	0.0600	0.710
0.50	0.6500	0.0600	0.710
0.75	0.6500	0.0600	0.710
1.00	0.6500	0.0600	0.710
1.25	0.6500	0.0600	0.710
1.50	0.6500	0.0600	0.710
1.75	0.6500	0.0600	0.710
2.00	0.6500	0.0600	0.710
2.25	0.6500	0.0600	0.710
2.50	0.6500	0.0600	0.710
2.75	0.6500	0.0600	0.710
3.00	0.6500	0.0600	0.710
3.25	0.6500	0.0600	0.710
3.50	0.6500	0.0600	0.710
3.75	0.6500	0.0600	0.710
4.00	0.6500	0.0600	0.710
4.25	0.6500	0.0600	0.710
4.50	0.6500	0.0600	0.710
4.75	0.6500	0.0600	0.710
5.00	0.6500	0.0600	0.710
5.25	0.6500	0.0600	0.710
5.50	0.6500	0.0600	0.710
5.75	0.6500	0.0600	0.710
6.00	0.6500	0.0600	0.710
6.25	0.6500	0.0600	0.710
6.50	0.6500	0.0600	0.710
6.75	0.6500	0.0600	0.710
7.00	0.6500	0.0600	0.710
7.25	0.6500	0.0600	0.710
7.50	0.6500	0.0600	0.710
7.75	0.6250	0.0850	0.710
8.00	0.6000	0.1100	0.710
8.25	0.4100	0.3000	0.710
8.50	0.4500	0.2600	0.710
8.75	0.4750	0.2350	0.710
9.00	0.5000	0.2100	0.710
9.25	0.5125	0.1975	0.710
9.50	0.5250	0.1850	0.710
9.75	0.5375	0.1725	0.710
10.00	0.5500	0.1600	0.710
10.25	0.5625	0.1475	0.710
10.50	0.5750	0.1350	0.710
10.75	0.5875	0.1225	0.710
11.00	0.6000	0.1100	0.710
11.25	0.6080	0.1020	0.710
11.50	0.6160	0.0940	0.710
11.75	0.6250	0.0850	0.710
12.00	0.6330	0.0770	0.710
12.25	0.6410	0.0690	0.710

Weld 12-02-2-70

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
12.50	0.6500	0.0600	0.710
12.75	0.6500	0.0600	0.710
13.00	0.6500	0.0600	0.710
13.25	0.6500	0.0600	0.710
13.50	0.6500	0.0600	0.710
13.75	0.6500	0.0600	0.710
14.00	0.6500	0.0600	0.710
14.25	0.6500	0.0600	0.710
14.50	0.6500	0.0600	0.710
14.75	0.6500	0.0600	0.710
15.00	0.6500	0.0600	0.710
15.25	0.6500	0.0600	0.710
15.50	0.6500	0.0600	0.710
15.75	0.6500	0.0600	0.710
16.00	0.6500	0.0600	0.710
16.25	0.6500	0.0600	0.710
16.50	0.6500	0.0600	0.710
16.75	0.6500	0.0600	0.710
17.00	0.6500	0.0600	0.710
17.25	0.6500	0.0600	0.710
17.50	0.6500	0.0600	0.710
17.75	0.6500	0.0600	0.710
18.00	0.6500	0.0600	0.710
18.25	0.6500	0.0600	0.710
18.50	0.6500	0.0600	0.710
18.75	0.6500	0.0600	0.710
19.00	0.6500	0.0600	0.710
19.25	0.6500	0.0600	0.710
19.50	0.6500	0.0600	0.710
19.75	0.6500	0.0600	0.710
20.00	0.6500	0.0600	0.710
20.25	0.6500	0.0600	0.710
20.50	0.6500	0.0600	0.710
20.75	0.6500	0.0600	0.710
21.00	0.6500	0.0600	0.710
21.25	0.6500	0.0600	0.710
21.50	0.6500	0.0600	0.710
21.75	0.6500	0.0600	0.710
22.00	0.6500	0.0600	0.710
22.25	0.6500	0.0600	0.710
22.50	0.6500	0.0600	0.710
22.75	0.6500	0.0600	0.710
23.00	0.6500	0.0600	0.710
23.25	0.6500	0.0600	0.710
23.50	0.6500	0.0600	0.710
23.75	0.6500	0.0600	0.710
24.00	0.6500	0.0600	0.710
24.25	0.6500	0.0600	0.710
24.50	0.6500	0.0600	0.710
24.75	0.6500	0.0600	0.710


Weld 12-02-2-70

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
25.00	0.6500	0.0600	0.710
25.25	0.6500	0.0600	0.710
25.50	0.6500	0.0600	0.710
25.75	0.6500	0.0600	0.710
26.00	0.6500	0.0600	0.710
26.25	0.6500	0.0600	0.710
26.50	0.6500	0.0600	0.710
26.75	0.6500	0.0600	0.710
27.00	0.6500	0.0600	0.710
27.25	0.6500	0.0600	0.710
27.50	0.6500	0.0600	0.710
27.75	0.6500	0.0600	0.710
28.00	0.6500	0.0600	0.710
28.25	0.6500	0.0600	0.710
28.50	0.6500	0.0600	0.710
28.75	0.6500	0.0600	0.710
29.00	0.6500	0.0600	0.710
29.25	0.6500	0.0600	0.710
29.50	0.6500	0.0600	0.710
29.75	0.6500	0.0600	0.710
30.00	0.6500	0.0600	0.710
30.25	0.6500	0.0600	0.710
30.50	0.6500	0.0600	0.710
30.75	0.6500	0.0600	0.710
31.00	0.6500	0.0600	0.710
31.25	0.6500	0.0600	0.710
31.50	0.6500	0.0600	0.710
31.75	0.6500	0.0600	0.710
32.00	0.6500	0.0600	0.710
32.25	0.6500	0.0600	0.710
32.50	0.6500	0.0600	0.710
32.75	0.6500	0.0600	0.710
33.00	0.6500	0.0600	0.710
33.25	0.6500	0.0600	0.710
33.50	0.6500	0.0600	0.710
33.75	0.6500	0.0600	0.710
34.00	0.6500	0.0600	0.710
34.25	0.6500	0.0600	0.710
34.50	0.6500	0.0600	0.710
34.75	0.6500	0.0600	0.710
35.00	0.6500	0.0600	0.710
35.25	0.6500	0.0600	0.710
35.50	0.6500	0.0600	0.710
35.75	0.6500	0.0600	0.710
36.00	0.6500	0.0600	0.710
36.25	0.6500	0.0600	0.710
36.50	0.6500	0.0600	0.710
36.75	0.6500	0.0600	0.710
37.00	0.6500	0.0600	0.710
37.25	0.6500	0.0600	0.710

Weld 12-02-2-70

Reference Distance (inches)	Remaining Wall	Crack Depth	Nominal Wall Thickness
37.50	0.6500	0.0600	0.710
37.75	0.6500	0.0600	0.710
38.00	0.6500	0.0600	0.710
38.25	0.6500	0.0600	0.710
38.50	0.6500	0.0600	0.710
38.75	0.6500	0.0600	0.710
39.00	0.6500	0.0600	0.710
39.25	0.6500	0.0600	0.710
39.50	0.6500	0.0600	0.710
39.75	0.6500	0.0600	0.710
40.00	0.6500	0.0600	0.710
40.25	0.6500	0.0600	0.710
40.50	0.6500	0.0600	0.710
40.75	0.6500	0.0600	0.710
41.00	0.6500	0.0600	0.710

W 0 1 2 0 1 1 1 7 0 ' 8 ' ' 0 0 1 1 0 1 0 4





Attachment 11
JAFFP-84-0979
October 21, 1984

Isometric Drawings for Reactor
Water Recirculation System

New York Power Authority
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333

STONE & WEBSTER ENGINEERING CORPORATION




-  - SPOOL PIECE
-  - SHOP WELD
-  - FIELD WELD
-  - ATTACHMENT

REF:
11825-FP-87A

POWER INDUSTRY GROUP	TITLE	SCALE: NONE
CHECKED	JAFITZPATRICK NUCLEAR POWER PLANT	DATE: 3-2-78
CORRECT	ISI WELD LOCATION IDENTIFICATION	SKETCH NUMBER
APPROVED	RX RECIRC SYSTEM SYS 02-2	ISI-BJ
REVISIONS		

STONE & WEBSTER ENGINEERING CORPORATION



- SPOOL PIECE
- - SHOP WELD
- - FIELD WELD
- (with T-junction) - ATTACHMENT

REF:
11825-FP-87A

SCALE NONE
DATE 2-24-78
SKETCH NUMBER
ISI-BJ
TITLE
JAFITZPATRICK NUCLEAR POWER PLANT
ISI WELD LOCATION IDENTIFICATION
RX RECIRC SYSTEM SYS 02-2
POWER INDUSTRY GROUP
CHECKED
CORRECT
APPROVED
REVISIONS

11825-FP-87A