

**Southern California Edison Company**

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

**J. G. HAYNES**  
STATION MANAGER

October 15, 1984

RECEIVED  
NRC

1984 OCT 19

SCE  
MT 10-29

REGION V A/P

TELEPHONE  
(714) 492-7700

U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362  
Follow-up Report, Inoperable Fire Doors - September 1984  
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),  
dated September 18, 1984

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in September 1984.

Fire doors found inoperable during the September routine surveillances are identified in the Attachment and include: 5 latching mechanism failures; 14 closure mechanism failures; and 2 doors blocked open typically for construction or maintenance activities. An investigation was conducted to determine the person or persons responsible for the blocked open fire doors, however, results were inconclusive. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established.

We are continuing the corrective actions to upgrade door latches and closure mechanisms. A disciplinary action policy was implemented August 15, 1984, by Station Management, in order to eliminate occurrences of blocked open fire doors without the required Fire Barrier Removal and Reinstallation Request.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in October 1984 will be submitted by November 21, 1984.

8410260038 841015  
PDR ADOCK 05000361  
S PDR


IE-28

Mr. J. B. Martin

-2-

If you require any additional information, please so advise.

Sincerely,



Enclosure

cc: A. E. Chaffee (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission  
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF SEPTEMBER 1984  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 5, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH2-103	9/25	9/26
FH2-302	9/5	9/19
FH3-302	9/9	Work in Progress
FH2-304	9/25	9/26
AC-308	9/9	9/10

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF SEPTEMBER 1984  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362  
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 14, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH2-101	9/11	9/12
AC-118	9/6	9/11
AC-126	9/6	9/11
AC-131	9/14	9/17
AC-239	9/7	9/8
AC-259	9/16	9/17
AC-305	9/16	9/17
AR-313	9/16	9/17
AC-341	9/17	9/18
AC-350	9/16	9/17
AC-351	9/5	9/6
C3-404	9/9	9/10
AR-405	9/12	9/14
C2-405	9/5	9/6

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF SEPTEMBER 1984  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362  
(Continued)

III. Doors Blocked Open:

Number of doors inoperable - 2, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AC-117	9/1
AR-504	9/21