

734

DOCKETED
USNRC

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

'84 OCT 25 A8:20

Before Administrative Judges:

Peter B. Bloch, Chairman
Dr. Kenneth A. McCollom
Dr. Walter H. Jordan

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

SERVED OCT 25 1984

Docket Nos. 50-445
50-446

In the Matter of

TEXAS UTILITIES ELECTRIC COMPANY, et al.

(Application for
Operating License)

(Comanche Peak Steam Electric Station,
Units 1 and 2)

October 24, 1984

MEMORANDUM
(Raw Data on U-Bolts)

We appreciate the speed with which Applicants responded to our Memorandum and Order of October 18, 1984 concerning raw data for U-Bolts. Although we had requested the data on short notice, we had not intended to impose unduly, believing that the raw data for Applicants' finding would be at hand. Had we been asked, a reasonable extension of time could have been granted.

On the other hand, the data filed yesterday are not the "raw data" we requested. We have been provided with a "Torque-Average (ft-lbs)," which does not permit us to examine the variance of readings on individual bolts. Furthermore, this data does not provide us with any indication of the procedure used to measure torque--in particular, whether it was measured by tightening or by loosening. We really want the raw data. Furthermore, we request the procedure that would help us to know how the readings were taken and the criteria for selecting the sample. (If there were any readings taken that were excluded from the sample, we also request the raw data on those readings.)

8410260090 841024
PDR ADDOCK 05000445
G PDR

DS02

O R D E R

For all the foregoing reasons and based on consideration of the entire record in this matter, it is this 24th day of October 1984

ORDERED:

That data and procedures (or equivalent evidence in affidavit form) responsive to the accompanying memorandum should be filed by November 9, 1984.

FOR THE
ATOMIC SAFETY AND LICENSING BOARD



Peter B. Bloch, Chairman
ADMINISTRATIVE JUDGE

Bethesda, Maryland