

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
WATERBURY WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

October 8, 1992
MP-92-1087

Re: 10CFR50.71(a)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555


Reference: Facility Operating License No. DPR-C5
Docket No. 50-336

Dear Sir:

This letter is forwarded to provide the report of operating and shutdown experience relating to Millstone Unit 2 for the month of September, 1992, in accordance with Appendix A Technical Specifications, Section 6.9.1.6. One additional copy of the report is enclosed.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY


Stephen E. Scace
Vice President - Millstone Station

SES/SD

cc: T. T. Martin, Region I Administrator
G. S. Vissing, NRC Project Manager, Millstone Unit No. 2
P. D. Sweland, Senior Resident Inspector, Millstone Unit Nos. 1, 2 & 3

140003
9210130355 920930
PDR ADOCK 05000336
R PDR
083422 REV 4-88

JEH

OPERATING DATA REPORT

DOCKET NO. 50 336
 DATE 10/8/92
 COMPLETED BY Doboe/Neron
 TELEPHONE (203) 447-1791
 EXT. 4678/5517

OPERATING STATUS

Notes: Items 21 and 22 cumulative are weighted averages. Unit operated at 2560 MWTH prior to its uprating to the current 2700 MWTH power level.

1. Unit Name: Millstone Unit 2
2. Reporting Period: September 1992
3. Licensed Thermal Power (Mwt): 2700
4. Nameplate Rating (Gross MWe): 909
5. Design Electrical Rating (Net MWe): 870
6. Maximum Dependable Capacity (Gross MWe): 923.10
7. Maximum Dependable Capacity (Net MWe): 873.10
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) since Last Report, Give Reasons:
N/A

9. Power Level To Which Restricted, If any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-To-Date	Cumulative
11. Hours In Reporting Period	<u>720.0</u>	<u>6575.0</u>	<u>146975.0</u>
12. Number Of Hours Reactor Was Critical	<u>0.0</u>	<u>3204.0</u>	<u>105257.6</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>2205.5</u>
14. Hours Generator On-Line	<u>0.0</u>	<u>3188.6</u>	<u>100357.4</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>468.2</u>
16. Gross Thermal Energy Generated (MWH)	<u>0.0</u>	<u>850623.0</u>	<u>276028682.4</u>
17. Gross Electrical Energy Generated (MWH)	<u>0.0</u>	<u>2827636.5</u>	<u>84404307.5</u>
18. Net Electrical Energy Generated (MWH)	<u>(-2715.0)</u>	<u>2713178.3</u>	<u>80958956.3</u>
19. Unit Service Factor	<u>0.0</u>	<u>48.5</u>	<u>68.3</u>
20. Unit Availability Factor	<u>0.0</u>	<u>48.5</u>	<u>68.6</u>
21. Unit Capacity Factor (Using MDC Net)	<u>-0.4</u>	<u>47.3</u>	<u>64.6</u>
22. Unit Capacity Factor (Using DER Net)	<u>-0.4</u>	<u>47.4</u>	<u>63.5</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>11.4</u>	<u>15.4</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>The Unit is presently shutdown for refueling, replacement of the steam generators and maintenance. Duration - 201 days.</u>			

25. If Unit Shutdown At End Of Report Period, Estimated Date of Startup: December, 1992
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-336
 UNIT: Millstone Unit 2
 DATE: 10/02/92
 COMPLETED BY: S. Dobo
 TELEPHONE: (203) 447-1791
 EXT: 4678

MONTH: SEPTEMBER 1992

DAY	AVG. DAILY POWER LEVEL (MWe-Net)	DAY	AVG. DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>---</u>
16	<u>0</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-336
 UNIT NAME Millstone 2
 DATE 10/02/92
 COMPLETED BY S. Doboe
 TELEPHONE (203) 447-1791
 EXT. 4678

REPORT MONTH SEPTEMBER 1992

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
03	920529	S	720	C	1	N/A	N/A	N/A	Continuation of the re-fueling, steam generator replacement and maintenance outage from the previous month.

¹F: Forced
S: Scheduled

²Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continued from
Previous month
5-Power Reduction
(Duration =0)
6-Other (Explain)

⁴Exhibic G - Instructions
for Preparation of Data
Entry Sheets for License
Event Report (LER) File
(NUREG-0161)

⁵Exhibit 1 - Same Source