

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

February 1, 1985

TVA-SQN-TS-57

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

In accordance with 10 CFR Part 50.90, we are enclosing 40 copies of a requested amendment to the operating license, DPR-77 and DPR-79, to change the Sequoyah Nuclear Plant units 1 and 2 technical specifications (T/S). The proposed change is provided in Enclosure 1. This proposed change will allow use of a fifth standby diesel generator (D/G) to satisfy limiting conditions for operation (LCO) 3.8.1 and 3.9.1.2 when one of the trained D/Gs is out of service. Also included in the change is a request to delete hose stations 0-26-866, -868, and -870 from T/S LCO 3.7.11.4. The justifications for the proposed T/S changes are provided in Enclosure 2.

Enclosed is a check for the \$150 amendment application fee required by 10 CFR 170.12.

This requested amendment has been evaluated pursuant to 10 CFR 50.92 and as stated in Enclosure 3, no significant hazards considerations are involved.

If you have any questions concerning this matter, please get in touch with Jerry Wills at FTS 858-2683.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Damer
J. A. Damer
Nuclear Engineer

8502130162 850201
PDR ADOCK 05000327
P PDR

Sworn to and subscribed before me
this 1st day of Feb. 1985

Paulette H. White
Notary Public
My Commission Expires 8-24-88

Enclosures (40)

cc: U.S. Nuclear Regulatory Commission (Enclosures)
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Accol 1/40 w/check \$150.00 # 24370