

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of

Omaha Public Power District  
(Fort Calhoun Station  
Unit No. 1)

}  
}  
}  
Docket No. 50-285

APPLICATION FOR AMENDMENT  
OF  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission ("the Commission"), Omaha Public Power District, holder of facility Operating License No. DPR-40, herewith requests that the Technical Specifications set forth in Appendix A to that License be amended to change the Engineered Safety Features System Initiation, Degraded Voltage Setting Limits.

The proposed changes in Technical Specifications are provided in Attachment A to this Application. A Discussion, Justification and No Significant Hazards Consideration Analysis, which demonstrates that the proposed changes do not involve significant hazards considerations, is appended in Attachment B. The proposed changes in specifications would not authorize any change in the types or any increase in the amounts of effluents or a change in the authorized power level of the facility.

WHEREFORE, Applicant respectfully requests that Specification 2.14, Table 2-1, of Appendix A to Facility Operating License No. DPR-40 be amended in the form attached hereto as Attachment A.

A copy of this Application, including its attachments, has been submitted to the Director - Nebraska State Division of Radiological Health, as required by 10 CFR 50.91.

OMAHA PUBLIC POWER DISTRICT

By JR Gayer  
Acting Division Manager  
Nuclear Operations

Subscribed and sworn to before me this 7<sup>th</sup> day of October, 1992.

Melva L. Champion  
Notary Public

