

**TEXAS UTILITIES GENERATING COMPANY**  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. #1 • DALLAS, TEXAS 75201

**BILLY R. CLEMENTS**  
VICE PRESIDENT, NUCLEAR OPERATIONS

October 12, 1984  
TXX-4335

Mr. D.R. Hunter, Chief  
Reactor Project Branch 2  
U.S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012


Docket No.: 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
CONTROL ROOM HVAC  
QA FILE: CP-84-29, SDAR-154  
FILE NO.: 10110

Dear Mr. Hunter:

On September 13, 1984 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding the safe shutdown analysis evaluations which did not consider a potential fire which could affect habitability of control room and alternate shutdown capability.

We are continuing our evaluation and anticipate completion by November 6, 1984.



Very truly yours,

*Billy R. Clements*

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8410260267 841012  
PDR ADOCK 05000445  
S PDR

1/0  
IE-27