

TEXAS UTILITIES GENERATING COMPANY  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

Log # TXX-4412  
File # 906.3  
905.4 c10

JOHN W. BECK  
MANAGER-LICENSING

February 7, 1985

Director of Nuclear Reactor Regulation  
Attention: Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 AND 50-446  
ADDITIONAL INSPECTION OF CPSES SAFETY  
INJECTION PUMPS

Dear Mr. Youngblood:


By letter dated December 3, 1984, the NRC requested formal notification of TUGCO's intent to comply with the staff's position for additional inspection of the multi-vane diffuser shroud in CPSES Safety Injection Pumps.

TUGCO has incorporated the NRC Staff's position as follows:

1. Revision 2 to TUGCO maintenance procedure MMI-307, "Safety Injection Pump Inspection" provides for both visual and surface examinations of the diffuser shroud to be performed in conjunction with the 9th refueling outage inspection of pump internals.
2. A section has been added to the ISI 10-Year Plan addressing the examinations described above for the safety injection pumps.

Should you have additional questions in this matter, please contact this office.

Sincerely,

  
John W. Beck

BSD/grr

Distribution: Original plus 15 copies

c - J. Stefano

8502130268 850267  
PDR ADOCK 05000445  
G PDR

Boo1  
/10