DCS No: 50410921104 Date: November 4, 1992

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-92-65

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:	Licensee Emergency Classification:
Niagara Mohawk Power Corporation	Notification of Unusual Even
Nine Mile Point Unit 2	Alert
Scriba, New York	Site Area Emergency
	General Emergency
Docket No.: 50-410	X Not Applicable
L'ense No.: NPF-69	

Subject: UNPLANNED REACTOR SHUTDOWN

Event No.: 24551

Event Location Code: FOW

On Wednesday, November 4, 1992, at about 10:08 am, Nine Mile Point Unit 2 tripped from 100% reactor power. This event occurred shortly after the licensee had observed smoke from a B reactor protection system (RPS) cabinet, in the control room. Upon observing this smoke, operators initiated a B RPS half scram since the smoke was from that portion of the system. Shortly afterwards, a quarter scram was received and a quarter of the control rods inserted. The insertion of a quarter of the rods initiated a level transient and a resulting full scram on low vessel level. All control rods inserted.

Preliminary investigation indicates that a relay in the A RPS logic, physically located by design in the B RPS panel overheated. Therefore, placing the B RPS half-scram in effect did not deenergize the relay. The relay continued to overheat and blew its fuse. When the fuse blew, one quarter of the reactor scram solenoids valves for the A RPS deenergized. With the B RPS half-scram already in affect, one quarter of the control rods fully inserted.

It appears no other component was damaged, bowever, this is still being investigated.

No ECCS systems were called upon to actuate. There were no radiological releases as a result of this incident. The plant is currently in hot shutdown and stable. The duration for this shutdown is not yet known.

An Emergency Preparedness (EP) drill that was ongoing at Unit 1 was temporarily suspended.

The licensee has informed the media.

The State of New York was informed.

Region I is reviewing the event details.

CONTACT: Larry Nicholson (215) 346-5128

9211100143 921104 PDR I&E PND-I-92-065 PDR 2-39

DCS No: 50410921104 Date: November 4, 1992

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-92-65

DISTRIBUTION:

OWFN Chairman Selin\*\* **MNBB** AEOD-\* L-St. PDR NL RES Mail:

ADM: DMB

DOT: Trans only \*\*

Comm. Rogers

IRM OIG\*\*

Comm. Curtiss Comm. Remick

Comm. de Planque

OCAA OIP

NRC Ops Ctr\*\*

Phillips

OCA

EDO

ACRS\*\*

OGC OPA NMSS

NRR\*\* (Phone Verif: A. Byrdsong 964-1168 or 964-1166)

OE

OSP

Regional Offices

EWW OIG

RI Resident Office 4 86 Pm.

Lensee: 4.07 Pm. (Reactor Licensees)

\*\* General list for sending PNs by FAX

Region I Form 83 (Rev. June 1992)