

Arizona Public Service Company

RECEIVED
NRC

1984 OCT -8 PM 3:29

October 3, 1984
ANPP-30735-TDS/TRB REGION V IAP

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 84-65
A 50.55(e) Potentially Reportable Deficiency Relating to
Instrument Leads Removed From The UCS Are Split.
File: 84-019-026; D.4.33.2

Reference: Telephone Conversation between D. Hollenbach and T. Bradish on
September 4, 1984

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the
referenced telephone conversation. At that time, it was estimated that a
determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim
Report is attached. It is now expected that this information will be
finalized by October 26, 1984, at which time a complete report will be
submitted.

Very truly yours,

E E Van Brunt / DBC

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVB/TRB/nj
Attachment

cc: See Page Two

8410300022 841003
PDR ADDCK 05000528
S PDR

TE-70

Mr. T. W. Bishop
DER 84-65
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
J. Vorees
J. R. Bynum
J. M. Allen
D. Canady
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. w. Welcher
H. D. Foster
D. R. Hawkinson
R. P. Zimmerman
L. Clyde
M. Woods
T. J. Bloom

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 84-58
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT 1

I. Potential Problem

Instrument leads removed from the UGS have shown splitting of the outer shielding. The splitting has exposed the ceramic insulation. In some areas, the insulation has deteriorated.

II. Approach To and Status Of Proposed Resolution

Bechtel Engineering is corresponding with Combustion Engineering (C-E) to determine reportability and the corrective action. C-E has forecast September 28, 1984 to provide their input.

III. Projected Completion of Corrective Action and Submittal of the Final Report

Evaluation of this condition and submittal of the Final Report is forecast to be completed by October 26, 1984.