

1.0 INTRODUCTION AND GENERAL DESCRIPTION OF PLANT

1.1 INTRODUCTION

The Westinghouse Electric Corporation (hereinafter referred to as Westinghouse) has developed this Reference Safety Analysis Report (RESAR-SP/90) for the Westinghouse Advanced Pressurized Water Reactor (WAPWR) as part of its continuing efforts toward design and licensing standardization of nuclear power plants. RESAR-SP/90 is a standard safety analysis report submitted initially for Preliminary Design Approval (PDA) in accordance with Appendix O, "Standardization of Design; Staff Review of Standard Designs," to Part 50 of Title 10 of the Code of Federal Regulations (hereinafter referred to as 10CFR). The ultimate objective is to obtain a Final Design Approval (FDA) of RESAR-SP/90 followed by a rulemaking proceeding and design certification.

1.2 GENERAL PLANT DESCRIPTION

1.2.2 Principal Design Criteria

RESAR-SP/90 is designed to comply with 10 CFR Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants." The specific applications of General Design Criteria to RESAR-SP/90 are discussed in Section 3.1.

1.6 MATERIAL INCORPORATED BY REFERENCE

The WAPWR Structural/Equipment Design Module incorporates, by reference, certain topical reports. The topical reports, listed in Table 1.6-1, have been filed previously in support of other Westinghouse applications.

The legend for the review status code letter follows:

- A - U.S. Nuclear Regulatory Commission review complete; USNRC acceptance letter issued.
- AE - U.S. Nuclear Regulatory Commission accepted as part of the Westinghouse emergency core cooling system (ECCS) evaluation model only; does not constitute acceptance for any purpose other than for ECCS analyses.
- B - Submitted to USNRC as background information; no undergoing formal USNRC review.
- O - On file with USNRC; older generation report with current validity; not actively under formal USNRC review.
- U - Actively under formal USNRC review.

TABLE 1.6-1
MATERIAL INCORPORATED BY REFERENCE

<u>Westinghouse Topical Report No.</u>	<u>Title</u>	<u>Revision Number</u>	<u>SAR Section Reference</u>	<u>Submitted to the NRC</u>	<u>Review Status</u>
WCAP-7427	Effective Structural Damping of the KEP L105 CRDM	Rev. 0	3.7	1/70	0
WCAP-7427	Effective Structural Damping of the KEP L105 CRDM	Addendum 1	3.7	12/70	0
WCAP-7558 (Non-Prop)	Seismic Vibration Testing with Sine Beats	Rev. 0	3.10	10/71	U
WCAP-8236(P) WCAP-8288	Safety Analysis of Eight-Grid 17x17 Fuel Assembly for Combined Seismic Loss-of-Coolant Accident	Addendum 1	3.7	4/74	A
WCAP-8252	Documentation of Selected Westinghouse Structural Analysis Computer Codes	Rev. 1	3.6	5/77	A
WCAP-8370	Westinghouse Water Reactor Divi- sions Quality Assurance Plan	Rev. 9A Amend. 1	17.1	2/81	A
WCAP-8587	Equipment Qualification Data Packages	Sup. 1 (Rev. 2)	3.10 3.11	2/79	U
WCAP-8587	Methodology for Qualifying Westinghouse WRD Supplied NSSS Safety-Related Electrical Equipment	Rev. 6	3.10 3.11	11/83	U
WCAP-8624(P) WCAP-8695	General Method of Developing Multifrequency-Biaxial Test Inputs for Bistables	Rev. 0	3/10	9/75 8/75	U
WCAP-8707-P-A (P), Vol I and II WCAP-8709-A, Vol I and II	MULTIFLEX-FORTRAN-IV Computer Program for Analyzing Thermal- Hydraulic Structure System Dynamics	Rev. 0	3.6	9/16/77	A
WCAP-8867	DEBLIN2 - A Computer Code to Synthesize Earthquake Acceleration Time Historics	Rev. 0	3/7	11/76	U
WCAP-10221	Simplified Pipe Whip Analysis and Restraint Design Procedures	Rev. 0	3.6	12/82	U

1.8 CONFORMANCE WITH THE STANDARD REVIEW PLAN

In accordance with 10CFR50.34(g), Table 1.8-1 of each PDA module identifies and evaluates deviations from the acceptance criteria of those sections of the NRC Standard Review Plan (NUREG-0800) pertinent to the subject module. Table 1.8-1 provides this list for the "Structural/Equipment Design".

TABLE 1.8-1
STANDARD REVIEW PLAN DEVIATIONS

<u>SRP Acceptance Criteria</u>	<u>Deviation</u>	<u>Section</u>
SRP 2.3.1 } SRP 3.3.1 } 100-year return period "fastest mile of wind" including vertical velocity distribution and gust factor	RESAR-SP/90 is based on the 1982 Edition of ANSI A58.1, which was issued after the latest revision of the SRP. Wind loadings are therefore tabulated using the 50-year recurrence wind instead of the 100-year recurrence wind referenced in the Regulatory Guide. Structural Design for winds greater than the 50-year magnitude is specified by utilization of the Importance Factor (see Section 3.3.1.1).	3.3.1
SRP 3.3.2 } SRP 3.5.1 } Tornado specification is based on ANSI 58.1	The tornado specification is based on ANSI/ANS2.3 - 1983 which was issued after the latest revision of the Standard Review Plan and Regulatory Guide 1.76.	3.3.2 3.5.1
SRP 2.5.2: The minimum value of the acceleration level for the OBE is currently one-half the reference acceleration for seismic design corresponding to the SSE.	The OBE has been established as 1/3 of SSE	3.7.1