## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-84-70 Date: 10/25/84

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Pacific Gas & Electric Co. Diablo Canyon Unit 1/2 Docket No. 50-275/323 San Luis Obispo County, CA Licensee Emergency Classification Notification of Unusual Event Alert Site Area Emergency General Emergency XX Not Applicable

SUBJECT: EARTHQUAKE CENTERED WITHIN 50 MILES OF REACTOR SITE

The Headquarters Operation Center was notified of an earthquake with a 4.7 Richter magnitude centered approximately 10 miles north of Solvang, CA that occurred at 3:36 A.M. (PDT), October 25, 1984. The epicenter was approximately 40 miles south of the Diablo Canyon Site. While not felt by site personnel, it did actuate the ultra-sensitive seismic monitors but not the regular safeguards seismic monitors. The licensee has not planned any special action as a result of the event other than analyzing the tapes from the tripped monitor as required by administrative procedures. There were no reports of any damage in the vicinity of Diablo Canyon, although, minor damage was reported to residents adjacent to the epicenter.

Neither the licensee or Region V plan to issue a press release, but will respond to any inquiries.

This information is current as of 9:30 A.M. (PDT), October 25, 1984.

CONTACT: R. T. Dodds FTS 463-3720 M. M. Mendonca (805) 595-3254

## DISTRIBUTION

ALLA	9:0	17 9.	50 8:10	Willste 2.5	3 9:5	50
H St. 7.75	MNBB	'Phillips'	E/W	Willste	Air Rights	Mail:
Chairman Pallidino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Zech	PA		OIA	RES		DOT:Trans
Comm. Bernthal	MPA		AEOD			Only
Comm. Roberts	ELD	1. I.S. (1997)	-	- 210. 7	T 7'- 2 T	7:04
Comm. Asselstine		Regions:	L	4-2.30,1	I-2:53 A	- 2.54
SECY			NSAC 10			
ACRS		Licensee	: 10:15			
CA			Licensees		REGION V:	
PDP.		Resident	Inspector	2.40	(Revised 3	/14/83)

8410300148 841025 PDR 1&E PND-V-84-070 PDR

0(1 1E-34