

Table of Contents

4.0	Reactor
4.1	Summary Description
4.1.1	References
4.2	Fuel System Design
4.2.1	Design Description
4.2.1.1	Fuel Rods
4.2.1.2	Fuel Assembly Structure
4.2.1.2.1	Bottom Nozzle
4.2.1.2.2	Top Nozzle
4.2.1.2.3	Guide and Instrument Thimbles
4.2.1.2.4	Grid Assemblies
4.2.1.3	Core Components
4.2.1.3.1	Rod Cluster Control Assembly
4.2.1.3.2	Burnable Poison Assembly
4.2.1.3.3	Neutron Source Assembly
4.2.1.3.4	Thimble Plug Assembly
4.2.2	Fuel System Design Criteria
4.2.3	Design Bases
4.2.3.1	Cladding
4.2.3.2	Fuel Material
4.2.3.3	Fuel Rod Performance
4.2.3.4	Spacer Grids
4.2.3.5	Fuel Assembly
4.2.3.6	Core Components
4.2.3.7	Testing, Irradiation Demonstration and Surveillance
4.2.4	Design Evaluation
4.2.4.1	Cladding
4.2.4.2	Fuel Materials Considerations
4.2.4.3	Fuel Rod Performance
4.2.4.4	Spacer Grids
4.2.4.5	Fuel Assembly
4.2.4.6	Reactivity Control Assembly and Burnable Poison Rods
4.2.5	Testing and Inspection Plan
4.2.5.1	Quality Assurance Program
4.2.5.2	Quality Control
4.2.5.3	Core Component Testing and Inspection
4.2.5.4	Onsite Inspection
4.2.6	References
4.3	Nuclear Design
4.3.1	Design Bases
4.3.1.1	Fuel Burnup
4.3.1.2	Negative Reactivity Feedbacks (Reactivity Coefficient)
4.3.1.3	Control of Power Distribution
4.3.1.4	Maximum Controlled Reactivity Insertion Rate
4.3.1.5	Shutdown Margins
4.3.1.6	Stability
4.3.1.7	Anticipated Transients Without Trip
4.3.2	Description
4.3.2.1	Nuclear Design Description

- 4.3.2.1.1 Catawba Unit 1 Lead Test Assembly (LTA) Demonstration Programs
- 4.3.2.1.2 Westinghouse Next Generation Fuel (NGF) LTA Demonstration Program
- 4.3.2.1.3 DOE Mixed Oxide (MOX) LTA Demonstration Program
- 4.3.2.2 Power Distributions
 - 4.3.2.2.1 Definitions
 - 4.3.2.2.2 Radial Power Distributions
 - 4.3.2.2.3 Assembly Power Distributions
 - 4.3.2.2.4 Axial Power Distributions
 - 4.3.2.2.5 Local Power Peaking
 - 4.3.2.2.6 Limiting Power Distributions
 - 4.3.2.2.7 Experimental Verification of Power Distribution Analysis
 - 4.3.2.2.8 Testing
 - 4.3.2.2.9 Monitoring Instrumentation
- 4.3.2.3 Reactivity Coefficients
 - 4.3.2.3.1 Fuel Temperature (Doppler) Coefficient
 - 4.3.2.3.2 Moderator Coefficients
 - 4.3.2.3.3 Power Coefficient
 - 4.3.2.3.4 Comparison of Calculated and Experimental Reactivity Coefficients
 - 4.3.2.3.5 Reactivity Coefficient Used in Transient Analysis
- 4.3.2.4 Control Requirements
 - 4.3.2.4.1 Doppler
 - 4.3.2.4.2 Variable Average Moderator Temperature
 - 4.3.2.4.3 Redistribution
 - 4.3.2.4.4 Void Content
 - 4.3.2.4.5 Rod Insertion Allowance
 - 4.3.2.4.6 Burnup
 - 4.3.2.4.7 Xenon and Samarium Poisoning
 - 4.3.2.4.8 pH Effects
 - 4.3.2.4.9 Experimental Confirmation
 - 4.3.2.4.10 Control
 - 4.3.2.4.11 Chemical Poison
 - 4.3.2.4.12 Rod Cluster Control Assemblies
 - 4.3.2.4.13 Reactor Coolant Temperature
 - 4.3.2.4.14 Burnable Poison
 - 4.3.2.4.15 Peak Xenon Startup
 - 4.3.2.4.16 Load Follow Control and Xenon Control
 - 4.3.2.4.17 Burnup
- 4.3.2.5 Control Rod Patterns and Reactivity Worth
- 4.3.2.6 Criticality of the Reactor During Refueling and Criticality of Fuel Assemblies
 - 4.3.2.6.1 New Fuel Vault Criticality Analysis Methodology
 - 4.3.2.6.2 Spent Fuel Storage Rack Criticality Analysis Methodology
- 4.3.2.7 Stability
 - 4.3.2.7.1 Introduction
 - 4.3.2.7.2 Stability Index
 - 4.3.2.7.3 Prediction of the Core Stability
 - 4.3.2.7.4 Stability Measurements
 - 4.3.2.7.5 Comparison of Calculations with Measurements
 - 4.3.2.7.6 Stability Control and Protection
- 4.3.2.8 Vessel Irradiation
- 4.3.3 Analytical Methods
 - 4.3.3.1 Computer Codes
 - 4.3.3.2 Computer Codes For Method 2
- 4.3.4 Deleted Per 2004 Update

- 4.3.5 Changes
- 4.3.6 References

- 4.4 Thermal and Hydraulic Design
 - 4.4.1 Description
 - 4.4.1.1 Design Description
 - 4.4.1.2 Critical Heat Flux Ratio or Departure from Nucleate Boiling Ratio and Mixing Technology
 - 4.4.1.2.1 Departure from Nucleate Boiling Technology
 - 4.4.1.2.2 Definition of Departure from Nucleate Boiling Ratio (DNBR)
 - 4.4.1.2.3 Mixing Technology
 - 4.4.1.2.4 Hot Channel Factors
 - 4.4.1.2.5 Effects of Rod Bow on DNBR
 - 4.4.1.3 Linear Heat Generation Rate
 - 4.4.1.4 Void Fraction Distribution
 - 4.4.1.5 Core Coolant Flow Distribution
 - 4.4.1.6 Core Pressure Drops and Hydraulic Loads
 - 4.4.1.6.1 Core Pressure Drops
 - 4.4.1.6.2 Hydraulic Loads
 - 4.4.1.7 Correlation and Physical Data
 - 4.4.1.7.1 Surface Heat Transfer Coefficients
 - 4.4.1.7.2 Total Core and Vessel Pressure Drop
 - 4.4.1.7.3 Void Fraction Correlation
 - 4.4.1.8 Thermal Effects of Operational Transients
 - 4.4.1.9 Uncertainties in Estimates
 - 4.4.1.9.1 Uncertainties in Fuel and Clad Temperatures
 - 4.4.1.9.2 Uncertainties in Pressure Drops
 - 4.4.1.9.3 Uncertainties Due to Inlet Flow Maldistribution
 - 4.4.1.9.4 Uncertainty in DNB Correlation
 - 4.4.1.9.5 Uncertainties in DNBR Calculations
 - 4.4.1.9.6 Uncertainties in Flow Rates
 - 4.4.1.9.7 Uncertainties in Hydraulic Loads
 - 4.4.1.9.8 Uncertainty in Mixing Coefficient
 - 4.4.1.10 Flux Tilt Considerations
 - 4.4.1.11 Fuel and Cladding Temperatures
 - 4.4.2 Design Bases
 - 4.4.2.1 Departure from Nucleate Boiling Design Basis
 - 4.4.2.2 Fuel Temperature Design Basis
 - 4.4.2.3 Core Flow Design Basis
 - 4.4.2.4 Hydrodynamic Stability Design Basis
 - 4.4.2.5 Other Considerations
 - 4.4.3 Description of the Thermal and Hydraulic Design of the Reactor Coolant System
 - 4.4.3.1 Plant Configuration Data
 - 4.4.3.2 Operating Restrictions on Pumps
 - 4.4.3.3 Power-Flow Operating Map (BWR)
 - 4.4.3.4 Temperature-Power Operating Map
 - 4.4.3.5 Load Following Characteristics
 - 4.4.3.6 Thermal and Hydraulic Characteristics Summary Table
 - 4.4.4 Evaluation
 - 4.4.4.1 Critical Heat Flux
 - 4.4.4.2 Core Hydraulics
 - 4.4.4.2.1 Flow Paths Considered in Core Pressure Drop and Thermal Design
 - 4.4.4.2.2 Inlet Flow Distributions
 - 4.4.4.2.3 Empirical Friction Factor Correlations
 - 4.4.4.3 Influence of Power Distribution
 - 4.4.4.3.1 Radial Power Distribution
 - 4.4.4.3.2 Axial Power Distributions
 - 4.4.4.4 Core Thermal Response

- 4.4.4.5 Analytical Techniques
 - 4.4.4.5.1 Core Analysis
 - 4.4.4.5.2 Steady State Analysis
 - 4.4.4.5.3 Experimental Verification
 - 4.4.4.5.4 Transient Analysis
- 4.4.4.6 Hydrodynamic and Flow Power Coupled Instability
- 4.4.4.7 Fuel Rod Behavior Effects from Coolant Flow Blockage
- 4.4.5 Testing and Verification
 - 4.4.5.1 Tests Prior to Initial Criticality
 - 4.4.5.2 Initial Power and Plant Operation
 - 4.4.5.3 Component and Fuel Inspections
- 4.4.6 Instrumentation Requirements
 - 4.4.6.1 Incore Instrumentation
 - 4.4.6.2 Overtemperature and Overpower \square T Instrumentation
 - 4.4.6.3 Instrumentation to Limit Maximum Power Output
 - 4.4.6.4 Loose Parts Monitoring System
 - 4.4.6.5 Flow Measurement Instrumentation and Technique
 - 4.4.6.5.1 Elbow Taps
- 4.4.7 References

- 4.5 Reactor Materials
 - 4.5.1 Control Rod System Structural Materials
 - 4.5.1.1 Materials Specifications
 - 4.5.1.2 Fabrication and Processing of Austenitic Stainless Steel Components
 - 4.5.1.3 Contamination Protection and Cleaning of Austenitic Stainless Steel
 - 4.5.2 Reactor Internals Materials
 - 4.5.2.1 Materials Specifications
 - 4.5.2.2 Controls on Welding
 - 4.5.2.3 Fabrication and Processing of Austenitic Stainless Steel Components
 - 4.5.2.4 Contamination Protection and Cleaning of Austenitic Stainless Steel

- 4.6 Functional Design of Reactivity Control Systems
 - 4.6.1 Information for Control Rod Drive System (CRDS)
 - 4.6.2 Evaluation of the CRDS
 - 4.6.3 Testing and Verification of the CRDS
 - 4.6.4 Information for Combined Performance of Reactivity Systems
 - 4.6.5 Evaluation of Combined Performance
 - 4.6.6 References

List of Tables

Table 4-1. Reactor Design Comparison Table

Table 4-2. Analytical Techniques In Core Design

Table 4-3. Design Loading Conditions For Reactor Core Components

Table 4-4. Reactor Core Description

Table 4-5. Nuclear Design Parameters

Table 4-6. Nuclear Design Parameters.

Table 4-7. Reactivity Requirements For Rod Cluster Control Assemblies

Table 4-8. UO₂ Benchmark Critical Experiments

Table 4-9. Axial Stability Index Pressurized Water Reactor Core With A 12 Foot Height

Table 4-10. Typical Neutron Flux Levels (n/cm²-sec) At Full Power

Table 4-11. Deleted Per 1998 Update

Table 4-12. Deleted Per 2001 Update

Table 4-13. Saxton Core II Isotopics Rod My, Axial Zone 6

Table 4-14. Critical Boron Concentrations, HZP, BOL

Table 4-15. Benchmark Critical Experiments B4C Control Rod Worth

Table 4-16. Comparison Of Measured And Calculated Moderator Coefficients At HZP, BOL

Table 4-17. Deleted Per 2000 Update

Table 4-18. Deleted Per 1993 Update

Table 4-19. Void Fractions At Nominal Reactor Conditions With Design Hot Channel Factors

Table 4-20. Measurements Required In The Calculation Of Reactor Flow Using A Calorimetric Technique

Table 4-21. Statistically Combined Uncertainty Factors for F_q, F_H, and F_z

Table 4-22. Elbow Tap Coefficients

Table 4-23. Fuel Assembly Design Information for Current Demonstration Programs

Table 4-24. Mechanical and Thermal Hydraulic Analysis Methods for Current Demonstration Programs

THIS PAGE LEFT BLANK INTENTIONALLY.

List of Figures

Figure 4-1. 17 X 17 Fuel Assembly Cross Section

Figure 4-2. Deleted Per 2001 Update

Figure 4-3. Deleted Per 2016 Update

Figure 4-4. Deleted Per 1993 Update

Figure 4-5. Deleted Per 1993 Update

Figure 4-6. Deleted Per 2001 Update

Figure 4-7. Deleted Per 2001 Update

Figure 4-8. Deleted Per 2001 Update

Figure 4-9. Full Length Rod Cluster Control and Drive Rod Assembly with Interfacing Components

Figure 4-10. Rod Cluster Control Assembly Outline

Figure 4-11. Hybrid B4C Absorber Rod

Figure 4-12. Deleted Per 2001 Update

Figure 4-13. Deleted Per 2000 Update

Figure 4-14. Deleted Per 1994 Update

Figure 4-15. Deleted Per 2001 Update

Figure 4-16. Thimble Plug Assembly

Figure 4-17. Fuel Loading Arrangement

Figure 4-18. Fuel Loading Arrangement

Figure 4-19. Production and Consumption of Higher Isotopes -

Figure 4-20. Boron Concentration Versus Typical Cycle Burnup With and Without Burnable Poison

Figure 4-21. Deleted Per 2000 Update

Figure 4-22. Typical Burnable Poison Loading Pattern IBFA Fuel

Figure 4-23. Typical Burnable Poison Loading Pattern Burnable Poison Rods

Figure 4-24. Normalized Power Density Distribution Near Beginning-Of-Life, Unrodded Core, Hot Full Power, No Xenon

Figure 4-25. Normalized Power Density Distribution Near Beginning-Of-Life, Unrodded Core, Hot Full, Equilibrium Xenon

Figure 4-26. Normalized Power Density Distribution Near Beginning-Of-Life, Group D 28% Inserted, Hot Full Power, Equilibrium Xenon

Figure 4-27. Normalized Power Density Distribution Near Middle-Of-Life, Hot Full Power, Equilibrium Xenon

Figure 4-28. Normalized Power Density Distribution Near End-Of-Life, Unrodded Core, Hot Full Power, Equilibrium Xenon

Figure 4-29. Normalized Power Density Distribution Near End-Of-Life, Group D 28% Inserted, Hot Full Power, Equilibrium Xenon

Figure 4-30. Rodwise Power Distribution in a Typical Assembly (G-9) Near Beginning-Of-Life, Hot Full Power, Equilibrium Xenon, Unrodded Core

Figure 4-31. Rodwise Power Distribution in a Typical Assembly (G-9) Near End-Of-Life, Hot Full Power, Equilibrium Xenon, Unrodded Core

Figure 4-32. Typical Axial Power Shapes Occurring at Beginning-Of-Life

Figure 4-33. Typical Axial Power Shapes Occurring at Middle-Of-Life

Figure 4-34. Typical Axial Power Shapes Occurring at End-Of-Life

Figure 4-35. Comparison of Assembly Axial Power Distribution with Core Average Axial Distribution, D Bank Slightly Inserted

Figure 4-36. Deleted Per 1998 Update

Figure 4-37. Deleted Per 2000 Update

Figure 4-38. Deleted Per 2000 Update

Figure 4-39. Deleted Per 2000 Update

Figure 4-40. Peak Linear Power During Control Rod Malfunction Overpower Transient

Figure 4-41. Peak Linear Power During Boration/Dilution Overpower Transients

Figure 4-42. Typical Comparison Between Calculated and Measured Relative Fuel Assembly Power Distribution

Figure 4-43. Comparison of Calculated and Measured Axial Shape

Figure 4-44. Comparison of Calculated and Measured Peaking Factors, FQ X PREL MAX Envelope as a Function of Core Height

Figure 4-45. Doppler Temperature Coefficient at BOL and EOL, Cycle 1

Figure 4-46. Doppler - Only Power Coefficient - BOL, EOL, Cycle 1

Figure 4-47. Doppler - Only Power Defect Coefficient - BOL, EOL, Cycle 1

Figure 4-48. Moderator Temperature Coefficient - BOL Cycle 1, No Rods

Figure 4-49. Moderator Temperature Coefficient - EOL Cycle 1

Figure 4-50. Moderator Temperature Coefficient as a Function of Boron Concentration - BOL Cycle 1, No Rods

Figure 4-51. Hot Full Power Temperature Coefficient During Cycle 1 for the Critical Boron Concentration

Figure 4-52. Total Power Coefficient - BOL, EOL, Cycle 1

Figure 4-53. Total Power Defect - BOL, EOL, Cycle 1

Figure 4-54. Rod Cluster Control Assembly Pattern

Figure 4-55. Accidental Simultaneous Withdrawal of Two Control Banks, EOL, HZP, Banks C and B Moving in the Same Plane

Figure 4-56. Deleted Per 1998 Update

Figure 4-57. Deleted Per 1998 Update

Figure 4-58. Axial Offset Versus Time PWR Core with 12-ft. Height and 121 Assemblies

Figure 4-59. XY Xenon Test Thermocouple Response Quadrant Tilt Difference Versus Time

Figure 4-60. Deleted Per 1998 Update

Figure 4-61. Comparison of Calculated and Measured Boron Concentration for 2-Loop Plant, 121 Assemblies, 12-Foot Core

Figure 4-62. Comparison of Calculated and Measured CB 3-Loop Plant with 157 Assemblies, 12-Foot Core

Figure 4-63. Comparison of Calculated and Measured CB 4-Loop Plant, 193 Assemblies, 12-Foot Core

Figure 4-64. Deleted Per 1997 Update

Figure 4-65. Measured Versus Predicted Critical Heat Flux - BWCMV

Figure 4-66. TDC Versus Reynolds Number for 26-inch Grid Spacing

Figure 4-67. Deleted Per 2001 Update

Figure 4-68. Deleted Per 2001 Update

Figure 4-69. Deleted Per 2001 Update

Figure 4-70. Void Fraction Versus Thermodynamic Quality H-Hsat/Hg-Hsat

Figure 4-71. Deleted Per 2001 Update

Figure 4-72. Deleted Per 1995 Update

Figure 4-73. Deleted per 1992 Update

Figure 4-74. Distribution of Incore Instrumentation

Figure 4-75. Deleted Per 2016 Update

Figure 4-76. Unit 1 Reactor Coolant System Temperature - Percent Power Map
Refer to 4.4.3.4 for applicability.

Figure 4-77. Unit 2 Reactor Coolant System Temperature - Percent Power Map
Refer to 4.4.3.4 for applicability.

Figure 4-78. Replacement of Secondary Sources

Figure 4-79. Typical Burnable Poison Rod (BWFC) Cross Section

Figure 4-80. Typical Burnable Poison Arrangement within An Assembly Burnable Poison Rods

Figure 4-81. Typical Burnable Poison Arrangement within An Assembly IFBA Fuel Rods

Figure 4-82. RFA 17 x 17 Fuel Assembly Cross Section

Figure 4-83. WABA Assembly Diagram

Figure 4-84. WABA Burnable Poison Rod Cross Section

Figure 4-85. 17x17 Westinghouse Robust Fuel Assembly Outline

Figure 4-86. Westinghouse Robust Fuel Rod Assembly

Figure 4-87. Hybrid B4C Absorber Rod (BWFC Demo)

Figure 4-88 Typical 17 x 17 Mark BW/MOX1 Fuel Assembly Configuration

4.0 Reactor

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.0.

THIS PAGE LEFT BLANK INTENTIONALLY.

4.1 Summary Description

This chapter describes 1) the mechanical components of the reactor and reactor core including the fuel rods and fuel assemblies, 2) the nuclear design, and 3) the thermal-hydraulic design.

The reactor core is comprised of an array of fuel assemblies which are similar in mechanical design, yet employ various levels of fuel enrichment. The initial core design employs three enrichments in a three-region core, whereas more enrichments may be employed for a particular refueling scheme. Fuel cycle times appropriate for the refueling interval and for the performance criteria utilized.

The core is cooled and moderated by light water at a pressure of 2250 psia in the Reactor Coolant System. The moderator coolant contains boron as a neutron poison. The concentration of boron in the coolant is varied as required to control relatively slow reactivity changes including the effects of fuel burnup. Additional boron, in the form of Wet Annular Burnable Absorbers (WABAs), or Burnable Poison Rods (BPRs), is employed to establish the desired initial reactivity as discussed in Section 4.2.1.3. An Integral Fuel Burnable Absorber (IFBA) coating may be used on some of the fuel to establish the desired initial reactivity.

Westinghouse is Catawba's current supplier of reload (fresh) fuel. Previously, Catawba operated with Framatome Cogema Fuels (FCF) reload fuel. FCF's Mark-BW design is described in Reference 3. Beginning with Catawba Unit 2 Cycle 11, the reload fuel is Westinghouse's Robust Fuel Assembly (RFA) design described in Reference 4. The Westinghouse 17x17 Optimized fuel, which was previously used at Catawba and now stored in the spent fuel pools, is described in Reference 2.

Two hundred and sixty-four fuel rods are mechanically joined in a square array to form a fuel assembly. The fuel rods are supported at intervals along their length by grid assemblies which maintain the lateral spacing between the rods throughout the design life of the assembly.

The RFA design used at Catawba consists of the VANTAGE+ fuel assembly base design (Reference 5) with several additional design features as described in Reference 4. The major design features are summarized below:

VANTAGE+

0.374 inch fuel Rod OD

ZIRLO clad fuel rods

ZIRLO guide thimbles, instrumentation tubes, midstructural grids, and intermediate flow mixer grids

Zirconium Diboride Integral Fuel Burnable Absorbers (IFBA)

Mid-enriched annular axial blanket pellets

High burnup fuel skeleton

Debris Filter Bottom Nozzle (DFBN)

Additional Duke/RFA Design Features

ZIRLO/Optimized ZIRLO™ clad fuel rods

Increased guide thimble and instrumentation tube thickness

Pre-oxide coating on the bottom of the fuel rods

Modified Low pressure drop structural mid-grids

Modified intermediate flow mixer grids

Protective bottom end grid

Quick disconnect top nozzle

Fuel rods positioned on the bottom nozzle

For the RFA design, the top and bottom grids and protective bottom grid are made of Inconel and the intermediate grids are made of ZIRLO. The grid assemblies consist of an "egg-crate" arrangement of interlocked straps. The straps contain spring finers and dimples for fuel rod support as well as coolant mixing vanes. The fuel rods contain natural or slightly enriched uranium dioxide ceramic cylindrical pellets and may also include axial blanket pellets (natural or low enriched annular or solid uranium dioxide pellets) and/or Integral Fuel Burnable Absorber (IFBA) coating on some of the enriched fuel pellets. The pellets are contained in ZIRLO tubing which is plugged and seal welded at the ends to encapsulate the fuel. Beginning in Region 26 (Cycle 24) of Catawba Unit 1, Optimized ZIRLO High Performance Fuel Cladding material will be utilized to contain the fuel pellets. The Optimized ZIRLO cladding material is further described in Reference 6. All fuel rods are pressurized with helium during fabrication to reduce stresses and strains to increase fatigue life.

The center position in the assembly is reserved for use by the incore instrumentation, while the remaining 24 positions in the array are equipped with guide thimbles joined to the grids and the top and bottom nozzles. Depending upon the position of the assembly in the core, the guide thimbles are used as core locations for rod cluster control assemblies (RCCAs), neutron source assemblies, wet annular burnable absorbers, or burnable poison assemblies. Otherwise, the guide thimbles are fitted with plugging devices to limit bypass flow.

The bottom nozzle is a box-like structure which serves as the bottom structural element of the fuel assembly and directs the coolant flow distribution to the assembly.

The top nozzle assembly functions as the upper structural element of the fuel assembly in addition to providing a partial protective housing of the RCCA or other components.

The RCCAs each consist of a group of individual absorber rods fastened at the top end to a common hub or spider assembly, containing full length absorber material to control the reactivity of the core under operating conditions.

The nuclear design analyses and evaluations establish physical locations for control rods and burnable poison rods and/or rods containing IFBA coated fuel and physical parameters such as fuel enrichments and boron concentration in the coolant. The nuclear design evaluation established that the reactor core has inherent characteristics which together with corrective actions of the reactor control and protective systems provide adequate reactivity control even if the highest reactivity worth RCCA is stuck in the fully withdrawn position.

The design also provides for inherent stability against diametral and azimuthal power oscillations and for control of induced axial power oscillation through the use of control rods.

The thermal-hydraulic design analyses and evaluations establish coolant flow parameters which assure that adequate heat transfer is provided between the fuel cladding and the reactor coolant. The thermal design takes into account local variations in dimensions, power generation, flow distribution and mixing. The mixing vanes incorporated in the fuel assembly spacer grid design induce additional flow mixing between the various flow channels within a fuel assembly as well as between adjacent assemblies.

Instrumentation is provided in and out of the core to monitor the nuclear, thermal-hydraulic, and mechanical performance of the reactor and to provide inputs to automatic control functions.

Table 4-1 presents the principle nuclear, thermal-hydraulic and mechanical design parameters for Westinghouse 17x17 Robust fuel used in Catawba Units 1 and 2.

The analytical techniques employed in the core design are tabulated in Table 4-2. The loading conditions considered in general for the core internals and components are tabulated in Table 4-3. Specific or limiting loads considered for design purposes of the various components are listed as follows: fuel assemblies in Section 4.2.3.5; neutron absorber rods, burnable poison rods, neutron source rods and thimble plug assemblies in Section 4.2.3.6.

4.1.1 References

1. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

2. Davidson, S. L., Iorij, J. A., "Reference Core Report, 17 x 17 Optimized Fuel Assembly", WCAP-9500-A, May 1982.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

3. BAW-10172P, Mark-BW Mechanical Design Report, Babcock & Wilcox, Lynchburg, Virginia, July 1988.
4. DPC-NE-2009P-A, Rev. 2, Duke Power Company Westinghouse Fuel Transition Report, December 2002.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

5. S.L. Davidson, T.L. Ryan, "VANTAGE+ Fuel Assembly Reference Core Report", WCAP-12610-P-A, April 1995.
6. Schueren, P., "Optimized ZIRLO™, WCAP-12610-P-A & CENPD-404-P-A Addendum 1-A, July 2006.

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.1.

THIS PAGE LEFT BLANK INTENTIONALLY.

4.2 Fuel System Design

4.2.1 Design Description

The Catawba Nuclear Station transition to the 17 x 17 Robust fuel assembly (RFA) design for reload fuel is discussed in Section 4.1. Descriptions of the RFA design and method of evaluation are included in Reference 33. Figure 4-85 shows a full length view of the Westinghouse Robust fuel assembly (Reference 33). Section 4.2.3.7 describes demonstration assembly designs and their methods of evaluation.

Each fuel assembly consists of 264 fuel rods, 24 guide thimble tubes and 1 instrumentation thimble tube arranged within a supporting structure. The instrumentation thimble is located in the center position and provides a channel for insertion of an incore neutron detector, if the fuel assembly is located in an instrumented core position. The guide thimbles provide channels for insertion of either a rod cluster control assembly, a neutron source assembly, a burnable poison assembly or a thimble plug assembly, depending on the position of the particular fuel assembly in the core. Figure 4-1 shows a cross-section of the fuel assembly array. Figure 4-82 shows a cross-section of the RFA fuel assembly array. The fuel rods are loaded into the fuel assembly structure so that there is clearance between the fuel rod ends and the top nozzles. The fuel assembly fuel rod, and core component design data are given in Table 4-4.

Each fuel assembly is installed vertically in the reactor vessel and stands upright on the lower core plate, which is fitted with alignment pins to locate and orient the assembly. After all fuel assemblies are set in place, the upper support structure is installed. Alignment pins, built into the upper core plate, engage and locate the upper ends of the fuel assemblies. The upper core plate then bears downward against the holddown springs on the top nozzle of each fuel assembly to hold the fuel assemblies in place.

Visual confirmation of the orientation of the fuel assemblies within the core is provided by an engraved identification number on a corner clamp on the top nozzle, and an indexing hole in the opposite corner clamp.

The NRC issued Generic Letter 90-02. "Alternative Requirements for Fuel Assemblies in the Design Features Section of Technical Specifications," on February 1, 1990, and Supplement 1 to Generic Letter 90-02 on July 31, 1992. In accordance with Generic Letter 90-02, Catawba Improved Technical Specification 4.2.1 states the following:

The reactor shall contain 193 fuel assemblies. Each assembly shall consist of a matrix of either zircaloy, ZIRLO, or Optimized ZIRLO™ clad fuel rods with an initial composition of natural or slightly enriched uranium dioxide (UO₂) as fuel material. Limited substitutions of ZIRLO, Optimized ZIRLO™, zirconium alloy or stainless steel filler rods for fuel rods, in accordance with approved applications of fuel rod configurations, may be used. Fuel assemblies shall be limited to those fuel designs that have been analyzed with applicable NRC staff-approved codes and methods, and shown by tests or analyses to comply with all fuel safety design bases. A limited number of lead test assemblies that have not completed representative testing may be placed in non-limiting core regions.

4.2.1.1 Fuel Rods

Deleted paragraph(s) per 2016 Update.

RFA

The fuel rods contain enriched uranium dioxide ceramic pellets and may also include axial blanket pellets (natural or low enriched annular or solid uranium dioxide pellets) and/or Integral Fuel Burnable Absorber (IFBA) coating on some of the enriched fuel pellets. The pellets are contained in ZIRLO tubing which is plugged and seal welded at the ends to encapsulate the fuel. Beginning in Region 26 (Cycle 24) of Catawba Unit 1, Optimized ZIRLO High Performance Fuel Cladding material will be utilized to contain the fuel pellets. The Optimized ZIRLO cladding material is further described in Reference 50. A schematic of the fuel rod is shown in Figure 4-86.

The fuel pellets are right circular cylinders consisting of uranium dioxide powder which is compacted by cold pressing and then sintered to the required density. The ends of each pellet are dished slightly to allow for greater axial expansion at the center of the pellets.

Void volume and clearances are provided within the rods to accommodate fission gases released from the fuel, differential thermal expansion between the cladding and the fuel, and fuel density changes during irradiation, thus avoiding overstressing the cladding or seal welds. Shifting of the fuel within the cladding during handling or shipping prior to core loading is prevented by a stainless steel helical spring which bears on top of the fuel. Prior to fuel rod loading, the bottom end plug is pressed and welded to the fuel tube. The pellets are then loaded in the fuel tube to the required stack height, the spring is inserted into the top end of the fuel tube, and the top end plug is pressed into the top end of the tube and welded. All of the fuel rods are internally pressurized with helium during the welding process to minimize compressive cladding stresses and prevent cladding flattening due to coolant operating pressures.

4.2.1.2 Fuel Assembly Structure

The fuel assembly structure consists of a bottom nozzle, top nozzle, guide and instrument thimbles, and grids, as shown in Figure 4-85 (RFA).

4.2.1.2.1 Bottom Nozzle

Deleted paragraph(s) per 2016 Update.

RFA

The bottom nozzle serves as a bottom structural element of the fuel assembly and directs the coolant flow distribution to the assembly. The square nozzle is fabricated from Type 304 stainless steel and consists of a perforated plate and four angle legs with bearing plates as shown in Figure 4-85. The legs form a plenum for the inlet coolant flow to the assembly. Coolant flows from the plenum in the bottom nozzle upward through the penetrations in the plate to the channels between the fuel rods. The penetrations in the plate are positioned between the rows of fuel rods. The plate also prevents accidental downward ejection of the fuel rods from the fuel assembly. The bottom nozzle is reconstitutable and is fastened to the fuel assembly guide thimbles by locked screws which penetrate through the nozzle and mate with a threaded plug in each guide thimble.

The RFA design includes the use of the Debris Filter Bottom Nozzle (DFBN) to reduce the possibility of fuel rod damage due to debris induced fretting. Flow holes are sized to minimize passage of debris large enough to cause damage while providing sufficient flow area, acceptable pressure drop and maintaining structural integrity of the nozzle. The DFBN includes a reinforcing skirt to enhance reliability during postulated adverse handling conditions during refueling.

Axial loads (holddown) imposed on the fuel assembly and the weight of the fuel assembly are transmitted through the bottom nozzle to the lower core plate. Indexing and positioning of the

fuel assembly is controlled by alignment holes in two diagonally opposite bearing plate which mate with locating pins in the lower core plate. Any lateral loads on the fuel assembly are transmitted to the lower core plate through the locating pins.

4.2.1.2.2 Top Nozzle

Deleted paragraph(s) per 2016 Update.

RFA

The RFA fuel assembly incorporates a reconstitutable top nozzle (RTN). The RTN attaches to the 24 guide tubes by way of lock tubes. The lock tube captures an insert on the upper end of each guide tube within a circumferential groove located on the inner diameter of the through-hole in the RTN top nozzle which receives the guide tube. In addition to allowing reconstitution of fuel rods and functioning as the upper structural element of the fuel assembly, the RTN also provides a partial protective housing for control components that are positioned within the fuel assembly's guide tubes. The RTN top nozzle consists of an adapter plate, enclosure, top plate, and pads. Holddown springs are mounted on the top plate as shown in Figure 4-85, and are fastened in place by bolts and clamps located at two diagonally opposite corners. On the other two corners integral pads are positioned which contain alignment holes for locating the upper end of the fuel assembly. The top nozzle structure is made of Type 304 stainless steel and the holddown springs are made of Inconel-718. The holddown spring clamp screws are made of Inconel 600 or 718.

Eight lead use assemblies (LUAs) were delivered with the first RFA fuel batch incorporating an improved top nozzle design referred to as the "Quick Release Top Nozzle" (QRTN) design. Catawba 1 Cycle 14 is the first full RFA fuel batch to implement the QRTN design. The QRTN design was licensed by Westinghouse using the Fuel Criteria Evaluation Process (FCEP) per Reference 33. As required by the Westinghouse FCEP SER (Reference 45), the NRC was notified in Reference 47 of the QRTN design. The QRTN design will be used in the RFA assembly in all future cycles.

The QRTN feature is utilized on the sixteen- (16) outer thimble tubes and is housed within the upper nozzle adapter plate. It consists of a locking ring that is rotated an eighth of a turn to lock and unlock the upper nozzle from the guide tubes of the fuel assembly skeleton. The top nozzle is attached to the guide tubes through axial interference between the lugs on the upper portion of the guide tubes and the locking ring when the locking ring has been rotated to the locked position in the top nozzle. The locking ring is prevented from accidentally unlocking by a spring that seats the locking ring such that rotational interference is encountered. To unlock the quick-disconnect feature, the spring must be compressed before rotating the locking ring.

The square adapter plate (common to both RTN and QRTN) is provided with round penetrations and semi-circular ended slots to permit the flow of coolant upward through the top nozzle. The ligaments in the plate cover the tops of the fuel rods and prevent their upward ejection from the fuel assembly. The enclosure is a box-like structure that sets the distance between the adapter plate and the top plate. The top plate has a large square hole in the center to permit access for the control rods and the control rod spiders.

If the fuel assemblies are damaged or develop leaking fuel rods, the fuel assemblies can be reconstituted in order to replace damaged rods. The typical replacement is a fuel rod that contains pellets of naturally enriched uranium dioxide (UO₂). Aside from enrichment, this rod is similar in design and behavior to a standard fuel rod and is analyzed using standard approved methods. If grid damage exists, solid filler rods made of stainless steel, Zircaloy, or ZIRLO could be used as a replacement. A maximum of 10 such filler rods can be substituted into a

single fuel assembly. Fuel assemblies with severe structural damage or with failed fuel pins that cannot be completely removed can be recaged or discharged. A recage operation entails transferring all of the sound fuel rods from the damaged cage to a new fuel assembly cage. This new fuel assembly will function the same as the assembly that it replaces.

As discussed in Reference 33, Duke's NRC-approved reconstitution topical report (Reference 29) will be used to support reconstitution of Robust fuel assemblies with filler rods. The methodology discussed in Reference 29 ensures acceptable nuclear, mechanical, and thermal-hydraulic performance of reconstitutable assemblies.

4.2.1.2.3 Guide and Instrument Thimbles

Deleted paragraph(s) per 2016 Update.

RFA

The guide thimbles are structural members that also provide channels for the neutron absorber rods, burnable poison rods, burnable poison rods, neutron source, or thimble plug assemblies. Each thimble is fabricated from ZIRLO tubing having two different diameters. The tube diameter at the top section provides the annular area necessary to permit rapid control rod insertion during a reactor trip. The lower portion of the guide thimble is swaged to a smaller diameter to reduce the diametral clearance and produce a dashpot action near the end of the control rod travel during normal trip operation. Holes are provided on the thimble tube above the dashpot to reduce the rod drop time. The dashpot is closed at the bottom by means of an end plug with a small flow port to avoid fluid stagnation in the dashpot during normal operation. A ZIRLO instrument sheath occupies the center lattice position and provides guidance and protection for the incore instrumentation assemblies.

4.2.1.2.4 Grid Assemblies

Deleted paragraph(s) per 2016 Update.

RFA

The fuel rods, as shown in Figure 4-85, are supported at intervals along their length by grid assemblies that maintain the lateral spacing between the rods. The grid assembly consists of individual slotted straps interlocked in an "egg-crate" arrangement. Each fuel rod is supported within each grid by the combination of support dimples and springs. The magnitude of the grid restraining force on the fuel rods is set high enough to minimize possible fretting without overstressing the cladding at the points of contact between the grids and fuel rods. The grid assemblies also allow axial thermal expansion of the fuel rods without imposing restraint sufficient to buckle or distort the fuel rods.

As shown in Figure 4-85, there are twelve grid assemblies in the RFA design. There are six intermediate mixing vane grids made of ZIRLO. This material is chosen for its low neutron absorption and resistance to corrosion. The internal straps include mixing vanes that project into the coolant stream and promote mixing of the coolant.

The RFA design also includes ZIRLO, modified intermediate flow mixer grids. As shown in Figure 4-85, modified intermediate flow mixer grids are located in the three uppermost spans between the structural intermediate grids. The modified intermediate flow mixer grids promote mixing, but are not intended to be structural members. Each modified intermediate flow mixer grid cell provides four point fuel rod support. The simplified cell arrangement allows the modified intermediate flow mixer grid to accomplish its flow mixing objective with minimal pressure drop.

The top and bottom grids, made of Inconel-718, do not include mixing vanes. Inconel-718 is used because of its corrosion resistance and high strength. The intersections of the individual straps are joined by brazing.

The RFA design also includes a protective bottom grid (PBG), which is similar to the modified intermediate flow mixer grid, but fabricated of Inconel without mixing vanes. The PBG is positioned directly above the bottom nozzle. The PBG provides added protection against debris induced fretting by trapping debris below the grid where it can wear against the solid end plug. The PBG also provides improved resistance to grid-to-rod fretting by means of additional support at the bottom of the fuel rod.

The spacer grid assemblies are fastened to the guide thimble assemblies to create an integrated structure. Attachment of the Inconel and ZIRLO spacer grids to the thimble tubes is performed using a mechanical 4-lobe bulge process, with the exception of the bottom end grid and bottom protective grid. These two grids are spot-welded to a stainless steel insert that is captured between the guide thimble end plug and the bottom nozzle by means of a stainless steel thimble screw. The mechanical bulge fastening process has been successfully used by Westinghouse since the introduction of zircaloy guide thimbles in 1969.

4.2.1.3 Core Components

4.2.1.3.1 Rod Cluster Control Assembly

Westinghouse Hybrid Enhanced Performance-RCCAs (Potential Spares stored in Spent Fuel Pool, Units 1 and 2)

The rod cluster control assemblies are used for shutdown and control purposes to offset fast reactivity changes. Figure 4-9 illustrates the rod cluster control assembly location in the reactor relative to the interfacing fuel assemblies and guide tube assemblies.

A rod cluster control assembly is comprised of a group of individual neutron absorber rods fastened at the top end to a common spider assembly, as illustrated in Figure 4-10.

These control rods are kept as potential spares for Units 1 and 2. The absorber materials used in the control rod design are boron carbide pellets and Ag-In-Cd alloy slugs. The absorber materials are essentially "black" to thermal neutrons and have sufficient additional resonance absorption to significantly increase their worth. The B₄C pellets are stacked on top of the extruded Ag-In-Cd rods, and the absorber materials are sealed in cold-worked stainless steel tubes (Figure 4-11). Sufficient diametral and end clearance is provided to accommodate relative thermal expansions and material swelling, as shown in Section 4.2.4.6.

The bottom end plugs are bullet-nosed to reduce the hydraulic drag during reactor trip and to guide smoothly into the dashpot section of the fuel assembly guide thimbles.

Westinghouse Chrome Coated Hybrid NG-RCCAs (Unit 2)

The Westinghouse Hybrid chrome coated NG-RCCA design will be used in Unit 2. The absorber materials used in this control rod design are B₄C pellets and Ag-In-Cd slugs. The B₄C pellets are stacked on top of the Ag-In-Cd rods, and the absorber materials are sealed in stainless steel tubes.

The outer surface of the absorber rod cladding is coated with an industrial hard-chrome plating. This coating is used as wear resistance for both the RCCA rodlets and the upper internals guide cards. The design includes a two piece cast spider assembly which is joined by a solitary weld. The absorber rods are attached to the spider assembly via a pinless connection. The pinless

connection is achieved via top-end plug extensions with flexure joints allowing for opposite thread connections with lock welds.

BWFC Ionitrided Hybrid RCCAs (Unit 1)

The B₄C ionitrided hybrid design control rods are used in Unit 1. The ionitrided hybrid RCCA consists of a group of 24 individual control rods fastened to a common spider assembly with lock pins and nuts. The absorber materials for the hybrid design are B₄C pellets stacked on top of an extruded Ag-In-Cd alloy tip. The absorber materials are encapsulated in cold worked stainless steel tubes. The absorber materials are seal welded at the bottom and top with end plugs to prevent contact with the reactor coolant. The diameter in the lower 12 inches of absorber has been decreased slightly. The stainless steel cladding is nitrogen treated to harden the surface and make it less susceptible to fretting wear. Sufficient diametral and end clearances are provided to accommodate relative thermal expansions and material swelling.

The BWFC ionitrided hybrid RCCA spider assembly is in the form of a cast spider. Since, the spider assembly is a one-piece cast design, the control rods and fingers are not required to be brazed to the spider hub. The RCCA spider is fabricated of 316L stainless steel. A spring is located in the lower part of the hub. The spider springs are fabricated from Inconel 718. The spring is preloaded and maintained within the hub by the action of a spring retainer and tension bolt. The spring pack consists of the spider spring, spring retainer, and spring tension bolt. The spring pack is designed to absorb the kinetic energy of the RCCA during an RCCA scram.

The absorber rods are fastened to the spider by lock pins and nuts. The top end of the rodlets are fastened to the spider with a flex joint. The threaded end of the upper end plug is inserted into the bottom of the spider boss hole. The lock pin is inserted into aligned holes of the upper end plug and spider boss. The control rod nut is torqued and welded to the spider boss. Then, the lock pin is spot welded on the spider boss hole face. The upper end is machined with a reduced diameter shank to provide flexibility to the joint (flex joint). The flex joint provides the ability to accommodate small operating or assembly misalignments.

Coated Rod Demo RCCAs (Unit 2 Only)

During the operation of Catawba 2 Cycles 3 & 4, three BWFC demonstration RCCAs were placed into service. Two of the RCCAs had chrome coated rodlets. The third had chromium carbide coated rodlets. The three were placed into operation as part of a demonstration project that initiated in C2BOC3. The purpose of the demonstration project was to determine the effect of the rod coating on control rod and guide card wear. While the coatings proved effective in reducing wear, they were determined to be less effective than the ionitride technique. These three demo coated RCCAs are now available for use in unit 2 reactor.

The BWFC demo RCCAs are functionally identical to the ionitrided RCCA already described. The only difference in designs was the wear resistant treatment of the poison rodlets and the poison rod cladding of the chromium carbide RCCA. The demonstration rods have a slightly larger OD than the ionitrided RCCAs (Reference Figure 4-87). The chrome coating was applied to the standard 0.381 inch OD of a SS-304 rod clad and creates a nominal 0.382 OD rodlet. The Chromium Carbide coating is applied to an inconel 625 clad. Operational experience from cycle 3 showed no impact on drop time due to the wear resistant coatings.

4.2.1.3.2 Burnable Poison Assembly

The WABA (Wet Annular Burnable Absorber), shown in Figure 4-83, consists of a cluster of burnable poison rods with Zircaloy-4 cladding. All other structural materials in the assembly are types 304 or 308 stainless steel except for the springs which are Inconel-718. The pellets in the WABA rods are made with 6.03 mg B10/cm. The WABA BPRA rod design is comprised of

annular pellets of aluminum oxide - boron carbide ($A1_2O_3-B_4$ burnable absorber material contained between two concentric Zircloy tubings. The Zircaloy tubings, which form the inner and outer clad for the BPRA rod are plugged and seal welded at the ends to encapsulate the annular stack of absorber material. Reactor coolant flows inside the inner tubing and outside the outer tubing of the annular rod. A WABA rod is shown in longitudinal and traverse cross-sections in Figure 4-84.

The BRPA upper structure provides an attachment for the burnable poison rods and is compressed between the reactor internals upper core plate and fuel assembly top nozzle. The BPRA provides a flow path to the upper head injection (UHI) support column. The upper structure holddown assembly is comprised of a holddown spring pack, baseplate assembly, holddown bar, two retainer pins, and a flow cup. All components are fabricated from 304L stainless steel except for the spring pack, which is wound from Inconel 718 wire. The BPRA upper structure is compressed by overcoming the spring preload, and forcing the hold down bar weldment down over the sleeve. The loading arms on the hold down bar directly contact the bottom surface of the upper core plate. The BPRA flow cup protrudes through the upper core plate flow hole and interfaces closely with the lower end nozzle of the UHI support column (reactor internals). The upper structure provides the required holddown force to prevent the BPRA from lifting out of the fuel assembly due to hydraulic loads, yet allows for fuel assembly growth due to irradiation.

4.2.1.3.3 Neutron Source Assembly

The purpose of the neutron source assembly is to provide a base neutron level to ensure that the detectors are operational and responding to core multiplication neutrons.

Both primary and secondary neutron source rods have been used. The primary source rod, containing a radioactive material, spontaneously emits neutrons during initial core loading and reactor startup. The two primary source assemblies were discharged after the first cycle.

The secondary source rod contains a stable material which must be activated by neutron bombardment during reactor operation. The activation results in the subsequent release of neutrons. This becomes a source of neutrons during periods of low neutron flux, such as during refueling and the subsequent startups.

Based on core design and core monitoring considerations, a reload core may not contain any secondary sources. If secondary source assemblies are used, typically two secondary source assemblies will be loaded into the core. Some cores may contain only one secondary source assembly (for example, if a source assembly is damaged during handling). As many as four secondary source assemblies may be used when activating new secondary source assemblies.

The secondary sources use a double encapsulated source rod design that utilizes a six finger configuration. The remaining rod locations within the source assembly contain thimble plugs. The outline drawing of the doubly encapsulated secondary source is shown in Figure 4-78. The source assemblies contain a holddown assembly identical to that of the burnable poison assembly. The secondary source rods contain pellets stacked to a height of approximately 88 inches. The rods in each assembly are permanently fastened at the top end to a holddown assembly.

The structural members are constructed of Type 304 stainless steel except for the springs. The springs exposed to the reactor coolant are Inconel 718.

4.2.1.3.4 Thimble Plug Assembly

Thimble plug assemblies limit bypass flow through the rod cluster control guide thimbles in fuel assemblies which do not contain either control rods, source rods, or burnable poison rods.

The thimble plug assembly, as shown in Figure 4-16, consists of a flat base plate with short rods suspended from the bottom surface and a spring pack assembly. The 24 short rods, called thimble plugs, project into the upper ends of the guide thimbles to reduce the bypass flow. Each thimble plug is permanently attached to the base plate by a nut which is lock-welded to the threaded end of the plug. Similar short rods are also used on the source assemblies and burnable poison assemblies to plug the ends of all vacant fuel assembly guide thimbles. When in the core, the thimble plug assemblies interface with both the upper core plate and with the fuel assembly top nozzles by resting on the adaptor plate. The spring pack is compressed by the upper core plate when the upper internals assembly is lowered into place.

All components in the thimble plug assembly, except for the springs, are constructed from Type 304 stainless steel. The springs are Inconel 718.

4.2.2 Fuel System Design Criteria

The plant design conditions are divided into four categories in accordance with their anticipated frequency of occurrence and risk to the public: Condition I - Normal Operation; Condition II - Incidents of Moderate Frequency; Condition III - Infrequent Incidents; Condition IV - Limiting Faults. The bases and description of plant operation and events involving each Condition are given in Chapter 15.

The reactor is designed so that its components meet the following performance and safety criteria:

1. The mechanical design of the reactor core components and their physical arrangement, together with corrective actions of the reactor control, protection, and emergency cooling systems (when applicable) assure that:
 - a. Fuel damage¹ is not expected during Condition I and Condition II events. It is not possible, however, to preclude a very small number of rod failures. These are within the capability of the plant cleanup system and are consistent with plant design bases. The number of rod failures is small enough such that the dose limits given in 10 CFR 100 will not be exceeded.
 - b. The reactor can be brought to a safe state following a Condition III event with only a small fraction of fuel rods damaged¹. The extent of fuel damage might preclude immediate resumption of operation.
 - c. The reactor can be brought to a safe state and the core can be kept subcritical with acceptable heat transfer geometry following transients arising from Condition IV events.
2. The fuel assemblies are designed to withstand loads induced during shipping, handling and core loading without exceeding the criteria of Section 4.2.3.5.
3. The fuel assemblies are designed to accept control rod insertions in order to provide the required reactivity control for power operations and reactivity shutdown conditions (if in such core locations).

¹ Fuel damage as used here is defined as penetration of the fission product barrier (i.e., the fuel rod clad)

4. All fuel assemblies have provisions for the insertion of incore instrumentation necessary for plant operation (if in such core locations).
5. The reactor internals in conjunction with the fuel assemblies and incore control components direct coolant through the core. This achieves acceptable flow distribution and restricts bypass flow so that the heat transfer performance requirements can be met for all modes of operation.

4.2.3 Design Bases

The fuel rod and fuel assembly design bases are established to satisfy the general performance and safety criteria presented in this section.

4.2.3.1 Cladding

Deleted paragraph(s) per 2016 Update.

RFA

1. Material and Mechanical Properties

ZIRLO combines low absorption cross section; high corrosion resistance to coolant, fuel and fission products; high strength and ductility at operating temperatures; and high reliability. Reference 1 documents the operating experience with ZIRLO as a clad material, and Reference 40 provides its mechanical properties with due consideration of temperature and irradiation effects.

Optimized ZIRLO enhances corrosion resistance of the ZIRLO cladding material. Reference 50 provides; the mechanical properties with due consideration of temperature and irradiation effects.

2. Stress-Strain Limits

Cladding Stress - The cladding stress design basis is the fuel system will not be damaged due to excessive fuel cladding stress (Reference 48). Cladding stress intensities, excluding pellet cladding interaction induced stress, are evaluated using ASME Pressure Vessel Code (Reference 49) guidelines. Stresses are combined to calculate maximum stress intensities which are compared to the criteria, based on the ASME code, given in Reference 48. An alternate methodology for evaluating cladding stress is to calculate the volume average effective stress with the Von Mises equation and show that it is less than the 0.2% offset cladding yield stress (Reference 40 and 51). The volume average effective stress is calculated considering interference due to uniform cylindrical pellet cladding contact caused by thermal expansion, pellet swelling and uniform cladding creep, and pressure differences, with due consideration of temperature and irradiation effects under Condition I and II events.

Cladding Tensile Strain - The total tensile creep strain is less than 1% from the unirradiated condition. The elastic tensile strain during a transient is less than 1% from the pre-transient value. This limit is consistent with proven practice.

3. Vibration and Fatigue

Strain Fatigue - The cumulative strain fatigue cycles are less than the design strain fatigue life. This basis is consistent with proven practice.

Vibration - Potential for fretting wear of the clad surface exists due to flow induced vibrations. This condition is taken into account in the design of the fuel rod support system. The clad wear depth is limited to acceptable values by the grid support dimple and spring design.

4. Chemical Properties of the Cladding

ZIRLO fuel rod cladding has been demonstrated to be fully compatible with the operating environment of the Reactor Coolant System throughout its operating lifetime and with the spent fuel pool environment for subsequent long-term storage. Reference 40 describes the chemical properties in detail.

4.2.3.2 Fuel Material

Deleted paragraph(s) per 2016 Update.

RFA

1. Thermal-Physical Properties

The thermal-physical properties of UO_2 are described in Reference 2 with due consideration of temperature and irradiation effects.

Fuel Pellet Temperatures - The center temperature of the hottest pellet is below the melting temperature of UO_2 . While a limited amount of center melting can be tolerated, the design conservatively precludes center melting. A calculated fuel center temperature of $4700^\circ F$ has been selected as an overpower limit to ensure no fuel melting. This provides sufficient margin for uncertainties as described in Section 4.4.1.9.1.

Fuel Pellet Density - The nominal design density of the fuel is 95.5% of theoretical.

2. Fuel Densification and Fission Product Swelling

The design bases and models used for fuel densification and swelling are provided in References 34 and 35.

3. Chemical Properties

Reference 40 provides the basis for justifying that no adverse chemical interactions occur between the fuel and its adjacent material.

4.2.3.3 Fuel Rod Performance

The detailed fuel rod design establishes such parameters as pellet size and density, cladding-pellet diametral gap, gas plenum size, and helium pre-pressurization level. The design also considers effects such as fuel density changes, fission gas release, cladding creep, and other physical properties which vary with burnup. The integrity of the fuel rods is ensured by designing to prevent excessive fuel temperatures, excessive internal rod gas pressures due to fission gas releases, and excessive cladding stresses and strains. This is achieved by designing the fuel rods to satisfy the conservative design bases in the following sections during Condition I and Condition II events over the fuel lifetime. For each design basis, the performance of the limiting fuel rod must not exceed the limits specified.

Deleted paragraph(s) per 2016 Update.

RFA

1. Fuel Rod Models

The basic fuel rod models and the ability to predict operating characteristics are given in Reference 35 and Section 4.2.4.

2. Mechanical Design Limits

Cladding collapse shall be precluded during the fuel rod design lifetime. The models described in Reference 5 are used for this evaluation.

The rod internal pressure shall remain below a value which causes the fuel-clad diametral gap to increase due to outward cladding creep during steady-state operation. Rod pressure is also limited so that extensive departure from nucleate boiling (DNB) propagation does not occur during normal operation and any accident event (Reference 36).

4.2.3.4 **Spacer Grids**

Deleted paragraph(s) per 2016 Update.

RFA

1. Material Properties and Mechanical Design Limits

Spacer grids made of two different materials, ZIRLO and Inconel-718, are used in the RFA design. The top and bottom grids and protective bottom grid are made of Inconel-718.

Lateral loads resulting from a seismic or LOCA event will not cause unacceptably high plastic grid deformation. Each fuel assembly's geometry will be maintained such that the fuel rods remain in an array amenable to cooling. The behavior of the grids under loading has been studied experimentally.

2. Vibration and Fatigue

The grids provide sufficient fuel rod support to limit fuel rod vibration and maintain cladding fretting wear to within acceptable limits.

4.2.3.5 **Fuel Assembly**

1. Structural Design

The structural integrity of the fuel assemblies is assured by setting design limits on stresses and deformations due to various non-operational, operational, and accident loads. These limits are applied to the design and evaluation of the top and bottom nozzles, guide thimbles, grids, and the thimble joints.

Deleted paragraph(s) per 2016 Update.

RFA

The design bases for evaluating the structural integrity of the Robust fuel assemblies are:

- a. Nonoperational - 4g loading with dimensional stability.
- b. Normal and abnormal loads for Condition I and II - the fuel assembly component structural design criteria are established for the two primary material categories, namely austenitic steels and ZIRLO. The stress categories and strength theory presented in the ASME Boiler and Pressure Vessel Code, Section III, are used as a general guide.

For austenitic steel structural components, Tresca criterion is used to determine the stress intensities. The design stress intensity value, S_m , is given by the lowest of the following:

- 1) One-third of the specified minimum tensile strength or 2/3 of the specified minimum yield strength at room temperature.
- 2) One-third of the tensile strength or 90% of the yield strength at operating temperature, but not to exceed 2/3 of the specified minimum yield strength at room temperature.

The stress intensity limits are given below. All stress nomenclature is per the ASME Boiler and Pressure Vessel Code, Section III.

<u>Categories</u>	<u>Limit</u>
General Primary Membrane Stress Intensity	S_M
Local Primary Membrane Stress Intensity	$1.5 S_m$
Primary Membrane plus Primary Bending Stress Intensity	$1.5 S_m$
Total Primary plus Secondary Stress Intensity Range	$3.0 S_m$

The ZIRLO structural components, which consist of guide thimbles, intermediate spacer grids, and fuel tubes are in turn subdivided into two categories because of material differences and functional requirements. The fuel tube and grid design criteria are covered separately in Section 4.2.3.1 and 4.2.3.4, respectively. The Zircaloy-4 and ZIRLO structural component stresses will be consistent with ASME Code Section III requirements after accounting for thinning due to corrosion (Reference 46). For the guide thimble design, the stress intensities, the design stress intensities, and the stress intensity limits are calculated using the same methods as for the austenitic steel structural components. For conservative purposes, the unirradiated properties of ZIRLO are used.

- c. Abnormal loads during Condition III or IV events - worst cases represented by seismic loads, or blowdown loads during a LOCA event.
 - 1) Deflections or failures of components cannot interfere with the reactor shutdown or emergency cooling of the fuel rods.

The fuel assembly structural component stresses under faulted conditions are evaluated using primarily the methods outlined in Appendix F of the ASME Boiler and Pressure Vessel Code, Section III.

For the austenitic steel fuel assembly components, the stress intensity and the design stress intensity value, S_m are defined in accordance with the rules described in the previous section for normal operating conditions. Since the current analytical methods utilize elastic analysis, the stress intensity limits are defined as the smaller values of $2.4S_m$ or $0.70S_u$ for primary membrane and $3.6S_m$ or $1.05S_u$ for primary membrane plus primary bending.

For the ZIRLO components the stress intensities are defined in accordance with the rules described in the previous section for normal operating conditions, and the design stress intensity values, S_m , are set at two-thirds of the material yield strength, S_y , at reactor operating temperature. This results in ZIRLO stress intensity limits being the smaller of $1.6S_y$ or $0.70S_u$ for primary membrane and $2.4S_y$ or $1.05S_u$ for primary membrane plus bending. For conservative purposes, the ZIRLO unirradiated properties are used to define the stress limits.

1. Thermal-hydraulic Design

This topic is covered in Section 4.4.

4.2.3.6 Core Components

The core components consist of the rod cluster control assemblies (RCCAs), the secondary source assemblies, the thimble plug assemblies and the burnable poison assemblies. A description of these components is provided in Section 4.2.1.

1. Thermal-Physical Properties of the Absorber Material

The absorber material for the RCCAs is hybrid B₄C pellets with a tip of Ag-In-Cd alloy slugs. The thermal-physical properties of Ag-In-Cd are described in Reference 2, and B₄C properties are described in References 2 and 13. The absorber material temperature shall not exceed its melting temperature (1454°F for Ag-In-Cd, 4400°F for B₄C).

The WABA burnable poison material is Al₂O₃-B₄C. The burnable poison rods are designed so that the absorber material remains below its softening temperature (1492°F for a referenced 12.5 weight percent boron). The melting point for WABAs is >> 1200°F. The softening temperature is defined in accordance with ASTM C 338. In addition the structural elements are designed to prevent excessive slumping.

2. Compatibility of the Absorber and Cladding Materials

The BWFC Ionitrided Hybrid control rod cladding is type 316 stainless steel tubing with ion-nitride treatment to limit wear of the cladding. The NG-RCCA cladding is type 304L stainless steel tubing with chrome coating to limit wear of the cladding. The burnable poison cladding is Zircaloy-4. Extensive in-reactor experience and available quantitative information shows that reaction rates between the RCCA cladding (both 304L and 316) stainless steel, Zircaloy-4, and water, or any contacting metals, is negligible at operational temperatures (References 2 and 13).

The WABA cladding is Zircaloy-4. Due to the relatively low pellet design temperature, no appreciable reaction will occur between the poison material and the cladding.

3. Cladding Stress-Strain Limits

For Conditions I and II the stress categories and strength theory presented in the ASME Boiler and Pressure Vessel Code, Section III, subsection NB-3000, are used as a general guide. The Code methodology is applied, as with fuel assembly structural design, where possible. For Conditions III and IV code stresses are not limiting. Failures of the burnable poison rods during these conditions must not interfere with reactor shutdown or cooling of the fuel rods.

The deformation or failure of the control rod cladding must not prevent reactor shutdown or cooling of the fuel rods. A breach in the cladding does not result in serious consequences because the Ag-In-Cd is relatively inert and, in the case of the B₄C material, it would take months for a significant loss of highly irradiated B₄C to occur and years for slightly irradiated B₄C to occur (Reference 13). The mechanical design bases for the control rods are consistent with the loading conditions of the ASME Boiler and Pressure Vessel Code, Section III:

- a. External pressure equal to the Reactor Coolant System operating pressure with appropriate allowance for overpressure transients.
- b. Wear allowance equivalent to 1,000 full power reactor trips.
- c. Bending of the rod due to a misalignment in the guide tube.

- d. Forces imposed on the rods during rod drop.
- e. Loads imposed by the accelerations of the control rod drive mechanism.
- f. Radiation exposure during maximum core life.
- g. Temperature effects from room to operating conditions.

The burnable poison assemblies, thimble plug assemblies, and source assemblies are static core components. The mechanical design of these components satisfies the following:

- a. Accommodate the differential thermal expansion between the fuel assembly and the core internals.
- b. Maintain positive contact with the fuel assembly and the core internals.

The design evaluation of the core components is discussed in Section 4.2.4.6.

4. Irradiated Behavior of Absorber Material

Operating experience and/or testing evaluation of the effects of irradiation upon the properties of Ag-In-Cd have shown that inpile corrosion behavior is similar to out-of-pile behavior and that, for low oxygen content water, corrosion rates are low (Reference 2). The major differences between irradiated B₄C and irradiated Ag-In-Cd are irradiation swelling, solubility of highly irradiated B₄C in the reactor coolant, and gaseous product release.

All of these material properties for B₄C are appropriately accommodated into the hybrid control rod design (Reference 13).

4.2.3.7 Testing, Irradiation Demonstration and Surveillance

Per Technical Specification 4.2.1, the fuel designs supplied on a reload basis are limited to those that have been analyzed with applicable NRC staff-approved codes and methods, and shown by tests or analyses to comply with all fuel safety design bases. Demonstration programs provide the fundamental engineering data used to develop codes and methods. Demonstration programs also provide representative testing to ensure that a fuel design complies with all fuel safety design bases.

Per Technical Specification 4.2.1, Catawba is allowed to operate with a limited number of lead test assemblies that have not completed representative testing as long as they are located in non-limiting core regions (locations).

Current Demonstration Programs

NGF – The Westinghouse Next Generation Fuel (NGF) design is being operated to ensure that possible fuel design changes will perform as expected in Duke cores.

MOX – The mixed-oxide (MOX) fuel program is demonstrating the use of uranium-dioxide fuel that is enriched with plutonium.

Fuel Design Data

UFSAR Section 4.2.1 contains detailed information for those fuel designs that are supplied on a reload basis. Lead test assemblies are not included in those descriptions, because some design features may be proprietary information for the fuel vendor and the actual design supplied on a reload basis may be different than the demonstration assemblies. Instead, Table 4-23 is used to communicate design data for any current demonstration assembly design. The design information in UFSAR Section 4.2.1 is updated with the first reload of fuel developed from the demonstration program.

Mechanical and Thermal-Hydraulic Analysis Methods

Table 4-24 communicates the mechanical and thermal-hydraulic analysis methods for any current demonstration program.

4.2.4 Design Evaluation

The fuel assemblies, fuel rods, and incore control components are designed to satisfy the performance and safety criteria of Section 4.2, the mechanical design bases of Section 4.2.3, and other interfacing nuclear and thermal-hydraulic design bases specified in Sections 4.3 and 4.4. Effects of Accident Conditions II, III, IV or Anticipated Transients Without Trip on fuel integrity are presented in Chapter 15 or supporting topical reports.

4.2.4.1 Cladding

Deleted paragraph(s) per 2016 Update.

RFA

1. Vibration and Wear

Fuel rod vibrations are flow induced. The effect of the vibration on the fuel assembly and individual fuel rods is minimal. The cyclic stress range associated with deflections of such small magnitude is insignificant and has no effect on the structural integrity of the fuel rod. No significant wear of the cladding or grid supports is expected during the life of the fuel assembly. Fuel vibration has been experimentally investigated.

2. Fuel Rod Internal Pressure and Cladding Stresses

The burnup dependent fission gas release model (Reference 35) is used in determining the internal gas pressures as a function of irradiation time. The fuel rod has been designed to ensure that the maximum internal pressure of the fuel rod will not exceed the value which would cause an increase in the fuel cladding diametral gap or extensive DNB propagation during normal operation.

The cladding stresses at a constant level fuel rod power are low. Compressive stresses are created by the pressure differential between the coolant pressure and the rod internal gas pressure. Because of the prepressurization with helium, the volume average effective stresses are always less than approximately 10,000 psi at the pressurization level used in this fuel rod design. Stresses due to the temperature gradient are not included in this average effective stress because thermal stresses are, in general, negative at the cladding inside diameter and positive at the cladding outside diameter and their contribution to the cladding volume average stress is small. Furthermore, the thermal stress decreases with time during steady-state operation due to stress relaxation. The stress due to a pressure differential is highest in the minimum power rod at the beginning-of-life due to low internal gas pressure and the thermal stress is highest in the maximum power rod due to the steep temperature gradient.

The internal gas pressure at beginning-of-life is approximately 1400 psia at operating temperature for a typical lead burnup fuel rod. The total tangential stress at the cladding inside diameter at beginning-of-life is approximately 14,400 psi compressive (~13,000 psi due to ΔP and ~1,400 psi due to ΔT) for a low power rod, operating at 5 kw/ft and approximately 12,000 psi compressive (~8,500 psi due to ΔP and ~3,500 psi due to ΔT) for a high power rod operating at 15 kw/ft. However, the volume average effective stress at beginning-of-life is between 8,000 psi (high power rod) and approximately 10,000 psi (low

power rod). These stresses are substantially below even the unirradiated cladding strength (~55,000 psi) at a typical cladding mean operating temperature of 700°F.

Tensile stresses could be created once the cladding has come in contact with the pellet. These stresses would be induced by the fuel pellet swelling during irradiation. Fuel swelling can result in small cladding strains (< 1% for expected discharge burnups but the associated cladding stresses are very low because of cladding thermal creep and irradiation-induced creep). The 1% strain criterion is extremely conservative for fuel-swelling driven cladding strain because the strain rate associated with solid fission products swelling is very slow.

Pellet thermal expansion due to power increases is considered the only mechanism by which significant stresses and strains can be imposed on the cladding. Power increases in commercial reactors can result from fuel shuffling, reactor power escalation following extended reduced power operation, and control rod movement. Cladding stress intensities, excluding pellet cladding interaction induced stress, are evaluated using ASME Pressure Vessel Code (Reference 49) guidelines. Stresses are combined to calculate maximum stress intensities which are compared to the criteria, based on the ASME code, given in Reference 48. (see Section 4.2.3.1). An alternate methodology for evaluating cladding stress is to calculate the volume average effective stress with the Von Mises equation and show that it is less than the 0.2% offset cladding yield stress (Reference 40 and 51). The volume average effective stress is calculated considering interference due to uniform cylindrical pellet cladding contact caused by thermal expansion, pellet swelling and uniform cladding creep, and pressure differences, with due consideration of temperature and irradiation effects under Condition I and II events.

Power increases can result in large cladding strains without exceeding the cladding yield stress because of cladding creep and stress relaxation. Based on high strain rate burst and tensile test data on irradiated tubing, 1% strain was determined to be a conservative lower limit for irradiated cladding ductility and thus was adopted as a design criterion (see Section 4.2.3.1). The intent of this criterion is to minimize the potential for clad failure due to excessive clad straining. This criterion addresses slow strain rate mechanisms where the effective clad stress never reaches the yield strength due to stress relaxation. A spectrum of pin power histories is analyzed to determine allowable changes in local linear heat rate (Δ kw/ft). At various times during the steady-state depletion, the power is increased locally on the rod until 1% clad strain is calculated. For each reload design, the allowable changes in local linear heat rate (Δ kw/ft) as a function of burnup are compared to predicted peaking changes that result from either Condition I or II events.

3. Materials and Chemical Evaluation

ZIRLO cladding has a high corrosion resistance to the coolant, fuel, and fission products. As shown in Reference 1, there is considerable PWR operating experience on the capability of ZIRLO as a cladding material. Optimized ZIRLO enhances corrosion resistance of the ZIRLO cladding material. Reference 50 provides the mechanical properties with due consideration of temperature and irradiation effects.

Controls on fuel fabrication specify maximum moisture levels to preclude cladding hydriding.

Metallographic examination of irradiated commercial fuel rods have shown occurrences of fuel/clad chemical interaction. Reaction layers of < 1 mil in thickness have been observed between fuel and clad at limited points around the circumference. Metallographic data indicates that this interface layer remains very thin even at high burnup. Thus, there is no indication of propagation of the layer and eventual cladding penetration.

4. Fretting

Cladding fretting has been experimentally investigated. No significant fretting of the cladding is expected during the life of the fuel assembly.

5. Stress Corrosion

Stress corrosion cracking is another postulated phenomenon related to fuel/clad chemical interaction. Out-of-pile tests have shown that in the presence of high cladding tensile stresses, large concentrations of selected fission products (such as iodine) can chemically attack the ZIRLO tubing and can lead to eventual cladding cracking. Extensive post-irradiation examination has produced no in-pile evidence that this mechanism is operative in commercial fuel.

6. Cycling and Fatigue

A comprehensive review of the available strain-fatigue models are conducted by Westinghouse as early as 1968. This review included the Langer-O'Donnell model (Reference 37), the Yao-Munse model, and the Manson-Halford model. Upon completion of this review and using the results of the Westinghouse experimental programs discussed below, it was concluded that the approach defined by Langer-O'Donnell would be retained and the empirical factors of their correlation modified in order to conservatively bound the results of the Westinghouse testing program.

The Westinghouse testing program was subdivided into the following subprograms:

- a. A rotating bend fatigue experiment on unirradiated Zircaloy-4 specimens at room temperature and at 725°F. Both hydrided and non-hydrided Zircaloy-4 cladding are tested.
- b. A biaxial fatigue experiment in gas autoclave on unirradiated Zircaloy-4 cladding, both hydrided and non-hydrided.
- c. A fatigue test program on irradiated cladding from the CVS and Yankee Core V conducted at Battelle Memorial Institute.

The results of these test programs provided information on different cladding conditions including the effect of irradiation, of hydrogen level, and of temperature.

The design equations followed the concept for the design criterion according to the ASME Boiler and Pressure Vessel Code, Section III.

It is recognized that a possible limitation to the satisfactory behavior of the fuel rods in a reactor which is subjected to daily load follow is the failure of the cladding by low cycle strain fatigue. During their normal residence time in reactor, the fuel rods may be subjected to ~ 1000 cycles with typical changes in power level from 50 to 100% of their steady-state values.

The assessment of the fatigue life of the fuel cladding is subject to considerable uncertainty due to the difficulty of evaluating the strain range which results from the cyclic interaction of the fuel pellets and cladding. This difficulty arises, for example, from such highly unpredictable phenomena as pellet cracking, fragmentation, and relocation. Nevertheless, since 1968 this particular phenomenon has been investigated analytically and experimentally. Strain fatigue tests on irradiated and nonirradiated hydrided ZIRLO claddings were performed which permitted a definition of a conservative fatigue life limit and recommendation on a methodology to treat the strain fatigue evaluation of the Westinghouse reference fuel rod designs.

It is believed that the final proof of the adequacy of a given fuel rod design to meet the load follow requirements can only come from incore experiments performed on actual reactors.

Experience in load follow dates back to early 1970 with the load follow operation of the Saxton reactor. Successful load follow operation has been performed on reactor A (> 400 load follow cycles) and reactor B (> 500 load follow cycles). In both cases, there was no significant coolant activity increase that could be associated with the load follow mode of operation.

Strain fatigue test results for Optimized ZIRLO cladding material demonstrates that the fatigue behavior is within the Westinghouse fatigue design limit.

7. Rod Bowing

Reference 38 presents the NRC-approved model used for evaluation of fuel rod bowing. The effects of rod bow on DNBR are described in Section 4.4.1.2.5.

8. Consequences of Power-Coolant Mismatch

This subject is discussed in Chapter 15.

9. Irradiation Stability of the Cladding

As shown in Reference 1, there is considerable PWR operating experience on the capability of ZIRLO as a cladding material. Extensive experience with irradiated ZIRLO is summarized in Reference 40. Reference 50 provides a summary as well as the conditions and limitations associated with the irradiation effects on Optimized ZIRLO cladding material.

10. Creep Collapse and Creepdown

This subject and the associated irradiation stability of cladding have been evaluated using the models described in Reference 5. It has been established that the design basis of no clad collapse during planned core life can be satisfied by limiting fuel densification, and by having a sufficiently high initial internal rod pressure.

11. Linear Heat Rate to melt

The fuel cannot exceed the temperature which could cause it to melt. Linear Heat Rate to Melt (LHRTM) limits are used to determine core protection limits which ensure that fuel melting will not occur. A generic LHRTM analysis is performed using the methodology described in Reference 33. The melt temperature of UO₂ used in the PAD fuel performance code is given in Reference 35. A fuel centerline temperature limit of 4700°F is conservatively used to cover the reduction on melt temperature with burnup and manufacturing and modeling uncertainties.

4.2.4.2 Fuel Materials Considerations

Deleted paragraph(s) per 2016 Update.

RFA

1. Dimensional Stability of the Fuel

The mechanical design of the fuel rods accounts for the different thermal expansion of the fuel and the cladding, and for the densification of the fuel pellets.

2. Potential for Chemical Interaction

Sintered, high density uranium dioxide fuel reacts only slightly with the cladding at core operating temperatures and pressures. In the event of cladding defects, the high resistance of uranium dioxide to attack by water, protects against fuel deterioration, although limited

fuel erosion can occur. The effects of water-logging on fuel behavior are discussed in Section 4.2.4.3, item 4.

3. Thermal Stability

As has been shown by operating experience and extensive experimental work, the thermal design parameters conservatively account for changes in the thermal performance of the fuel elements due to pellet fracture which may occur during power operation. Observations from several Westinghouse PWR's (Reference 6) have shown that fuel pellets can densify under irradiation to a density higher than the manufactured values. Fuel densification and subsequent settling of the fuel pellets can result in local and distributed gaps in the fuel rods. Fuel densification has been minimized by improvements in the fuel manufacturing process and by specifying a high initial fuel density.

The evaluation of fuel densification effects and their considerations in fuel design are described in References 34 and 35.

4. Irradiation Stability

The treatment of fuel swelling and fission gas release are described in Reference 35.

4.2.4.3 Fuel Rod Performance

Deleted paragraph(s) per 2016 Update.

RFA

In calculating the steady-state performance of a nuclear fuel rod, the following factors must be considered:

1. Cladding creep and elastic deflection;
2. Pellet density changes, thermal expansion, gas release, and thermal properties as a function of temperature and burnup; and
3. Internal pressure as a function of fission gas release, rod geometry, and temperature distribution.

These effects are evaluated using a fuel rod design model (Reference 35) which includes appropriate models for time dependent fuel densification. With these interacting factors considered, the model determines the fuel rod performance characteristics for a given rod geometry, power history, and axial power shape. In particular, internal gas pressure, fuel and cladding temperatures, and cladding deflections are calculated. The fuel rod is divided into several axial sections and radially into a number of annular zones. Fuel density changes are calculated separately for each segment. The effects are integrated to obtain the internal rod pressure.

The initial rod internal pressure is selected to delay fuel/clad mechanical interaction and to avoid the potential for flattened rod formation. It is limited, however, by the design criteria for the rod internal pressure given in Section 4.2.3.3.

The gap conductance between the pellet surface and the cladding inner diameter is calculated as a function of the composition, temperature, and pressure of the gas mixture, the gap size, and contact pressure between the cladding and the pellet. After computing the fuel temperature for each pellet annular zone, the fractional fission gas release is assessed using an empirical model derived from experimental data (Reference 35). The total amount of gas released is based on the generation rate which is in turn a function of burnup. Finally, the gas release is summed over all the zones and the pressure is calculated.

1. Fuel-Cladding Mechanical Interaction

One factor in fuel element duty is potential mechanical interaction of fuel and cladding. This fuel/clad interaction produces cyclic stresses and strains in the cladding, and these in turn consume clad fatigue life. The reduction of fuel/clad interaction is therefore a goal of design. In order to achieve this goal and to enhance the cyclic operational capability of the fuel rod, the technology for using pre-pressurized fuel rods has been developed.

Initially the gap between the fuel and cladding is sufficient to prevent hard contact between the two. However, during power operation a gradual compressive creep of the cladding onto the fuel pellet occurs due to the external pressure exerted on the rod by the coolant. Cladding compressive creep eventually results in the fuel/clad contact. During this period of fuel/clad contact changes in power level could result in changes in cladding stresses and strains. By using pre-pressurized fuel rods to partially offset the effect of the coolant external pressure, the rate of cladding creep toward the surface of the fuel is reduced. Fuel rod pre-pressurization delays the time at which fuel/clad contact occurs and hence, significantly reduces the number and extent of cyclic stresses and strains experienced by the cladding both before and after fuel/clad contact. These factors result in an increase in the fatigue life margin of the cladding and lead to greater cladding reliability. If gaps should form in the fuel stacks, cladding flattening will be prevented by the rod pre-pressurization so that the flattening time will be greater than the fuel core life.

2. Irradiation Experience

Westinghouse fuel operational experience is presented in Reference 1.

3. Fuel and Cladding Temperature

The methods used for evaluation of fuel rod temperatures are presented in Reference 33.

4. Water-logging

Local cladding deformations typical of water-logging (*) bursts have never been observed in commercial Westinghouse fuel. Experience has shown that the small number of rods which have acquired cladding defects, regardless of primary mechanism, remain intact and do not progressively distort or restrict coolant flow. In fact such small defects are normally observed through reductions in coolant activity to be progressively closed upon further operation due to the buildup of zirconium oxide and other substances. Secondary failures which have been observed in defected rods are attributed to hydrogen embrittlement of the cladding. Post-irradiation examinations point to the hydriding failure mechanism rather than a waterlogging mechanism; such secondary failures do not result in flow blockage. Hence, the presence of such fuel, the quantity of which must be maintained below technical specification limits, does not in any way exacerbate the effects of any postulated transients.

Zircaloy clad fuel rods which have failed due to water-logging (Reference 9) indicate that that the very rapid power transients are required for fuel failure. Normal operational transients are limited to about 40 cal/gm-min. (peak rod), while the Spert tests (Reference 10) indicate that 120 cal/gm to 150 cal/gm are required to rupture the cladding even with very short transients (5.5 milli sec period).

5. Potentially Damaging Temperature Effects During Transients

The fuel rod experiences many operational transients (intentional maneuvers) during its residence in the core. A number of thermal effects must be considered when analyzing the fuel rod performance.

The cladding can be in contact with the fuel pellet at some time in the fuel lifetime. Clad-pellet interaction occurs if the fuel pellet temperature is increased after the cladding is in contact with the pellet. Clad-pellet interaction is discussed in Section 4.2.4.3.

Clad flattening, as shown in Reference 5, has been observed in some operating power reactors. Thermal expansion (axial) of the fuel rod stack against a flattened section of cladding could cause failure of the cladding. This is no longer a concern because clad flattening is precluded during the fuel residence in the core (see Section 4.2.4.1).

Potential differential thermal expansion between the fuel rods and the guide thimbles during a transient is considered in the design. Excessive bowing of the fuel rods is precluded because the grid assemblies allow axial movement of the fuel rods relative to the grids. Specifically, thermal expansion of the fuel rods is considered in the grid design and fuel assembly grid restraint system so that axial loads imposed on the fuel rods, during a thermal transient, will not result in excessively bowed fuel rods.

6. Fuel Element Burnout and Potential Energy Release

As discussed in Section 4.4.1.2, the core is protected from DNB over the full range of possible operating conditions. In the extremely unlikely event that DNB should occur, the cladding temperature will rise due to the steam blanketing at the rod surface and the consequent degradation in heat transfer. During this time there is a potential for chemical reaction between the cladding and the coolant. However, because of the relatively good film boiling heat transfer following DNB, the energy release resulting from this reaction is insignificant compared to the power produced by the fuel.

7. Coolant Flow Blockage Effects on Fuel Rods

This evaluation is presented in Section 4.4.4.7.

4.2.4.4 **Spacer Grids**

Deleted paragraph(s) per 2016 Update.

RFA

The coolant flow channels are established and maintained by the structure composed of grids and guide thimbles. The lateral spacing between fuel rods is provided and controlled by a spring/dimple support system. Contact of the fuel rods on the dimples is maintained through the clamping force of the grid springs. Lateral motion of the fuel rods is opposed by the spring force and the internal moments generated between the spring and the support dimples. Intermediate Flow Mixers (IFMs) are located in the three uppermost spans between structural grids and provide mid-span mixing in the hottest fuel assembly spans. Grid testing as described in Reference 42 has been performed for the RFA design to confirm design acceptability.

The fuel assembly component stress levels are limited by the grid design. For example, stresses in the fuel rod due to thermal expansion and ZIRLO irradiation growth are limited by the relative motion of the rod as it slips over the grid spring and dimple surfaces.

4.2.4.5 **Fuel Assembly**

Deleted paragraph(s) per 2016 Update.

RFA

1. Loads Applied by Core Restraint System

The upper core plate bears downward against the fuel assembly top nozzle springs. The springs are designed to accommodate the differential thermal expansion and irradiation growth between the fuel assembly and the core internals. Lateral position is maintained through the engagement of the core pins on the top and bottom core plate with "S" holes in the top and bottom nozzles.

2. Analysis of Accident Loads

Grid crush analyses using combined seismic and LOCA loadings show that the fuel assembly will maintain a geometry that is capable of being cooled under the worst-case accident Condition IV event. Minimum grid crush strength has been confirmed through testing.

Load carrying capability of the fuel assembly for both normal service and faulted conditions has been confirmed through analysis and testing.

No interference with control rod insertion into thimble tubes will occur during a Safe Shutdown Earthquake (SSE).

Stresses in the fuel assembly caused by a trip of the rod cluster control assembly have little influence on fatigue because of the small number of events during the life of an assembly. Assembly components and prototype fuel assemblies made from production parts have been subjected to structural tests as described in Reference 42 to verify that the structural design criteria are met.

3. Loads Applied in Fuel Handling

The fuel assembly design loads for shipping have been established at 4 g's. Accelerometers are permanently placed into the shipping cask to monitor and detect fuel assembly accelerations that would exceed the criteria. Past history and experience has indicated that loads which exceed the allowable limits rarely occur. Exceeding the limits requires reinspection of the fuel assembly for damage. Tests on various fuel assembly components such as the grid assembly, sleeves, and structure joints have been performed to assure that the shipping design limits do not result in impairment of fuel assembly function.

4. Long Term Core Cooling

The topics of debris down-stream effects, In-vessel effects, and fuel blockage criteria are address in Section 6.3.2. The assembly design has no impact on the ability to meet long term core cooling requirements. Therefore, the assembly design meets the requirement listed in Section 4.2.2, Item 1 with respect to the assembly's effect on emergency cooling systems.

4.2.4.6 Reactivity Control Assembly and Burnable Poison Rods

1. Internal Pressure and Cladding Stresses During Normal, Transient and Accident Conditions

The designs of the burnable poison, source rods and B₄C absorber rods provide a sufficient cold void volume to accommodate the internal pressure increase during operation. The void volume for the release of helium in the WABA rods (A₁₂O₃-B₄C) is obtained through the use of an annular plenum within the rod. For source rods and the B₄C absorber rods, a void volume is provided in the cladding in order to limit the internal pressure increase until end-of-life (see Figure 4-11 and Figure 4-81).

The stress analysis of the source rods assumes 100 percent gas release to the rod void volume in addition to the initial pressure within the rod. The WABA burnable poison rods

cladding stress limit and calculated maximum stress value are acceptable per Reference 39. For the B₄C control rod a 30% gas release is assumed.

For all core component rods during normal transient and accident conditions, the void volume limits the internal pressure to values which satisfy the criteria in Section 4.2.3.6. These limits are established not only to assure that peak stresses do not reach unacceptable values, but also to limit the amplitude of the oscillatory stress component in consideration of the fatigue characteristics of the materials.

Rod, guide thimble, and dashpot flow analyses indicate that the flow is sufficient to prevent coolant boiling. Therefore, clad temperatures at which the clad material has adequate strength to resist coolant operating pressures and rod internal pressures are maintained.

2. Thermal Stability of the Absorber/Poison Material, Including Phase Changes and Thermal Expansion

The radial and axial temperature profiles have been determined by considering gap conductance, thermal expansion, and neutron or gamma heating of the contained material as well as gamma heating of the clad.

The maximum temperatures of the absorber/poison materials were calculated to be less than their respective melting temperatures. The thermal expansion properties of the absorber material are discussed in References 2 and 13.

Sufficient diametral and end clearances have been provided in the neutron absorber, burnable poison, and source rods to accommodate the relative thermal expansion between the enclosed material and the surrounding clad and end plug.

3. Irradiation Stability of the Absorber/Poison Material, Taking into Consideration Gas Release and Swelling

The irradiation stability of the absorber/poison material is discussed in References 2 and 13. Irradiation produces no deleterious effects in the absorber/poison material.

Gas release is not a concern for the Ag-In-Cd absorber material because no gas is released by the absorber material. Sufficient diametral and end clearances are provided to accommodate expected gas release from the B₄C and swelling of the absorber material.

4. Potential for Chemical Interaction

The structural materials selected have good resistance to irradiation damage and are compatible with the reactor environment.

Corrosion of the materials exposed to the coolant is quite low and proper control of chloride and oxygen in the coolant will prevent the occurrence of stress corrosion. The potential for interference with rod cluster control movement due to possible corrosion phenomena is very low.

4.2.5 Testing and Inspection Plan

4.2.5.1 Quality Assurance Program

The Quality Assurance Program Manuals for Framatome Cogema Fuels (Reference 11) and Westinghouse Electric Company (Reference 41) have been developed to serve in planning and monitoring activities for the design and manufacture of nuclear fuel assemblies and associated components. These programs control all activities affecting product quality, commencing with design and development, and continuing through procurement, materials handling, fabrication,

testing, inspection, storage, and transportation. The program also provides for the indoctrination and training of personnel and for the auditing activities affecting product quality through a formal auditing program.

4.2.5.2 Quality Control

Quality control philosophy is generally based on the following inspections being performed to a 95% confidence that at least 95% of the product meets specification, unless otherwise noted.

1. Fuel System Components and Parts

The characteristics which are inspected depends upon the component parts, and generally includes dimensional/visual appearance checks, audits of test reports/material certification, and nondestructive examinations such as X-ray and/or ultrasonic.

All materials used in the fuel are accepted and released by personnel at the vendor facility.

2. Pellets

Inspection is performed for dimensional characteristics such as diameter, density, length, and squareness of ends. Additional visual inspections are performed for cracks, chips, and surface conditions according to approved standards.

Density is determined in terms of weight per unit length. Chemical analyses are taken on a specified sample basis throughout pellet production.

3. Rod Inspection

Fuel rod, control rod, burnable poison and source rod inspection consists of the following nondestructive examination techniques and methods, as applicable.

a. Leak Testing

Each rod is tested using a calibrated mass spectrometer with helium being the detectable gas.

b. Enclosure Welds

Rod welds are inspected by ultrasonic or X-ray techniques, in accordance with a qualified standards, equipment, and personnel.

c. Dimensional

All rods are dimensionally inspected prior to final release. The requirements include such items as length, camber, and visual appearance.

d. Plenum Dimensions

All fuel rods are inspected to ensure proper plenum dimensions using methods such as gamma scanning or real-time x-rays.

e. Pellet-to-Pellet Gaps

All fuel rods are inspected to ensure that no significant gaps exist within the pellet stack using methods such as gamma scanning or real-time x-ray.

f. Enrichment Control

All fuel rods are inspected to verify proper enrichment prior to assembly loading using methods such as gamma scanning.

g. Traceability

Fabrication records establish and maintain traceability of fuel rod locations within the bundle to fuel rod IDs, and fuel rod IDs to their associated components.

4. Assemblies

Each fuel, rod cluster control (or control rod), wet annular burnable absorber (or burnable absorber), secondary source rod, and thimble tube plugging assembly is inspected for compliance with drawing and specification requirements.

5. Other Inspections

The following inspections are performed as part of the routine inspection operation:

- a. Tool and gage inspection and control including standardization to primary and/or secondary working standards. Tool inspection is performed at prescribed intervals on all serialized tools.

Complete records are kept of calibration and conditions of tools.

- b. Audits are performed of inspection activities and records to assure that prescribed methods are followed and that records are correct and properly maintained.
- c. Surveillance inspection where appropriate, and audits of outside contractors are performed to ensure conformance with specified requirements.

6. Process Control

To prevent the possibility of mixing enrichments during fuel manufacture and assembly, strict enrichment segregation and other process controls are exercised.

The UO₂ powder is kept in sealed containers with the contents identified by descriptive tagging. An identification tag completely describing the contents is affixed to the containers before transfer to powder storage. Isotopic content is confirmed by analysis.

Only authorized personnel can transfer powder from storage to a specific pelleting production line. All pellet production lines are physically separated from each other and pellets of only a single nominal enrichment and density are produced at any given time.

Finished pellets are placed on trays, identified, and transferred to segregated storage racks within the confines of the pelleting area. Samples from each pellet lot are tested for isotopic content and impurity levels prior to acceptance by Quality Control. Physical barriers prevent mixing of pellets of different nominal densities and enrichments in this storage area.

Loading of pellets into the cladding is performed in an isolated production line and only one pellet stack configuration is loaded on a line at a time.

A serialized traceability number is placed on each fuel tube that remains with that tube throughout the fabrication process. This identification number is recorded versus bundle location as fully fabricated fuel rods are loaded into the bundle.

Verification of proper rod loading is performed to ensure rods have been loaded into the correct locations within the bundle. This verification is performed manually by a QA inspector, or automatically by a computerized system as each rod ID is recorded versus its location within the bundle. The top nozzle is inscribed with a permanent identification number providing traceability to the fuel contained in the assembly.

Similar traceability is provided for all insert assemblies.

4.2.5.3 Core Component Testing and Inspection

Tests and inspection are performed on each core component to verify the mechanical characteristics. In the case of the rod cluster control assembly, prototype testing has been conducted and both manufacturing test/inspections and functional testing at the plant site are performed.

During the component manufacturing phase, the following requirements apply to the core components to assure the proper functioning during reactor operation:

1. All materials are procured to specifications to attain the desired standard of quality.
2. All rods are checked for integrity by the methods described in Section 4.2.5.2.
3. To assure proper fitup with the fuel assembly, the rod cluster control, burnable poison, and source assemblies are installed in a fuel assembly to demonstrate there is no excessive restriction or binding. Also, other applicable dimensional requirements described in Section 4.2.5.2 help ensure proper and unrestricted control rod and component operation.

Finally, the rod cluster control assemblies are functionally tested per Technical Specifications following core loading, but prior to criticality, to demonstrate reliable operation of the assemblies. Additionally, following refueling, but prior to power operation, control rod worth measurements are performed on the control and shutdown banks. Thus, any anomalies would be detected by this surveillance.

If a rod cluster control assembly cannot be moved by its mechanism, adjustments in the boron concentration ensure that adequate shutdown margin would be achieved following a trip. Thus, inability to move one rod cluster control assembly can be tolerated. More than one inoperable rod cluster control assembly could be tolerated, but would impose additional demands on the plant operator. Therefore, the number of inoperable rod cluster control assemblies has been limited to one.

Historical Information shown in Italics below:

During initial pre-operational testing, each assembly was operated (and tripped) one time at no flow/cold conditions and one time at full flow/hot conditions. In addition, selected assemblies, amounting to about 15 to 20% of the total assemblies were operated at no flow/operating temperature conditions and full flow/ambient conditions. Also the slowest rod and the fastest rod were tripped 10 times at no flow/ambient conditions and at full flow/operating temperature conditions. Thus, each assembly was tested a minimum of 2 times or up to a maximum of 14 times to ensure the assemblies are properly functioning.

4.2.5.4 Onsite Inspection

Detailed written procedures are used by the station staff for the postshipment inspection of all new fuel and associated components such as control rods and other inserts. The procedures are specific, and their implementation is continuously monitored. QA audits the data or information compiled as a result of the use of these procedures. A master fuel handling procedure specifies the sequence in which handling and inspection takes place.

4.2.6 References

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

1. Skaritka, J., et al., "Operational Experience with Westinghouse Cores", WCAP-8183, Rev. 17, August 1989

2. *Beaumont, M.D., et. al. (Ed.), "Properties of Fuel and Core Component Materials", WCAP-9179, Revision 1 (Proprietary) and WCAP-9224, July 1978.*
3. Deleted Per 1998 Update
4. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

5. *George, R.A., et. al., "Revised Clad Flattening Model", WCAP-8377 (Proprietary) and WCAP-8381, July 1974.*
6. *Eggleston, F., "Safety Related Research and Development for Westinghouse Pressurized Water Reactors - Program Summaries," WCAP-8768, Revision 2, October 1978.*
7. *Beaumont, M. D., et al., (Ed), "Verification Testing and Analyses of the 17 x 17 Optimized Fuel Assembly", WCAP-9401-P-A, August 1981 and WCAP-9402-A, August 1981.*
8. Deleted Per 1998 Update
9. Western New York Nuclear Research Center Correspondence with the AEC on February 11 and August 27, 1971, Docket 50-57.
10. Stephan, L. A., "The Effects of Cladding Material and Heat Treatment on the Response of Waterlogged UO₂ Fuel Rods to Power Bursts", IN-ITR-111, January 1970.
11. "Quality Assurance Program for Framatome Cogema Fuels", 56-1177617-06, March 3, 2000.
12. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

13. *Skaritka, J. (Ed.), "Hybrid B₄C Absorber Control Rod Evaluation Report", WCAP-8846-A, October 1977.*
14. *Davidson, S. L., Iorri, J. A., "Reference Core Report - 17 x 17 Optimized Fuel Assembly", WCAP-9500-A, May 1982.*
15. Deleted Per 1998 Update
16. Deleted Per 1994 Update.
17. Deleted Per 1998 Update
18. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

19. *BAW-2119, Catawba Unit 1, Cycle 6 Reload Report, Babcock & Wilcox, Lynchburg, Virginia, October 1990.*

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

20. *BAW-10172P, Mark-BW Mechanical Design Report, Babcock & Wilcox, Lynchburg, Virginia, July 1988.*
21. *BAW-10147, Rev. 1, Fuel Rod Bowing in Babcock & Wilcox Fuel Designs, Lynchburg, Virginia, May 1983.*
22. *H. N. Berkow (NRC) letter to M. S. Tuckman (Duke), Duke Power Company's Use of TACO3 and the Fuel Rod Gas Pressure Criterion for the Oconee, McGuire, and Catawba*

Nuclear Stations (TAC Nos. M89554, M89555, M89556, M89548 and M89549), April 3, 1995.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

23. *TACO3 - Fuel Pin Thermal Analysis Computer Code, BAW-10162P-A, B&W Fuel Company, Lynchburg, VA, November 1989.*
24. *Program to Determine In-Reactor Performance of B&W Fuels - Cladding Creep Collapse, B&W, BAW-10084P-A, Rev. 3, Lynchburg, VA, July 1995.*
25. ASME Code Section III, "Nuclear Power Plant Components"

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

26. *BAW-10183P-A, Fuel Rod Gas Pressure Criterion, B&W Fuel Company, July 1995.*
27. Nuclear Regulatory Commission, Letter to All Light-Water Reactor Licensees and Applicants, from James G. Partlow, February 1, 1990, "Alternative Requirements for Fuel Assemblies in Design Features Section of Technical Specifications (Generic Letter 90-02)."
28. Duke Power Company, Letter from D.L. Rehn to NRC, July 5, 1995, re: Supplement 1 to the Proposed Technical Specification Amendment Which Modifies the Requirements for Fuel Assemblies in the Design Features Section of Technical Specifications in Accordance with Generic Letter 90-02, Supplement 1.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

29. *DPC-NE-2007P-A, Duke Power Company Fuel Reconstitution Analysis Methodology, October 1995.*
30. *DPC-NE-2001P-A, Rev. 1, "Fuel Mechanical Reload Analysis Methodology for Mark-BW fuel," October 1990 (DPC Proprietary).*
31. *DPC-NE-2008P-A, "Fuel Mechanical Reload Analysis Methodology Using TACO3," SER dated April 3, 1995 (DPC Proprietary).*
32. Deleted per 2000 Update.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

33. *DPC-NE-2009P-A, Rev.3a, Duke Power Company Westinghouse Fuel Transition Report, September 2011.*
34. Hellman, J. M. (Ed.), "Fuel Densification Experimental Results and Models for Reactor Operation", WCAP-8218-P-A, March 1975 (Proprietary) and WCAP-8219-A, March 1975.
35. Miller, J. V. (Ed.), "Improved Analytical Models Used in Westinghouse Fuel Rod Design Computations", WCAP-8785, October 1976.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

36. *Risher, D. H., et. al., "Safety Analysis for the Revised Fuel Rod Internal Pressure Design Basis", WCAP-8963 (Proprietary), November 1976, WCAP-8964, August 1977.*
37. O'Donnel, W.J. and Langer, B.F., "Fatigue Design Basis for Zircaloy Components", Nuclear Science and Engineering, 20, 1-12, 1964.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

38. *Skaritka, J. (Ed.), "Fuel Rod Bow Evaluation", WCAP-8691, Rev. 1, July 1979.*

39. Skaritka, J., "Wet Annular Burnable Absorber Evaluation Report", WCAP-10021-P-A, Rev. 1, October 1983.
40. S. L. Davidson, T. L. Ryan, "VANTAGE+ Fuel Assembly Reference Core Report", WCAP-12610-P-A, April 1995.
41. Westinghouse Electric Corporation Energy System Business Unit Quality Management System, QMS, Rev. 3, October 1999.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

42. S. L. Davidson, "VANTAGE 5 Fuel Assembly Reference Core Report", WCAP-10444-P-A, September 1985.
43. BAW-10186P-A, Extended Burnup Evaluation, Framatome Cogema Fuels, SER dated January 25, 1999.
44. BAW-10179A, Safety Criteria and Methodology for Acceptable Cycle Reload Analyses, August 1, 1993.
45. WCAP-12488P-A, Westinghouse Fuel Criteria Evaluation Process, October 1994.
46. WCAP-12488P-A, Addendum 1, Rev. 1, Westinghouse Fuel Criteria Evaluation Process, December 2001.
47. LTR-NRC-02-2, Fuel Criterion Evaluation Process (FCEP) Notification of the Quick Release Top Nozzle (QRTN) Design, Henry Sepp (Westinghouse) to J. S. Wermiel (USNRC), January 15, 2002.
48. K.E. Bahr, Revision 1-A to WCAP-10125-P-A Addendum 1-A, Extended Burnup Evaluation of Westinghouse Fuel, Revision to Design Criteria, December 2004 (includes 6/10/2004 letter from NRC (Herbert N. Berkow) to Westinghouse (James A. Gresham), Final Safety Evaluation for Revision 1 to WCAP-10125-P-A, Addendum 1-A, Extended Burnup Evaluation of Westinghouse Fuel, Revision to Design Criteria (TAC No. MC1646))
49. ASME Pressure Vessel Code Section III, Article NG-3000, 1998.
50. Schueren, P., "Optimized ZIRLO™", WCAP-12610-P-A & CENPD-404-P-A Addendum 1-A, July 2006.
51. S.L. Davidson (ed.), et al., "Extended Burnup Evaluation of Westinghouse Fuel", WCAP-10125-P-A, December 1985.

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.2.

THIS PAGE LEFT BLANK INTENTIONALLY.

4.3 Nuclear Design

4.3.1 Design Bases

This section describes the design bases and functional requirements used in the nuclear design of the fuel and reactivity control system and relates these design bases to the General Design Criteria (GDC) in 10CFR 50, Appendix A. Where appropriate, supplemental criteria such as the Final Acceptance Criteria for Emergency Core Cooling Systems are addressed. Before discussing the nuclear design bases it is appropriate to briefly review the four major categories ascribed to conditions of plant operation.

The full spectrum of plant conditions is divided into four categories, in accordance with the anticipated frequency of occurrence and risk to the public:

1. Condition I - Normal Operation
2. Condition II - Incidents of Moderate Frequency
3. Condition III - Infrequent Faults
4. Condition IV - Limiting Faults.

In general, the Condition I occurrences are accommodated with margin between any plant parameter and the value of that parameter which would require either automatic or manual protective action. Condition II incidents are accommodated with, at most, a shutdown of the reactor with the plant capable of returning to operation after corrective action. Fuel damage (fuel damage as used here is defined as penetration of the fission product barrier, i.e., the fuel rod clad) is not expected during Condition I and Condition II events. It is not possible, however, to preclude a small number of rod failures. These are within the capability of the plant cleanup system and are consistent with the plant design basis.

Condition III incidents shall not cause more than a small fraction of the fuel elements in the reactor to be damaged, although sufficient fuel element damage might occur to preclude immediate resumption of operation. The release of radioactive material due to Condition III incidents should not be sufficient to interrupt or restrict public use of these areas beyond the exclusion radius. Furthermore, a Condition III incident shall not, by itself generate a Condition IV fault or result in a consequential loss of function of the reactor coolant or reactor containment barriers.

Condition IV occurrences are faults that are not expected to occur, but are defined as limiting faults which must be designed against. Condition IV faults shall not cause a release of radioactive material that results in an undue risk to public health and safety.

The core design power distribution limits related to fuel integrity are met for Condition I occurrences through conservative design and maintained by the action of the control system. The requirements for Condition II occurrences are met by providing an adequate protection system which monitors reactor parameters. The control and protection systems are described in Chapter 7 and the consequences of Condition II, III and IV occurrences are given in Chapter 15.

4.3.1.1 Fuel Burnup Basis

The fuel rod design basis is described in Section 4.2. The nuclear design basis is to install sufficient reactivity in the fuel to attain a region discharge burnup of approximately 50,000

MWD/MTU. The above along with the design basis in Section 4.3.1.3, Control of Power Distribution, satisfies GDC-10.

Discussion

Fuel burnup is a measure of fuel depletion which represents the integrated energy output of the fuel (MWD/MTU) and is a convenient means for quantifying fuel exposure criteria.

The core design lifetime or design discharge burnup is achieved by installing sufficient initial excess reactivity in each fuel region and by following a fuel replacement program (such as that described in Section 4.3.2) that meets all safety related criteria in each cycle of operation.

Initial excess reactivity installed in the fuel, although not a design basis, must be sufficient to maintain core criticality at full power operating conditions throughout cycle life with equilibrium xenon, samarium, and other fission products present. The end of design cycle life is defined to occur when the chemical shim concentration is essentially zero with control rods present to the degree necessary for operational requirements (e.g., the controlling bank at the "bite" position). In terms of chemical shim boron concentration this represents approximately 5 ppm with no control rod insertion. The design cycle life can be extended past the minimum boron conditions by a Tave, combination Tave/power or power level coastdown. The moderator temperature reduction and/or power reduction provides the positive reactivity necessary to extend power operation capability.

A limitation on initial installed excess reactivity is not required other than as is quantified in terms of other design bases such as core negative reactivity feedback and shutdown margin discussed below.

4.3.1.2 Negative Reactivity Feedbacks (Reactivity Coefficient)

Basis

The fuel temperature coefficient will be negative and the moderator temperature coefficient of reactivity will be non-positive for power operating conditions, thereby providing negative reactivity feedback characteristics. The design basis meets GDC-11.

Discussion

When compensation for a rapid increase in reactivity is considered, there are two major effects. These are the resonance absorption effects (Doppler) associated with changing fuel temperature and the spectrum effect resulting from changing moderator density. These basic physics characteristics are often identified by reactivity coefficients. The use of slightly enriched uranium ensures that the Doppler coefficient of reactivity is negative. This coefficient provides the most rapid reactivity compensation. The core is also designed to have an overall negative moderator temperature coefficient of reactivity so that average coolant temperature or void content provides another, slower compensatory effect. Nominal power operation is permitted only in a range of overall negative moderator temperature coefficient. The negative moderator temperature coefficient can be achieved through use of fixed burnable poison and/or control rods by limiting the reactivity held down by soluble boron.

Burnable poison content (quantity and distribution) is not stated as a design basis other than as it relates to accomplishment of a non-positive moderator temperature coefficient at power operating conditions discussed above.

4.3.1.3 Control of Power Distribution

Basis

The nuclear design basis is that, with at least a 95 percent confidence level:

1. The fuel will not be operated at greater than the LOCA linear heat rate criteria by establishing the appropriate core power distribution (F_q) limit in the Core Operational Report (COLR).
2. Under abnormal conditions including the maximum overpower condition, the fuel peak power will not cause melting as defined in Section 4.4.2.2.
3. The fuel will not operate with a power distribution that violates the departure from nucleate boiling (DNB) design basis (see Section 4.4.2.1) under Condition I and II events including the maximum overpower condition.
4. Fuel management will be such as to produce rod powers and burnups consistent with the assumptions in the fuel rod mechanical integrity analysis of Section 4.2.

The above basis meets GDC-10.

Discussion

Calculation of extreme power shapes which affect fuel design limits is performed with proven methods and verified frequently with measurements from operating reactors. The conditions under which limiting power shapes are assumed to occur are chosen conservatively with regard to any permissible operating state.

Even though there is good agreement between peak power calculations and measurements, a nuclear uncertainty margin (Section 4.3.2.2.1) is applied to calculated peak local power. Such a margin is provided both for the analysis for normal operating states and for anticipated transients.

4.3.1.4 Maximum Controlled Reactivity Insertion Rate

Basis

The maximum reactivity insertion rate due to withdrawal of rod cluster control assemblies at power or by boron dilution is limited. During normal power operation, the maximum controlled reactivity rate change is less than 45 pcm/ sec.¹ A maximum reactivity change rate of 65 pcm/sec for accidental withdrawal of control banks is set such that peak heat generation rate and DNBR do not exceed the maximum allowable at overpower conditions. This satisfies GDC-25.

The maximum reactivity worth of control rods and the maximum rates of reactivity insertion employing control rods are limited so as to preclude rupture of the coolant pressure boundary or disruption of the core internals to a degree which would impair core cooling capacity due to a rod withdrawal or ejection accident (See Chapter 15).

Following any Condition IV event (rod ejection, steamline break, etc.) the reactor can be brought to the shutdown condition and the core will maintain acceptable heat transfer geometry. This satisfies GDC-28.

Discussion

Reactivity addition associated with an accidental withdrawal of a control bank (or banks) is limited by the maximum rod speed (or travel rate) and by the worth of the bank(s). The maximum control rod speed is 45 inches per minute and the maximum rate of reactivity change

¹ 1 pcm = 10E-5 $\Delta\rho$ (See footnote Table 4-5)

considering two control banks moving is less than 65 pcm/sec. During normal operation at power and with normal control rod overlap, the maximum reactivity change rate is less than 45 pcm/sec.

The reactivity change rates are conservatively calculated assuming unfavorable axial power and xenon distributions. The peak xenon burnout rate is 25 pcm/min, significantly lower than the maximum reactivity addition rate of 45 pcm/sec for normal operation and 65 pcm/sec for accidental withdrawal of two banks in 100% overlap.

4.3.1.5 Shutdown Margins

Basis

Minimum shutdown margin as specified in the Core Operating Limits Report is required at any power operating condition, in the startup, hot standby, hot shutdown and cold shutdown conditions.

In all analysis involving reactor trip, the single, highest worth rod cluster control assembly is postulated to remain untripped in its full-out position (stuck rod criterion). This satisfies GDC-26.

Discussion

Two independent reactivity control systems are provided, namely control rods and soluble boron in the coolant. The control rod system can compensate for the reactivity effects of the fuel and water temperature changes which accompany power level changes over the range from full-load to no-load. In addition, the control rod system provides the minimum shutdown margin under Condition I events and is capable of making the core subcritical rapidly enough to prevent exceeding acceptable fuel damage limits assuming that the highest worth control rod is stuck out upon trip.

The boron system can compensate for all xenon burnout reactivity changes and will maintain the reactor in the cold shutdown. Thus, backup and emergency shutdown provisions are provided by a mechanical and a chemical shim control system which satisfies GDC-26.

Basis

When fuel assemblies are in the pressure vessel and the vessel head is not in place, k_{eff} will be maintained at or below 0.95 with control rods and soluble boron. Further, the fuel will be maintained sufficiently subcritical that removal of all rod cluster control assemblies will not result in criticality.

Discussion

ANSI Standard N210-1976 specifies a k_{eff} not to exceed 0.95 in spent fuel storage racks and transfer equipment flooded with pure water. No criterion is given for the refueling operation; however, a five percent margin, which is consistent with spent fuel storage and transfer and the new fuel storage, is adequate for the controlled and continuously monitored operations involved.

The boron concentration required to meet the refueling shutdown criteria is specified in the Core Operating Limits Report. Verification that this shutdown criteria is met, including uncertainties, is achieved using standard Duke Power Company design methods as described in References 10, 22, and 19. The subcriticality of the core is continuously monitored as described in the Technical Specifications.

Core subcriticality during refueling operations is maintained at an appropriate level by limiting new fuel assembly clusters in the core region to an appropriate combinations based on the core refueling boron concentration (References 56, 57, and 58 - responses to NRC IEB89-03,

"Potential Loss of Required Shutdown Margin During Refueling Operations"). The plant fuel handling guidelines (operations procedures and training for fuel handling) are used to ensure that adequate subcriticality margin is maintained.

4.3.1.6 Stability

Basis

The core will be inherently stable to power oscillations at the fundamental mode. Spatial power oscillations within the core with a constant core power output, should they occur, can be reliably and readily detected and suppressed. This satisfies GDC-12.

Discussion

Oscillations of the total power output of the core, from whatever cause, are readily detected by the loop temperature sensors and by the nuclear instrumentation. The core is protected by these systems and a reactor trip would occur if power increased unacceptably, preserving the design margins to fuel design limits. The stability of the turbine/steam generator/core systems and the reactor control system is such that total core power oscillations are not normally possible. The redundancy of the protection circuits ensures an extremely low probability of exceeding design power levels.

The core is designed so that diametral and azimuthal oscillations due to spatial xenon effects are self-damping with little or no operator action required to suppress them. The stability to diametral oscillations is so great that this excitation is highly improbable. Convergent azimuthal oscillations can be excited by prohibited motion of individual control rods. Such oscillations are readily observable and alarmed, using the excore long ion chambers. Indications are also continuously available from incore thermocouples and loop temperature measurements. Moveable incore detectors can be activated to provide more detailed information. In all cores, these horizontal plane oscillations are self-damping by virtue of reactivity feedback effects designed into the core.

However, axial xenon spatial power oscillations may occur as the result of rod motion and power maneuvers during the majority of core life. The control bank and excore detectors are provided for control and monitoring of axial power distributions. Assurance that fuel design limits are not exceeded is provided by reactor Overpower ΔT and Overttemperature ΔT trip functions which use the measured axial power imbalance as an input.

4.3.1.7 Anticipated Transients Without Trip

The effects of anticipated transients with failure to trip are not considered in the design bases of the plant. Analysis has shown that the likelihood of such a hypothetical event is negligibly small. Furthermore, analysis of the consequences of a hypothetical failure to trip following anticipated transients has shown that no significant core damage would result, system peak pressures would be limited to acceptable values and no failure of the Reactor Coolant System would result (Reference 1). However, in order to comply with the ATWS rule (10CFR 50.62), an ATWS Mitigation System has been installed. This system, is described in Section 7.7.1.11.

4.3.2 Description

4.3.2.1 Nuclear Design Description

The reactor core consists of a specified number of fuel rods which are held in bundles by spacer grids and top and bottom fittings. The fuel rods are constructed of Zircaloy cylindrical tubes

containing UO_2 fuel pellets. The bundles, known as fuel assemblies, are arranged in a pattern which approximates a right circular cylinder.

Each fuel assembly contains a 17 x 17 rod array composed of 264 fuel rods, 24 rod cluster control assemblies and an instrumentation thimble. Fuel rod locations may at any time during plant life have, as justified by analysis, non-fuel filler rods in fuel locations. Figure 4-1 shows a cross sectional view of a 17x17 fuel assembly and the related rod cluster control locations. Further details of the fuel assembly are given in Section 4.2.

The fuel rods within a given assembly are of the same enrichment design radially. Axially, the rods/assembly may be of a constant enrichment, or they may be blanketed, meaning that the top and bottom end portions of the fuel may be at a lower enrichment. Three different "constant enrichment" fuel assembly regions are used in the initial core loading to establish a favorable radial power distribution. Two regions consisting of the two lower enrichments are interspersed so as to form a checkerboard pattern in the central portion of the core. The third region is arranged around the periphery of the core and contains the highest enrichment.

Typical reload patterns are shown in Figure 4-17 or Figure 4-18. This loading pattern has both fresh and burned fuel interspersed in a checkerboard pattern in the center of the core. The core will normally operate approximately 420 to 510 full-power days, accumulating approximately 16,000 to 20,000 MWD/MTU per cycle. The exact reloading pattern, positions of assemblies, number and enrichment of fresh assemblies and their placement are dependent on the energy requirement for a specific cycle, and the burnup and power histories of the previous cycles.

The core average enrichment is determined by the amount of fissionable material required to provide the desired core lifetime and energy requirements, namely a design region average discharge burnup. The physics of the burnout process is such that operation of the reactor depletes the amount of fuel available due to the absorption of neutrons by the U-235 atoms and their subsequent fission. The rate of U-235 depletion is directly proportional to the power level at which the reactor is operated. In addition, the fission process results in the formation of fission products, some of which readily absorb neutrons. These effects, depletion and the buildup of fission products, are partially offset by the buildup of plutonium shown in Figure 4-19 for the 17 x 17 fuel assembly, which occurs due to the non-fission absorption of neutrons in U-238. Therefore, at the beginning of any cycle a reactivity reserve equal to the depletion of the fissionable fuel and the buildup of fission product poisons over the specified cycle life must be "built" into the reactor. This excess reactivity is controlled by neutron absorbing material in the form of boron dissolved in the primary coolant and burnable poison. Burnable poisons may be within discrete rods or as a coating on the fuel pellets (or Integral Fuel Burnable Absorber, IFBA).

The concentration of boric acid in the primary coolant is varied to provide control and to compensate for long-term reactivity requirements. The concentration of the soluble neutron absorber is varied to compensate for reactivity changes due to fuel burnup, fission product poisoning including xenon and samarium, burnable poison depletion, and the cold-to-operating moderator temperature change. Using its normal makeup path, the Chemical and Volume Control System (CVCS) is capable of inserting negative reactivity at a rate of approximately 30 pcm/min when the reactor coolant boron concentration is 100 ppm. If the emergency boration path is used, the CVCS is capable of inserting negative reactivity at a rate of approximately 65 pcm/min when the reactor coolant concentration is 1000 ppm and approximately 75 pcm/min when the reactor coolant boron concentration is 100 ppm. The peak burnout rate for xenon is 25 pcm/min (Section 9.3.4.3.1 discusses the capability of the CVCS to counteract xenon decay). Rapid transient reactivity requirements and safety shutdown requirements are met with control rods.

As the boron concentration is increased, the moderator temperature coefficient becomes less negative. The use of a soluble poison alone would result in a positive moderator coefficient at beginning-of-life for the first cycle and most reload cycles. Therefore, burnable poison is used in the first core, and reload cores when necessary, to reduce the soluble boron concentration sufficiently to ensure that the moderator temperature coefficient is negative for power operating conditions. During operation the poison content in the core is depleted thus adding positive reactivity to offset some of the negative reactivity from fuel depletion and fission product buildup. The depletion rate of the burnable poison is not critical since chemical shim is always available and flexible enough to cover any possible deviations in the expected burnable poison depletion rate. Figure 4-20 is a graph of a typical core depletion with and without burnable poison. Note that even at end-of-life conditions some residual poison remains resulting in a net decrease in the cycle lifetime. Reload cores may contain fresh burnable poison for power distribution and for moderator coefficient control.

In addition to reactivity control, the burnable poison is strategically located to provide favorable radial and axial power distributions. The burnable poison is either axially centered or slightly offset to shape the axial power distribution to a desired shape. Figures 4-80 and 4-81 show the burnable poison distribution within a fuel assembly for the several burnable poison patterns used in a 17 x 17 array. A typical burnable poison loading pattern is shown in Figure 4-22 and Figure 4-23 for reload cores.

Table 4-4 through Table 4-7 contain a summary of the reactor core design parameters, including reactivity coefficients, delayed neutron fraction and neutron lifetimes. Sufficient information is included to permit an independent calculation of the nuclear performance characteristics of the core.

4.3.2.1.1 Catawba Unit 1 Lead Test Assembly (LTA) Demonstration Programs

Catawba Unit 1 is involved in two lead test assembly demonstration programs, Westinghouse Next Generation Fuel (NGF) LTA program and Department of Energy (DOE) Mixed Oxide (MOX) LTA program.

4.3.2.1.2 Westinghouse Next Generation Fuel (NGF) LTA Demonstration Program

Eight NGF LTAs were inserted into Catawba Unit 1 Cycle 15 (C1C15). They will be irradiated in C1C15 and C1C16 after which four NGF LTAs will be discharged for post irradiation examination (PIE) work and four re-inserted into C1C17. The NGF LTAs discharged from C1C16 will be reinserted into C1C18. The NGF LTAs are described in Section 4.2.3.7. The NGF LTAs are neutronicallly identical to the Westinghouse RFA fuel currently resident and modeled in the core reload design methodology. Therefore from a nuclear design aspect, there is no difference in modeling or treatment for the NGF LTAs. The NGF LTAs have two additional grids, however analysis shows negligible impact upon nuclear design results. Placement of these LTAs in the core design considered Tech Spec 4.2.1 for placement of lead assembly in non-limiting core locations as well as the need to meet desired test program requirements, i.e. peaking, burnup, etc.

4.3.2.1.3 DOE Mixed Oxide (MOX) LTA Demonstration Program

The United States MOX Fuel Project is part of an international nonproliferation program that has the goal of disposing of surplus weapons plutonium in the United States and Russia. A MOX fuel lead test assembly demonstration program at Catawba will precede the use of significant quantities of MOX fuel. The purpose of the MOX LTA program is to demonstrate analytical capabilities of predictive software and performance of MOX fuel.

C1C16 inserted four MOX LTAs into Catawba Unit 1. They were irradiated in C1C16 and C1C17 after which the MOX LTAs were discharged for PIE work. The PIE work involved removing five MOX fuel pins from one of the MOX LTAs and replacing (reconstitute) the MOX assembly with stainless steel rods. Additional PIE work to remove more MOX LTA fuel pins may be performed on one or more of the MOX LTAs in the future. The MOX LTAs may be reinserted into a future Catawba Unit 1 core design for a third cycle of irradiation after all PIE work is completed. The MOX LTAs are described in Section 4.2.3.7.

The Catawba reactor use a 17x17 pressurized water (PWR) fuel assembly design. The Advanced Mark-BW/MOX1 fuel assembly is deployed with the MOX fuel. The fuel assembly lattice is characterized by a central instrument tube, 24 control rod guide tubes, and 264 fuel pins. The Mark-BW/MOX1 fuel assembly mechanical design is based on the proven Mark-BW design that was deployed at Catawba for many years. The Mark-BW/MOX1 fuel assembly contains features of the current Mark-BW design, plus M5TM fuel pin cladding, and mid-span mixing grids (MSMGs). The MSMGs were added to maintain hydraulic similarity with co-resident fuel.

The MOX assembly design uses multiple concentrations of plutonium in each assembly as shown in the radial fuel assembly zoning diagram (Figure 4-88). In this context, the plutonium concentration refers to the mass ratio of plutonium to total heavy metal (plutonium plus uranium). Using multiple fuel pin concentration zones minimizes the intra-assembly power peaking that result from the sharp thermal neutron flux gradient between adjacent uranium and MOX fuel assemblies. Key MOX fuel pin and assembly design parameters are summarized in Section 4.2.3.7.

Placement of the MOX LTAs in the core design considered Tech Spec 4.2.1 for placement of lead assemblies in non-limiting core locations and Safety Evaluation (SE) requirements for using the NRC approved CASMO-4/SIMULATE-3 MOX Nuclear Design Methodology (Reference 22), as well as the need to meet desired MOX LTA program requirements, i.e. peaking, burnup, etc.

Transition to CASMO-4/SIMULATE-3 MOX Nuclear Design Methodology (Reference 22) was required to model cores containing mixed oxide fuel (MOX). SE requirements stipulated for use of CASMO-4/SIMULATE-3 MOX Nuclear Design methodology in DPC-NE-1005-P-A (Reference 22) applicable for MOX LTA are:

1. CASMO-4 methodology is acceptable for Catawba nuclear design analysis for LEU fuel and up to four MOX LTAs.
2. Four MOX LTAs with at least two LTAs placed in instrumented locations.
3. Introduction of significantly different fuel designs will require further validation of the CASMO-4 physics methods for application to Catawba and McGuire by the licensee and will require review by the NRC staff.

All of these SE requirements are satisfied. Four MOX LTAs were inserted into C1C16 in core location C-08 and its symmetric locations. These locations are not the limiting core locations during the nominal depletion and all four of these locations are instrumented. No new fuel design is incorporated into the C1C16 core design that was not evaluated in DPC-NE-1005-P-A (Reference 22).

4.3.2.2 Power Distributions

The accuracy of power distribution calculations has been confirmed through comparisons of predicted versus measured power distributions as described in References 10, 22, and 55 and

through ongoing comparisons between predicted and measured powers performed for each reload core design.

4.3.2.2.1 Definitions

Power distributions are quantified in terms of hot channel factors. These factors are a measure of the peak pellet power within the reactor core and the total energy produced in a coolant channel and are expressed in terms of quantities related to the nuclear or thermal design namely:

Power density is the thermal power produced per unit volume of the core (KW/liter).

Linear Power density is the thermal power produced per unit length of active fuel (KW/ft). Since fuel assembly geometry is standardized, this is the unit of power density most commonly used. For all practical purposes, it differs from KW/liter by a constant factor which includes geometry and the fraction of the total thermal power which is generated in the fuel rod.

Average linear power density is the total thermal power produced in the fuel rods divided by the total active fuel length of all rods in the core.

Local heat flux is the heat flux at the surface of the cladding (BTU-ft⁻²-hr⁻¹). For nominal rod parameters, this differs from linear power density by a constant factor.

Rod power or rod integral power is the length integrated linear power density in one rod (KW).

Average rod power is the total thermal power produced in the fuel rods divided by the number of fuel rods (assuming all rods have equal length).

The hot channel factors used in the discussion of power distributions in this section are defined as follows:

F_Q , Heat Flux Hot Channel Factor, is defined as the maximum local fuel rod linear power density divided by the average fuel rod linear power density, assuming nominal fuel pellet and rod parameters.

F_Q^{SCUF} , Nuclear Heat Flux Hot Channel Factor or Statistically Combined Hot Channel Factor is defined as the maximum local heat flux on the surface of a fuel rod divided by the average fuel rod heat flux, allowing for manufacturing tolerances on fuel pellets and rods.

F_Q^E , Engineering Heat Flux Hot Channel Factor, is the allowance on heat flux required for manufacturing tolerances. The engineering factor allows for local variations in enrichment, pellet density and diameter, surface area of the fuel rod and eccentricity of the gap between pellet and clad.

$F_{\Delta H}^N$, Nuclear Enthalpy Rise Hot Channel Factor, is defined as the ratio of the integral of linear power along the rod with the highest integrated power to the average rod power.

Manufacturing tolerances, hot channel power distribution and surrounding channel power distributions are treated explicitly in the calculation of the DNB ratio described in Section 4.4.

F_z , Axial Peaking Factor, is defined as the ratio of the nuclear heat flux hot channel factor, F_Q , divided by the nuclear enthalpy rise hot channel factor, $F_{\Delta H}$. The axial peaking factor, F_z , can be defined on a core average or assembly average basis.

Relationships between F_Q , $F_{\Delta H}$ and F_z are defined below.

$$F_Q = F_{\Delta H} \times F_z$$

$$F_{\Delta H} = F_q/F_z$$

$$F_z = F_q/F_{\Delta H}$$

4.3.2.2.2 Radial Power Distributions

The power shape in horizontal sections of the core at full power is a function of the fuel and burnable poison loading patterns and the presence or absence of a single bank of full length control rods. Thus, at any time in the cycle, a horizontal section of the core can be characterized as unrodded or with group D control rods. These two situations combined with burnup effects determine the radial power shapes which can exist in the core at full power. The effects on radial power shape due to power level, xenon, samarium, and moderator density are considered also, but these are small. The effect of non-uniform flow distribution is negligible. While radial power distributions in various planes of the core are often illustrated, the core radial enthalpy rise distribution as determined by the integral of power up each channel is of greater interest. Figure 4-24 through Figure 4-29 show typical radial power distributions for one-quarter of the core for representative operating conditions. These conditions are 1) Hot Full Power (HFP) at Beginning-of-Life (BOL) - unrodded - no xenon, 2) HFP at BOL - unrodded - equilibrium xenon, 3) HFP near BOL - Bank D inserted (28%) - equilibrium xenon, 4) HFP near Middle- of-Life (MOL) - unrodded - equilibrium xenon, 5) HFP at End-of-Life (EOL) - unrodded - equilibrium xenon, and 6) HFP at End-of-Life (EOL) - Bank D inserted (28%) - equilibrium xenon.

Since the position of the hot channel varies from time to time, a single reference radial design power distribution is selected for DNB calculations. This reference power distribution is chosen conservatively to concentrate power in one area of the core, minimizing the benefits of flow redistribution. Assembly powers are normalized to core average power. The radial power distribution of the fuel rods within an assembly and their variations with burnup is utilized in thermal calculations and fuel rod design as discussed in Section 4.2.

4.3.2.2.3 Assembly Power Distributions

For the purpose of illustration, assembly power distributions from similar BOL and EOL conditions corresponding to Figure 4-25 and Figure 4-28 respectively, are given for the same assembly in Figure 4-30 and Figure 4-31 respectively.

Since the detailed power distribution surrounding the hot channel varies from time to time, a conservatively flat assembly power distribution is assumed in the DNB analysis, described in Section 4.4. $F_{\Delta H}^N$ is a variable limit which depends on the location and magnitude of the axial peak, F_z . Care is taken in the nuclear design of all fuel cycles and all operating conditions to ensure that a flatter assembly power distribution does not occur with limiting values of $F_{\Delta H}^N$ (see References 44 and 55).

4.3.2.2.4 Axial Power Distributions

The shape of the power profile in the axial or vertical direction is largely under the control of the operator through either the manual operation of the full length control rods or automatic motion of full length rods responding to manual operation of the CVCS, and to a lesser extent, the axial power profile can be controlled by the core designer depending on the choice of fuel and burnable poison designs. Nuclear effects which cause variations in the axial power shape include moderator density, Doppler effect on resonance absorption, spatial xenon and burnup. Automatically controlled variations in total power output and full length rod motion are also important in determining the axial power shape at any time. Signals are available to the

operator from the excore ion chambers which are long ion chambers outside the reactor vessel running parallel to the axis of the core. Separate signals are taken from the top and bottom halves of the chambers. The difference between top and bottom signals from each of four pairs of detectors is displayed on the control panel and called the flux difference, ΔI . Calculations of core average peaking factor for many plants and measurements from operating plants under many operating situations are associated with either ΔI or axial offset in such a way that an upper bound can be placed on the peaking factor. For these correlations, axial offset is defined as:

$$\text{axial offset} = \frac{\phi_t - \phi_b}{\phi_t + \phi_b}$$

and ϕ_t and ϕ_b are the top and bottom detector readings.

Representative axial power shapes for BOL, MOL, and EOL conditions are shown in Figure 4-32 through Figure 4-34. These figures cover a wide range of axial offset including values not permitted at full power.

Figure 4-35 compares the axial power distribution for several assemblies at different distances from inserted control rods with the core average distribution.

4.3.2.2.5 Local Power Peaking

Fuel densification, which has been observed to occur under irradiation in several operating reactors, causes the fuel pellets to shrink both axially and radially. The pellet shrinkage combined with random hang-up of fuel pellets results in gaps in the fuel column when the pellets below the hung-up pellet settle in the fuel rod. The gaps vary in length and location in the fuel rod. Because of decreased neutron absorption in the vicinity of the gap, power peaking occurs in the adjacent fuel rods resulting in an increased power peaking factor. However, current fuel designs employed in the design of reactor cores for Catawba Nuclear Station make use of fuel pellets with higher initial densities which hot cell and gamma scan measurements have shown do not develop significant gaps. Fuel densification is discussed in UFSAR Section 4.2.3.2. Per Reference 55, no power peaking penalties due to fuel densification effects are used in the nuclear analysis.

4.3.2.2.6 Limiting Power Distributions

According to the ANSI classification of plant conditions (See Chapter 15), Condition I occurrences are those which are expected frequently or regularly in the course of power operation, maintenance, or maneuvering of the plant. As such, Condition I occurrences are accommodated with margin between any plant parameter and the value of that parameter which would require either automatic or manual protective action. Inasmuch as Condition I occurrences occur frequently or regularly, they must be considered from the point of view of affecting the consequences of fault conditions (Conditions II, III and IV). In this regard, analysis of each fault condition described is generally based on a conservative set of initial conditions corresponding to the most adverse set of conditions which can occur during Condition I operation.

The list of steady state and shutdown conditions, permissible deviations (such as one coolant loop out of service) and operational transients is given in Chapter 15. Implicit in the definition of normal operation is proper and timely action by the reactor operator. That is, the operator follows recommended operating procedures for maintaining appropriate power distributions and takes any necessary remedial actions when alerted to do so by the plant instrumentation. Thus,

as stated above, the worst or limiting power distribution which can occur during normal operation is to be considered as the starting point for analysis of ANSI Conditions II, III and IV events.

Improper procedural actions or errors by the operator are assumed in the design as occurrences of moderate frequency (ANSI Condition II). Some of the consequences which might result are discussed in Chapter 15. Therefore, the limiting power distributions which result from such Condition II events, are those power distributions which deviate from the normal operating condition at the recommended axial offset band, e.g., due to lack of proper action by the operator during a xenon transient following a change in power level brought about by control rod motion. Power distributions which fall in this category are used for determination of the reactor protection system setpoints so as to maintain margin to overpower or DNB limits.

Power distribution control within the reactor core is maintained by defining allowable limits for the nuclear heat flux hot channel factor, nuclear enthalpy rise hot channel factor, axial flux difference (AFD) and control rod insertion. The purpose of these limits is two fold. First, they provide assurance that the ECCS acceptance criteria is not exceeded during a loss of coolant accident (LOCA), and second, they provide assurance that DNBR limits are not exceeded during condition I and II transients. Limits for the above parameters are specified in either Technical Specifications, or the Core Operating Limits report (COLR).

The Topical report titled, "Nuclear Design Methodology for Core Operating Limits of Westinghouse Reactors", Reference 43, describes the methodology used to assure that the power peaking limits are not exceeded during condition I and II transients. This report focuses on the analysis performed to determine the power dependent axial flux difference and rod insertion limits (RILs), and the $f(\Delta I)$ penalty function for the over-power delta-T (OPDT) and over-temperature delta-T (OTDT) trip functions. A qualitative description of the analysis performed to establish these limits follows. Refer to Reference 43 for a detailed description of the analysis performed to set these limits.

An analysis is performed for each reload core design to confirm the adequacy of the current power dependent axial flux difference limits, rod insertion limits and the $f(\Delta I)$ penalty function. If the results from the analysis indicate that the current limits are no longer valid, new limits are derived based on this analysis. Once the new limits are developed, the appropriate changes to the Technical Specifications and the COLR are performed. However, if the new limits are found to overly restrict core operation, a new core design may be pursued in an attempt to reduce the magnitude core peaking during condition I and II transients, since a decrease in peaking will translate into a less restrictive $f(\Delta I)$ penalty and less limiting axial flux difference and rod insertion limits.

The analysis performed to develop axial flux difference limits, rod insertion limits and the $f(\Delta I)$ penalty function involves the generation and evaluation of several thousand three dimensional power distributions. Power distributions used in this evaluation are developed as a function of the following variables.

1. Burnup
2. Reactor power
3. Coolant temperature
4. Rod position
5. Xenon

The generation of conservative limits is assured through the generation of power distributions which are more severe than the power distributions expected to occur during normal or transient operation. Conservatism is introduced into the analysis by assuming instantaneous changes

in reactor power, soluble boron and rod positions. The selection of severe xenon distributions for the peaking analysis also adds another degree of conservatism to the analysis. Using these assumptions in concert provides a high level of confidence that the AFD limits, the rod insertion limits and the $f(\Delta I)$ penalty functions developed will be conservative. The analysis performed assumes the application of appropriate uncertainty factors to the power distribution used in the analysis as described in Reference 43. The nuclear uncertainty factors used are based on a 95 percent probability and 95 percent confidence level.

The methodology of Reference 43 assumes that the plant is in compliance with the following conditions. These conditions are assumed to exist during normal plant operation.

1. Control rods in a single bank move together with no individual rod insertion differing by more than 12 steps (indicated) from the bank demand position;
2. Control banks are sequenced with overlapping banks;
3. The control bank insertion limits are not violated;
4. Axial power distribution procedures, which are given in terms of flux difference control and control bank position, are observed.

The power dependent operational AFD and rod insertion limits are developed to ensure that the design basis local power peaking limits for the loss of coolant accident (LOCA) and the DNBR peaking limits for the loss of flow accident (LOFA) are not exceeded. The power dependent AFD limits are developed assuming only condition I type transients. LOCA local peaking limits (F_q Limits) are established for each reload core design and included in the Core Operating Limits Report (COLR). LOFA DNB limits are defined in terms of maximum allowable total peaks (MATPs), which are representative of a constant DNBR, and are a function of both the magnitude and location of the axial peak. The generation of MATP limits are described in detail in Reference 44. If the power dependent AFD limits that are developed are overly restrictive such that the plant cannot operate about the ARO full power target AFD, a new set of AFD and rod insertion limits can be developed to allow power operation between 80% and 100% rated thermal power (RTP). These limits are known as Base Load AFD limits and are established by defining a narrow AFD band about the target AFD. By limiting the imbalance band about the target AFD, additional peaking margin can be gained through the reduction of transient xenon induced peaking effects.

Reactor protection system (RPS) AFD limits are developed through the analysis of power distributions produced from both condition I and II transients. If the results of the analysis performed confirm that the current set of RPS AFD limits are valid, the analysis performed to set the $f(\Delta I)$ penalty is also confirmed. However, if the current set of RPS AFD limits are exceeded, new RPS AFD limits are developed and the $f(\Delta I)$ penalty function recalculated. The $f(\Delta I)$ penalty trip reset function portion of the OPDT and OTDT trip functions is used to ensure that both DNB and center-line fuel melt (CFM) margin exists during postulated condition I and II transients.

Several condition II transients are evaluated in order to develop RPS AFD limits. These transients are:

1. Boron dilution with control rods in automatic or manual
2. Reduction in feedwater temperature
3. Increase in feedwater flow
4. Increase in steam flow
5. Inadvertent opening of a steam line valve
6. Uncontrolled bank withdrawal accident
7. Control rod mis-operation.

The initial conditions for the above transients are assumed to be within the conditions of normal operation outlined previously. Control rod motion during the transient is not constrained to the RILs since these limits do not mitigate the consequences of the accident, or produce a reactor trip. The analysis performed considers a range of reactor powers, with the upper limit in reactor power assumed to be less than or equal to 118% RTP. A reactor trip is assumed to occur at this power level.

RPS DNB evaluations are performed for each of the transients described above to confirm if current RPS AFD limits are bounding, or to generate new RPS AFD limits. DNB evaluations are performed as a function of both reactor power and inlet temperature. The $f(\Delta I)$ penalty functions for the OPDT and OTDT trip functions are developed using the RPS AFD space defined in this analysis. The peak power densities produced from the condition I and II transients are also verified to be less than that required to produce center-line fuel melt.

Both F_q and $F_{\Delta H}$ peaking limits are monitored as required by Technical Specifications to assure that initial conditions for the loss of coolant and loss of flow accidents are not exceeded. F_q limits are power dependent and increase with decreasing power as shown in Technical Specifications. $F_{\Delta H}$ limits are also power dependent and increase with decreasing reactor power and can be essentially defined by the following equation.

$$F_{\Delta H} = \text{MARP}[1 + 0.3(1 - P)]$$

Maximum allowable radial peaks (MARPs) are developed based on the thermal conditions produced from the loss of flow accident and are a function of both the magnitude and location of the axial peak. MARPs are algebraically derived from MATP limits, which are discussed in depth in Reference 44.

Core designs are developed based on allowable F_q , $F_{\Delta H}$ and rod insertion limits. The limiting power distributions for a core design typically occur with control banks at or near their rod insertion limit. Therefore, power operation about the HFP ARO equilibrium xenon target AFD is recommended since operation about this target AFD will result in an increase in margin to both the F_q and $F_{\Delta H}$ limits.

When a situation is possible in normal operation which could result in local power densities in excess of those assumed as the pre-condition for a subsequent hypothetical accident, but which would not itself cause fuel failure, administrative controls and alarms are provided for returning the core to a safe condition. These alarms are described in Chapter 7, Chapter 15, and Chapter 16.

4.3.2.2.7 Experimental Verification of Power Distribution Analysis

Verification of predicted versus measured power distributions has been performed as part of the licensing of Duke Power Company's reload design methodology as described in References 10, 22, and 55. An in depth discussion of these comparisons can be found in these references. The conversion of measured reaction rates into three-dimensional power distributions was performed using the computer code DETECTOR as described in Reference 38. The DETECTOR algorithm has been integrated into a new code named COMET as described in Reference 50. A detailed description of this code's input and output is included in this reference. The measured versus calculational comparison is normally performed periodically throughout the cycle lifetime of the reactor as required by Technical Specifications. Figures 4-42 and 4-43 demonstrate conceptual radial and axial comparisons for calculated versus measured power distributions.

In a measurement of the heat flux hot channel factor, F_Q , with the movable detector system described in Sections 7.7.1 and 4.4.6, the following uncertainties have to be considered:

1. Reproducibility of the measured signal
2. Errors in the calculated relationship between detector current and local flux
3. Errors in the calculated relationship between detector flux and peak rod power some distance from the measurement thimble.

The appropriate allowance for category 1 above has been quantified by repetitive measurements made with several inter-calibrated detectors by using the common thimble features of the incore detector system. This system allows more than one detector to access any thimble. Errors in category 2 above are quantified to the extent possible, by using the fluxes measured at one thimble location to predict fluxes at another location which is also measured. Local power distribution predictions are verified in critical experiments on arrays of rods with simulated guide thimbles, control rods, burnable poisons, etc. These critical experiments provide quantification of errors of types 2 and 3 above.

Statistical analyses have been performed in References 10, 22, and 55 to develop observed nuclear reliability factors (ONRFs) for both the nuclear heat flux hot channel factor, F_Q , the nuclear enthalpy rise hot channel factor, $F_{\Delta H}$ and the axial peak uncertainty factor, F_z . Predicted versus measured power distributions were compared for several cycles at different burnup points during each cycle in order to generate a statistical data base. The analysis performed in References 10 and 55 assumed that the difference between the measured and predicted powers was a normal distribution. This assumption was subsequently confirmed by performing a D-prime test to establish the normality of the distribution. The one-sided upper tolerance limit methodology was used to develop the ONRF based on a 95 percent probability and a 95% confidence level. For an in depth discussion on how these ONRFs were developed, refer to Reference 10. References 10 and 55 refer to the statistical analysis performed for CASMO-3/SIMULATE-3 Nuclear Design power distribution analysis methods. For the CASMO-4/SIMULATE-3 MOX methods, an additional statistical analysis is performed when the D-prime test for normality shows that the difference between the measured and predicted powers is non normally distributed. The non-parametric statistical evaluation is described in Reference 23 and was used in Reference 22 to develop the ONRFs based on a 95/95 one-sided tolerance confidence level. The 95/95 uncertainty of a distribution is the m^{th} worst comparison where m is a function of the number of comparisons. For an in depth discussion on how these ONRFs were developed, refer to Reference 22.

The ability of the advanced Nodal Code SIMULATE-3 to predict local pin powers was assessed in References 10 and 22. The predictive capability of SIMULATE-3 was assessed by comparing predicted pin powers against measured pin powers for several B&W critical experiments. The results of these comparisons and the resulting statistical analysis showed that SIMULATE-3 could predict peak pin power to within approximately 1.0%. However, a value of 2% was selected for CASMO-3/SIMULATE-3P methods (Reference 10). For CASMO-4/SIMULATE-3 MOX methods, the calculated pin uncertainty is 1.69% for low enriched Uranium (LEU) fuel and 2.15% for mixed oxide (MOX) fuel (Reference 22).

In References 10, 22, and 55 statistically combined uncertainty factors for F_Q and $F_{\Delta H}$ are produced by statistically combining the local peaking factor and the engineering hot channel factor with the observed nuclear reliability factors for F_Q and $F_{\Delta H}$. The uncertainty factor for F_z was also developed in References 10, 22, and 55. The statistically combined uncertainty factors for F_Q , $F_{\Delta H}$, and F_z are shown in Table 4-21. Note that CASMO-4/SIMULATE-3 uncertainties in this table bound uncertainty values developed in Reference 22.

The above uncertainties are used in the LOCA, center-line fuel melt, transient strain, and DNBR evaluations of design transients.

4.3.2.2.8 Testing

An extensive series of physics tests is performed on each core. These tests and the criteria for satisfactory results are described in Chapter 14. Since not all limiting situations can be created at beginning-of-life, the main purpose of the tests is to provide a check on the calculational methods used in the predictions for the conditions of the test. Tests are performed at the beginning of each reload cycle to verify that the reactor core is operating as designed.

4.3.2.2.9 Monitoring Instrumentation

The adequacy of instrument numbers, spatial deployment, required correlations between readings and peaking factors, calibration and errors are described in References 2, 6, and 9. The relevant conclusions are summarized here in Sections 4.3.2.2.7 and 4.4.6.

Provided the limitations given in Section 4.3.2.2.6 on rod insertion and flux difference are observed, the excore detector system provides adequate online monitoring of power distributions. Further details of specific limits on the observed rod positions and flux difference are given in the Technical Specifications or Core Operating Limits Report (COLR). Limits for alarms, reactor trip, etc., are given in the Technical Specifications. Descriptions of the systems provided are given in Section 7.7.

4.3.2.3 Reactivity Coefficients

The kinetic characteristics of the reactor core determine the response of the core to changing plant conditions or to operator adjustments made during normal operation, as well as the core response during abnormal or accidental transients. These kinetic characteristics are quantified in reactivity coefficients. The reactivity coefficients reflect the changes in the neutron multiplication due to varying plant conditions such as power, moderator or fuel temperatures, or less significantly due to a change in pressure or void conditions. Since reactivity coefficients change during the life of the core, ranges of coefficients are employed in transient analysis to determine the response of the plant throughout life. The results of such simulations and the reactivity coefficients used are presented in Chapter 15. The reactivity coefficients are calculated on a corewide basis using SIMULATE-3, an advanced nodal code. The effect of radial and axial power distribution on core average reactivity coefficients is implicit in those calculations and is not significant under normal operating conditions.

For example, a skewed xenon distribution which results in changing axial offset by 5 percent changes the moderator and Doppler temperature coefficients by less than 0.01 pcm/°F and 0.03 pcm/°F respectively. An artificially skewed xenon distribution which results in changing the radial $F_{\Delta H}^N$ by 3 percent changes the moderator and Doppler temperature coefficients by less than 0.03 pcm/°F and 0.001 pcm/°F respectively. The spatial effects are accentuated in some transient conditions and are included; for example, in the postulated rupture of the main steamline break and the rupture of an RCCA mechanism housing described in Sections 15.1.5 and 15.4.8.

The analytical methods and calculational models used in calculating the reactivity coefficients are given in Section 4.3.3. These models have been confirmed through extensive testing and benchmarking as described herein; results of these tests are discussed in Section 4.3.3.

Quantitative information for calculated reactivity coefficients, including fuel-Doppler coefficient, moderator coefficients (density, temperature, pressure, void) and power coefficient is given in the following sections.

4.3.2.3.1 Fuel Temperature (Doppler) Coefficient

The fuel temperature (Doppler) coefficient is defined as the change in reactivity per degree change in effective fuel temperature and is primarily a measure of the Doppler broadening of U-238 and Pu-240 resonance absorption peaks. Doppler broadening of other isotopes such as U-236, Np-237, etc. are also considered but their contributions to the Doppler effect are small. An increase in fuel temperature increases the effective resonance absorption cross sections of the fuel and produces a corresponding reduction in reactivity.

The Doppler temperature coefficient is calculated using a three-dimensional simulator. The coefficient is calculated by performing a set of cases which vary the effective fuel temperature about a mean fuel temperature. The resulting reactivity difference between the two fuel temperatures divided by the change in fuel temperature defines the Doppler temperature coefficient. The moderator temperature is held constant for the calculation. Spatial variations in the fuel temperature are taken into account by functionalizing the fuel temperature against local power density.

Doppler temperature coefficients are shown as a function of fuel temperature in Figure 4-45 for both BOC and EOC conditions. The Doppler-only contribution to the power coefficient, defined later, is shown in Figure 4-46 as a function of relative core power. The integral of the differential curve on Figure 4-46 is the Doppler contribution to the power defect and is shown in Figure 4-47 as a function of relative power. The Doppler coefficient becomes more negative as a function of life as the Pu-240 content increases, thus increasing the Pu-240 resonance absorption. The minimum and maximum limits of the Doppler coefficient used in accident analyses are given in Chapter 15.

4.3.2.3.2 Moderator Coefficients

The moderator coefficient is a measure of the change in reactivity due to a change in specific coolant parameters such as density, temperature, pressure or void. The coefficients so obtained are moderator density, temperature, pressure and void coefficients.

4.3.2.3.2.1 Moderator Density and Temperature Coefficients

The moderator temperature (density) coefficient is defined as the change in reactivity per unit change in the moderator temperature (density). Generally, the effect of the changes in moderator density as well as the temperature are considered together. A decrease in moderator density results in less moderation and hence a decrease in reactivity. Therefore, the moderator density coefficient is positive. As temperature increases, density decreases (for a constant pressure) and hence the moderator temperature coefficient becomes more negative. An increase in coolant temperature, keeping the density constant, leads to a hardened neutron spectrum and results in an increase in resonance absorption in U-238, Pu-240 and other isotopes. The hardened spectrum also causes a decrease in the fission to capture ratio in U-235 and Pu-239. Both of these effects make the moderator temperature coefficient more negative. Since water density changes more rapidly with temperature as temperature increases, the moderator temperature (density) coefficient becomes more negative (positive) with increasing temperature.

The soluble boron used in the reactor as a means of reactivity control also has an effect on moderator temperature coefficient since the soluble boron poison density as well as the water density is decreased when the coolant temperature rises. A decrease in the soluble poison concentration introduces a positive component in the moderator temperature coefficient.

Thus, if the concentration of soluble poison is large enough, the net value of the coefficient may be positive. With the burnable poison present, however, the initial hot boron concentration is sufficiently low that the moderator temperature coefficient is negative at full power operating temperatures. The effect of control rods is to make the moderator temperature coefficient negative by reducing the required soluble boron concentration and by increasing the "leakage" of the core.

Positive moderator temperature coefficients are allowed at reactor powers less than 100% rated thermal power. Specifically, the moderator temperature coefficient shall be less than or equal to 7 pcm/°F from 0% rated thermal power through 70% rated thermal power, and less than or equal to 0 pcm/°F at 100% rated thermal power. The moderator temperature coefficient decreases linearly from 7 pcm/°F at 70% rated thermal power to 0 pcm/°F at 100% rated thermal power.

With burnup, the moderator temperature coefficient becomes more negative primarily as a result of boric acid dilution but also to an extent from the effects of the buildup of plutonium and fission products.

The moderator coefficient is calculated for the various plant conditions by varying the moderator temperature (and density) about a mean temperature. This calculation is performed using a three dimensional reactor simulator. The moderator temperature coefficient is shown as a function of core temperature and boron concentration for the unrodded and rodded core in Figure 4-48 through Figure 4-50. The temperature range covered is from cold (68°F) to about 600°F. The contribution due to Doppler coefficient (because of a change in moderator temperature) has been subtracted from these results. Figure 4-51 shows the hot, full power moderator temperature coefficient plotted as a function of first cycle lifetime for the critical boron concentration condition based on the design boron letdown condition.

The moderator coefficients presented here are calculated on a corewide basis, since they are used to describe the core behavior in normal and accident situations when the moderator temperature changes can be considered to affect the entire core.

4.3.2.3.2.2 Moderator Pressure Coefficient

The moderator pressure coefficient relates the change in moderator density, resulting from a reactor coolant pressure change, to the corresponding effect on neutron production. This coefficient is of much less significance in comparison with the moderator temperature coefficient. A change of 50 psi in pressure has approximately the same effect on reactivity as a half-degree change in moderator temperature. This coefficient can be determined from the moderator temperature coefficient by relating the change in pressure to the corresponding change in density. The moderator pressure coefficient is negative over a portion of the moderator temperature range at beginning-of-life (-0.004 pcm/psi, BOL) but is always positive at operating conditions and becomes more positive during life (+0.3 pcm/psi, EOL).

4.3.2.3.2.3 Moderator Void Coefficient

The moderator void coefficient relates the change in neutron multiplication to the presence of voids in the moderator. In a PWR, this coefficient is not very significant because of the low void content in the coolant. The core void content is less than one-half of one percent and is due to

local or statistical boiling. The void coefficient varies from 50 pcm/percent void at BOL and at low temperatures to -250 pcm/percent void at EOL and at operating temperatures. The negative void coefficient at operating temperature becomes more negative with fuel burnup.

4.3.2.3.3 Power Coefficient

The combined effect of moderator temperature and fuel temperature change as the core power level changes is called the total power coefficient and is expressed in terms of reactivity change per percent power change. The power coefficient at BOL and EOL conditions is given in Figure 4-52.

The power coefficient becomes more negative with burnup, reflecting the combined effect of moderator and fuel temperature coefficient changes with burnup. The power defect (integral reactivity effect) at BOL and EOL is given in Figure 4-53.

4.3.2.3.4 Comparison of Calculated and Experimental Reactivity Coefficients

References 10 and 22 describes the comparison of calculated and experimental reactivity coefficients in detail. Based on the data presented there, it is estimated that the accuracy of the current analytical model is:

± 0.2 percent $\Delta\rho$ for Doppler and power defect.

± 2 pcm/ $^{\circ}$ F for the moderator coefficient.

Experimental evaluation of the calculated coefficients is done during the physics startup tests described in Chapter 14.

4.3.2.3.5 Reactivity Coefficient Used in Transient Analysis

Reactivity coefficients are calculated as part of the safety analysis for each reload core using NRC-approved methodology to systematically confirm that the reactivity coefficients used in the licensing Chapter 15 accident analyses are bounding. The models used to perform these calculations are based on the available operating history of the previous cycle to assure best estimate calculations. Determination of whether a nuclear-related physics parameter is within the bounding value assumed in the Reference safety analysis is made by performing explicit calculations of the parameter.

Table 4-5 gives the limiting values for the reactivity coefficients. The limiting values are used as design limits in the transient analysis. The exact values of the coefficient used in the analysis depend on whether the transient of interest is examined at the BOL or EOL, whether the most negative or the most positive (least negative) coefficients are appropriate, and whether spatial non-uniformity must be considered in the analysis. Conservative values of coefficients, considering various aspects of analysis are used in the transient analysis. This is described in Chapter 15. A description of the combination of nuclear parameters used in Chapter 15 can be found in References 45 and 46.

Cycle 1 best estimate reactivity coefficients are shown in Figure 4-45 through Figure 4-53. The need for a reevaluation of any accident in a subsequent cycle is contingent upon whether or not the coefficients for that cycle fall within the identified range used in the analysis presented in Chapter 15. Control rod requirements are given in Table 4-7 for the core described and for a hypothetical equilibrium cycle since these are markedly different. These latter numbers are provided for information only and their validity in a particular cycle would be an unexpected coincidence.

4.3.2.4 Control Requirements

To ensure the shutdown margin stated in the Technical Specifications under conditions where a cooldown to ambient temperature is required, concentrated soluble boron is added to the coolant. Boron concentrations for several core conditions are listed in Table 4-6. For all core conditions including refueling, the boron concentration is well below the solubility limit. The rod cluster control assemblies are employed to bring the reactor to the hot shutdown condition. The minimum required shutdown margin is given in the Technical Specifications.

The ability to accomplish the shutdown for hot conditions is demonstrated in Table 4-7 by comparing the difference between the rod cluster control assembly reactivity available with an allowance for the worst stuck rod with that required for control and protection purposes. The shutdown margin includes an allowance of 10 percent based on the available rod worth for analytic uncertainties. The largest reactivity control requirement appears at EOL when the moderator temperature coefficient reaches its peak negative value as reflected in the larger power defect.

The control rods are required to provide sufficient reactivity to account for the power defect from full power to zero power and to provide the required shutdown margin. The reactivity addition resulting from power reduction consists of contributions from Doppler, variable average moderator temperature, flux redistribution, and reduction in void content as discussed below.

4.3.2.4.1 Doppler

The Doppler effect arises from the broadening of U-238 and Pu-240 resonance peaks with an increase in effective pellet temperature. This effect is most noticeable over the range of zero power to full power due to the large pellet temperature increase with power generation.

4.3.2.4.2 Variable Average Moderator Temperature

When the core is shut down to the hot, zero power condition, the average moderator temperature changes from the equilibrium full load value determined by the steam generator and turbine characteristics (steam pressure, heat transfer, tube fouling, etc.) to the equilibrium no load value, which is based on the steam generator shell side design pressure.

Since the moderator coefficient is negative, there is a reactivity addition with power reduction. The moderator coefficient becomes more negative as the fuel depletes because the boron concentration is reduced. This effect is the major contributor to the increased requirement at end-of-life.

4.3.2.4.3 Redistribution

During full power operation, the coolant density decreases with core height, and this, together with partial insertion of control rods, results in less fuel depletion near the top of the core. Under steady state conditions, the relative power distribution will be slightly asymmetric towards the bottom of the core. On the other hand, at hot zero power conditions, the coolant density is uniform up the core, and there is no flattening due to Doppler. The result will be a flux distribution which at zero power can be skewed toward the top of the core. The reactivity insertion due to the skewed distribution is calculated with an allowance for effects of xenon distribution.

4.3.2.4.4 Void Content

A small void content in the core is due to nucleate boiling at full power. The void collapse coincident with power reduction makes a small reactivity contribution.

4.3.2.4.5 Rod Insertion Allowance

At full power, the control bank is operated within a prescribed band of travel to compensate for small periodic changes in boron concentration, changes in temperature and very small changes in the xenon concentration not compensated for by a change in boron concentration. When the control bank reaches either limit of this band, a change in boron concentration is required to compensate for additional reactivity changes. Since the insertion limit is set by a rod travel limit, a conservatively high calculation of the inserted worth is made which accounts for possible transient xenon effects.

4.3.2.4.6 Burnup

Excess reactivity of 12 - 15 percent $\Delta\rho$ (hot) is installed at the beginning of each cycle to provide sufficient reactivity to compensate for fuel depletion and fission products throughout the cycle. This reactivity is controlled by the addition of soluble boron to the coolant and by burnable poison. The soluble boron concentration for several core configurations, the unit boron worth, and burnable poison worth are given in Table 4-4 through Table 4-6. Since the excess reactivity for burnup is controlled by soluble boron and/or burnable poison, it is not included in control rod requirements.

4.3.2.4.7 Xenon and Samarium Poisoning

Changes in xenon and samarium concentrations in the core occur at a sufficiently slow rate, even following rapid power level changes, that the resulting reactivity change can be controlled by changing the soluble boron concentration.

4.3.2.4.8 pH Effects

Changes in reactivity due to a change in coolant pH, if any, are sufficiently small in magnitude and occur slowly enough to be controlled by the boron system. Further details are provided in Reference 11.

4.3.2.4.9 Experimental Confirmation

The calculation of the core reactivity change from normal operating conditions to shutdown conditions with all rods inserted (ARI) and the highest worth rod stuck out of the core are not typically measured. However, several reactivity components of this reactivity change are measured for each reload core. Comparisons between predicted and measured isothermal temperature coefficients (ITCs), control rod worths and critical boron concentrations are performed at BOC HZP conditions for each reload core. Through these comparisons the ability of the nuclear codes to accurately predict the behavior of the reload core and safety related parameters is confirmed. Additional comparisons that are performed throughout the cycle which confirm the reload models accuracy are summarized below.

1. Comparisons between predicted and measured full power or near full power boron concentrations and power distributions.
2. Comparisons of predicted versus measured critical conditions (e.g. rod position, boron concentration and xenon worth) during the reactor startup following a reactor trip.

3. Comparisons of the predicted versus measured EOC ITC.

The results of these comparisons provide a high level of confidence in the ability of the core model to predict control requirements, or shutdown margin. As an additional degree of conservatism in addition to the highest worth stuck rod, shutdown margin calculations include a 10% allowance for uncertainty in the calculated rod worth, a rod insertion allowance and also an allowance to account for transient xenon effects. The accuracy of the analytical model to predict control requirements, based on comparisons between measured and predicted startup data, is believed to be within 0.3% $\Delta\rho$.

4.3.2.4.10 Control

Core reactivity is controlled by means of a chemical poison dissolved in the coolant, rod cluster control assemblies, and burnable poison rods as described below.

4.3.2.4.11 Chemical Poison

Boron in solution as boric acid is used to control relatively slow reactivity changes associated with:

1. The moderator temperature defect in going from cold shutdown at ambient temperature to the hot operating temperature at zero power,
2. The transient xenon and samarium poisoning, such as that following power changes or changes in rod cluster control position,
3. The excess reactivity required to compensate for the effects of fissile inventory depletion and buildup of long-life fission products.
4. The burnable poison depletion.

The boron concentrations for various core conditions are presented in Table 4-6.

4.3.2.4.12 Rod Cluster Control Assemblies

Full length Rod Cluster Control Assemblies exclusively are employed in this reactor. The number of respective full length assemblies is shown in Table 4-4. The full length rod cluster control assemblies are used for shutdown and control purposes to offset fast reactivity changes associated with:

1. The required shutdown margin in the hot zero power, stuck rods condition,
2. The reactivity compensation as a result of an increase in power above hot zero power (power defect including Doppler, and moderator reactivity changes),
3. Unprogrammed fluctuations in boron concentration, coolant temperature, or xenon concentration (with rods not exceeding the allowable rod insertion limits),
4. Reactivity ramp rates resulting from load changes.

The allowed full length control bank reactivity insertion is limited at full power to maintain shutdown capability. Because of the reduction in the magnitude of the power defect with decreasing power, control rod reactivity requirements are also reduced and more rod insertion is allowed.

The control bank position is monitored and the operator is notified by an alarm if the limit is approached. The determination of the insertion limit uses conservative xenon distributions and axial power shapes. In addition, the rod cluster control assembly withdrawal pattern determined

from these analyses is used in determining power distribution factors and in determining the maximum worth of an inserted rod cluster control assembly ejection accident. For further discussion, refer to the Technical Specifications on rod insertion limits.

Power distribution, rod ejection and rod misalignment analyses are based on the arrangement of the shutdown and control groups of the rod cluster control assemblies shown in Figure 4-54. All shutdown rod cluster control assemblies are withdrawn before withdrawal of the control banks is initiated. In going from zero to 100 percent power, control banks A, B, C and D are withdrawn sequentially in 50% overlap. The limits of rod positions and further discussion on the basis for rod insertion limits are provided in the Technical Specifications.

4.3.2.4.13 Reactor Coolant Temperature

Reactor coolant (or moderator) temperature control has added flexibility in reactivity control of the Westinghouse PWR. This feature takes advantage of the negative moderator temperature coefficient inherent in a PWR to:

1. Maximize return to power capabilities.
2. Provide ± 5 percent power load regulation capabilities without requiring control rod compensation.

Reactor coolant temperature control supplements the dilution capability of the plant by lowering the reactor coolant temperature to supply positive reactivity through the negative moderator coefficient of the reactor. After the transient is over, the system automatically recovers the reactor coolant temperature to the programmed value.

Moderator temperature control of reactivity, like soluble boron control, has the advantage of not significantly affecting the core power distribution. However, unlike boron control, temperature control can be rapid enough to achieve reactor power change rates of 5 percent/minute.

The Catawba Nuclear Station does not currently use a Low T_{ave} power increase maneuver; such maneuvers are administratively restricted by procedure.

4.3.2.4.14 Burnable Poison

Burnable poison may be in the form of discrete rods or as a coating on the fuel pellets (or Integrated Fuel Burnable Absorber, IFBA).

The burnable poison rods provide partial control of the excess reactivity available at the beginning of the cycle. In doing so, these rods prevent the moderator temperature coefficient from being positive at normal operating conditions. They perform this function by reducing the requirement for soluble poison in the moderator at the beginning of the cycle as described previously. For purposes of illustration, a typical burnable poison rod pattern in the core together with the number of rods per assembly is shown in Figure 4-22. The typical mechanical designs of these rods are shown in Table 4-4. The boron in the rods is depleted with burnup but at a sufficiently slow rate so that the resulting critical concentration of soluble boron is such that the moderator temperature coefficient remains negative at all times for full power operating conditions. The burnable poison rods also provide control of the axial power distribution by shifting power to the upper or lower region of the core through selective positioning of the absorber region.

The burnable poison that is used as a coating applied directly to the fuel pellet, such as IFBA (Integral Fuel Burnable Absorber), behaves similarly to the discrete rods. However, the negative reactivity effect of the IFBA in the core lasts for a shorter duration than that of the burnable poison rods. The residual negative reactivity at the end of the cycle is also generally less for

IFBA than discrete burnable poison rods, which tends to reduce fuel enrichment costs. IFBA pellets are used in a variable number of rods within an assembly to allow some freedom of control on how much reactivity hold down is introduced to that assembly. Typically radial arrangements of IFBA rods within an assembly can be found in Figure 4-81. Axially, the placement and number of the IFBA pellets as well as the thickness of the poison coating can vary to allow some control of reactivity hold down, axial offset, and internal rod pressure. Table 4-3 lists typical mechanical designs of the assemblies with IFBA.

The arrangement of assemblies with IFBA within the core may include locations with or without control rods. In some cases, the use of both burnable poison rods and IFBA might be used. In all cases, assemblies with discrete burnable poison rods are limited to core locations without control rods.

4.3.2.4.15 Peak Xenon Startup

Compensation for the peak xenon buildup is accomplished using the boron control system. Startup from the peak xenon condition is accomplished with a combination of rod motion and boron dilution. The boron dilution may be made at any time, including during the shutdown period, provided the shutdown margin is maintained.

4.3.2.4.16 Load Follow Control and Xenon Control

During load follow maneuvers, power changes are accomplished using control rod motion and dilution or boration by the boron system as required. Control rod motion is limited by the control rod insertion limits on full length rods as provided in the Technical Specifications and discussed in Sections 4.3.2.4.12 and 4.3.2.4.13. The power distribution is maintained within acceptable limits through the location of the full length rod bank. Reactivity changes due to the changing xenon concentration can be controlled by rod motion and/or changes in the soluble boron concentration.

Rapid power increases (5%/min) from reduced power during load follow operation are accomplished with a combination of rod motion, moderator temperature reduction, and boron dilution. Compensation for the rapid power increase is accomplished initially by a combination of rod withdrawal and moderator temperature reduction. As the slower boron dilution takes effect after the initial rapid power increase, the moderator temperature returns to the programmed value.

4.3.2.4.17 Burnup

Control of the excess reactivity for burnup is accomplished using soluble boron and/or burnable poison. The boron concentration must be limited during operating conditions to ensure the moderator temperature coefficient is negative. Sufficient burnable poison is installed at the beginning of a cycle to give the desired cycle lifetime without exceeding the boron concentration limit. The typical minimum boron concentration is 5 ppm.

4.3.2.5 Control Rod Patterns and Reactivity Worth

The full length rod cluster control assemblies are designated by function as the control groups and the shutdown groups. The terms "group" and "bank" are used synonymously throughout this report to Catawba Nuclear Station UFSAR Chapter 4 describe a particular grouping of control assemblies. The rod cluster assembly pattern is displayed in Figure 4-54 and is not expected to change during the life of the plant. The control banks are labeled A, B, C, and D and the shutdown banks are labeled SA, SB, etc., as applicable. Each bank, although operated

and controlled as a unit, is comprised of two subgroups. The axial position of the full length rod cluster control assemblies may be controlled manually or automatically.

The rod cluster control assemblies are all dropped into the core following actuation of reactor trip signals. Two criteria have been employed for selection of the control groups. First the total reactivity worth must be adequate to meet the requirements specified in Table 4-7. Second, in view of the fact that these rods may be partially inserted at power operation; the total power peaking factor should be low enough to ensure that the power capability requirements are met. Analyses indicate that the first requirement can be met either by a single group or by two or more banks whose total worth equals at least the required amount. The axial power shape would be more peaked following movement of a single group of rods worth three to four percent $\Delta\rho$; therefore, four banks (described as A, B, C, and D in Figure 4-54) each worth approximately one percent $\Delta\rho$ have been selected.

The position of control banks for criticality under any reactor condition is determined by the concentration of boron in the coolant. On an approach to criticality, boron is adjusted to ensure that criticality will be achieved with control rods above the insertion limit set by shutdown and other considerations (See the Technical Specifications). Early in the cycle there may also be a withdrawal limit at low power to maintain a negative moderator temperature coefficient.

Ejected rod worths are given in Section 15.4.8 for several different conditions.

Allowable deviations due to misaligned control rods are discussed in the Technical Specifications.

A representative calculation for two banks of control rods withdrawn simultaneously (rod withdrawal accident) is given in Figure 4-55.

Calculation of control rod reactivity worth versus time following reactor trip involves both control rod velocity and differential reactivity worth. The rod position versus time of travel after rod release normalized to "Distance to top of Dashpot" and "Drop time to Dashpot" is discussed in Chapter 15 for hybrid RCC material. For nuclear design purposes, the reactivity worth versus rod position is calculated by a series of steady state calculations at various control rod positions assuming all rods out of the core as the initial position in order to minimize the initial reactivity insertion rate. Also to be conservative, the rod of highest worth is assumed stuck out of the core and the flux distribution (and thus reactivity importance) is assumed to be skewed to the bottom of the core. The result of these calculations is discussed in Chapter 15.

The shutdown groups provide additional negative reactivity to assure an adequate shutdown margin. Shutdown margin is defined as the amount by which the core would be subcritical at hot shutdown if all rod cluster control assemblies are tripped, but assuming that the highest worth rod remains fully withdrawn and no changes in xenon or boron take place. However, with all rod control cluster assemblies verified to be fully inserted by two independent means, it is not necessary to account for a stuck rod control cluster assembly in the SDM calculation. The loss of control rod worth due to the material irradiation is negligible since only bank D is slightly inserted in the core under normal operating conditions.

The values given in Table 4-7 show that the available reactivity in withdrawn rod cluster control assemblies provides the design bases minimum shutdown margin allowing for the highest worth cluster to be at its fully withdrawn position. An allowance for the uncertainty in the calculated worth of N-1 rods and the effects of transient xenon are made before determination of the shutdown margin.

4.3.2.6 Criticality of the Reactor During Refueling and Criticality of Fuel Assemblies

Criticality of fuel assemblies outside the reactor is precluded by adequate design of fuel transfer, shipping and storage facilities and by administrative control procedures. The two principal methods of preventing criticality are limiting the fuel assembly array size and limiting assembly interaction by fixing the minimum separation between assemblies and/or inserting neutron poisons between assemblies.

The design basis for preventing criticality outside the reactor is that, considering possible variations, there is a 95 percent probability at a 95 percent confidence level that the effective multiplication factor (k_{eff}) of the fuel assembly array will be less than or equal to 0.95 as recommended in ANSI/ANS-57.2-1983. The conditions that are assumed in meeting this design basis are outlined in Section 9.1.2.3.1.2.

The analysis method used to ensure the criticality safety of fuel assemblies is dependent on the conditions being analyzed.

These methods conform to ANSI N18.2-1973, "Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants," Section 5.7; ANSI/ANS-57.2-1983, "Design Requirements for LWR Spent Fuel Storage Facilities at Nuclear Power Stations," Section 6.4.2.2; ANSI N16.9-1975, "NRC Standard Review Plan," Section 9.1.2; and the NRC guidance, "Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light Water Reactor Power Plants" contained in an NRC memo from Laurence Kopp dated August 19, 1998.

4.3.2.6.1 New Fuel Vault Criticality Analysis Methodology

The new fuel vaults are designed exclusively for temporary storage of fresh unirradiated fuel. ANSI/ANS - 57.3 - 1983, "Design Requirements for New LWR Fuel Storage Facilities", simply requires that k_{eff} be maintained at less than or equal to 0.98 under optimum moderation conditions. Analysis used to determine k_{eff} in these storage racks must therefore assume maximum allowable fuel enrichments. Criticality control relies strictly on the wide spacing between individual storage locations and a specified upper limit for as-built fuel assembly enrichment. The absence of other factors such as soluble boron, fixed poisons, burnup effects, and fission products makes for a relatively straightforward analysis. The normally dry condition of the fuel vaults introduces the possibility of water intrusion. Consequently, full density water flooding was conservatively modeled as a normal condition in this analysis. Other less likely events which could create low density moderator conditions (i.e. foaming, misting, etc.) dictated analysis of optimum moderator conditions as an accident condition. Vault criticality analysis is therefore performed as a function of both enrichment and moderator density.

The SCALE Version 4.4 system of computer codes (Reference 63) was employed for the new fuel vault criticality analyses. These calculations used the CSAS25 sequence of codes in the Criticality Safety Analysis Sequences (CSAS) control module in SCALE 4.4. The CSAS25 control sequence first runs two processing codes (BONAMI for resonance self-shielding, and NITAWL-II to produce a working transport cross-section library) before performing the criticality calculations on the new fuel vault model with KENO V.a (a 3-D Monte Carlo criticality code) to determine a system k_{eff} . The new fuel vault criticality calculations used the SCALE-4.4 238-group neutron library based on ENDF-B Version 5 data.

To demonstrate the validity of SCALE-4.4 for performing criticality calculations, a set of critical experiments was evaluated to establish an appropriate method bias and uncertainty. These critical experiments are summarized in Table 4-8. They include a diverse group of water-moderated, uranium oxide fuel rod arrays, separated by various materials. The experiments are

representative of LWR storage conditions, including the Catawba new and spent fuel storage racks.

A total of 41 of the 58 critical experiments in Table 4-8 – those at the highest enrichment of 4.31 wt % U-235 – were selected for determination of a method bias and uncertainty to be applied to the maximum 95/95 k_{eff} calculations for the Catawba new fuel storage racks. SCALE-4.4 calculations for these experiments yielded a benchmark bias of +0.0061 Δ k (average under-prediction of k_{eff}) and an uncertainty of $\pm 0.0071\Delta$ k.

4.3.2.6.2 Spent Fuel Storage Rack Criticality Analysis Methodology

The Catawba SFPs are designed to store fresh and irradiated fuel assemblies in a wet, borated environment. The SFPs consist of a uniform array of storage cells of equivalent spacing, and are designed to store both fresh and irradiated fuel assemblies.

SCALE-4.4 (described in Section 4.3.2.6.1) was used to evaluate storage of LEU fuel assemblies at maximum enrichment (5.0 wt % U-235) and with no credit taken for fuel assembly irradiation (burnup). A total of 41 of the 58 critical experiments in Table 4-8 – those at the highest enrichment of 4.31 wt % U-235 – were selected for determination of a method bias and uncertainty to be applied to the maximum 95/95 k_{eff} calculations for the Catawba SFPs. SCALE-4.4 calculations for these experiments yielded a benchmark bias of +0.0061 Δ k (average under-prediction of k_{eff}) and an uncertainty of $\pm 0.0071\Delta$ k.

The SFP criticality analysis was performed with partial credit for soluble boron, in accordance with 10 CFR 50.68(b)(4) and the NRC memo from Laurence Kopp – “Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light Water Reactor Power Plants,” – dated August 19, 1998. The maximum 95/95 k_{eff} , including all pertinent biases and uncertainties, is less than 1.0 in unborated water, and less than 0.95 with 200 ppm soluble boron. Additional details of the method used can be found in Reference 64.

The criticality analysis methodology differs for storing MOX fuel assemblies in the Catawba SFPs, and is addressed in Reference 65.

4.3.2.6.2.1 Spent Fuel Storage Rack Sub-Region Interface Criticality Analysis Methodology

Because the Catawba SFPs have two defined fuel storage configurations – one for LEU fuel and one for MOX fuel (Reference 65) – it is important to examine the reactivity effects of storing one storage configuration next to another. This analysis is performed to determine if there is a need for administrative restrictions at the boundaries.

SCALE-4.4 (described in Section 4.3.2.6.1) was used to evaluate storage of LEU fuel adjacent to the storage configuration of MOX fuel assemblies. Acceptable interface boundary conditions between storage configurations were obtained by varying the boundaries between the two storage regions to determine the worst case configurations for coupling between assemblies in different regions. The boundaries were then reflected to simulate an infinite array. The k_{eff} of these infinite boundary arrays were compared to the base k_{eff} of infinite arrays of either fuel region creating the boundary. Where the infinite boundary k_{eff} exhibited an increase relative to the k_{eff} of the regions comprising the boundary, conservative storage restrictions were imposed at the interface.

4.3.2.7 Stability

4.3.2.7.1 Introduction

The stability of the PWR cores against xenon-induced spatial oscillations and the control of such transients are discussed extensively in References 6, 14, 15, and 16. The design bases are given in Section 4.3.1.6.

In a large reactor core, xenon-induced oscillations can take place with no corresponding change in the total power of the core. The oscillation may be caused by a power shift in the core which occurs rapidly in comparison with the xenon-iodine time constants. Such a power shift occurs in the axial direction when a plant load change is made by control rod motion and results in a change in the moderator density and fuel temperature distributions. Such a power shift could occur in the diametral plane of the core as a result of abnormal control action.

Due to negative power coefficient of reactivity, PWR cores are inherently stable to oscillations in total power. Protection against total power instabilities is provided by the Control and Protection System as described in Section 7.7. Hence, the discussion on the core stability will be limited here to xenon-induced spatial oscillations.

4.3.2.7.2 Stability Index

Power distributions, either in the axial direction or in the X-Y plane, can undergo oscillations due to perturbations introduced in the equilibrium distributions without changing the total core power. The overtones in the current PWRs, and the stability of the core against xenon-induced oscillations can be determined in terms of the eigenvalues of the first flux overtones. Writing, either in the axial direction or in the X-Y plane, the eigenvalue ξ of the first flux harmonic as:

$$\xi = b + ic, \quad \text{Equation 4.3-1}$$

then b is defined as the stability index and $T = 2\pi/c$ as the oscillation period of the first harmonic. The time-dependence of the first harmonic $\delta\phi$ in the power distribution can now be represented as:

$$\delta\phi(t) = Ae^{\xi t} = ae^{bt} \cos ct, \quad \text{Equation 4.3-2}$$

where A and a are constants. The stability index can also be obtained approximately by:

$$b = \frac{1}{T} \ln \frac{A_{n+1}}{A_n} \quad \text{Equation 4.3-3}$$

where A_n , A_{n+1} are the successive peak amplitudes of the oscillation and T is the time period between the successive peaks.

4.3.2.7.3 Prediction of the Core Stability

Analysis of both the axial and X-Y xenon transient tests and actual axial xenon transients, discussed in Section 4.3.2.7.5, show that the calculational model is adequate for the prediction of core stability.

4.3.2.7.4 Stability Measurements

1. Axial Measurements

Two axial xenon transient tests conducted in a PWR with a core height of 12 feet and 121 fuel assemblies are reported in Reference 17, and will be briefly discussed here. The tests were performed at approximately 10 percent and 50 percent of cycle life.

Both a free-running oscillation test and a controlled test were performed during the first test. The second test at mid-cycle consisted of a free-running oscillation test only. In each of the free-running oscillation tests, a perturbation was introduced to the equilibrium power distribution through an impulse motion of the control bank D and the subsequent oscillation period. In the controlled test conducted early in the cycle, the part length rods were used to follow the oscillations to maintain an axial offset within the prescribed limits. The axial offset of power was obtained from the excore ion chamber readings (which has been calibrated against the incore flux maps) as a function of time for both free-running tests as shown in Figure 4-58.

The total core power was maintained constantly during these spatial xenon tests, and the stability index and the oscillation period were obtained from a least-square fit of the axial offset data in the form of Equation (4.3-2). The axial offset of power is the quantity that properly represents the axial stability in the sense that it essentially eliminates any contribution from even order harmonics including the fundamental mode. The conclusions of the tests are:

- a. The core was stable against induced axial xenon transients both at the core average burnups of 1550 MWD/MTU and 7700 MWD/MTU. The measured stability indices are -0.041 hr^{-1} for the first test (Curve 1 of Figure 4-58 and -0.014 hr^{-1} for the second test (Curve 2 of Figure 4-58). The corresponding oscillation periods are 32.4 hrs. and 27.2 hrs., respectively.
 - b. The reactor core becomes less stable as fuel burnup progresses and the axial stability index was essentially zero at 12,000 MWD/MTU.
2. Measurements in the X-Y Plane

Two X-Y xenon oscillation tests were performed at a PWR plant with a core height of 12 feet and 157 fuel assemblies. The first test was conducted at a core average burnup of 1540 MWD/MTU and the second at a core average burnup of 12900 MWD/MTU. Both of the X-Y xenon tests show that the core was stable in the X-Y plane at both burnups. The second test shows that the core became more stable as the fuel burnup increased and all Westinghouse PWRs with 121 and 157 assemblies are expected to be stable throughout their burnup cycles.

In each of the two X-Y tests, a perturbation was introduced to the equilibrium power distribution through an impulse motion of one rod cluster control unit located along the diagonal axis. Following the perturbation, the uncontrolled oscillation was monitored using the moveable detector and thermocouple system and the excore power range detectors. The quadrant tilt difference (QTD) is the quantity that properly represents the diametral oscillation in the X-Y plane of the reactor core in that the differences of the quadrant average powers over two symmetrically opposite quadrants essentially eliminates the contribution to the oscillation from the azimuthal mode. The QTD data were fitted in the form of Equation (4.3-2) through a least-square method. A stability index of -0.076 hr^{-1} with a period of 29.6 hours was obtained from the thermocouple data shown in Figure 4-59.

It was observed in the second X-Y xenon test that the PWR core with 157 fuel assemblies had become more stable due to an increased fuel depletion and the stability index was not determined.

4.3.2.7.5 Comparison of Calculations with Measurements

The analysis of the axial xenon transient tests was performed in an axial slab geometry using a flux synthesis technique. The direct simulation of the axial offset data was carried out using the PANDA code (Reference 18). The analysis of the X-Y xenon transient tests was performed in an X-Y geometry using a modified TURTLE (Reference 47) code. Both the PANDA and TURTLE codes solve the two-group time-dependent neutron diffusion equation with time-dependent xenon and iodine concentrations. The fuel temperature and moderator density feedback is limited to a steady-state model. All the X-Y calculations were performed in an average enthalpy plane.

The basic nuclear cross-sections used in this study were generated from a unit cell depletion program which has evolved from the codes LEOPARD (Reference 48) and CINDER (Reference 20). The detailed experimental data during the tests including the reactor power level, enthalpy rise and the impulse motion of the control rod assembly, as well as the plant follow burnup data were closely simulated in the study.

The results of the stability calculation for the axial tests are compared with the experimental data in Table 4-9. The calculations show conservative results for both of the axial tests with a margin of approximately -0.01 hr^{-1} in the stability index.

Deleted Paragraph(s) Per 2001 Update.

An analytical simulation of the first X-Y xenon oscillation test shows a calculated stability index of

-0.081 hr^{-1} , in good agreement with the measured value of -0.076 hr^{-1} . As indicated earlier, the second X-Y xenon test showed that the core had become more stable compared to the first test and no evaluation of the stability index was attempted. This increase in the core stability in the X-Y plane due to increased fuel burnup is due mainly to the increased magnitude of the negative moderator temperature coefficient.

Previous studies of the physics of xenon oscillations are reported in the series of topical reports, References 14, 15, and 16. A more detailed description of the experimental results and analysis of the axial and X-Y xenon transient tests is presented in Reference 17 and Section 1 of Reference 21.

4.3.2.7.6 Stability Control and Protection

The excore detector system is utilized to provide indications of xenon-induced spatial oscillations. The readings from the excore detectors are available to the operator and also form part of the protection system.

1. Axial Power Distribution

For maintenance of proper axial power distributions, the operator is instructed to maintain an axial offset within a prescribed operating band, based on the excore detector readings. Should the axial offset be permitted to move far enough outside this band, the protection limit will be reached and the power will be automatically reduced.

Twelve foot PWR cores become less stable to axial xenon oscillations as fuel burnup increases. Instabilities may occur near BOC of a reload cycle, assuming that no operator action is performed to mitigate the consequences of the xenon oscillation. However, free xenon oscillations are not permitted to occur except for special tests. The full length control rod banks are sufficient to dampen and control any axial oscillations present. Should the axial offset be inadvertently permitted to move far enough outside the control band due to an

axial xenon oscillation, or any other reason, the protection limit on axial offset will be reached and the power will automatically be reduced.

2. Radial Power Distribution

The core described herein is calculated to be stable against X-Y xenon induced oscillations at all times in life.

The X-Y stability of large PWRs has been further verified as part of the startup physics test program for PWR cores with 193 fuel assemblies. The measured X-Y stability of the cores with 157 and 193 assemblies was in good agreement with the calculated stability as discussed in Sections 4.3.2.7.4 and 4.3.2.7.5. In the unlikely event that X-Y oscillations occur, actions can be taken, to increase the natural stability of the core. This is based on the fact that several actions could be taken to make the moderator temperature coefficient more negative, which will increase the stability of the core in the X-Y plane.

Provisions for protection against asymmetric perturbations in the X-Y power distribution that could result from equipment malfunctions are made in the protection system design. This includes control rod drop, rod misalignment and asymmetric loss of coolant flow.

A more detailed discussion of the power distribution control in PWR cores is presented in References 6 and 7.

4.3.2.8 Vessel Irradiation

A brief review of the methods and analyses used in the determination of neutron and gamma ray flux attenuation between the core and the pressure vessel is given below. A more complete discussion on the pressure vessel irradiation and surveillance program is given in Section 5.3.

The materials that serve to attenuate neutrons originating in the core and gamma rays from both the core and structural components consist of the core baffle, core barrel, neutron pads and associated water annuli all of which are within the region between the core and the pressure vessel.

In general, few group neutron diffusion theory codes or advanced nodal codes are used to determine fission power density distributions within the active core and the accuracy of these analyses is verified by incore measurements on operating reactors. Region and rodwise power sharing information from the core calculations is then used as source information in two-dimensional S_n transport calculations which compute the flux distributions throughout the reactor.

The neutron flux distribution and spectrum in the various structural components varies significantly from the core to the pressure vessel. Representative values of the neutron flux distribution and spectrum are presented in Table 4-10. The values listed are based on time averaged equilibrium cycle reactor core parameters and power distributions; and thus, are suitable for long term nvt projections and for correlation with the radiation damage estimates.

As discussed in Section 5.3, the irradiation surveillance program utilizes actual test samples to verify the accuracy of the calculated fluxes at the vessel.

4.3.3 Analytical Methods

A description of the methodologies and computer codes used in the evaluation of the reactor core designs are described in the topical reports titled "Nuclear Physics Methodology for Reload Design" (Reference 19), "Nuclear Design Methodology Using CASMO-3/SIMULATE -3P" (Reference 10), "Nuclear Design Methodology Using CASMO-4/SIMULATE-3 MOX" (Reference

22), and also in Reference 45 and 55. These methodologies are NRC approved to perform nuclear design analyses and either CASMO-3P/SIMULATE-3P (Reference 10) or CASMO-4/SIMULATE-3 MOX (Reference 22) methods are applicable to low enriched uranium (LEU) fuel analyses. The transition to CASMO-4/SIMULATE-3 MOX methods is required to model cores containing mixed oxide fuel (MOX) within the limitation specified in the safety evaluation contained in Reference 22 or to model cores with fuel containing gadolinia. This methodology is also applicable to cores containing only LEU fuel. Since many generic analyses were performed with CASMO-3/SIMULATE-3P methods, this methodology will be retained in the UFSAR even after transition. An overview of the nuclear design analyses performed as part of the licensing basis of each reload core design follows. Details pertaining to the analyses performed can be found in the referenced topical reports.

The design of a reload core initially requires the development of a preliminary loading pattern which satisfies desired energy, feed batch size and enrichment requirements. Following this initial step, analyses are performed to ensure that applicable safety, fuel mechanical and thermal limits are also satisfied. Calculation of these limits are performed using NRC approved thermal hydraulic, system thermal hydraulic (e.g. RETRAN) and space-time kinetics transient analysis codes. A conservative set of safety, mechanical or thermal limits are determined and assured through the selection of conservative initial conditions, boundary conditions, code options, key physics parameters and core thermal hydraulic models. Key physics parameters, which are identified for each analysis, are calculated for each reload core and verified to be bounded by the values used in the licensing analysis. The confirmation cycle-specific values of the key physics parameters relative to the values used in the licensing analysis ensures that the analyses performed to establish safety, mechanical and thermal limits bound the reload core. The method employed to select the key physics parameters important to each Chapter 15 event are described in References 45 and 46.

4.3.3.1 Computer Codes

The methodology used to perform reload design nuclear calculations is based on CASMO-3 and SIMULATE-3. The computer codes used are described as follows.

CASMO-3 is a multigroup two-dimensional transport theory code for fuel assembly burnup calculations. It uses a library of 40 or 70 energy group cross sections based primarily on the ENDF/B-IV data base. Certain data used in the CASMO-3 library, such as the Xe-135 yields and fission spectra data for U-235 and Pu-239, are taken from ENDF/B-V. CASMO-3 produces two-group cross sections, assembly discontinuity factors, fission product data, detector reaction rates, and pin power data. The data from CASMO-3 is reformatted into two- or three-dimensional tables using a data processing program, TABLES-3, for input to the three-dimensional code SIMULATE-3. SIMULATE-3 interpolates the data from TABLES-3 for the independent variables for certain core conditions that SIMULATE-3 models.

SIMULATE-3 is a two-group three-dimensional coarse mesh diffusion theory code based on the QPANDA neutronics model. SIMULATE-3 accounts for the effects of fuel and moderator temperature feedback using a nodal thermal-hydraulics model. The program explicitly models the baffle and reflector region. The program uses data from CASMO-3 for each pin in the fuel assembly and uses inter-assembly and intra-assembly data obtained from the coarse mesh solution to reconstruct the power distribution for each pin.

The primary uses of this program include the calculation of critical boron concentrations, control rod worths, reactivity coefficients, boron worths, kinetics data and the time dependent behavior of the xenon distribution following a change in reactor power, or perturbation in the three-

dimensional power distribution. Shutdown margin, and ejected and stuck rod worth calculations are also performed with SIMULATE-3.

The capability of the SIMULATE-3 code to predict measured power distributions has been demonstrated by comparisons between measured and predicted power distributions as described in Reference 10. The capability of SIMULATE-3 to predict pin power distributions has been demonstrated through comparison of measured and predicted pin powers for the B&W critical experiments. These comparisons are also described and discussed in Reference 10.

Predicted versus measured reactivity comparisons are contained in Reference 10 and are also performed as part of the startup and physics testing program at the beginning of each cycle. The predictive capability of SIMULATE-3 is also assessed through core follow power distribution and critical boron concentration comparisons and the evaluation of startup conditions following a reactor trip.

The estimated accuracy of these analytical methods are described in the appropriate Topical Reports (References 10, 22, and 55.)

4.3.3.2 Computer Codes For Method 2

Another methodology used to perform reload design nuclear calculations is based on CASMO-4 and SIMULATE-3 MOX. This methodology is similar to CASMO-3/SIMULATE-3P methodology described in Section 4.3.3.1 with additional capabilities included to model mixed oxide (MOX) fuel. The CASMO-4/SIMULATE-3 MOX methodology is also used to model reactor cores with fuel containing gadolinia. The computer codes used are described as follows.

CASMO-4 is a multigroup two-dimensional transport theory code for fuel assembly burnup calculations. It uses a library of 70 energy group cross sections based primarily on the ENDF/B-IV data base. Certain data used in the CASMO-4 library, such as the Xe-135 yields, and fission spectra data for U-235 and Pu-239, as well as data for Ag, Gd, Er, and Tm are taken from ENDF/B-V. Data for Pu-241 was taken from JENDL-2. This code produces two-group cross sections, assembly discontinuity factors, fission product data, detector reaction rates, and pin power data. The data from CASMO-4 is reformatted into two- or three-dimensional tables using a data processing program, CMS-LINK, for input to the three-dimensional code SIMULATE-3 MOX. SIMULATE-3 MOX interpolates the data from CMS-LINK for the independent variables for certain core conditions that SIMULATE-3 MOX models.

SIMULATE-3 MOX is a two-group three-dimensional coarse mesh diffusion theory code based on the QPANDA neutronics model. SIMULATE-3 MOX includes enhancements to model the steep thermal flux gradient between MOX and LEU fuel and is applicable for analysis of cores containing LEU fuel with and without gadolinia or cores containing LEU fuel and MOX LTA fuel. SIMULATE-3 MOX accounts for the effects of fuel and moderator temperature feedback using its nodal thermal-hydraulics model. The program explicitly models the baffle and reflector region. The program uses data from CASMO-4 for each pin in the fuel assembly and uses inter-assembly and intra-assembly flux data obtained from the coarse mesh solution to reconstruct the power distribution for each pin.

The primary uses of this program include the calculation of critical boron concentrations, control rod worths, reactivity coefficients, boron worths, kinetics data and the time dependent behavior of the xenon distribution following a change in reactor power, or perturbation in the three-dimensional power distribution. Shutdown margin, and ejected and stuck rod worth calculations are also performed with this code.

The capability of the SIMULATE-3 MOX code to predict measured power distributions in LEU, gadolinia and MOX core designs has been demonstrated by comparisons between measured

and predicted power distributions as described in Reference 22. The capability of SIMULATE-3 MOX to predict pin power distributions has been demonstrated through comparison of measured and predicted pin powers for the B&W critical experiments for LEU, LEU fuel containing gadolinia and three MOX critical experiments for MOX fuel. These comparisons are described in Reference 22.

Predicted versus measured reactivity comparisons are contained in Reference 22 and are also performed as part of the startup and physics testing program at the beginning of each cycle. The predictive capability of SIMULATE-3 MOX is also assessed through core follow power distribution and critical boron concentration comparisons and the evaluation of startup conditions following a reactor trip.

Based on comparison with measured data, it is estimated that the accuracy of current analytical methods is:

- ±0.2 percent $\Delta\rho$ for the Doppler power defect
- ±2 pcm/°F for moderator temperature coefficient
- ±50 ppm for critical boron concentration with depletion
- ±3 percentg for power distributions
- ±0.2 percent $\Delta\rho$ for rod bank worth
- ±4 pcm/step for the differential rod worth
- ±0.5 pcm/ppm for boron worth
- ±0.1 percent $\Delta\rho$ for the moderator defect

4.3.4 Deleted Per 2004 Update

Fuel Temperature (Doppler) Calculations UFSAR Section was removed per 2004 Update. See Section 4.3.5 Changes for details.

4.3.5 Changes

Section 4.3.4, Fuel Temperature (Doppler) Calculations was removed for the following reasons:

1. It is not a major area of nuclear design, such as Section 4.3.1 – Design Bases, Section 4.3.2 – Description, and Section 4.3.3 – Analytical Methods. It is not required as part of Reg Guide 1.70, Standard Format.
2. The utilization of fuel temperature data in a reactor physics code should appropriately characterize core reactivity and feedback effects. The primary function of a fuel performance code is to conservatively characterize the fuel temperature from a mechanical point of view. Although a fuel performance code may be used to develop fuel temperature data for use in a reactor physics code, it is intended that the use of fuel temperature data will appropriately characterize neutronic behavior.
3. Topical Report DPC-NF-2010, contained a description of the generation of fuel temperature data used as input to the neutronics code. This statement was removed, and the NRC approved Revision 2 of this topical report by letter dated June 24, 2003.
4. The fuel temperature data used within SIMULATE-3 is developed from data derived from the fuel rod thermal model within SIMULATE-3K.

4.3.6 References

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

1. *"Westinghouse Anticipated Transients Without Reactor Trip Analysis"*, WCAP-8330, August 1974.
2. *Spier, E.M., "Evaluation of Nuclear Hot Channel Factor Uncertainties"*, WCAP-7308-L-P-A (Proprietary) June 1988 and WCAP-7810-A, June 1988.
3. Deleted Per 1998 Update.
4. Deleted Per 1998 Update.
5. Deleted Per 1998 Update.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

6. *Moore, J. S., "Power Distribution Control of Westinghouse Pressurized Water Reactors"*, WCAP-7208 (Proprietary), September 1968 and WCAP-7811, December 1971.
7. *Morita, T., et al., "Topical Report, Power Distribution Control and Load Following Procedures"*, WCAP-8385 (Proprietary) and WCAP-8403, September 1974.
8. Deleted Per 1998 Update.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

9. *McFarlane, A. F., Topical Report "Power Peaking Factors"*, WCAP-7912-P-A (Proprietary) and WCAP-7912-A, January 1975.
10. DPC-NE-1004A, Rev. 1, "Design Methodology Using CASMO-3/SIMULATE-3P", SER Rev. 1a Dated April 1996.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

11. *Cermak, J. O., et al., "Pressurized Water Reactor pH - Reactivity Effect Final Report"*, WCAP-3696-8 (EURAE-2074), October 1968.
12. *Strawbridge, L. E. and Barry, R. F., "Criticality Calculation for Uniform Water-Moderated Lattices"*, Nucl. Sci. and Eng. 23, 58 (1965).
13. Deleted Per 1998 Update.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

14. *Poncelet, C. G. and Christie, A. M., "Xenon-Induced Spatial Instabilities in Large Pressurized Water Reactors"*, WCAP-3680-20, (EURAE-1974), March 1968.
15. *Skogen, F. B. and McFarlane, A. F., "Control Procedures for Xenon-Induced X-Y Instabilities in Large Pressurized Water Reactors"*, WCAP-3680-21, (EURAE-2111), February 1969.
16. *Skogen, F. B. and McFarlane, A. F., "Xenon-Induced Spatial Instabilities in Three-Dimensions"*, WCAP-3680-22 (EURAE-2116), September 1969.
17. *Lee, J. C., et al., "Axial Xenon Transient Tests at the Rochester Gas and Electric Reactor"*, WCAP-7964, June 1971.
18. *Altomare, S. and Minton, G., "The PANDA Code"*, WCAP-7048-P-A (Proprietary) and WCAP-7757-A, February 1975.
19. DPC-NE-2010A, "Duke Power Company McGuire Nuclear Station, Catawba Nuclear Station Nuclear Physics Methodology for Reload Design", Rev. 2, June 24, 2003.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

20. *England, T. R., "CINDER - A One-Point Depletion and Fission Product Program", WAPD-TM-334, August 1962.*
21. *Eggleston, F. T., "Topical Report Safety-Related Research and Development for Westinghouse Pressurized Water Reactors, Program Summaries, Spring 1976", WCAP-8768, June 1976.*
22. DPC-NE-1005-P-A, Rev 01, "Nuclear Design Methodology using CASMO-4/SIMULATE-3 MOX", SER dated November 12, 2008.
23. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.126, "An Acceptable Model and Related Statistical Methods for the Analysis of Fuel Densification," Revision 1, March 1978.
24. Deleted Per 1998 Update.
25. Deleted Per 1998 Update.
26. Deleted Per 1998 Update.
27. Deleted Per 1998 Update.
28. Deleted Per 1998 Update.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

29. *Nodvik, R. J. "Saxton Core II Fuel Performance Evaluation, Part II, "Evaluation of Mass Spectrometric and Radiochemical Analyses of Irradiated Saxton Plutonium Fuel", WCAP-3385-56 Part II July 1970.*
30. Deleted Per 1998 Update.
31. Deleted Per 1998 Update.
32. Deleted Per 2007 Update.
33. Deleted Per 2007 Update.
34. Deleted Per 2007 Update.
35. Deleted Per 2007 Update.
36. Deleted Per 2007 Update.
37. Deleted Per 2007 Update.
38. Duke Power Company, "DETECTOR User's Manual", COM-0204.C6-10-0197, March, 1993.
39. Deleted Per 1998 Update.
40. Deleted Per 1998 Update.
41. Deleted Per 1998 Update.
42. Deleted Per 1998 Update.
43. DPC-NE-2011P-A, "Duke Power Company Nuclear Design Methodology for Core Operating Limits of Westinghouse Reactors," Rev. 1, Oct. 1, 2002 (DPC Proprietary).
44. DPC-NE-2004P-A, Rev. 1, "Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology using VIPRE-01," SER dated February 20, 1997 (DPC Proprietary).
45. DPC-NE-3001P-A, "Multidimensional Reactor Transients and Safety Analysis Physics Parameters Methodology", November, 1991 (DPC Proprietary).

46. DPC-NE-3002-A, Through Rev. 4 "FSAR Chapter 15, System Transient Analysis Methodology," SER dated April 6, 2001.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

47. *Altomare, S. and Barry, R. F., "The TURTLE 24.0 Diffusion Depletion Code", WCAP-7213-P-A (Proprietary) and WCAP-7758-A, February 1975.*

48. *Barry, R. F., "LEOPARD - A Spectrum Dependent Non-Spatial Depletion Code for the IBM-7094", WCAP-3269-26, September 1963.*

49. Deleted Per 1998 Update.

50. Duke Energy, "Core Monitoring and Evaluation of Technical Specifications", Documented in AD-IT-ALL-0002, Software Qualification Assurance (SDQA) Program Administration.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

51. *DPC-NE-2008P-A, "Fuel Mechanical Reload Analysis Methodology Using TACO3", SER dated April 3, 1995 (DPC Proprietary).*

52. Nuclear Regulatory Commission, Letter to All Holders of Operating Licenses or Construction Permits for Pressurized Water Reactors, November 21, 1989, NRC Bulletin No. 89-03, "Potential Loss of Required Shutdown Margin During Refueling Operations."

53. Duke Power Company, Letter from H.B. Tucker to NRC, January 26, 1990, re: Response to NRC Bulletin No. 89-03, "Potential Loss of Required Shutdown Margin During Refueling Operations."

54. Nuclear Regulatory Commission, Letter from D.B. Matthews to H.B. Tucker (DPC), March 5, 1990, re: Response to Bulletin 89-03 - Catawba, McGuire and Oconee Nuclear Stations (TACS 75413, 75414, 75433, 75434, 75439, 75440, and 75441).

55. DPC-NE-2009 P-A, "Westinghouse Fuel Transition Report," Rev. 2, Dec. 18, 2002.

56. Nuclear Regulatory Commission, Letter to All Holder of Operating Licenses or Contruction Permits for Pressurized Water Reactors, from C.E. Rossi, November 21, 1989, NRC Bulletin No. 89-03, "Potential Loss of Required Shutdown Margin During Refueling Operations."

57. Duke Power Company, Letter from H.B. Tucker to NRC, January 26, 1990, "Oconee Nuclear Station, Units 1, 2 and 3; Docket Nos. 50-269, 270, and 287, McGuire Nuclear Station, Units 1 and 2; Dockets Nos. 50-369 and 370, Catawba Nuclear Station, Units 1 and 2; Docket Nos. 50-412 and 414, Response to NRC Bulletin No. 89-03, Potential Loss of Required Shutdown Margin During Refueling Operations"

58. Nuclear Regulatory Commission, Letter from D.B. Matthews to H.B. Tucker (DPC), March 5, 1990, "response to Bulletin 89-03 - Catawba, McGuire and Oconee Nuclear stations (TACS 75413, 75414, 75343, 75434, 75439, 75440, and 75441)."

59. Deleted Per 2007 Update.

60. "Criticality Experiments with Subcritical Clusters of 2.35 Wt% and 4.31%²³⁵U Enriched UO₂ Rods in Water at a Water-to-Fuel Volume Ratio of 1.6," Pacific Northwest Laboratory, NUREG/CR-1547, PNL-3314, July 1980.

61. "Critical Separation Between Subcritical Clusters of 2.35 Wt%²³⁵U Enriched UO₂ Rods in Water with Fixed Neutron Poisons," Pacific Northwest Laboratory, PNL-2438, October 1977.

62. "Critical Experiments to Provide Benchmark Data on Neutron Flux Traps," S. R. Bierman, PNL-6205, June 1988.

63. Oak Ridge National Laboratory, SCALE 4.4 – A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation, NUREG/CR-0200 (Rev. 5), CCC-545, March 1997.
64. Letter from Dhiaa Jamil (Duke) to U.S. NRC, “Catawba Nuclear Station, Units 1 and 2, Proposed Technical Specification Amendment, Technical Specification 3.7.16, Spent Fuel Assembly Storage, and 4.3, Fuel Storage,” – September 13, 2005.
65. “Proposed Amendments to the Facility Operating License and Technical Specifications to Allow Insertion of Mixed Oxide (MOX) Fuel Lead Assemblies and Request for Exemption from Certain Regulations in 10 CFR Part 50,” Package Transmittal from M.S. Tuckman (Duke Power) to U.S. NRC Document Control Desk, February 27, 2003.
66. Nuclear Regulatory Commission Safety Evaluation Report for the adoption of Technical Specifications Task Force (TSTF) - 248 dated May 28th, 2010; License Amendments No. 254 for Catawba Unit 1 and No. 249 for Catawba Unit 2.

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.3.

4.4 Thermal and Hydraulic Design

4.4.1 Description

The Catawba Nuclear Station transition from Mark-BW fuel assembly to the 17 x 17 Robust Fuel Assembly (RFA) design for reload supplied fuel is discussed in Section 4.1. Thermal-hydraulic characteristics and analysis methods utilized in the licensing evaluation of the RFA are given in Reference 95 (DPC-NE-2009P-A).

This section will discuss the thermal-hydraulic characteristics of the Mark-BW and RFA designs.

4.4.1.1 Design Description

Table 4-1 provides the design parameters for the 17 x 17 Robust Fuel Assembly (RFA) design .

Deleted Paragraph(s) Per 2016 Update.

The RFA fuel design is based on the VANTAGE+ fuel assembly design, licensed by the NRC in Reference 96 (WCAP-12610P-A). The VANTAGE+ designed evolved from the VANTAGE 5 & 5H fuel assembly designs. The RFA design used at Catawba is described in Section 4.1.

Deleted Paragraph(s) Per 2016 Update.

4.4.1.2 Critical Heat Flux Ratio or Departure from Nucleate Boiling Ratio and Mixing Technology

The minimum DNBRs for the rated power, design overpower and anticipated transient conditions are given in Table 4-1. The minimum DNBR in the limiting flow channel will be downstream of the peak heat flux location (hot spot) due to the increased downstream enthalpy rise.

DNBRs are calculated by using the correlation and definitions described in the following Sections 4.4.1.2.1 and 4.4.1.2.2. The VIPRE-01 computer code (discussed in Section 4.4.4.5.1) is used to determine the flow distribution in the core and the local conditions in the hot channel for use in the DNB correlation. The use of hot channel factors is discussed in Section 4.4.4.3.1 (nuclear hot channel factors) and in Section 4.4.1.2.4 (engineering hot channel factors).

4.4.1.2.1 Departure from Nucleate Boiling Technology

Deleted Paragraph(s) Per 2016 Update.

The WRB-2M CHF correlation (Reference 97, WCAP-15025P-A) was developed by Westinghouse. The CHF correlation was developed from CHF data (241 points) on various test sections. These test sections simulated geometry and grid designs for both IFM and non-IFM heated spans. The WRB-2M CHF correlation (Reference 97) is appropriate for use in thermal-hydraulic analyses for the RFA. The WRB-2M correlation is applicable to the following range of variables:

Pressure	$1495 \leq P \leq 2425$ psia
Local Mass Velocity	$0.97 \leq G_{loc} \leq 3.1$ Mlbm / ft ² – hr
Local Quality	$-0.1 \leq X_{loc} \leq 0.29$

Heated Length	$L_h \leq 14$ feet
Grid Spacing	$10 \leq g_{sp} \leq 20.6$ inches
Equivalent Hydraulic Diameter	$0.37 \leq d_e \leq 0.46$ inches
Equivalent Heated Diameter	$0.46 \leq d_h \leq 0.54$ inches

The WRB-2M correlation will be used for Catawba RFA DNB analyses.

4.4.1.2.2 Definition of Departure from Nucleate Boiling Ratio (DNBR)

Deleted Paragraph(s) Per 2016 Update.

The DNB heat flux ratio (DNBR) as applied to the robust fuel assembly design for both the typical and thimble cold wall cells is:

$$\text{DNBR} = \frac{q''_{\text{DNB,N}}}{q''_{\text{loc}}}$$

Where:

$$q''_{\text{DNB,N}} = \frac{q''_{\text{DNB,EU}}}{F}$$

The above equation was revised in 2000 update.

and $q''_{\text{DNB,EU}}$ is the uniform critical heat flux as predicted by the WRB-2M DNB correlation, Reference 97.

F is the flux shape factor to account for nonuniform axial heat flux distributions, Reference 97.

4.4.1.2.3 Mixing Technology

The rate of heat exchange by mixing between flow channels is proportional to the difference in the local mean fluid enthalpy of the respective channels, the local fluid density, and flow velocity. The proportionality is expressed by the dimensionless thermal diffusion coefficient (TDC) which is defined as:

$$\text{TDC} = \frac{w'}{\rho V a}$$

where:

w = flow exchange rate per unit length, lbm/ft-sec

ρ = fluid density, lbm /ft³

V = fluid velocity, ft/sec

a = lateral flow area between channels per unit length, ft²/ft

The application of the TDC in the thermal-hydraulic analysis for determining the overall mixing effect or heat exchange rate is presented in Reference 7.

As a part of an ongoing research and development program, Westinghouse and directed mixing tests at Columbia University (Reference 13). These series of tests, using the "R" mixing vane

grid design on 13, 26 and 32 inch grid spacing, were conducted in pressurized water loops at Reynolds numbers similar to that of a PWR core under the following single and two phase (subcooled boiling) flow conditions:

Pressure	1500 to 2400 psia
Inlet temperature	332 to 642°F
Mass velocity	$1.0 \times 3.5 \times 10^6$ lbm/hr-ft ²
Reynolds number	1.34 to 7.45×10^5
Bulk outlet quality	-52.1 to-13.5%

TDC is determined by comparing the thermal hydraulic code predictions with the measured subchannel exit temperatures. Data for 26 inch axial grid spacing are presented in Figure 4-66 where the thermal diffusion coefficient is plotted versus the Reynolds number. TDC is found to be independent of Reynolds number, mass velocity, pressure and quality over the ranges tested. The two phase data (local, subcooled boiling) fell within the scatter of the single phase data. The effect of two-phase flow on the value of TDC has been demonstrated by Cadek (Reference 13), Rowe and Angle (References 14 and 15), and Gonzalez - Santalo and Griffith (Reference 16). In the subcooled boiling region, the values of TDC were indistinguishable from the single phase values. In the quality region, Rowe and Angle show that in the case with rod spacing similar to that in PWR reactor core geometry, the value of TDC increased with quality to a point and then decreased, but never below the single phase value. Gonzalez - Santalo and Griffith showed that the mixing coefficient increased as the void fraction increased.

The data from these tests on the "R" grid showed that a design TDC value of 0.038 (for 26 inch grid spacing) can be used in determining the effect of coolant mixing. This value for the TDC of 0.038 is applicable to analyses of RFA fuel assemblies with the VIPRE-01 code.

A mixing test program similar to the one described above was conducted at Columbia University for the 17 x 17 geometry and mixing vane grids on 26 inch spacing (Reference 17). The mean value of TDC obtained from these tests was 0.059 and all data were well above the current design value of 0.038.

In addition, since the actual reactor grid spacing is approximately 10 inches in the IFM grid spans for the RFA design, additional margin is available for this design (the value of TDC increases as grid spacing decreases per Reference 13).

4.4.1.2.4 Hot Channel Factors

The total hot channel factors for heat flux and enthalpy rise are defined as the maximum-to-core average ratios of these quantities. The heat flux hot channel factor considers the local maximum linear heat generation rate at a point (the hot spot), and the enthalpy rise hot channel factor involves the maximum integrated value along a channel (the hot channel).

Each of the total hot channel factors considers a nuclear hot channel factor (see Section 4.4.4.3) describing the neutron power distribution and an engineering hot channel factor, which allows for variations in flow conditions and fabrication tolerances. The engineering hot channel factors are made up of subfactors which account for the influence of the variations of fuel pellet diameter, density, enrichment and eccentricity; fuel rod diameter pitch and bowing; inlet flow distribution; flow redistribution; and flow mixing.

Heat Flux Engineering Hot Channel Factor, F_{Q}^E

The kW/ft engineering hot channel factor is used to evaluate the maximum linear heat generation rate in this core. This subfactor is determined by statistically combining the fabrication variances for the fuel pellet diameter, density, and enrichment and has a value of 1.03 at the 95 percent probability level with 95 percent confidence. No DNB penalty is taken for the short relatively low intensity heat flux spikes caused by variations in the above parameters, as well as fuel pellet eccentricity and fuel rod diameter variation per Reference 18.

Enthalpy Rise Engineering Hot Channel Factor, $F_{\Delta H}^E$

The effect of variations in flow conditions and fabrication tolerances on the hot channel enthalpy rise is directly considered in the VIPRE-01 core thermal subchannel analysis (See Section 4.4.4.5.1) under any reactor operating condition. The items considered contributing to the enthalpy rise engineering hot channel factor are discussed below:

1. Pellet diameter, density and enrichment and fuel rod diameter:

Variations in pellet diameter, density and enrichment and fuel rod diameter, are considered statistically in establishing the limit DNBRs (see Section 4.4.2.1) for the statistical core design methodology (Reference 92) employed in this application. Uncertainties in these variables are determined from sampling of manufacturing data.

2. Inlet Flow Maldistribution:

The consideration of inlet flow maldistribution in core thermal performances is discussed in Section 4.4.4.2.2. A design basis of 5 percent reduction in coolant flow to the hot assembly is used in the VIPRE-01 analysis.

3. Flow Redistribution:

The flow redistribution accounts for the reduction in flow in the hot channel resulting from the high flow resistance in the channel due to the local or bulk boiling. The effect of the non-uniform power distribution is inherently considered in the VIPRE-01 analysis for every operating condition which is evaluated.

4. Flow Mixing:

The subchannel mixing model incorporated in the VIPRE-01 Code and used in reactor design is based on experimental data. The mixing vanes incorporated in the spacer grid design induce additional flow mixing between the various flow channels in a fuel assembly as well as between adjacent assemblies. This mixing reduces the enthalpy rise in the hot channel resulting from local power peaking or unfavorable mechanical tolerances.

4.4.1.2.5 Effects of Rod Bow on DNBR

The phenomenon of fuel rod bowing, as described in References 82 and 89, must be accounted for in the DNBR safety analysis of Condition I and Condition II events for each plant application and fuel type. Applicable generic credits for margin resulting from retained conservatism in the evaluation of DNBR and/or margin obtained from measured plant operating parameters (such as $F_{\Delta H}^N$ or core flow)--which are more conservative than those required by the plant safety analysis--can be used to offset the effect of rod bow.

For the purpose of determining the amount of DNBR margin available to offset the rod bow penalties the following relationship must be applied:

$$\% \text{ DNBR Margin} = \left[\frac{\text{Design DNBR Limit}}{\text{Statistical DNBR Limit}} - 1 \right] \times 100 \%$$

Note: The above equation was revised in the 2000 update.

Deleted Paragraph(s) Per 2016 Update.

For Catawba RFA fuel application, using the WRB-2M correlation, the statistical DNBR limit is 1.30 while the design DNBR limit is 1.45.

The rod bow DNB penalty is calculated using WCAP-8691, Rev. 1 methodology (Reference 82).

The safety analysis for Catawba maintains sufficient margin between the design limit DNBR's and the statistical limit DNBR's (1.30) to accommodate the rod bow DNBR penalty identified in Reference 82, which is applicable to 17x17 RFA analysis utilizing the WRB-2M DNB correlation.

4.4.1.3 Linear Heat Generation Rate

The core average and maximum LHGRs are given in Table 4-1. The method of determining the maximum LHGR is given in Section 4.2.1.3.

4.4.1.4 Void Fraction Distribution

The calculated core average and the hot subchannel maximum and average void fractions are presented in Table 4-19 for operation at full power with design hot channel factors. The void models used in the VIPRE-01 computer code are described in Section 4.4.1.7.3.

4.4.1.5 Core Coolant Flow Distribution

The reactor coolant inlet flow distribution is a function of the flow profile exiting the lower internals of the reactor vessel. Once entering the fuel assemblies, the inlet flow distribution (pressure drop) and the radial core power distribution (density head) together determine the magnitude and direction of the crossflow. In the open lattice construction of a PWR core, there is lateral communication between all individual subchannels as well as fuel assemblies. Therefore, while localized pressure or density differences can exist, the effect is mitigated by the inherent characteristics of fluid flow. Due to this, no significant changes occur during core life and no orificing is necessary in the reactor design.

4.4.1.6 Core Pressure Drops and Hydraulic Loads

4.4.1.6.1 Core Pressure Drops

The analytical model and experimental data used to calculate the pressure drops shown in Table 4-1 are described in Section 4.4.1.7. The core pressure drop includes the fuel assembly, lower core plate, and upper core plate pressure drops. The full power operation pressure drop values shown in Table 4-1 are the unrecoverable pressure drops across the vessel, including the inlet and outlet nozzles, and across the core. These pressure drops are based on the best estimate flow for actual plant operating conditions as described in Section 5.1.1. This section also defines and describes the thermal design flow (minimum flow) which is the basis for reactor core thermal performance and the mechanical design flow (maximum flow) which is used in the mechanical design of the reactor vessel internals and fuel assemblies. Since the best estimate flow is that flow which is most likely to exist in an operating plant, the calculated core pressure drops in Table 4-1 are based on this best estimate flow rather than the thermal design flow.

Uncertainties associated with the core pressure drop values are discussed in Section 4.4.1.9.2.

The pressure drops quoted in Table 4-1 for the RFA are based on twelve grids. Reference 98 (WCAP-10144P-A) states that the addition of three IFM grids resulted in an increase in the

overall pressure drop in a VANTAGE 5 core when compared to the 17x17 OFA design. The increase in overall pressure drop for a 17x17 RFA and VANTAGE 5 cores are comparable.

4.4.1.6.2 Hydraulic Loads

The fuel assembly hold down springs are designed to keep the fuel assemblies in contact with the lower core plate under all Condition I and II events with the exception of the turbine overspeed transient associated with a loss of external load. The hold down springs are designed to tolerate the possibility of an over deflection associated with fuel assembly liftoff for this case and provide contact between the fuel assembly and the lower core plate following this transient. More adverse flow conditions occur during a loss of coolant accident. These conditions are presented in Chapter 15.

Hydraulic loads at normal operating conditions are calculated considering the mechanical design flow which is described in Section 5.1 and accounting for the minimum core bypass flow based on manufacturing tolerances. Core hydraulic loads at cold plant startup conditions are based on the cold mechanical design flow, but are adjusted to account for the coolant density difference. Conservative core hydraulic loads for a pump overspeed transient, which could possibly create flow rates 20 percent greater than the mechanical design flow, are evaluated to be approximately twice the fuel assembly weight.

Core hydraulic loads were measured during the prototype assembly tests described in Reference 5.

VANTAGE+ fuel assemblies were separately tested for hydraulic load capability and the results are reported in Reference 96 (WCAP-1260P-A). The RFA design is similar to the VANTAGE+ design with respect to the hydraulic load capability.

4.4.1.7 Correlation and Physical Data

4.4.1.7.1 Surface Heat Transfer Coefficients

Forced convection heat transfer coefficients are obtained from the familiar Dittus-Boelter correlation (Reference 90), with the properties evaluated at bulk fluid conditions:

$$\frac{hD_e}{K} = 0.023 \left(\frac{D_e G}{\mu} \right)^{0.8} \left(\frac{C_p \mu}{K} \right)^{0.4}$$

Where:

- h = heat transfer coefficient, BTU/hr-ft²-°F
- D_e = equivalent diameter, ft
- K = thermal conductivity, BTU/hr-ft-°F
- G = mass velocity, lbm/hr-ft²
- μ = dynamic viscosity, lbm/ft-hr
- C_p = heat capacity, BTU/lbm-°F

This correlation has been shown to be conservative (Reference 22) for rod bundle geometries with pitch to diameter ratios in the range used by PWRs.

The onset of nucleate boiling occurs when the clad wall temperature reaches the amount of superheat predicted by Thom's (Reference 23) correlation. After this occurrence the outer clad wall temperature is determined by:

$$\Delta t_{\text{sat}} = [0.072 \exp(-P/1260)] (q'')^{0.5}$$

where:

Δt_{sat} = wall superheat, $T_w - T_{\text{sat}}$, °F

q'' = wall heat flux, BTU/hr-ft²

p = pressure, psia

T_w = outer clad wall temperature, °F

T_{sat} = saturation temperature of coolant at P , °F

4.4.1.7.2 Total Core and Vessel Pressure Drop

Unrecoverable pressure losses occur as a result of viscous drag (friction) and/or geometry changes (form) in the fluid flow path. The flow field is assumed to be incompressible, turbulent, single-phase water. These assumptions apply to the core and vessel pressure drop calculations for the purpose of establishing the primary loop flow rate. Two-phase considerations are neglected in the vessel pressure drop evaluation because the core average void is negligible (see Table 4-19). Two phase flow considerations in the core thermal subchannel analyses are considered and the models are discussed in Section 4.1.7.1 of Reference 89. Core and vessel pressure losses are calculated by equations of the form:

$$\Delta P_L = \left(K + F \frac{L}{D_e} \right) \frac{\rho V^2}{2g_c} \quad (144)$$

where:

ΔP_L = unrecoverable pressure drop, lbf/in²

ρ = fluid density, lbf/ft³

L = length, ft

D_e = equivalent diameter, ft

V = fluid velocity, ft/sec

g_c = 32.174 lbf-ft/lbf-sec²

K = form loss coefficient, dimensionless

F = friction loss coefficient, dimensionless

Fluid density is assumed to be constant at the appropriate value for each component in the core and vessel. Because of the complex core and vessel flow geometry, precise analytical values for the form and friction loss coefficients are not available. Therefore, experimental values for these coefficients are obtained from geometrically similar models.

Values are quoted in Table 4-1 for unrecoverable pressure loss across the reactor vessel, including the inlet and outlet nozzles, and across the core. The pressure drop for the vessel was calculated based on as built vessel geometry.

Tests of the primary coolant loop flow rates were made (see Section 4.4.5.1) prior to initial criticality to verify that the flow rates used in the design, which were determined in part from the pressure losses calculated by the method described here, are conservative.

The core pressure drop includes the fuel assembly, lower core plate, and upper core plate pressure drops. The vessel is based on the full power operation pressure drop. This includes the unrecoverable pressure drops across the vessel, including the inlet and outlet nozzles, and across the core. These pressure drops are based on the best estimate flow for actual plant operating conditions as described in Section 5.1.1. The core and vessel pressure drops for RFA fuel are shown in Table 4-1.

4.4.1.7.3 Void Fraction Correlation

There are three separate void regions considered in flow boiling in a PWR as illustrated in Figure 4-70. They are the wall void region (no bubble detachment), the subcooled boiling region (bubble detachment) and the bulk boiling region.

Deleted Paragraph(s) Per 2016 Update.

In the wall void region, the point where local boiling begins is determined when the clad temperature reaches the amount of superheat predicted by Thom's (Reference 23) correlation (discussed in Section 4.4.1.7.1). The void fraction in this region is calculated using EPRI's (Reference 90) relationship. The bubble detachment point, where the superheated bubbles break away from the wall, is determined by using the EPRI subcooled boiling model (Reference 90).

The void fraction in the subcooled boiling region (that is, after the detachment point) is calculated from the EPRI (Reference 90) correlation. This correlation predicts the void fraction from the detachment point to the bulk boiling region.

The void fraction in the bulk boiling region is calculated from the EPRI (Reference 90) correlation. This model accounts for the effect of phase slip on void fraction.

4.4.1.8 Thermal Effects of Operational Transients

DNB core safety limits are generated as a function of coolant temperature, pressure, core power and axial and radial power distributions. Operation within these DNB safety limits insures that the DNB design basis is met for both steady-state operation and for anticipated operational transients that are slow with respect to fluid transport delays in the primary system. In addition, for fast transients, e.g., uncontrolled rod bank withdrawal at power incident (Chapter 15) specific protection functions are provided as described in Section 7.2 and the use of these protection functions is described in Chapter 15. The thermal response of the fuel is discussed in Section 4.2.4.3.

4.4.1.9 Uncertainties in Estimates

4.4.1.9.1 Uncertainties in Fuel and Clad Temperatures

Fuel temperatures are a function of crud, oxide, clad, gap, and pellet conductances. Uncertainties in the fuel temperature calculation are essentially of two types: fabrication uncertainties such as variations in the pellet and clad dimensions and the pellet density; and model uncertainties such as variations in the pellet conductivity and the gap conductance.

Deleted Paragraph(s) Per 2016 Update.

Uncertainties in the calculation of the fuel temperatures have been quantified by comparison of the thermal model to the in-pile thermocouple measurements, References [31](#) through [37](#), by out-of-pile measurements of the fuel and clad properties, References [38](#) through [49](#), and by measurements of the fuel and clad dimensions during fabrication. The resulting uncertainties are then used in all evaluations involving the fuel temperature. The effect of densification on fuel temperature uncertainties is presented in Reference [50](#). Uncertainties are accounted for in the RFA fuel melt analysis as explained in Section [4.2.4.1](#).

In addition to the temperature uncertainty described above for both designs, the measurement uncertainty in determining the local power, and the effect of density and enrichment variations on the local power are considered in establishing the heat flux hot channel factor. These uncertainties are described in Reference [100](#).

Reactor trip setpoints as specified in the Technical Specification include allowance for instrument and measurement uncertainties such as calorimetric error, instrument drift and channel reproducibility, temperature measurement uncertainties, noise, and heat capacity variations.

Uncertainty in determining the cladding temperatures results from uncertainties in the crud and oxide thicknesses. Because of the excellent heat transfer between the surface of the rod and the coolant, the film temperature drop does not appreciably contribute to the uncertainty.

4.4.1.9.2 Uncertainties in Pressure Drops

Core and vessel pressure drops based on the best estimate flow, as described in Section [5.1](#), are quoted in [Table 4-1](#). The uncertainties quoted are based on the uncertainties in the analytical extension of these values to the reactor application.

A major use of the core and vessel pressure drops is to determine the primary system coolant flow rates as discussed in Section [5.1](#). In addition, as discussed in Section [4.4.5.1](#), tests on the primary system prior to initial criticality verify that a conservative primary system coolant flow rate has been used in the design and analyses of the plant.

4.4.1.9.3 Uncertainties Due to Inlet Flow Maldistribution

The effects of uncertainties in the inlet flow maldistribution criteria used in the core thermal analyses is discussed in Section [4.4.4.2.2](#).

4.4.1.9.4 Uncertainty in DNB Correlation

The uncertainty in the DNB correlation (Section [4.4.1.2](#)) can be written as a statement of the probability of not being in DNB based on the statistics of the DNB data. The WRB-2M correlation uncertainty used in DNB analyses is given in Reference [97](#) (WCAP-15025P-A).

4.4.1.9.5 Uncertainties in DNBR Calculations

The uncertainties in the DNBRs calculated by VIPRE-01 analysis (see Section [4.4.4.5.1](#)) due to nuclear peaking factors are accounted for by applying conservatively high values of the nuclear peaking factors and including measurement error allowances in the statistical evaluation of the limit DNBR (see Section [4.4.2.1](#)). In addition, engineering hot channel factors are included in the SCD procedure as discussed in Section [4.4.1.2.4](#).

The ability of the VIPRE-01 computer code to accurately predict flow and enthalpy distributions in rod bundles is discussed in Section [4.4.4.5.1](#) and in Reference [90](#). Studies have been performed (Reference [89](#)) to determine the sensitivity of the minimum DNBR in the hot channel

to the void fraction correlation (see also Section [4.4.1.7.3](#)); the inlet velocity distribution assumed as boundary conditions for the analysis; and the turbulent momentum factor. The results of these studies show that the minimum DNBR in the hot channel is relatively insensitive to variations in these parameters. The range of variations considered in these studies covered the range of possible variations in these parameters. An uncertainty of 5% in DNBR is included in the design procedure to account for any VIPRE-01 Code uncertainty.

4.4.1.9.6 Uncertainties in Flow Rates

The uncertainties associated with loop flow rates are discussed in Section [5.1](#). A thermal design flow is defined for use in core thermal performance evaluations which accounts for both prediction and measurement uncertainties. In addition, a maximum of 8.5 percent of the Thermal Design Flow is assumed to be ineffective for core heat removal capability because it bypasses the core through the various available vessel flow paths described in Section [4.4.4.2.1](#).

4.4.1.9.7 Uncertainties in Hydraulic Loads

As discussed in Section [4.4.1.6.2](#), hydraulic loads on the fuel assembly are evaluated for a pump overspeed transient which creates flow rates 20 percent greater than the mechanical design flow. The mechanical design flow as stated in Section [5.1](#) is greater than the best estimate or most likely flow rate value for the actual plant operating condition.

4.4.1.9.8 Uncertainty in Mixing Coefficient

The value of the mixing coefficient, TDC, used in VIPRE-01 analyses for this application is 0.038. The mean value of TDC obtained in the "R" grid mixing tests described in Section [4.4.1.2.3](#) was 0.042 (for 26 inch grid spacing). The value 0.038 is one standard deviation below the mean value; and approximately 90 percent of the data gives values of TDC greater than 0.038 (Reference [23](#)).

The results of the mixing tests done on 17 x 17 geometry, as discussed in Section [4.4.1.2.3](#), had a mean value of TDC of 0.059 and standard deviation of $\sigma = 0.007$. Hence the current design value of TDC is almost 3 standard deviations below the mean for 26 inch grid spacing.

In addition, since the actual grid spacing is approximately 10 inches in the IFM grid spans for the RFA design, additional margin is available for this design, since the value of TDC increases as grid spacing decreases (Reference [13](#)).

4.4.1.10 Flux Tilt Considerations

Significant quadrant power tilts are not anticipated during normal operation since this phenomenon is caused by some perturbation for example, a dropped or misaligned rod cluster control assembly could cause changes in hot channel factors; however, these events are analyzed separately in [Chapter 15](#). Other possible cases for quadrant power tilts include x-y xenon transients, inlet temperature mismatches, enrichment variations within tolerances and so forth.

In addition to unanticipated quadrant power tilts as described above, other readily explainable asymmetries may be observed during calibration of the excore detector quadrant power tilt alarm. During operation, incore maps are taken at least once per month and, periodically, additional maps are obtained for calibration purposes. Each of these maps is reviewed for deviations from the expected power distributions. Asymmetry in the core, from quadrant to quadrant, is frequently a consequence of the design when assembly and/or components

shuffling and rotation requirements do not allow exact symmetry preservation. In each case, the acceptability of an observed asymmetry, planned or otherwise depends solely on meeting the required accident analyses assumptions.

In practice, once acceptability has been established by review of the incore maps, the quadrant power tilt alarms and related instrumentation are adjusted to indicate zero Quadrant Power Tilt Ratio as the final step in the calibration process. This action ensures that the instrumentation is correctly calibrated to alarm in the event an unexplained or unanticipated change occurs in the quadrant to quadrant relationships between calibration intervals. Proper functioning of the quadrant power tilt alarm is significant because allowances are only made in design analyses of quadrant power tilts up to 2.0%. Finally in the event that unexplained flux tilts do occur, the Improved Technical Specifications (Section 3.2.4) provide appropriate corrective actions to ensure continued safe operation of the reactor.

4.4.1.11 Fuel and Cladding Temperatures

A discussion of fuel and cladding temperatures and associated parameters is presented in Section [4.2](#). A discussion of fuel clad integrity is presented in Section [4.2.4.1](#).

4.4.2 Design Bases

The overall objective of the thermal and hydraulic design of the reactor core is to provide adequate heat transfer which is compatible with the heat generation distribution in the core such that heat removal by the Reactor Coolant System or the Emergency Core Cooling System (when applicable) assures that the following performance and safety criteria requirements are met:

1. Fuel damage (defined as penetration of the fission product barrier, i.e. the fuel rod clad) is not expected during normal operation and operational transients (Condition I) or any transient conditions arising from faults of moderate frequency (Condition II). It is not possible, however, to preclude a very small number of rod failures. These will be within the capability of the plant cleanup system and are consistent with the plant design bases.
2. The reactor can be brought to a safe state following a Condition III event with only a small fraction of fuel rods damaged (see above definition) although sufficient fuel damage might occur to preclude resumption of operation.
3. The reactor can be brought to a safe state and the core can be kept subcritical with acceptable heat transfer geometry following transients arising from Condition IV events.

In order to satisfy the above criteria, the following design bases have been established for the thermal and hydraulic design of the reactor core.

4.4.2.1 Departure from Nucleate Boiling Design Basis

Basis

There will be at least a 95 percent probability that departure from nucleate boiling (DNB) will not occur on the limiting fuel rods during normal operation and operational transients and any transient conditions arising from faults of moderate frequency (Condition I and II events), at a 95 percent confidence level. Historically, this criterion has been conservatively met by adhering to the following thermal design basis: there must be at least a 95 percent probability that the minimum departure from nucleate boiling ratio (DNBR) of the limiting power rod during Condition I and II events is greater than or equal to the DNBR limit of the DNB correlation being used. The DNBR limit for the correlation is established based on the variance of the correlation

such that there is a 95 percent probability with 95 percent confidence that DNB will not occur when the calculated DNBR is at the DNBR limit.

Deleted Paragraph(s) Per 2016 Update.

The DNBR analysis limit is determined in part by the Critical Heat Flux (CHF) correlation used. DPC's analysis of the robust fuel assembly design uses the WRB-2M CHF correlation which has a correlation limit of 1.14 (Reference [97](#), WCAP-15025P-A).

The design method employed to meet the DNB design basis is the Statistical Core Design Methodology (Reference [95](#)). Uncertainties in plant operating parameters, nuclear and thermal parameters, fuel fabrication parameters, and the CHF correlation are considered statistically to determine a statistical DNBR limit (SDL). Since the parameter uncertainties are considered in determining the statistical DNBR limit, the SCD analyses are performed using values of input parameters without uncertainties. For this application the statistical DNBR value is 1.30. This value is the bases for Improved Technical Specifications and for consideration of the applicability of unreviewed safety questions as defined in 10CFR 50.59.

In addition to the above considerations, a specific plant retained margin has been considered in the present analysis. In particular, a design DNBR value of 1.45 or higher was employed in safety analyses as the limiting value against which the results of the design transients are checked. The plant allowance available between the DNBR limit used in the safety analysis and the statistical DNBR limit is not required to meet the design basis discussed earlier. This allowance will be used for flexibility in the design, operation, and analyses on a cycle-by-cycle basis. For instance, individual cycle designs may use the allowance for improved fuel management or increased plant availability.

General Discussion

By preventing departure from nucleate boiling (DNB), adequate heat transfer is assured between the fuel cladding and the reactor coolant, thereby preventing cladding damage as a result of inadequate cooling. Maximum fuel rod surface temperature is not a design basis as it will be within a few degrees of coolant temperature during operation in the nucleate boiling region. Limits provided by the nuclear control and protection systems are such that this design basis will be met for transients associated with Condition II events including overpower transients. There is an additional large DNBR margin at rated power operation and during normal operating transients.

4.4.2.2 Fuel Temperature Design Basis

Basis

During modes of operation associated with Condition I and Condition II events, there is at least a 95% probability that the peak KW/FT fuel rods will not exceed the UO₂ for Mark-BW analyses melting temperature at the 95 percent confidence level. The melting temperature of UO₂ is given in Reference [94](#). The melting temperature of UO₂ for RFA analyses is given in Reference [99](#). By precluding UO₂ melting, the fuel geometry is preserved and possible adverse effects of molten UO₂ on the cladding are eliminated.

Discussion

Fuel rod thermal evaluations are performed at rated power, maximum overpower and during transients at various burnups. These analyses assure that the fuel temperature design basis is met. They also provide input for the evaluation of Condition III and IV faults given in [Chapter 15](#).

4.4.2.3 Core Flow Design Basis

Basis

A minimum of 91.5 percent of the thermal flow rate will pass through the fuel rod region of the core and be effective for fuel rod cooling. Coolant flow through the thimble tubes as well as the leakage from the core barrel-baffle region into the core are not considered effective for heat removal.

Discussion

Core cooling evaluations are based on the thermal flow rate (minimum flow) entering the reactor vessel. A maximum of 8.5 percent of this value is allotted as bypass flow. This includes rod cluster control guide thimble cooling flow, head cooling flow, baffle leakage, and leakage to the vessel outlet nozzle.

The bypass flow calculation includes effects on other flow paths due to the overall increased hydraulic resistance of the RFA fuel due to intermediate flow mixing (IFM) grids. The core bypass flow will be verified on a cycle specific basis.

4.4.2.4 Hydrodynamic Stability Design Basis

Basis

Modes of operation associated with Condition I and II events shall not lead to hydrodynamic instability.

4.4.2.5 Other Considerations

The above design bases together with the fuel clad and fuel assembly design bases given in Section [4.2.3](#) are sufficiently comprehensive so additional limits are not required.

Fuel rod diametral gap characteristics, moderator-coolant flow velocity and distribution, and moderator void are not inherently limiting. Each of these parameters is incorporated into the thermal and hydraulic models used to ensure the above mentioned design criteria are met. For instance, the fuel rod diametral gap characteristics change with time (see Section [4.2.4.3](#)) and the fuel rod integrity is evaluated on that basis. The effect of the moderator flow velocity and distribution (see Section [4.4.1.2](#)) and moderator void distribution (see Section [4.4.1.4](#)) are included in the core thermal (VIPRE-01) evaluation and thus affect the design bases.

Meeting the fuel clad integrity criteria covers possible effects of clad temperature limitations. As noted in Section [4.2.4.3](#), the fuel rod conditions change with time. A single clad temperature limit for Condition I or Condition II events is not appropriate since of necessity it would be overly conservative. A clad temperature limit is applied to the loss of coolant accident, control rod ejection accident, and locked rotor accident.

4.4.3 Description of the Thermal and Hydraulic Design of the Reactor Coolant System

4.4.3.1 Plant Configuration Data

Plant configuration data for the thermal hydraulic and fluid systems external to the core are provided in the appropriate [Chapter 5](#), [Chapter 6](#), and [Chapter 9](#). Implementation of the Emergency Core Cooling System (ECCS) is discussed in [Chapter 15](#). Some specific areas of interest are the following:

1. Total coolant flow rates for the Reactor Coolant System (RCS) and each loop are provided in [Table 5-1](#). Flow rates employed in the evaluation of the core are presented in Section [4.4](#).
2. Total RCS volume including pressurizer and surge line, RCS liquid volume including pressurizer water at steady state power conditions are given in [Table 5-1](#).
3. The flow path length through each volume is calculated for input to the RETRAN-02 Plant Simulation Model described in Section [15.0](#).
4. The height of fluid in each component of the RCS is calculated for input to the RETRAN-02 Plant Simulation Model described in Section [15.0](#). The components of the RCS are water filled during power operation with the pressurizer being approximately 60 percent water filled.
5. Components of the ECCS are to be located so as to meet the criteria for net positive suction head described in Section [6.3](#).
6. Line length and sizes for the Safety Injection System are determined so as to guarantee a total system resistance which will provide, as a minimum, the fluid delivery rates assumed in the safety analyses described in [Chapter 15](#).
7. The parameters for components of the RCS are presented in Section [5.4](#) component and subsystem design.
8. The steady state pressure drops and temperature distributions through the RCS are presented in [Table 5-1](#).

4.4.3.2 Operating Restrictions on Pumps

The minimum Net Positive Suction Head (NPSH) and minimum seal injection flow rate must be established before operating the reactor coolant pumps. With the minimum labyrinth seal injection flow rate established, the operator will have to verify that the system pressure satisfies NPSH requirements.

4.4.3.3 Power-Flow Operating Map (BWR)

Not applicable to Pressurized Water Reactors.

4.4.3.4 Temperature-Power Operating Map

The relationship between Reactor Coolant System temperature and power for nominal power operation is shown in [Figure 4-76](#) (Unit 1) and [Figure 4-77](#) (Unit 2). The above referenced figures are for general information. Computational sources should be consulted for actual predicted behavior and/or operational limits. In addition, the figures do not reflect operation under a reduced T-average coastdown scheme.

The effects of reduced core flow due to inoperative pumps is discussed in Section [15.3](#). Natural circulation capability of the system is shown in Section [15.2.6](#).

4.4.3.5 Load Following Characteristics

The Reactor Coolant System is designed on the basis of steady state operation at full power heat load. The reactor coolant pumps utilize constant speed drives as described in Section [5.4](#) and the reactor power is controlled to maintain average coolant temperature at a value which is a linear function of load, as described in Section [7.7](#). Operation with one pump out of service requires adjustment only in Reactor Trip System setpoints as discussed in Section [7.2](#).

4.4.3.6 Thermal and Hydraulic Characteristics Summary Table

The thermal and hydraulic characteristics are given in [Table 4-1](#) and [Table 4-4](#).

4.4.4 Evaluation

4.4.4.1 Critical Heat Flux

The critical heat flux correlation utilized in the core thermal analysis is explained in detail in Section [4.4.1.2](#).

4.4.4.2 Core Hydraulics

4.4.4.2.1 Flow Paths Considered in Core Pressure Drop and Thermal Design

The following flow paths for core bypass flow are considered:

1. Flow through the spray nozzles into the upper head for head cooling purposes.
2. Flow entering into the RCC guide thimbles to cool the control rods.
3. Leakage flow from the vessel inlet nozzle directly to the vessel outlet nozzle through the gap between the vessel and the barrel.
4. Flow introduced between the baffle and the barrel for the purpose of cooling these components and which is not considered available for core cooling.
5. Flow in the gaps between the fuel assemblies on the core periphery and the adjacent baffle wall.

The above contributions are evaluated to confirm that the design value of the core bypass flow is met. The analysis value of core bypass flow for the standard plant is equal to 7.5 percent of the total vessel flow. The uncertainty is 1.5%. The core bypass flow will be verified on a cycle specific basis.

Flow model test results for the flow path through the reactor are discussed in Section [4.4.1.7.2](#).

4.4.4.2.2 Inlet Flow Distributions

Data have been considered from several 1/7 scale hydraulic reactor model tests, References [24](#), [25](#), and [64](#), in arriving at the core inlet flow maldistribution criteria to be used in the VIPRE-01 analyses (see Section [4.4.4.5.1](#)). VIPRE-01 analyses made, using these data, have indicated that a conservative design basis is to consider 5 percent reduction in the flow to the hot assembly.

4.4.4.2.3 Empirical Friction Factor Correlations

Two empirical friction factor correlations are used in the VIPRE-01 computer code (described in Section [4.4.4.5.1](#)).

The friction factor in the axial direction, parallel to the fuel rod axis, is evaluated using the Blasius relation (Reference [90](#)). The code evaluates both the turbulent and laminar equations and selects the maximum value. The relations are:

$$f_{\text{turbulent}} = 0.32 \text{ Re}^{-0.25}$$

$$f_{\text{laminar}} = 64 \text{ Re}^{-1.0}$$

The loss coefficient for flow in the lateral direction, normal to the fuel rod axis, is calculated by the equation:

$$K_G = 0.5 \left(\frac{\text{Channel Centroid Distance}}{\text{Fuel Rod Pitch}} \right)$$

where:

the centroid distance is calculated as described in Reference [90](#).

Extensive comparisons of VIPRE-01 predictions using these correlations to experimental data are given in Reference [90](#), and verify the applicability of these correlations in PWR design.

4.4.4.3 Influence of Power Distribution

The core power distribution which is largely established at beginning-of-life by fuel enrichment, loading pattern, and core power level is also a function of variables such as control rod worth and position, and fuel depletion throughout lifetime. Radial power distributions in various planes of the core are often illustrated for general interest, however, the core radial enthalpy rise distribution as determined by the integral of power up each channel is of greater importance for DNB analyses. These radial power distributions, characterized by $F_{\Delta H}^N$ (defined in Section [4.3.2.2.1](#)) as well as axial heat flux profiles are discussed in the following two sections.

4.4.4.3.1 Radial Power Distribution

Since DNB is a function of the three dimensional core power distribution and magnitude (channel integral enthalpy rise), separation of radial and axial power distributions are necessary for DNB predictions. If the core power level, coolant inlet conditions, and the limiting DNBR are fixed and an axial power distribution selected, the corresponding maximum radial fuel rod power can be calculated. When this calculation is performed for a multitude of axial peak magnitude and locations, a family of curves is generated that show the maximum allowable peaking (MAP) for a statepoint as a function of axial power distribution. The curves, usually expressed in terms of total peaking, are the locus of points where the minimum DNBR is equal to the design limit.

For the radial power distribution component, the magnitude of the peak pin is adjusted during generation of the MAP curves but the relative distribution is preserved. This distribution, called the reference radial peaking, is shown in Reference [89](#) and is assumed to bound, in terms of DNB performance, actual power distributions that occur during plant operations. MAP limits provide the linkage between the DNBR criteria, the core nuclear power distributions, and the reactor fluid conditions during all the steady state and transient analyses. The MAP curves define the maximum value that the Nuclear Designer can allow peaking to increase to before the 95/95 DNBR criteria is exceeded. This allows the Nuclear Designer to quickly evaluate the core loading pattern for acceptable operation during steady state nominal conditions and during design basis transients.

The MAP curves also define the relationship of increased peaking with reduced power level.

For reduced power, the MAP limits are adjusted by the equation:

$$K = [1 + 0.3 (1-P)]$$

where K is the MAP adjustment factor and P is the fraction of rated thermal power.

The permitted relaxation of radial peaking is considered in the DNB protection setpoints and allows radial power shape changes with rod insertion to the insertion limits (Reference [68](#)), thus allowing greater flexibility in the nuclear design.

4.4.4.3.2 Axial Power Distributions

As discussed in Section [4.3.2.2](#), the axial power distribution can vary as a result of rod motion, power change, or due to a spatial xenon transient which may occur in the axial direction. Consequently it is necessary to measure the axial power imbalance by means of the ex-core-nuclear detectors (as discussed in Section [4.3.2.2.7](#)) and protect the core from excessive axial power imbalance.

The reference axial shape used in establishing core DNB limits (that is overtemperature ΔT protection system setpoints) is a chopped cosine shape with a peak to average value of 1.60. The Reactor Trip System provides automatic reduction of the trip setpoints on excessive axial power imbalance.

To determine the magnitude of the setpoint reduction, other axial shapes skewed to the bottom and top of the core are analyzed. The course of those accidents in which DNB is a concern is analyzed in [Chapter 15](#) assuming that the protection set points have been set on the basis of these shapes. In many cases the axial power distribution in the hot channel changes throughout the course of the accident due to rod motion, coolant temperature and power level changes.

The initial conditions for the accidents for which DNB protection is required are assumed to be those permissible within the axial offset control strategy employed. In the case of the loss of flow accident the hot channel heat flux profile is very similar to the power density profile in normal operation preceding the accident. The limiting Condition II DNBR transient is analyzed and the system response used in a VIPRE-01 subchannel model to verify acceptable DNB performance. Maximum Allowable Peaking values are calculated for various axial power distributions as described in Section [4.4.4.3.1](#). The fluid conditions used are taken from the most limiting DNB point during the transient. These design shape evaluations bound all normal operation axial power distributions.

4.4.4.4 Core Thermal Response

A general summary of the steady-state thermal-hydraulic design parameters including thermal output, flow rates, etc., is provided in [Table 4-1](#) for all loops in operation.

As stated in Section [4.4.2](#), the design bases of the application are to prevent DNB and to prevent fuel melting for Condition I and II events. The protective systems described in [Chapter 7](#) are designed to meet these bases. The response of the core to Condition II transients is given in [Chapter 15](#).

4.4.4.5 Analytical Techniques

4.4.4.5.1 Core Analysis

The objective of reactor core thermal design is to determine the maximum heat removal capability in all flow subchannels and show that the core safety limits, as presented in the Improved Technical Specifications are not exceeded while compounding engineering and nuclear effects. The thermal design considers local variations in dimensions, power generation, flow redistribution, and mixing. VIPRE-01 is a realistic three-dimensional matrix model which has been developed to account for hydraulic and thermal effects on the enthalpy rise in the

core, Reference [90](#). The behavior of the limiting subchannel is determined by analyzing a conservatively flat limiting assembly radial power distribution. The inlet flow velocity, inlet temperature, and exit pressure to the subchannels are given as boundary conditions. After selecting an axial power distribution and core power level, the VIPRE-01 code calculates the subchannel fluid conditions and surface heat flux of the fuel rod at discrete axial levels. Flow redistribution and mixing are calculated by the code and the local variations in fuel assembly dimensions and power generation are accounted for in the SCD procedure. In this manner, the behavior of the limiting subchannel with respect to DNBR is conservatively modeled.

4.4.4.5.2 Steady State Analysis

The VIPRE-01 computer program, as approved by the NRC (Reference [90](#)), is used to determine coolant density, mass velocity, enthalpy, vapor void, static pressure, and DNBR distributions along parallel flow channels within a reactor core under all expected operating conditions. The VIPRE-01 Code is described in detail in Reference [90](#), including models and correlations used. In addition, a discussion on experimental verification of VIPRE-01 is given in Reference [90](#).

Estimates of uncertainties are discussed in Section [4.4.1.9](#).

4.4.4.5.3 Experimental Verification

Extensive experimental verification is presented in Reference [90](#).

The VIPRE-01 analysis is based on a knowledge and understanding of the heat transfer and hydrodynamic behavior of the coolant flow and the mechanical characteristics of the fuel elements. The use of the VIPRE-01 analysis provides a realistic evaluation of the core performance and is used in the thermal analyses as described above.

4.4.4.5.4 Transient Analysis

The VIPRE-01 thermal-hydraulic computer code is also used for transient analyses.

4.4.4.6 Hydrodynamic and Flow Power Coupled Instability

Boiling flows may be susceptible to thermohydrodynamic instabilities (Reference [70](#)). These instabilities are undesirable in reactors since they may cause a change in thermohydraulic conditions that may lead to a reduction in the DNB heat flux relative to that observed during a steady flow condition or to undesired forced vibrations of core components. Therefore, a thermohydraulic design criterion was developed which states that modes of operation under Condition I and II events shall not lead to thermohydrodynamic instabilities.

Two specific types of flow instabilities are considered for Westinghouse PWR operation. These are the Ledinegg or flow excursion type of static instability and the density wave type of dynamic instability.

A Ledinegg instability involves a sudden change in flow rate from one steady state to another. This instability occurs (Reference [70](#)) when the slope of the reactor coolant system pressure drop-flow rate curve ($\partial\Delta P / \partial G|_{\text{internal}}$) becomes algebraically smaller than the loop supply (pump head) pressure dropflow rate curve ($\partial\Delta P / \partial G|_{\text{external}}$). The criterion for stability is thus $(\partial\Delta P / \partial G|_{\text{internal}}) > (\partial\Delta P / \partial G|_{\text{external}})$. The Westinghouse pump head curve has a negative slope ($\delta\Delta P / \delta G|_{\text{external}} < 0$) whereas the reactor coolant system pressure drop-flow curve has a

positive slope ($\delta\Delta P / \delta G|_{\text{internal}} > 0$) over the Condition I and Condition II operational ranges. Thus, the Ledinegg instability will not occur.

The mechanism of density wave oscillations in a heated channel has been described by Lahey and Moody (Reference [71](#)). Briefly, an inlet flow fluctuation produces an enthalpy perturbation. This perturbs the length and the pressure drop of the single phase region and causes quality or void perturbations in the two-phase regions which travel up the channel with the flow. The quality and length perturbations in the two-phase region create two-phase pressure drop perturbations. However, since the total pressure drop across the core is maintained by the characteristics of the fluid system external to the core, then the two-phase pressure drop perturbation feeds back to the single phase region. These resulting perturbations can be either attenuated or self-sustained.

A simple method has been developed by Ishii (Reference [72](#)) for parallel closed channel systems to evaluate whether a given condition is stable with respect to the density wave type of dynamic instability. This method had been used to assess the stability of typical Westinghouse reactor designs (References [73](#), [74](#), and [75](#)), including Virgil C. Summer, under Condition I and II operation. The results indicate that a large margin to density wave instability exists, e.g., increases on the order of 200% of rated reactor power would be required for the predicted inception of this type of instability.

The application of the method of Ishii (Reference [72](#)) to Westinghouse reactor designs is conservative due to the parallel open channel feature of Westinghouse PWR cores. For such cores, there is little resistance to lateral flow leaving the flow channels of high power density to lower power density channels. This coupling with cooler channels has led to the opinion that an open channel configuration is more stable than the above closed channel analysis under the same boundary conditions. Flow stability tests (Reference [76](#)) have been conducted where the closed channel systems were shown to be less stable than when the same channels were cross connected at several locations. The cross connections were such that the resistance to channel to channel cross flow and enthalpy perturbations would be greater than that which would exist in a PWR core which has a relatively low resistance to cross flow.

Flow instabilities which have been observed have occurred almost exclusively in closed channel systems operating at low pressure relative to the Westinghouse PWR operating pressures. Kao, Morgan and Parker (Reference [77](#)) analyzed parallel closed channels stability experiments simulating a reactor core flow. These experiments were conducted at pressures up to 2200 psia. The results showed that for flow and power levels typical of power reactor conditions, no flow oscillations could be induced above 1200 psia.

Additional evidence that flow instabilities do not adversely affect thermal margin is provided by the data from the rod bundle DNB tests. Many Westinghouse type rod bundles have been tested over wide ranges of operating conditions with no evidence of premature DNB or of inconsistent data which might be indicative of flow instabilities in the rod bundle.

In summary, it is concluded that thermohydrodynamic instabilities will not occur under Condition I and II modes of operation for Westinghouse PWR reactor designs. A large power margin, greater than doubling rated power, exists to predicted inception of such instabilities. Analysis has been performed which shows that minor plant to plant differences in flow ratios, fuel assembly length, etc. will not result in gross deterioration of the above power margins

4.4.4.7 Fuel Rod Behavior Effects from Coolant Flow Blockage

Coolant flow blockages can occur within the coolant channels of a fuel assembly or external to the reactor core. The effects of fuel assembly blockage within the assembly on fuel rod

behavior is more pronounced than external blockages of the same magnitude. In both cases, the flow blockages cause local reductions in coolant flow. The amount of local flow reduction, where it occurs in the reactor, and how far along the flow stream the reduction persists are considerations which will influence the fuel rod behavior. The effects of coolant flow blockages in terms of maintaining rated core performance are determined both by analytical and experimental methods. The experimental data are usually used to augment analytical tools such as computer programs similar to the VIPRE-01 program. Inspection of the DNB correlation (Section [4.4.1.2](#) and References [87](#) and [93](#)) shows that the predicted DNBR is dependent upon the local values of quality and mass velocity.

The VIPRE-01 Code is capable of predicting the effects of local flow blockages on DNBR within the fuel assembly on a subchannel basis, regardless of where the flow blockage occurs. In Reference [90](#), it is shown that for a fuel assembly similar to the Westinghouse design, VIPRE-01 accurately predicts the flow distribution within the fuel assembly when the inlet nozzle is completely blocked. Full recovery of the flow was found to occur about 30 inches downstream of the blockage. With the reference reactor operating at the nominal full power conditions specified in [Table 4-1](#), the effects of an increase in enthalpy and decrease in mass velocity in the lower portion of the fuel assembly would not result in the reactor reaching the design DNBR specified in Section [4.4.2.1](#).

From a review of the open literature, it is concluded that flow blockage in "open lattice cores" similar to the Westinghouse cores cause flow perturbations which are local to the blockage. For instance, A. Ohtsubol (Reference [78](#)), et al., show that the mean bundle velocity is approached asymptotically about 4 inches downstream from a flow blockage in a single flow cell. Similar results were also found for 2 and 3 cells completely blocked. P. Basmer (Reference [79](#)), et al., tested an open lattice fuel assembly in which 41 percent of the subchannels were completely blocked in the center of the test bundle between spacer grids. Their results show the stagnant zone behind the flow blockage essentially disappears after 1.65 L/De or about 5 inches for their test bundle. They also found that leakage flow through the blockage tended to shorten the stagnant zone or, in essence, the complete recovery length. Thus, local flow blockages within a fuel assembly have little effect on subchannel enthalpy rise. The reduction in local mass velocity is then the main parameter which affects the DNBR. If the plants were operating at full power and nominal steady state conditions as specified in [Table 4-1](#), a reduction in local mass velocity greater than 70 percent would be required to reduce the DNBR to the design DNBR. The above mass velocity effect on the DNB correlation was based on the assumption of fully developed flow along the full channel length. In reality a local flow blockage is expected to promote turbulence and thus would likely not effect DNBR at all.

Coolant flow blockages induce local crossflows as well as promote turbulence. Fuel rod behavior is changed under the influence of a sufficiently high crossflow component. Fuel rod vibration could occur, caused by this crossflow component, through vortex shedding or turbulent mechanisms. If the crossflow velocity exceeds the limit established for fluid elastic stability, large amplitude whirling results. The limits for a controlled vibration mechanism are established from studies of vortex shedding and turbulent pressure fluctuations. The crossflow velocity required to exceed fluid elastic stability limits is dependent on the axial location of the blockage and the characterization of the crossflow (jet flow or not). These limits are greater than those for vibratory fuel rod wear. Crossflow velocity above the established limits can lead to mechanical wear of the fuel rods at the grid support locations. Fuel rod wear due to flow induced vibration is considered in the fuel rod fretting evaluation (Section [4.2](#)) for each fuel type.

4.4.5 Testing and Verification

4.4.5.1 Tests Prior to Initial Criticality

A reactor coolant flow test was performed following fuel loading, but prior to initial criticality. Coolant loop pressure drop data is obtained in this test. This data, in conjunction with coolant pump performance information, allowed determination of the coolant flow rates at reactor operating conditions. This test verifies that proper coolant flow rates have been used in the core thermal and hydraulic analysis. RCS flow is re-measured every operating cycle.

4.4.5.2 Initial Power and Plant Operation

Core power distribution measurements are made at several core power levels (see [Chapter 14](#)). These tests are used to insure that conservative peaking factors are used in the core thermal and hydraulic analysis.

4.4.5.3 Component and Fuel Inspections

Inspections performed on the manufactured fuel are delineated in Section [4.2.5](#). Fabrication measurements critical to thermal and hydraulic analysis are obtained to verify that the engineering hot channel factors in the design analyses (Section [4.4.1.2.4](#)) are met.

4.4.6 Instrumentation Requirements

4.4.6.1 Incore Instrumentation

Instrumentation is located in the core so that by correlating movable neutron detector information with fixed thermocouple information, radial, axial, and azimuthal core characteristics may be obtained for all core quadrants.

The incore instrumentation system is comprised of thermocouples, positioned to measure fuel assembly coolant outlet temperatures at preselected positions, and fission chamber detectors positioned in guide thimbles which run the length of selected fuel assemblies to measure the neutron flux distribution. [Figure 4-74](#) shows the number and location of instrumented assemblies in the core.

The core-exit thermocouples provide a backup to the flux monitoring instrumentation for monitoring power distribution. The routine, systematic, collection of thermocouple readings by the operator provides a data base. From this data base, abnormally high or abnormally low readings, quadrant temperature tilts, or systematic departures from a prior reference map can be deduced.

The movable incore neutron detector system could be used for more detailed mapping if the thermocouple system were to indicate an abnormality. These two complementary systems are more useful when taken together than either system alone would be. The incore instrumentation system is described in more detail in Section [7.7.1.9](#).

The incore instrumentation is provided to obtain data from which fission power density distribution in the core, coolant enthalpy distribution in the core, and fuel burnup distribution may be determined.

4.4.6.2 Overtemperature and Overpower ΔT Instrumentation

The Overtemperature ΔT trip protects the core against DNB. The Overpower ΔT trip protects against excessive power (fuel rod rating protection).

As discussed in Section [7.2.1.1.2](#), factors included in establishing the Overtemperature ΔT and Overpower ΔT trip setpoints includes the reactor coolant temperature in each loop and the axial distribution of core power through the use of the two section excore neutron detectors.

4.4.6.3 Instrumentation to Limit Maximum Power Output

The outputs of the three ranges (source, intermediate, and power) of detectors, with the electronics of the nuclear instruments, are used to limit the maximum power output of the reactor within their respective ranges.

There are six radial locations containing a total of eight neutron flux detectors installed around the reactor in the primary shield. The source and intermediate range detectors include two combined source and intermediate range fission chambers installed on opposite "flat" portions of the core positioned with the centerline of sensitive volume corresponding to one half the core height. The power range detectors include four dual section uncompensated ionization chamber assemblies for the power range are installed vertically at the four corners of the core and located equidistant from the reactor vessel at all points and, to minimize neutron flux pattern distortions, within one foot of the reactor vessel. Each power range detector provides two signals corresponding to the neutron flux in the upper and in the lower sections of a core quadrant. The three ranges of detectors are used as inputs to monitor neutron flux from a completely shutdown condition up to 120 percent of full power with the capability of recording overpower excursions up to 200 percent of full power.

The output of the power range channels is used for:

1. The rod speed control function,
2. To alert the operator to an excessive power unbalance between the quadrants,
3. Protect the core against rod ejection accidents and
4. Protect the core against adverse power distributions resulting from dropped rods.

Details of the neutron detectors and nuclear instrumentation design and the control and trip logic are given in [Chapter 7](#). The limits on neutron flux operation and trip setpoints are given in the Technical Specifications.

4.4.6.4 Loose Parts Monitoring System

The Loose Parts Monitoring System is described in Section [7.8.8](#).

4.4.6.5 Flow Measurement Instrumentation and Technique

Technical Specifications require that total reactor flow (total flow through the vessel from all loops) be above some minimum value. The minimum flow value is thermal design flow corrected for flow measurement uncertainties. Historically, this uncertainty has been specified as 4.5%. However, flow measurement uncertainties can be reduced by using modern statistical error combination techniques combined with an elbow tap flow measurement method. In most cases, several components contribute to the overall uncertainty of the measurement. [Table 4-20](#) provides a list of typical components involved in the calorimetric loop flow measurement and that contribute to the elbow tap flow measurement uncertainty. The total reactor flow

measurement uncertainty is then calculated as the statistical combination of the individual loop flow uncertainties.

4.4.6.5.1 Elbow Taps

The reactor coolant flow measurement is based upon the normalization of the cold leg elbow tap signals to constants derived from averaged calorimetric from previous fuel cycles. The elbow tap coefficients are listed in [Table 4-22](#) and RCS flow rate calculations are described in Section [7.2.2.2.2](#).

4.4.7 References

1. Deleted Per 1998 Update
2. Deleted Per 1998 Update
3. Deleted Per 1998 Update
4. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

5. *Davidson, S. L., Iorii, J A., Motley, F. E., Lee, Y. C., Bogard, T., Bryan, W. J., "Verification Testing and Analyses of the 17 x 17 Optimized Fuel Assembly", WCAP-9401P-A, August 1981 (Proprietary) and WCAP-9402A, March 1979.*
6. Tong, L. S., "Boiling Crisis and Critical Heat Flux", TID-25887, 1972.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

7. *Motley, F. E. and Cadek, F. F., "DNB Tests Results for New Mixing Vane Grids (R)", WCAP-7695-P-A (Proprietary), July 1972 and WCAP-7958-A, January 1975.*
8. Deleted Per 1998 Update
9. Deleted Per 1998 Update
10. Deleted Per 1998 Update
11. Deleted Per 1998 Update
12. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

13. *Cadek, F. F., Motley, F. E. and Dominicus, D. P., "Effect of Axial Spacing on Interchannel Thermal Mixing with the R Mixing Vane Grid", WCAP-7941-P-A (Proprietary), January 1975 and WCAP-7959-A, January 1975.*
14. Rowe, D. S., Angle, C. W., "Crossflow Mixing Between Parallel Flow Channels During Boiling, Part II Measurements of Flow and Enthalpy in Two Parallel Channels", BNWL-371, Part 2, December 1967.
15. Rowe, D. S., Angle, C. W., "Crossflow Mixing Between Parallel Flow Channels During Boiling, Part III Effect of Spacers on Mixing Between Two Channels", BNWL-371, Part 3, January 1969.
16. Gonzalez-Santalo, J. M. and Griffith, P., "Two-Phase Flow Mixing in Rod Bundle Subchannels", ASME Paper 72-WA/NE-19.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

17. *Motley, F. E., Wenzel, A. H., Cadek, F. F., "The Effect of 17 x 17 Fuel Assembly Geometry on Interchannel Thermal Mixing", WCAP-8298-P-A (Proprietary), January 1975 and WCAP-8299-A, January 1975.*
18. *Hill, K. W., Motley, F. E., and Cadek, F. F., "Effect of Local Heat Flux Spikes on DNB in Non-Uniform Heated Rod Bundles", WCAP-8174, August 1973 (Proprietary) and WCAP-8202, August 1973 (Non-Proprietary).*
19. *Cadek, F. F., "Interchannel Thermal Mixing with Mixing Vane Grids", WCAP-7667-P-A (Proprietary), January 1975 and WCAP-7755-A, January 1975.*
20. Deleted Per 1998 Update
21. Deleted Per 1998 Update
22. *Weisman, J., "Heat Transfer to Water Flowing Parallel to Tube Bundles", Nucl. Sci. Eng., 6, 78-79 (1959).*
23. *Thom, J. R. S., Walker, W. M., Fallon, T. A. and Reising, G. F. S., "Boiling in Sub-cooled Water During Flowup Heated Tubes or Annuli", Proc. Instn, Mchn. Engrs., 180, Pt. C, 226-46 (1955-66).*

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

24. *Hetsroni, G., "Hydraulic Tests of the San Onofre Reactor Model", WCAP-3269-8, June 1964.*
25. *Hetsroni, G., "Studies of the Connecticut-Yankee Hydraulic Model", NYO-3250-2, June 1965.*
26. Deleted Per 1998 Update
27. Deleted Per 1998 Update
28. Deleted Per 1998 Update
29. Deleted Per 1998 Update
30. Deleted Per 1998 Update
31. *Kjaerheim, G. and Rolstad, E., "In Pile Determination of UO Thermal Conductivity, Density Effects and Gap Conductance", HPR-80, December 1967.*
32. *Kjaerheim, G., "In-Pile Measurements of Centre Fuel Temperatures and Thermal Conductivity Determination of Oxide Fuels", paper IFA-175 presented at the European Atomic Energy Society Symposium on Performance Experience of Water-Cooled Power Reactor Fuel, Stockholm, Sweden (October 21-22, 1969).*

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

33. *Cohen, I., Lustman, G. and Eichenberg, D., "Measurement of the Thermal Conductivity of Metal-Clad Uranium Oxide Rods during Irradiation", WAPD-228, 1960.*
34. *Clough, D. J. and Sayers, J. B., "The Measurement of the Thermal Conductivity of UO₂ under Irradiation in the Temperature Range 150°-1600°C", AERE-R²4690, UKAEA Research Group, Harwell, December 1964.*
35. *Stora, J. P., Debernardy, DeSigoyer, B., Delmas, R., Deschamps, P., Ringot, C. and Lavaud, B., "Thermal Conductivity of Sintered Uranium Oxide under In-Pile Conditions", EURAEC-1095, 1964.*

36. Devold, I., "A Study of the Temperature Distribution in UO Reactor Fuel Elements", AE-318, Aktiebolaget Atomenergi, Stockholm, Sweden, 1968.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

37. *Balfour, M. G., Christensen, J. A. and Ferrari, H. M., "In-Pile Measurement of UO₂ Thermal Conductivity", WCAP-2923, 1966.*
38. Howard, V. C., and Gulvin, T. G., "Thermal Conductivity Determinations on Uranium Dioxide by a Radial Flow Method", UKAEA IG-Report 51, November 1960.
39. Lucks, C. F., and Deem, H. W., "Thermal Conductivity and Electrical Conductivity of UO₂," in Progress Reports Relating to Civilian Applications, BMI-1448 (Rev.) for June 1960: BMI-1489 (Rev.) for December 1960 and BMI-1518 (Rev.) for May 1961.
40. Danial, J. L., Matolich, Jr., J., and Deem, H. W. "Thermal Conductivity of UO₂", HW-69945, September 1962.
41. Feith, A. D., "Thermal Conductivity of UO₂ by a Radial Heat Flow Method", TID-21668, 1962.
42. Vogt, J., Grandell L. and Runfors, U., "Determination of the Thermal Conductivity of Unirradiated Uranium Dioxide", AB Atomenergi Report RMB-527, 1964, Quoted by IAEA Technical Report Series No. 59, "Thermal Conductivity of Uranium Dioxide".
43. Nishijima, T., Kawada, T. and Ishihata, A., "Thermal Conductivity of Sintered UO₂ and Al₂O₃ at High Temperature", *J. American Ceramic Society*, 48, 31, 34 (1965).
44. Ainscough, J. B. and Wheeler, M. J., "Thermal Diffusivity and Thermal Conductivity of Sintered Uranium Dioxide", in Proceedings of the Seventh Conference of Thermal Conductivity, p. 467, National Bureau of Standards, Washington, 1968.
45. Godfrey, T. G., Fulkerson, W., Killie, T. G., Moore, J. P. and McElroy, D. L. "Thermal Conductivity of Uranium Dioxide and Armco Iron by an Improved Radial Heat Flow Technique", ORNL-3556, June 1964.
46. Stora, J. P., et al., "Thermal Conductivity of Sintered Uranium Oxide Under In-Pile Conditions", EURAEC-1095, August 1964.
47. Bush, A. J., "Apparatus for Measuring Thermal Conductivity to 2500°C", Westinghouse Research Laboratories Report 64-1P6-401-43, (Proprietary) February 1965.
48. Asamoto, R. R., Anselin, F. L. and Conti, A. E., "The Effect of Density on the Thermal Conductivity of Uranium Dioxide", GEAP-5493, April 1968.
49. Kruger, O. L., "Heat Transfer Properties of Uranium and Plutonium Dioxide", Paper 11-N-68F presented at the Fall meeting of Nuclear Division of the American Ceramic Society, September 1968, Pittsburgh.

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

50. *Hellman, J. M. (Ed.), "Fuel Densification Experimental Results and Model for Reactor Application", WCAP-8218-P-A (Proprietary) March 1975 and WCAP-8219-A, March 1975.*
51. *Hochreiter, L. E., Chelemer, H. and Chu, P. T., "THINC-IV An Improved Program for Thermal-Hydraulic Analysis of Rod Bundle Cores", WCAP-7956, June 1973.*
52. Deleted Per 1998 Update
53. Deleted Per 1998 Update

54. Deleted Per 1998 Update
55. Deleted Per 1998 Update
56. Deleted Per 1998 Update
57. Deleted Per 1998 Update
58. Deleted Per 1998 Update
59. Deleted Per 1998 Update
60. Deleted Per 1998 Update
61. Deleted Per 1998 Update
62. Deleted Per 1998 Update
63. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

64. *Carter, F. D., "Inlet Orificing of Open PWR Cores", WCAP-9004, January 1969 (Proprietary) and WCAP-7836, January 1972 (Non-Proprietary).*
65. *Shefcheck, J., "Application of the THINC Program to PWR Design", WCAP-7359-L (Proprietary), August 1969 and WCAP-7838, January 1972.*
66. Deleted Per 1998 Update
67. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

68. *McFarlane, A. F., "Power Peaking Factors", WCAP-7912-P-A (Proprietary), January 1975 and WCAP-7912-A, January 1975.*
69. *Morita, T., et al., "Topical Report, Power Distribution Control and Load Following Procedures", WCAP-8385 (Proprietary), September 1974 and WCAP-8403, September 1974.*
70. Boure, J. A., Bergles, A. E. and Tong, L. S., "Review of Two-Phase Flow Instability", Nucl. Engr. Design 25 (1973) p. 165-192.
71. Lahey, R. T., and Moody, F. J., "The Thermal Hydraulics of a Boiling Water Reactor", American Nuclear Society, 1977.
72. Saha, P., Ishii, M., and Zuber, N., "An Experimental Investigation of the Thermally Induced Flow Oscillations in Two-Phase Systems", J. of Heat Transfer, No. 1976, pp. 616-622.
73. Virgil, C., Summer FSAR, Docket #50-395.
74. Byron/Braidwood FSAR, Docket #50-456.
75. South Texas FSAR, Docket #50-498.
76. Kakac, S., Vexiroglu, T. N., Akyuzlu, K., Berkol, O., "Sustained and Transient Boiling Flow Instabilities in a Cross-Connected Four-Parallel-Channel Upflow System", Proc. of 5th International Heat Transfer Conference, Tokyo, Sept. 3-7, 1974.
77. Kao, H. S., Morgan, C. D., and Parker, W. B., "Prediction of Flow Oscillation in Reactor Core Channel", Trans. ANS, Vol. 16, 1973, pp. 212-213.

78. Ohtsubo, A., and Uruwashi, S., "Stagnant Fluid due to Local Flow Blockage", Nucl. Sci. Technol., 9, No. 7, 433-434, (1972).
79. Basmer, P., Kirsh, D. and Schultheiss, G. F., "Investigation of the Flow Pattern in the Recirculation Zone Downstream of Local Coolant Blockages in Pin Bundles", *Atomwirtschaft*, 17, No. 8, 416-417, (1972). (In German).

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

80. *Burke, T. M., Meyer, C. E. and Shefcheck J., "Analysis of Data from the Zion (Unit 1) THINC Verification Test", WCAP-8453 (Proprietary), December 1974 and WCAP-8454, December 1974.*
81. *Graham, K. F., and Forker, H. M., "A N-16 Transit Time Flow Measurement System (TTFM) Description and Performance", WCAP-9172 (Proprietary), October 1977.*
82. Skaritka, J., Editor "Fuel Rod Bow Evaluation," WCAP-8691, Revision 1, July, 1979.
83. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

84. *BAW-10172P, Mark-BW Mechanical Design Report, Babcock & Wilcox, Lynchburg, Virginia, July 1988.*
85. Deleted Per 2001 Update
86. Deleted Per 1998 Update

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

87. *BAW-10159P-A, BWCMV Correlation of Critical Heat Flux in Mixing Vane Grid Fuel Assemblies, Babcock & Wilcox, Lynchburg, Virginia, July 1990.*
88. *BAW-51-1175225, Pressure Drop Test Report for the Mark-BW Debris Trapping Bottom Nozzle, Babcock & Wilcox, Lynchburg, Virginia, June 1989.*
89. *DPC-NE-2004P-A, Rev. 1, "Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology Using VIPRE-01," SER dated February 20, 1997 (DPC Proprietary). 1997.*
90. *EPRI NP-2511-CCMA, VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores, Battelle, Richland, Washington, August 1989.*

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

91. *BAW-10147P-A, Rev. 1, Fuel Rod Bowing in Babcock & Wilcox Fuel Designs, Babcock & Wilcox, Lynchburg, Virginia, May 1983.*
92. *DPC-NE-2005P-A, Rev. 2, "Thermal-Hydraulic Statistical Core Design Methodology," SER dated February 1995 (DPC Proprietary).*
93. *BAW-10199P-A, The BWU Critical Heat Flux Correlations, Framatome Cogema Fuels, Lynchburg, Virginia, April 1996.*
94. *BAW-10162P-A, TAC03 - Fuel Pin Thermal Analysis Computer Code, Babcock & Wilcox, Lynchburg, Virginia, October 1989.*

HISTORICAL INFORMATION IN ITALICS BELOW NOT REQUIRED TO BE REVISED

95. *DPC-NE-2009P-A, Duke Power Company Westinghouse Fuel Transition Report, Rev. 2, Dec. 18, 2002.*

96. *S. L. Davidson and T. L. Ryan, "VANTAGE+ Fuel Assembly Reference Core Report", WCAP-12610P-A, April 1995.*
97. *WCAP-15025P-A, "Modified WRB-2 Correlation, WRB-2M, for Predicting Critical Heat Flux in 17x17 Rod Bundles with Modified LPD Mixing Vane Grids, Westinghouse Energy Systems", April 1999.*
98. *WCAP-10444P-A, "Westinghouse Reference Core Report VANTAGE 5 Fuel Assembly", September 1985.*
99. *WCAP-6065, "Melting Point of Irradiated Uranium-Dioxide", Christensen, J. A., Allio, R. J. and Biancheria, A., February 1965.*
100. *DPC-NF-2010-A, Duke Power Company, McGuire and Catawba Nuclear Station, Nuclear Physics Methodology For Reload Design, Duke Power Company, Charlotte, N.C., Rev. 1, Oct. 1, 2002.*

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.4.

4.5 Reactor Materials

4.5.1 Control Rod System Structural Materials

4.5.1.1 Materials Specifications

All parts exposed to reactor coolant are made of metals which resist the corrosive action of the water. Three types of metals are used exclusively: stainless steels, nickel-chrome-iron and cobalt based alloys. In the case of stainless steels, only austenitic and martensitic stainless steels are used. For pressure boundary parts, the martensitic stainless steels are not used in the heat treated conditions which cause susceptibility to stress corrosion cracking or accelerated corrosion in the Westinghouse pressurized water reactor (PWR) water chemistry.

1. Pressure vessel

All pressure containing materials comply with Section III of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, and are fabricated from austenitic (Type 304) stainless steel.

2. Coil stack assembly

The coil housings require a magnetic material. Both low carbon cast steel and ductile iron have been successfully tested for this application. The choice, made on the basis of cost, indicates that ductile iron will be specified on the control rod drive mechanism (CRDM). The finished housings are zinc plated or flame sprayed to provide corrosion resistance.

Coils are wound on bobbins of molded Dow Corning 302 material, with double glass insulated copper wire. Coils are then vacuum impregnated with silicon varnish. A wrapping of mica sheet is secured to the coil outside diameter. The result is a well insulated coil capable of sustained operation at 200 degrees centigrade.

1. Latch assembly

Magnetic pole pieces are fabricated from Type 410 stainless steel. All nonmagnetic parts, except pins and springs, are fabricated from Type 304 stainless steel. Haynes 25 is used to fabricate link pins. Springs are made from nickel-chrome-iron alloy (Inconel-X). Latch arm tips are clad with Stellite-6 to provide improved wearability. Hard chrome plate and Stellite-6 are used selectively for bearing and wear surfaces.

2. Drive rod assembly

The drive rod assembly utilizes a Type 410 stainless steel drive rod. The coupling is machined from Type 403 stainless steel. Other parts are Type 304 stainless steel with the exception of the springs which are nickel-chrome-iron alloy and the locking button which is Haynes 25.

4.5.1.2 Fabrication and Processing of Austenitic Stainless Steel Components

The discussions provided in Section 5.2.3 concerning the processes, inspections, and tests on austenitic stainless steel components to assure freedom from increased susceptibility to intergranular corrosion caused by sensitization, and the discussions provided in Section 5.2.3 on the control of welding of austenitic stainless steels, especially control of delta ferrite, are applicable to the austenitic stainless steel pressure housing components of the CRDM.

4.5.1.3 Contamination Protection and Cleaning of Austenitic Stainless Steel

The CRDM's are cleaned prior to delivery in accordance with the guidance of ANSI 45.2.1. Process specifications in packaging and shipment are discussed in Section 5.2.3. Although the procedure at the construction site is not in the Westinghouse Nuclear Steam Supply System scope of supply, Westinghouse personnel do conduct surveillance of these operations to assure that manufacturers and installers adhere to appropriate requirements as discussed in Section 5.2.3.

4.5.2 Reactor Internals Materials

4.5.2.1 Materials Specifications

All the major material for the reactor internals is Type 304 stainless steel. Parts not fabricated from Type 304 stainless steel include bolts and dowel pins which are fabricated from Type 316 stainless steel and radial support key bolts which are fabricated of Inconel-750. These materials are listed in Table 5-8. There are no other materials used in the reactor internals or core support structures which are not otherwise included in the ASME Code, Section III, Appendix I.

4.5.2.2 Controls on Welding

The discussions provided in Section 5.2.3 are applicable to the welding of reactor internals and core support components.

4.5.2.3 Fabrication and Processing of Austenitic Stainless Steel Components

The discussion provided in Section 5.2.3.4 verifies conformance of reactor internals and core support structures with Regulatory Guide 1.44.

Regulatory Guide 1.36 is not applicable to the reactor vessel internals since no insulation material of any kind is used on these structures.

The discussion provided in Section 5.2.3.4.6 verifies conformance of reactor internals and core support structures with Regulatory Guide 1.31.

The discussion provided in Section 5.3.1.4 verifies conformance of reactor internals with Regulatory Guide 1.34.

The discussion provided in Section 5.3.1.4 verifies conformance of reactor internals and core support structures with Regulatory Guide 1.71.

4.5.2.4 Contamination Protection and Cleaning of Austenitic Stainless Steel

The discussion provided in Section 5.2.3.4 is applicable to the reactor internals and core support structures and verify conformance with ANSI 45 specifications and Regulatory Guide 1.37.

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.5.

4.6 Functional Design of Reactivity Control Systems

4.6.1 Information for Control Rod Drive System (CRDS)

The CRDS is described in Section 3.9.4.1. Figure 3-293 and Figure 3-294 provide the details of the control rod drive mechanisms, and Figure 4-9 provides the layout of the CRDS. No hydraulic system is associated with its functioning. The instrumentation and controls for the Reactor Trip System are described in Section 7.2 and the Reactor Control System is described in Section 7.7.

4.6.2 Evaluation of the CRDS

The CRDS has been analyzed in detail in a failure mode and effects analysis (FMEA) (Reference 1). This study, and the analyses presented in Section Chapter 15, demonstrates that the CRDS performs its intended safety function, a reactor trip, by putting the reactor in a subcritical condition when a safety system setting is approached, with any assumed credible failure of a single active component. The essential elements of the CRDS (Those required to ensure reactor trip) are isolated from non-essential portions of the CRDS (The Rod Control System) as described in Section 7.2.

Despite the extremely low probability of a common mode failure impairing the ability of the Reactor Trip System to perform its safety function, analyses have been performed in accordance with the requirements of WASH-1270. These analyses documented in References 2 and 3 have demonstrated that acceptable safety criterion would not be exceeded even if the CRDS were rendered incapable of functioning during a reactor transient for which their function would normally be expected.

The design of the control rod drive mechanism is such that failure of the control rod drive mechanism cooling system will, in the worst case, result in an individual control rod trip of a full reactor trip (see Section 9.2).

4.6.3 Testing and Verification of the CRDS

The CRDS is extensively tested prior to its operation. These tests may be subdivided into five categories, 1) prototype tests of components, 2) prototype CRDS tests, 3) production tests of components following manufacture and prior to installation, 4) onsite preoperational and initial startup tests, and 5) periodic inservice tests. These tests which are described in Sections 3.9.4.4, 14.2, and 3.1.4 (of the Technical Specifications) are conducted to verify the operability of the CRDS when called upon to function.

4.6.4 Information for Combined Performance of Reactivity Systems

As is indicated in Chapter 15, the only postulated events which assume credit for reactivity control systems other than a reactor trip to render the plant subcritical are the steam line break, feedwater line break, and loss of coolant accident. The reactivity control systems for which credit is taken in these accidents are the reactor trip and the Safety Injection System (SIS). Additional information on the CRDS is presented in Section 3.9.4 and on the SIS in Section 6.3. Note that no credit is taken for the boration capabilities of the Chemical and Volume Control System (CVCS) as a system in the analysis of transients presented in Chapter 15. Information on the capabilities of the CVCS is provided in Section 9.3.4. The adverse boron dilution possibilities due to the operation of the CVCS are investigated in Section 15.4.6. Prior proper

operation of the CVCS has been presumed as an initial condition to evaluate transients and appropriate Controls have been prepared to ensure the correct operation or remedial action.

4.6.5 Evaluation of Combined Performance

The evaluation of the steam line break, feedwater line break and loss of coolant accident which presume the combined actuation of the Reactor Trip System to the CRDS and the SIS are presented in Sections 15.1.5, 15.2.8, and 15.6.5. Reactor trip signals and safety injection signals for these events are generated from functionally diverse sensors and actuate diverse means of reactivity control, i.e., control rod insertion and injection of soluble poison.

Non-diverse but redundant types of equipment are only utilized in the processing of the incoming sensor signals into appropriate logic which initiates the protective action. This equipment is described in detail in Section 7.2 and 7.3. In particular, note that protection from equipment failures is provided by redundant equipment and periodic testing. Effects of failures of this equipment have been extensively investigated as reported in Reference 4. This FMEA verifies that any single failure will not have a deleterious effect upon the Engineering Safety Features Actuation System. Adequacy of the Emergency Core Cooling System and SIS performance under faulted conditions is verified in Section 6.3.

4.6.6 References

1. Shopsy, W. D., "Failure Mode and Effects Analysis (FMEA) of the Solid State Full Length Rod Control System," WCAP-8976, September 1977.
2. "Westinghouse Anticipated Transients Without Trip Analysis," WCAP-8330, August 1974.
3. Gangloff, W. C. and Loftus, W. D., "An Evaluation of Solid State Logic Reactor Protection in Anticipated Transients," WCAP-7706-L (Proprietary) and WCAP-7706 (Non-Proprietary), February 1971.
4. Mesmeringer, J. C., "Failure Mode and Effects Analysis (FMEA) of the Engineering Safeguard Features Actuation System," WCAP-8584 Revision 1, (Proprietary) and WCAP-8760 Revision 1, (Non-Proprietary), February 1980.

THIS IS THE LAST PAGE OF THE TEXT SECTION 4.6.