

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) BYRON, UNIT 1						DOCKET NUMBER (2) 0 5 0 0 0 4 5 4			PAGE (3) 1 OF 2	
------------------------------------	--	--	--	--	--	--------------------------------------	--	--	--------------------	--

TITLE (4)  
MISSED SURVEILLANCE FOR 2A DIESEL GENERATOR

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)
0	1	1	1	8	5	0	0	5				0 5 0 0 0
												0 5 0 0 0

OPERATING MODE (9) 3	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)												
POWER LEVEL (10) 01010	<input type="checkbox"/> 20.406(a)(i)	<input type="checkbox"/> 20.406(a)(ii)	<input type="checkbox"/> 20.406(a)(iii)	<input type="checkbox"/> 20.406(a)(iv)	<input type="checkbox"/> 20.406(a)(v)	<input checked="" type="checkbox"/> 20.406(a)(vi)	<input type="checkbox"/> 20.406(a)(vii)	<input type="checkbox"/> 20.406(a)(viii)	<input type="checkbox"/> 20.406(a)(ix)	<input type="checkbox"/> 20.406(a)(x)	<input type="checkbox"/> 20.406(a)(xi)	<input type="checkbox"/> 20.406(a)(xii)	<input type="checkbox"/> 20.406(a)(xiii)
	<input type="checkbox"/> 60.73(a)(1)(i)	<input type="checkbox"/> 60.73(a)(1)(ii)	<input type="checkbox"/> 60.73(a)(1)(iii)	<input type="checkbox"/> 60.73(a)(1)(iv)	<input type="checkbox"/> 60.73(a)(1)(v)	<input type="checkbox"/> 60.73(a)(1)(vi)	<input type="checkbox"/> 60.73(a)(1)(vii)	<input type="checkbox"/> 60.73(a)(1)(viii)	<input type="checkbox"/> 60.73(a)(1)(ix)	<input type="checkbox"/> 60.73(a)(1)(x)	<input type="checkbox"/> 60.73(a)(1)(xi)	<input type="checkbox"/> 60.73(a)(1)(xii)	<input type="checkbox"/> 60.73(a)(1)(xiii)
	OTHER (Specify in Abstract below and in Part, NRC Form 306A)												

LICENSEE CONTACT FOR THIS LER (12) Daryl Prisby, System Test Engineer, Ext. 603							TELEPHONE NUMBER 8 1 1 5 2 3 4 - 1 5 1 4 4 1				
NAME							AREA CODE				

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
A	E R	D I G	C 6 3 4	N					

SUPPLEMENTAL REPORT EXPECTED (14)			EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE: ) <input checked="" type="checkbox"/> NO						

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

A daily surveillance for the 2A Diesel Generator was not performed. Upon discovery of this condition, the surveillance was immediately performed and completed satisfactorily. Licensed operators have been reminded of the importance of performing required surveillances on schedule.

IE 22  
|||

8502130519 850126  
PDR ADOCK 05000454  
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  BYRON, UNIT 1	DOCKET NUMBER (2)  0   5   0   0   0   4   5   4	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8   5	-   0   0   5	-   0   0	0   2	OF	2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On 1/10/85 at 2205 the plant entered Mode 3 for the first time. Tech Spec requirements for this mode, include performing the daily surveillance for the 2A Diesel Generator. On 1/11/85 at 2359 with the plant still in Mode 3, the 2A DG surveillance was not performed, thus violating Tech Spec surveillance requirement 4-8.13. After this condition was discovered, the surveillance was immediately performed and produced successful results.

At the time of the violation, there were no core alterations or positive reactivity insertions being made and hence, with the plant in Mode 3, there was no impact on plant or public safety.

As a preventative action, a revision has been made to the shiftly and daily operating surveillance data package cover sheet LBOS 0.1-3. This revision lists the 2A Diesel Generator Daily Surveillance LBOS 8.1.3.a-1 under documents to be attached. A further revision is being implemented which would require a check off for documents attached. There have been no previous occurrences.



**Commonwealth Edison**  
Byron Nuclear Station  
4450 North German Church Road  
Byron, Illinois 61010

January 26, 1985

LTR: BYRON 85-0136

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Dear Sir:

The enclosed Licensee Event Report from Byron Generating Station is being transmitted to you in accordance with the requirements of 10CFR50.73(a)(2)(i) which requires a 30 day written report.

This report is number 85-005-00, Docket No. 50-454.

Very truly yours,

for R. E. Querio  
Station Superintendent  
Byron Nuclear Power Station

REQ/vda

Enclosure: Licensee Event Report No. 85-005-00

cc: J. G. Keppler, NRC Region III Administrator  
J. Hinds, NRC Resident Inspector  
INPO Record Center  
CECO Distribution List

IE22  
11