

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[01] M D C C N 2 [2] 0 0 - 0 0 0 0 0 - 0 0 [3] 4 1 1 1 1 [4] [] [] [5]

CON'T [01] REPORT SOURCE [L] [6] 0 5 0 0 0 3 1 8 [7] 1 2 2 0 8 3 [8] 1 0 1 7 8 4 [9]

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[02] At 1140 during normal operation, Reactor Protection System Channel D for
[03] Steam Generator Low Pressure trip was found to be inoperable T.S.
[04] 3.3.1.1 The trip unit was repaired and returned to service at 1235.
[05] The three redundant channels remained operable during this event.
[06] Similar events: none.
[07]
[08]

[09] SYSTEM CODE [I] [A] [11] CAUSE CODE [E] [12] CAUSE SUBCODE [G] [13] COMPONENT CODE [I] [N] [S] [T] [R] [U] [14] COMP. SUBCODE [P] [15] VALVE SUBCODE [Z] [16]
[17] LER/R-1 REPORT NUMBER [8] [3] SEQUENTIAL REPORT NO. [0] [7] [3] OCCURRENCE CODE [] [0] [3] REPORT TYPE [X] [] REVISION NO. [1]
ACTION TAKEN [C] [18] FUTURE ACTION [X] [19] EFFECT ON PLANT [Z] [20] SHUTDOWN METHOD [Z] [21] HOURS [0] [0] [0] [0] ATTACHMENT SUBMITTED [N] [23] NRPD-4 FORM SUB. [Y] [24] PRIME COMP. SUPPLIER [N] [25] COMPONENT MANUFACTURER [P] [3] [1] [4]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[10] Channel D inoperability was due to Power Supply failure (Power Mate No.
[11] DRA 15-0.750) which was replaced and channel returned to service. Power
[12] Supply was returned to manufacturer who replaced 10 capacitors and one
[13] diode with no corrective action recommended. Due to discontinuing model
[14] production we are evaluating replacement. No further action required.

[15] FACILITY STATUS [E] [28] % POWER [1] [0] [0] [29] OTHER STATUS [N/A] [30] METHOD OF DISCOVERY [B] [31] DISCOVERY DESCRIPTION [Technician Observation] [32]

[16] ACTIVITY RELEASED [Z] [33] CONTENT OF RELEASE [Z] [34] AMOUNT OF ACTIVITY [N/A] [35] LOCATION OF RELEASE [N/A] [36]

[17] PERSONNEL EXPOSURES NUMBER [0] [0] [0] [37] TYPE [Z] [38] DESCRIPTION [N/A] [39]

[18] PERSONNEL INJURIES NUMBER [0] [0] [0] [40] DESCRIPTION [N/A] [41]

[19] LOSS OF OR DAMAGE TO FACILITY TYPE [Z] [42] DESCRIPTION [N/A] [43] 8410300453 841017 PDR ^DOCK 05000318 S PDR

[20] PUBLICITY ISSUED [N] [44] DESCRIPTION [N/A] [45] NRC USE ONLY

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

October 18, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Docket No. 50-318
License No. DPR 69

Dear Sirs:

The attached revision to LER 83-73/3L is being forwarded to you for your information.

Should you have any questions regarding this report, we would be pleased to discuss them with you.

Very truly yours,

LBR

L. B. Russell
Plant Superintendent

LBR:RA^{R.A.}mdh

cc: Dr. Thomas E. Murley
Director, Office of Management Information
and Program Control
Messrs: A. E. Lundvall, Jr.
J. A. Tiernan

IE22
11