

1901 Chouteau Avenue  
Post Office Box 149  
St. Louis, Missouri 63166  
314-554-2650

**UNION ELECTRIC** February 28, 1996

Donald F. Schnell  
Senior Vice President  
Nuclear

cc U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Gentlemen:

ULNRC-03342

DOCKET NUMBER 50-483  
CALLAWAY PLANT

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION  
CONCERNING THE REVISION TO TECHNICAL SPECIFICATION  
3/4.8.1, A.C. SOURCES

Reference: ULNRC-3244, dated July 25, 1995

This letter transmits revised technical specification pages that were previously provided by the referenced letter and additional information requested in telephone conversations between Union Electric, Wolf Creek Nuclear Operating Corporation personnel and the NRC Staff. The conclusions reached in the Safety Evaluation, the Significant Hazards Evaluation, and the Environmental Consideration transmitted by the above reference are still applicable.

Attachment 1 responds to questions and comments presented by the NRC. Attachments 2 provides revised Technical Specification Pages.

If you have any questions concerning this matter, please contact me.

Very truly yours,

Donald F. Schnell

JMC/mlo  
Attachments

040123

9603050041 960228  
PDR ADOCK 05000483  
P PDR

AOD11

STATE OF MISSOURI      )  
                              )      S S  
CITY OF ST. LOUIS      )

Donald F. Schnell, of lawful age, being first duly sworn upon oath says that he is Senior Vice President-Nuclear and an officer of Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By

Donald F. Schnell

Donald F. Schnell  
Senior Vice President  
Nuclear

SUBSCRIBED and sworn to before me this Twenty-eighth day  
of February, 1996.

Barbara J. Pfaff

BARBARA J. PFAFF  
NOTARY PUBLIC - STATE OF MISSOURI  
MY COMMISSION EXPIRES APRIL 22, 1997.  
ST. LOUIS COUNTY

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

M. H. Fletcher  
Professional Nuclear Consulting, Inc.  
19041 Raines Drive  
Derwood, MD 20855-2432

L. Joe Callan  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive  
Suite 400  
Arlington, TX 76011-8064

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Kristine M. Thomas (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E16  
11555 Rockville Pike  
Rockville, MD 20852-2738

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102

Don Woodlan  
TU Electric  
1601 Bryan Street  
Dallas, TX 75201-3411

Pat Nugent  
Pacific Gas & Electric  
Regulatory Services  
P.O. Box 56  
Avila Beach, CA 93424

bcc: D. Shafer/A160.761  
/QA Record (CA-758)  
E210.01  
DFS/Chrono  
D. F. Schnell  
J. E. Birk  
J. V. Laux  
R. D. Affolter  
G. L. Randolph  
R. J. Irwin  
P. M. Barrett  
J. D. Blosser  
A. C. Passwater  
D. E. Shafer  
W. E. Kahl  
S. Wideman (WCNOC)  
F. C. Wilks, PE (Bechtel)  
H. D. Bono  
NSRB (Patty Reynolds)  
J. M. Chapman  
A140.0001.002(1170)

Response to Request for Additional Information

The information in brackets [ ] is Technical Specification number/information specific to the Union Electric (UE) submittal.

NRC Comment 1:

Proposed Technical Specification Bases 3/4.8 and 6.8g - Diesel Fuel Oil Testing Program. Wolf Creek Nuclear Operating Corporation (WCNOC) and UE should use "in accordance with" referring to requirements in applicable ASTM Standards.

Response:

WCNOC and UE had proposed to delete the phrase "in accordance with" and replace it with "based on" to allow minor exceptions from a specific ASTM standard while still meeting the intent of the standard. These exceptions are sometimes necessary due to the impracticality of a test or due to an ASTM standard not being meant for diesel fuel oil. In a telecon with the NRC on June 16, 1995 it was agreed that these exceptions should be listed in the Bases. Since these exceptions are listed in the Bases and are not required to be changed via a license amendment, acceptable flexibility is provided. Therefore, the wording in proposed Technical Specification Bases 3/4.8 and 6.8g has been revised to use the phrase "in accordance with."

NRC Comment 2.

The new Administrative Controls Sections 6.5.1.6i [6.5.1.6q] and 6.5.2.8m [6.5.2.8l], which were submitted by Reference 2, refer to Standard Technical Specifications Sections 5.5.1.2 and 5.5.2.3 respectively, but these sections are not in, NUREG-01431, Revision 1, "Westinghouse Standard Technical Specifications."

Response:

Item i [Item q] was being proposed to be added to Technical Specification 6.5.1.6 to require that the Plant Safety Review Committee [On-site Review Committee] be responsible for the review of the Diesel Fuel Oil Testing Program. This proposed change was consistent with Section 5.5.1.2 of NUREG-1431, Revision 0, "Westinghouse Standard Technical Specifications."

A new item m [item l] was proposed to be added to Technical Specification 6.5.2.8 to require audits of the Diesel Fuel Oil Testing Program be performed under the cognizance of the Nuclear Safety Review Committee [Nuclear Safety Review Board]. This proposed change was consistent with Section 5.5.2.3 of NUREG-1431, Revision 0.

In a telecon with the NRC on June 16, 1995 it was recommended that WCNO and UE follow what had been submitted and approved for the Florida Power and Light, Turkey Point Units (letter dated October 20, 1994). The above changes were consistent with what had been approved for Florida Power and Light. WCNO and UE have reviewed NUREG-1431, Revision 1 and concur with the NRC that these requirements are not in revision 1 of the Standard Technical Specifications. Based on this information and the latest discussions with the NRC Staff, WCNO and UE have revised these pages to delete 6.5.1.6i [6.5.1.6q] and 6.5.2.8m [6.5.2.81].

NRC Comment 3.

Provide additional justification for removal of Surveillance Requirement 4.8.1.1.2g.2 [4.8.1.1.2f.2], single-load rejection test, from Technical Specifications.

Response:

The justification for deletion of the single-load rejection test takes into account diesel generator responses to previously performed full-load rejection and single-load rejection tests as well as plant events that have occurred during this testing. The single-load rejection test is an insignificant transient compared to the other transient tests being performed and is a duplication of the testing of the generator and engine capabilities to handle a transient. The justification includes:

- **Enveloping the Single-Load Rejection Test**

A. The single-load rejection test is enveloped by the full load rejection test since the proposed change revises the frequency criteria to  $60 \pm 5.4$  Hertz which is the current frequency for the single largest load rejection test. Figure 1 provides a strip chart recording for the Callaway Plant for a typical full-load rejection test. Figure 2 provides a recording for Wolf Creek Generating Station (WCGS) of a typical full-load rejection test.

B. The single-load rejection test is enveloped since the initial diesel generator loading sequencing produces a voltage and frequency swing much larger than that caused by rejection of the single largest load. This is because the locked rotor currents and torque changes of the starting motor have a larger effect than that of the same motor being rejected. The diesel generator returning to steady state values, indicates that the governor is working to handle load changes both positive and negative (frequency swings) and the voltage regulator is handling both positive and negative changes (voltage swings). When the largest load is sequenced onto the diesel generator with the majority of the other loads already sequenced on, the governor, the engine,

and the regulator/ exciter are tested and sufficient margin is available to handle a transient at least equivalent to the loss of the single largest load, if recovery to steady state values occur.

The voltage and frequency swings for the single - load rejection test at WCGS and Callaway Plant stay within steady state values at all times in the transient. The voltage and frequency swings that occur during the load sequencing are much greater than the swings during the rejection and indicate that the connected loads can handle the transient of the single-load rejection. Figures 3 and 4 demonstrate that the single-load rejection test is not significant for demonstrating operability of the diesel generator.

Figure 3 provides a strip chart recording for the Callaway Plant that is typical of the "Blackout Load Sequencing the ESW Pump Load Rejection Tests." It indicates that the sequencing load transients are of a much greater magnitude than the Essential Service Water (ESW) pump load rejection. The voltage and frequency swings on page 4 of Figure 3 for the ESW pump start, shows a minimum of 3323 Vac to a maximum of 4600 Vac for the voltage transient and a minimum of 58.2 Hz to a maximum of 61.1 Hz for the frequency transient. The duration of the transient to steady state was 1.7 seconds for the voltage transient and 3.0 seconds for the frequency transient. The ESW pump rejection shown on page 7 of Figure 3 indicates no minimum voltage transient and a rise from the steady state voltage of 4155 Vac to a maximum of 4234 Vac with a duration of 0.2 seconds. The frequency transient shows no minimum frequency transient and a rise from the steady state frequency of 60.2 Hz to a maximum of 60.6 Hz with a duration of 1.1 seconds.

Figure 4 provides a recording of voltage and frequency for WCGS during a typical single-load rejection test (pump trip followed by a pump start). During the single-load rejection test, initial voltage was established at 3990 Vac and frequency was 60 Hertz. When the ESW pump was tripped the maximum transient voltage was 4042 Vac (52 Vac swing) and the maximum frequency was 60.4 Hertz (0.4 Hertz swing). The transient caused by starting the pump was much greater. Voltage ranged from 3307 Vac to 4357 Vac (1050 Vac swing). Frequency ranged from 58.7 to 60.7 (2 Hertz swing).

The voltage regulator action is based on error from the desired voltage setting and the error signal is given a gain. This action is the same in both positive and negative directions and there are no dead bands in this process.

- Performance of the Single-Load Rejection test Represents Potential Risk to Other Safety Related Systems.

The ESW pump provides cooling water for the diesel generator. the pump must successfully be restarted within five minutes after shutdown or the emergency diesel generator must be shutdown. Stopping and restarting the ESW pump can produce water hammer events which are undesirable occurrences and can cause damage to the system. These water hammer events are caused by the system producing vacuum areas at high points and the partial draindown of the system when the pump is stopped.

NRC Inspection Reports 50-483/92009, 50-482/9131, and 50-482/9136 provide documented concerns about water hammer events that have occurred at the Callaway Plant and WCGS. NRC Information Notice 92-81 documents the NRC's concerns associated with industry water hammer events. And at least five water hammer events have occurred on the ESW System at Callaway Plant and are documented on internal corrective action documents.

- Rejection of a Combination of Other Loads Equivalent to the Largest Load.

It would not be feasible to use a combination of other loads equivalent to the ESW pump as a replacement for the single-load rejection test. The ability to reject these loads simultaneously from the diesel generator, to produce any meaningful data, currently does not exist at WCGS or Callaway Plant. In order to perform this test using equivalent loads, plant system modifications would have to be made to be able to simultaneously reject these loads such that the data obtained would represent a meaningful test. These modifications could introduce failure mechanisms into the affected systems that would otherwise not have been there, thus impacting the ability of these systems to perform their intended safety functions.

NRC Comment 4.

Surveillance Requirement 4.8.1.1.2g.8 [4.8.1.1.2f.8] - verification that auto connected loads do not exceed 6201 kW. The NRC Staff requested additional information on whether this surveillance was being deleted or relocated to another document. Additionally, the staff requested how this surveillance was performed.

Response:

WCNOC and UE requested Surveillance Requirement 4.8.1.1.2g.8 [4.8.1.1.2f.8] be eliminated from technical specifications. Based on a telephone conversation with the NRC, the surveillance requirement will be relocated to Chapter 16 of the Updated Safety

Analysis Report [Final Safety Analysis Report] and controlled by the 10 CFR 50.59 process.

Total diesel generator kW load is determined using surveillance procedure STS KJ-001A [ISP-SA-2413A], "Integrated D/G and Safeguards Actuation Test Train A," and STS KJ-001B [ISP-SA-2413B], "Integrated D/G and Safeguards Actuations Test Train B." The requirements of these procedures take into account indicated amp load, indicated voltage, and power factor. These procedures require that the kW load must be  $\leq$  6201 kW. The results of these tests are trended as part of the Emergency Diesel Generator Reliability Program.

NRC Comment 5.

Surveillance Requirement 4.8.1.1.2h [4.8.1.1.2g] - simultaneous starting of both diesel generators after any modification which could affect diesel generator interdependence. The NRC Staff requested a discussion of how the modification process detects and tracks concerns relating to the interdependence of the diesel generators.

Response:

WCNOC and UE had proposed to revise surveillance requirement 4.8.1.1.2h [4.8.1.1.2g] to eliminate the performance of this surveillance requirement after any modifications which could affect emergency diesel generator interdependence. WCNOC and UE are withdrawing the proposed change as it will be addressed as part of the conversion to the Improved Standard Technical Specification.

NRC Comment 6:

Technical Specification 4.8.1.1.2g.7 (proposed 4.8.1.1.2g.6) [4.8.1.1.2f.7 (proposed 4.8.1.1.2g.6)] - 2 hour overload test. The Technical Specifications should still require the diesel generator operate for greater than 2 hours in an overloaded condition with a footnote indicating that this portion of the surveillance need not be performed provided the auto-connected loads remain below the 6201 kW continuous rating of the diesel generator.

Response:

Proposed Technical Specification 4.8.1.1.2g.6 has been revised to verify the diesel generator operates for greater than or equal to 2 hours loaded to an indicated 6600 to 6821 kW if auto-connected loads increase above 6201 kW. Additionally, WCNOC and UE have retained the existing footnote to provide guidance to avoid routine overloading of the engine.

# TYPICAL FULL LOAD REJECT TRANSIENT

0380825




Figure 1  
Typical Full-Load Rejection Test  
(Page 1 of 1)

Callaway  
Reference  
S453922

STS KJ-001A  
Step 5.3.13  
10/16/94




Figure 2  
Typical Full-Load Rejection Test  
(Page 1 of 1)

R80

8000

psi

KPa

MPa

159  
SN-2413A  
Sector  
7.4  
10/5/93  
08:20  
Run 600ST-D346  
STS-516 249  
10000

psi

KPa

MPa

10000

psi

KPa

MPa

25 mm/sec

0

psi

KPa

MPa

50000

psi

KPa

MPa

0

psi

KPa

MPa

0

psi

KPa

MPa

0

psi

KPa

MPa

0

psi

KPa

MPa

E80

psi

KPa

MPa

8.04

mm

sec



Blackout without SRS - Train A

P111143

Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 1 of 8)

**Breaker step 0  
Energize buses & start CCP**

-0.49 sec:



**End Voltage Build-up**

Figure 3 Blackout Load Sequencing the ESW Pump Load Rejection Tests




Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 3 of 8)




Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 4 of 8)




Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 5 of 8)

57

E  
P  
S




Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 6 of 8)

4155  
Vac

- 4234 Vac

0.2 sec

ESW

PUMP

SHED

60.2 Hz

- 60.6 Hz

1.1 sec




Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 7 of 8)




Figure 3  
Blackout Load Sequencing the ESW Pump Load Rejection  
Tests  
(Page 8 of 8)




Figure 4  
 Single-Load Rejection Test (followed by ESW pump start)  
 (Page 1 of 1)