Mr. William R. McCollum Vice President - Catawba Site Duke Power Company 4800 Concord Road York, SC 29745

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION ON SETPOINT TOLERANCE FOR MAIN STEAM SAFETY VALVES (TAC NO. M94190, M94191)

Dear Mr. McCollum:

By letter dated November 15, 1996, you submitted a proposed amendment to Technical Specification (TS) 3/4.7.1 and the associated Bases to increase the setpoint tolerance of the main steam safety valves (MSSVs) from plus or minus one percent to plus or minus three percent. Additional information is requested, as identified in the enclosure, to enable the staff to continue its review.

This requirement affects nine or fewer responderts, and therefore, it is not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

/s/ Robert E. Martin, Senior Project Manager Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-413, 50-414

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:	JCrlenjak, RII
Docket File	JZwolinski, O-14-E-4
PUBLIC	EMerschoff, RII
PDII-2 R/F	OGC, 0-15 B18
SVarga, 0-14-E-4	ACRS , T-2-E-26
RJones, 0-8-E-23	

9603210325 960319 PDR ADOCK 05000413 P PDR

NRC FILE CENTER COPY

AT DESIGNATION OF THE OWNER OF THE		AND REAL PROPERTY AND ADDRESS OF A DREAM PROPERTY AND ADDRESS OF A DREAM PROPERTY AND ADDRESS OF A DREAM PROPERTY ADDRE	AND REAL PROPERTY AND ADDRESS OF ADDRESS OF ADDRESS OF	The second second second second second second
OFFICE	PDII-2/LA	POLI-2/PM	PDILTZAD	SRXB Gla
NANE	L. BERRY	P. MARTIN	H. BERKOW	RJONES
DATE	3/19/96	3 1/5/96	3/19/96	3115 196
OFFICIA	L RECORD COPY	FILE NAM	E: G:\CATAWBA	A\CAT94190.LTR



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

.....

March 19, 1996

Mr. William R. McCollum Vice President - Catawba Site Duke Power Company 4800 Concord Road York, SC 29745

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION ON SETPOINT TOLERANCE FOR MAIN STEAM SAFETY VALVES (TAC NO. M94190, M94191)

Dear Mr. McCollum:

By letter dated November 15, 1996, you submitted a proposed amendment to Technical Specification (TS) 3/4.7.1 and the associated Bases to increase the setpoint tolerance of the main steam safety valves (MSSVs) from plus or minus one percent to plus or minus three percent. Additional information is requested, as identified in the enclosure, to enable the staff to continue its review.

This requirement affects nine or fewer respondents, and therefore, it is not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

larty

Robert E. Martin, Senior Project Manager Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

1 4

Docket No. 50-413, 50-414

Enclosure: Request for Additional Information

cc w/encl: See next page

Mr. W. R. McCollum Duke Power Company

cc:

Mr. M. S. Kitlan Regulatory Compliance Manager Duke Power Company 4800 Concord Road York, South Carolina 29745

Mr. Paul R. Newton Legal Department (PB05E) Duke Power Company 422 South Church Street Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire Winston and Strawn 1400 L Street, NW Washington, DC 20005

North Carolina Municipal Power Agency Number 1 1427 Meadowwood Boulevard P. O. Box 29513 Raleigh, North Carolina 27626-05()

Mr. Peter R. Harden, IV Account Sales Manager Westinghouse Electric Corporation Power Systems Field Sales P. O. Box 7288 Charlotte, North Carolina 28241

County Manager of York County York County Courthouse York, South Carolina 29745

Richard P. Wilson, Esquire Assistant Attorney General South Carolina Attorney General's Office P. O. Box 11549 Columbia, South Carolina 29211

Piedmont Municipal Power Agency 121 Village Drive Greer, South Carolina 29651

Mr. T. Richard Puryear Owners Group (NCEMC) Duke Power Company 4800 Concord Road York, South Carolina 29745 Catawba Nuclear Station

North Carolina Electric Membership Corporation P. O. Box 27306 Raleigh, North Carolina 27611

Senior Resident Inspector 4830 Concord Road York, South Carolina 29745

Regional Administrator, Region II U. S. Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Max Batavia, Chief Bureau of Radiological Health South Carolina Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201

Mr. G. A. Copp Licensing - EC050 Duke Power Company 526 South Church Street Charlotte, North Carolina 28242-0001

Saluda River Electric P. O. Box 929 Laurens, South Carolina 29360

Ms. Karen E. Long Assistant Attorney General North Carolina Department of Justice P. O. Box 629 Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner Division of Emergency Management 116 West Jones Street Raleigh, North Carolina 27603-1335

Dayne H. Brown, Director Division of Radiation Protection N.C. Department of Environment, Health and Natural Resources P. O. Box 27687 Raleigh, North Carolina 27611-7687

CATAWBA NUCLEAR STATION, UNITS 1 AND 2 REQUEST FOR ADDITIONAL INFORMATION CHANGE OF TECHNICAL SPECIFICATION REGARDING MSSV SETPOINT TOLERANCE

- Provide the details of your reanalyses for the transients and accidents that are affected by the proposed change of MSSV setpoint tolerance including the following:
 - Major transient curves for each of the events reanalyzed, including primary and secondary pressure, DNBR, steam generator water level, subcooling margin, etc.
 - Major assumptions used in these analyses (especially the ones different from the analyses of record).
- Provide the peak clad temperature following a SBLOCA from your reanalysis and compare it with your analysis of record.
- Provide the results of the revised dose analysis following an SGTR considering this change and compare it with your previous analysis of record.
- 4) Confirm that the methodologies used for reanalyses of each event are consistent with those used in the original licensing analyses. Identify any differences in methodology and provide justification.
- 5) Provide clarification for the changes made to TS Table 3.7-1.