

APPENDIX 1

Evaluation of Westinghouse Report WCAP 10456, "The Effects of Thermal Aging on the Structural Integrity of Cast Stainless Steel Piping for Westinghouse Nuclear Steam Supply Systems"

INTRODUCTION

The primary coolant piping in some Westinghouse Nuclear Steam Supply Systems (NSSS) contain cast stainless steel base metal and weld metal. The base metal and weld metal are fabricated to produce a duplex structure of delta (δ) ferrite in an austenitic matrix. The duplex structure produces a material that has a higher yield strength, improved weldability and greater resistance to intergranular stress-corrosion cracking than a single phase austenitic material. However, as early as 1965 (Ref.1), it was recognized that long time thermal aging at primary loop water temperatures (550°F-650°F) could significantly affect the Charpy impact toughness of the duplex structured alloys. Since the Charpy impact test is a measure of a material's resistance to fracture, a loss in Charpy impact toughness could result in reduced structural stability in the piping system.

The purpose of Report WCAP 10456 is to evaluate whether cast stainless steel base metal and weld metal containing postulated cracks will be sensitive to unstable fracture during the 40 year life of a nuclear power plant. In order to determine whether a piping system will behave

in such a fashion, the pipe materials' mechanical properties, design criteria and method of predicting failure must be established. In this evaluation, we will assess the mechanical properties of thermally aged cast stainless steel pipe materials, which are reported in Report WCAP 10456.

DISCUSSION

1. Weld Metal

Report WCAP 10456 refers to test results reported in a paper by Slama, et.al. (Ref. 2) to conclude that the weld metal in primary loop piping would not be overly sensitive to aging and that the aged cast pipe base metal material would be structurally limiting. In the Slama report eight (8) welds were evaluated. The tensile properties were only slightly affected by aging. The Charpy U-notch impact energy in the most highly sensitive weld decreased from 7daJ/cm^2 (40 ft-lbs) to near 4daJ/cm^2 (24 ft-lbs) after aging for 10,000 hours at 400°C (752°F). This change was not considered significant. The relatively small effect of aging on the weld, as compared to cast pipe material was reported to be caused by a difference in microstructure and lower levels of ferrite in the weld than in the cast pipe material.

2. Cast Stainless Steel Pipe Base Metal

Report WCAP 10456 contains mechanical property test results from a number of heats of aged cast stainless steel material and a metallurgical study, which was performed by Westinghouse, to support a statistically based model for predicting the effect of thermal aging on the Charpy impact test properties of cast stainless steel. As a result of these tests and the proposed model, Westinghouse concludes that the fracture toughness test results from one heat of material tested represents end-of-life conditions for the ten (10) plants surveyed. The ten (10) plants surveyed are identified as Plants A through J.

a. Mechanical Property Test Results Reported in WCAP 10456

Mechanical property test results on aged and unaged cast stainless steel materials which were reported in a paper by Landerman and Bamford (Ref. 3), Bamford, Landerman and Diaz (Ref. 4), Slama et. al. (Ref. 2) were discussed in Report 10456. In addition, Westinghouse performed confirmatory Charpy V notch and J-integral tests on aged cast stainless steel material, which was tested and evaluated by Slama et. al.

The results of these tests indicate that:

- (1) The fatigue crack growth rates of aged or unaged material in air and pressurized water reactor environments were equivalent.
- (2) Tensile properties were essentially unaffected except for a slight increase in tensile strength and a decrease in ductility.
- (3) J-integral test results indicate that the J_{1C} and tearing modulus, T , are affected by aging.

b. Mechanism Study in WCAP 10456

The tests and literature survey conducted by Westinghouse indicate that the proposed mechanism of aging occurs in the range of operating temperatures for pressurized water reactors and the data from accelerated aging studies can be used to predict the behavior at operating temperatures.

c. Cast Stainless Steel Pipe Test

The materials data discussed in the previous section of this evaluation were obtained from small specimens. As a consequence, the J-R results are limited to relatively short crack extensions. To investigate the behavior of cast stainless steel in actual piping geometry, Westinghouse performed two experiments, one of which was with thermally aged cast stainless steel and the other test was identical except that the steel was not thermally aged.

Each pipe tested contained a throughwall circumferential crack to the extent specified in WCAP 10456. The pipe sections were closed at the ends, pressurized to nominal PWR operating pressure and then bending loads were applied.

The results of the tests were very similar, in that both pipes displayed extensive ductility, and stable crack extension. There was no observed unstable crack extension or fast fracture.

The results of the Westinghouse pipe experiments indicate that cast stainless steel, both aged and unaged, can withstand crack extensions well beyond the range of the J-R results with small specimens. However, if crack extension is predicted in an actual application of thermally aged cast stainless steel in a piping system, we believe that it is prudent to limit the applied J to 3000 in-lbs/in² or less unless further studies and/or experiments demonstrate that higher values are tolerable. Loss of initial toughness due to thermal aging of cast stainless steels at normal nuclear facility operating temperatures occurs slowly over the course of many years; therefore, continuing study of the aging phenomenon may lead to a relaxation of this position. Conversely, in the unlikely event that the total loss of toughness and the rate of toughness are greater than those projected in this evaluation, the staff will take appropriate action to limit the values to that which can be justified by experimental data. Because the aging is a slow process, the staff believes there would be sufficient time for the staff to recognize the problem and to rectify the situation. However, the staff believes this situation is highly unlikely because the staff has accepted only the lower bounds of data that were gathered among ten plants encompassing the range of materials in use.

d. Effects of Thermal Aging on Westinghouse Supplied Centrifugally Cast Reactor Coolant Piping Reported in WCAP 10456

The reactor coolant cast stainless steel piping materials in the plants identified in WCAP 10456 as A through J, were produced to the specification SA-351, Class CF8A as outlined in ASME Code Section II, Part A and also to Westinghouse Equipment Specification G-678864, as revised. For these materials, Westinghouse has calculated the predicted end-of-life Charpy U-notch properties, based on their proposed model. The two (2) standard deviation end-of-life lower limit value for all the plants surveyed was greater than the Charpy U notch properties of the aged reference materials, which Westinghouse indicates represents end-of-life properties for all the plants. As a result, Westinghouse concluded that the amount of embrittlement in the aged reference material exceed the amount projected at end-of-life for all cast stainless steel pipe materials in Plants A through J.

Conclusions

Based on our review of the information and data contained in Westinghouse Report WCAP 10456, we conclude that:

1. Weld metal that is used in cast stainless steel piping system is initially less fracture resistant than the cast stainless steel base metal. However, the weld metal is less susceptible to thermal aging than the cast stainless steel base metal. Hence, at end-of-life the cast stainless steel base metal is anticipated to be the least fracture resistant material.

2. The Westinghouse proposed model may be used to predict the relative amount of embrittlement on a heat of cast stainless steel material. The two standard deviation lower confidence limit for this model will provide a useful engineering estimate of the predicted end-of-life Charpy impact properties for cast stainless steel base metal.

3. Since there is considerable scatter in J-integral test data for the heats of material tested, lower bound values for J_{1c} and T should be used as engineering estimates for the fracture resistance of the aged reference material. We believe these values should also provide a lower bound for the fracture resistance of aged and unaged weld metal. If crack extension is predicted in an actual application of cast stainless steel in a piping system, we conclude that the applied J should be limited to 3000 in-lbs/in² or less unless further studies and tests demonstrate that higher values are tolerable. The Westinghouse pipe tests demonstrate that this may be possible.

4. Since the predicted end-of-life Charpy impact values for the materials in Plants A through J are greater than the value measured for the aged reference material, the lower bound fracture properties for aged reference material may be used to determine the fracture resistance for the cast stainless steel material in Plants A through J.

REFERENCES

- (1) F. H. Beck, E. A. Schoefer, J. W. Flowers, M. E. Fontana, "New Cast High Strength Alloy Grades by Structural Control," ASTM STP 369 (1965)
- (2) G. Slama, P. Petrequin, S. H. Masson, T. R. Mager, "Effect of Aging on Mechanical Properties of Austenitic Stainless Steel Casting and Welds," presented at SMIRT 7 Post Conference Seminar 6 - Assuring Structural Integrity of Steel Reactor Pressure Boundary Components, August 29/30, 1983, Monterey, Ca.
- (3) E. I. Landerman and W. H. Bamford, "Fracture Toughness and Fatigue Characteristics of Centrifugally Cast Type 316 Stainless Steel After Simulated Thermal Service Conditions. Presented at the Winter Annual Meeting of the ASME, San Francisco, Ca., December 1978 (MPC-8 ASME)
- (4) W. H. Bamford, E. I. Landerman and E. Diaz, "Thermal Aging of Cast Stainless Steel and Its Impact on Piping Integrity." Presented at ASME Pressure Vessel and Piping Conference, Portland, Oregon, June 1983. To be published in ASME Trans.