




**GULF STATES UTILITIES COMPANY**

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704  
AREA CODE 409 838 6631

February 1, 1985  
RBG- 20065  
File Nos. G9.5, G9.25.1.1

Mr. Robert D. Martin, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV, Office of Inspection and Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011



Dear Mr. Martin:

River Bend Station Unit 1  
Docket No. 50-458  
Final Report/DR-197

Gulf States Utilities Company (GSU) has completed its evaluation of DR-197 concerning the consequence of the seismic testing on the mechanical portion of compressor assembly ILSV\*C3A supplied by Tennessee Valley Authority. An analytical evaluation (4221.512-327-006A) concludes that the mechanical portion of ILSV\*C3A and the motor have sufficient capacity to sustain one SSE and five OBEs during the lifetime of the plant. GSU has therefore determined this condition is not reportable under 10CFR50.55(e). Qualification of the remaining electrical equipment is considered as part of the overall equipment qualification program.

Sincerely,

*William J. Reid*  
for J. E. Booker  
Manager-Engineering,  
Nuclear Fuels & Licensing  
River Bend Nuclear Group

8502150540 850201  
PDR ADOCK 05000458  
S PDR

*M*  
JEB/VJD/lp

cc: Director of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

NRC Resident Inspector-Site

110  
IE-27