

OPERATING DATA REPORT

DOCKET NO. 50-298
 DATE 1-3-85
 COMPLETED BY J.K. Salisbury
 TELEPHONE 402-825-3811

OPERATING STATUS

1. Unit Name: Cooper Nuclear Station
2. Reporting Period: December, 1984
3. Licensed Thermal Power (MWt): 2381
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764

Notes

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.0	8,784.0	92,089.0
12. Number Of Hours Reactor Was Critical	0.0	5,952.6	72,955.6
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	0.0	5,902.3	71,820.6
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0.0	10,926,853.0	141,440,011.0
17. Gross Electrical Energy Generated (MWH)	0.0	3,618,141.0	45,024,496.0
18. Net Electrical Energy Generated (MWH)	0.0	3,469,953.0	43,386,612.0
19. Unit Service Factor	0.0	67.2	78.0
20. Unit Availability Factor	0.0	67.2	78.0
21. Unit Capacity Factor (Using MDC Net)	0.0	51.7	61.7
22. Unit Capacity Factor (Using DER Net)	0.0	50.8	60.6
23. Unit Forced Outage Rate	0.0	2.2	3.7

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
1984 Refueling and Maintenance Outage starting September 16, 1984, with an
approximate 7 month duration.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 1, 1985

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

8502150635 841231
 PDR ADOCK 05000298
 R PDR

IE24
1/1

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-298

UNIT CNS

DATE 1-3-85

COMPLETED BY J.K. Salisbury

TELEPHONE 402-825-3811

MONTH December, 1984

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-298
 UNIT NAME CNS
 DATE 1-3-85
 COMPLETED BY J.K. Salisbury
 TELEPHONE 402-825-3811

REPORT MONTH December, 1984

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
(None during this reporting period)									

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)


³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

Operations Narrative
Cooper Nuclear Station
December, 1984

The plant remained shutdown in the month of December for the 1984 Refueling and Maintenance Outage.



Nebraska Public Power District

COOPER NUCLEAR STATION
P.O. BOX 98, BROWNVILLE, NEBRASKA 68321
TELEPHONE (402) 825-3811

CNSS850001

January 3, 1985

Director, Office of Management Information
and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Monthly Operation Status Report for December 1984
Docket No. 50-298

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for December 1984. The report includes Operating Status, Average Daily Unit Power Level, Unit Shutdown Data, and a Narrative Summary of Operating Experience.

Should you have any comments or require additional information regarding this report, please contact me.

Sincerely,

P. V. Thomason
Division Manager of
Nuclear Operations

PVT:lb

Enclosure

cc: G. D. Watson w/enc.
A. C. Gehr w/enc.
R. D. Martin w/enc.

IE24
1/1