

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

February 11, 1985

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 85-028
NO/JHL:acm
Docket No. 50-339
License No. NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NO. 2
PROPOSED TECHNICAL SPECIFICATION CHANGE


Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment, in the form of a change to the Technical Specifications, to Operating License NPF-7 for North Anna Power Station, Unit No. 2.

The proposed change revises Technical Specification 3/4.4.7, Table 4.4-3, for North Anna Unit No. 2, to eliminate the requirement from sampling chlorides and fluorides when the reactor coolant system is drained below the reactor pressure vessel nozzles and the internals and/or head are in place. The proposed change for North Anna Unit No. 2 is provided in Attachment 1. A discussion of the proposed change is provided in Attachment 2.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this request does not involve an unreviewed safety question as defined in 10CFR50.59 and it does not pose a significant hazards consideration as defined in 10CFR50.92.

We have reviewed this request in accordance with the criteria in 10 CFR 170.12. A voucher check in the amount of \$150 is enclosed as an application fee.

Very truly yours,


W. L. Stewart

8502190030 850211
PDR ADOCK 05000339
P PDR

Rec'd upack \$150.00
A001
1/1

VIRGINIA ELECTRIC AND POWER COMPANY TO

Harold R. Denton

Attachments

1. Proposed Technical Specification Change
2. Discussion of Proposed Technical Specification Change
3. Voucher Check for \$150

cc: Mr. James P. O'Reilly
Regional Administrator
Region II

Mr. M. W. Branch
NRC Resident Inspector
North Anna Power Station

Mr. Charles Price
Department of Health
109 Governor Street
Richmond, Virginia 23219

