

UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20345

NOV 21 1973

DOCKET NO. 50-219

LICENSEE: Jersey Central Power & Light Company (JCPL)

FACILITY: Oyster Creek Nuclear Generating Station (OC)

SUMMARY OF MEETING HELD ON NOVEMBER 13, 1973, TO DISCUSS THE OC QUALITY ASSURANCE PROGRAM FOR OPERATIONS

On November 13, 1973, representatives of JCPL and GPU Service Corporation met with members of the Regulatory staff to discuss the draft of JCPL's revised QA Program. This revision responds to the request for more detailed information that was sent to the licensee by letter dated July 3, 1973, and also incorporates the results of discussions held at the meeting with the Regulatory staff on September 5, 1973. Representatives of Metropolitan Edison attended the meeting as observers.

A list of the attendees is attached to this report. Significant points discussed are summarized below.

D. Gaines, QA Manager, JCPL, described the present status of their QA effort. Procedures for the QA Manual were being written at that time by JCPL with assistance by consultants from MPR Associates and NUS. He characterized the work level as approximately nine people working full time on these procedures. Priorities were being given to those procedures which are required at the earliest time.

Mr. Cummins of the Regulatory staff gave favorable comments about the JCPL draft. He stated that commitments should be made in the appropriate sections of the document to applicable ANSI Standards and Regulatory Guides. In response to JCPL's concern that this would be an open-ended commitment to revisions of these documents that would cause them to be in violation of their program as soon as revisions were issued, Mr. Cummins stated that the commitments should be to a specific revision and/or date of the appropriate document. Mr. Cummins then indicated specifically the various sections where commitments to particular standards would be required.


Mr. Cummins asked that the periodic reviews of the QA Program by the Vice President be described more fully to indicate the scope and depth of this review.

B/71
1

NOV 27 1973

It was agreed that the required qualifications for organizational positions would be given in the QA Program but that the actual qualifications of personnel filling those positions would be given in the cover letter that transmits the program.

Mr. Gaines stated that he anticipates submitting the QA Program on or about November 30, 1973.



T. V. Wambach
Operating Reactors Branch #1
Directorate of Licensing

Enclosure:
List of Attendees

cc: AEC PDR
Local PDR
RP Assistant Directors
RP Branch Chiefs
T. J. Carter
J. M. Hendrie
TR Assistant Directors
TR Branch Chiefs
T. V. Wambach
R. Bevan
M. Kaufman
S. Lewis
RO (3)
ACRS (3)
Principal Staff Participants

LIST OF ATTENDEES

MEETING ON NOVEMBER 13, 1973, WITH JCPL

S. Cummins	AEC - L:TR
J. Costello	AEC - L:TR
F. Liederbach	AEC - L:TR
T. Wambach	AEC - L:RP
D. Gaines	JCPL
N. Trikouros	GPUSC
S. Lawyer	Met Ed
W. Potts	Met Ed