

GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

February 11, 1985

Director
Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Technical Specification Change Request No. 132


In accordance with 10CFR50.90 and 10CFR50.91, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16 request changes to Appendix A of that license.

The subject Technical Specification Change Request incorporates NUREG 0737 required accident monitoring instrumentation as identified by Generic Letter No. 83-36 and will revise sections 3.13 and 4.13. In addition, this Technical Specification Change Request provides clarification and consistency between all accident monitoring instrumentation.

This Technical Specification Change Request has been reviewed and approved by Responsible Technical and Independent Safety Reviewers in accordance with Technical Specification section 6.5.

A check for \$150.00 to cover the fee required for the review of our application for the Technical Specification Change Request has been provided.

Very truly yours,


Peter B. Fiedler
Vice President and Director
Oyster Creek

8502190205 850211
PDR ADOCK 05000219
P PDR

PBF/BH/dam
attachment

cc: Dr. Thomas E. Murley, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station
Forked River, NJ 08731

Agg Rec'd w/out check