

OCT 19 1984

Mr. Dennis L. Farrar  
Director of Licensing  
Commonwealth Edison Company  
P. O. Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Preoperational Test Deferrals

In a letter dated September 28, 1984, you proposed to defer preoperational testing on the Auxiliary Building Ventilation and Containment Purge Systems to the period between fuel loading and 25% of full power. You also proposed that retesting on Process Radiation Monitoring, Control Room Ventilation, Main Steam Isolation Valves, Diesel Generator Ventilation, Process Radiation Monitoring - Loops, 2, 5, Leakage Control, Fuel Pool Cooling, Pipe Vibration (test), Control Room Chilled Water and Containment Ventilation Systems be deferred until after fuel loading.

We have reviewed the proposed preoperational test deferrals and justification. We agree with the justifications for the deferrals and find them acceptable as proposed.

Sincerely,

~~ORIGINAL SIGNED BY:~~

B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

cc: See next page

CONCURRENCES:

DL:LB#1  
LOIshan:es  
10/19/84

DL:LB#1  
BJYoungblood  
10/19/84

DIST:

Docket File  
NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#1 Rdg  
MRushbrook  
LOIshan  
OELD, Attorney  
ACRS (16)

EJordan  
NGrace



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OCT 19 1984

Docket No.: STN 50-454

Mr. Dennis L. Farrar  
Director of Licensing  
Commonwealth Edison Company  
P. O. Box 767  
Chicago, Illinois 60690


Dear Mr. Farrar:

Subject: Preoperational Test Deferrals

In a letter dated September 28, 1984, you proposed to defer preoperational testing on the Auxiliary Building Ventilation and Containment Purge Systems to the period between fuel loading and 25% of full power. You also proposed that retesting on Process Radiation Monitoring, Control Room Ventilation, Main Steam Isolation Valves, Diesel Generator Ventilation, Process Radiation Monitoring - Loops, 2, 5, Leakage Control, Fuel Pool Cooling, Pipe Vibration (test), Control Room Chilled Water and Containment Ventilation Systems be deferred until after fuel loading.

We have reviewed the proposed preoperational test deferrals and justification. We agree with the justifications for the deferrals and find them acceptable as proposed.

Sincerely,

  
B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

cc: See next page

BYRON

Mr. Dennis L. Farrar  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

cc: Mr. William Kortier  
Atomic Power Distribution  
Westinghouse Electric Corporation  
Post Office Box 355  
Pittsburgh, Pennsylvania 15230

Michael Miller  
Isham, Lincoln & Beale  
One First National Plaza  
42nd Floor  
Chicago, Illinois 60603

Mrs. Phillip B. Johnson  
1907 Stratford Lane  
Rockford, Illinois 61107

Dr. Bruce von Zellen  
Department of Biological Sciences  
Northern Illinois University  
DeKalb, Illinois 61107

Mr. Edward R. Crass  
Nuclear Safeguards & Licensing  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603

Mr. Julian Hinds  
U. S. Nuclear Regulatory Commission  
Byron/Resident Inspectors Offices  
4448 German Church Road  
Byron, Illinois 61010

Ms. Diane Chavez  
528 Gregory Street  
Rockford, Illinois 61108

Mr. James G. Keppler  
U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Joseph Gallo, Esq.  
Isham, Lincoln & Beale  
Suite 840  
1120 Connecticut Avenue, N. W.  
Washington, D. C. 20036

Doug Cassel, Esq.  
Jane Whicher, Esq.  
109 N. Dearborn Street  
Chicago, Illinois 60602

Ms. Pat Morrison  
5568 Thunderidge Drive  
Rockford, Illinois 61107

David C. Thomas, Esq.  
77 S. Wacker Drive  
Chicago, Illinois 60601

Ms. Lorraine Creek  
Rt. 1, Box 182  
Manteno, Illinois 60950