



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 7, 1984

MEMORANDUM FOR: Gus C. Lainas, Assistant Director for Operating Reactors, DL  
THRU: John F. Stolz, Chief, Operating Reactors Branch #4, DL  
FROM: George Rivenbark, Project Manager, Operating Reactors  
Branch #4, DL  
SUBJECT: BACKFIT ISSUE AT EDWIN I. HATCH NUCLEAR PLANT, UNITS 1&2

BACKFIT ISSUE: Tech Spec changes are required to ensure operability of high water level trip and turbine bypass systems.

Date issue raised with licensee: 10/28/83

Licensee's Position: Licensee does not concur with NRC position.

Milestones:

- 1/23/83; Issue raised in memo from W. Butler to G. Lainas
- 10/28/83; NRC letter to licensee stating implementation of these Tech Specs will be deferred pending resolution of this issue generically.
- Closed out as a plant specific issue. Issue to be brought before CRGR as a generic issue by DSI.

Applicability to other facilities: Applicable to all BWRs.

Next Scheduled Action: DSI preparing CRGR package on schedule to be determined.

*George Rivenbark*  
George Rivenbark, Project Manager  
Operating Reactors Branch #4, DL

8502190309 840904  
PDR FOIA  
EVANS84-596 PDR