



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 4, 1984

Docket No. 50-366

NOTE TO: J. F. Stolz

FROM: G. Rivenbark X27136

SUBJECT: BACKFIT ISSUE AT EDWIN I. HATCH NUCLEAR PLANT, UNITS 1 & 2

BACKFIT ISSUE: Tech Spec changes are required to ensure operability of high water level trip and turbine bypass systems.

Date issue raised with licensee: 10/28/83

Licensee's Position: Licensee does not concur with NRC position.

Milestones:

- 1/23/83; Issue raised in memo from W. Butler to G. Lainas
- 10/28/83; NRC letter to licensee stating implementation of these Tech Specs will be deferred pending resolution of this issue generically.
- (Pending); Issue to be brought before CRGR.

Applicability to other facilities: Applicable to all BWRs.

Next Scheduled Action: DSI preparing CRGR package on schedule to be determined.

A handwritten signature in cursive script, appearing to read "George Rivenbark".

George Rivenbark, Project Manager
Operating Reactors Branch No. 4
Division of Licensing

B502190310 B40904
PDR FOIA
EVANS84-596 PDR