

SAFETY EVALUATION REPORT
PLANT HATCH UNIT-2

In a letter dated October 4, 1982 from J. T. Beckham of Georgia Power Company (the licensee) to the Director of NRR, a change to Technical Specification Figures 3.2.3-1 and 3.2.3-2 for Plant Hatch unit 2 was requested. The change would increase the operating limit minimum critical power ratio (OL-MCPR) which is based upon analysis of abnormal operational occurrences.

The licensee has requested this change to correct an error detected in the reload analysis which had been submitted to the staff in March, 1982, and was used to determine the present OL-MCPR specification. General Electric Company discussed the impact of the error in a letter dated June 8, 1982 from H.C. Pfefferlen (GE) to D.G. Eisenhut (NRC). The nature of the error was such that an operational transient occurring near the end-of-cycle could result in a violation of the MCPR safety limit if the plant was operating at the technical specification limit at the time of the transient. The plant is currently operating at an OL-MCPR which reflects the corrected analysis and is more restrictive than required by the present specification. The proposed change will conservatively revise the OL-MCPR based upon corrected analyses.

In support of its proposal, the licensee has submitted supplemental reload analyses based upon the approved General Electric Company report "Generic Reload Fuel Application", NEDE-24011-P-A-2 and NEDO-24011-A-2, July 1981. Pressurization event analyses were performed using the approved (and corrected) ODYN code. The results, using the "B" option for calculating Δ CPR, indicate that the feedwater controller failure to

maximum flow event is the most limiting transient. The OL-MCPR for P8x8R fuel must be ≥ 1.29 , and for 8x8R fuel the OL-MCPR must be ≥ 1.27 . The exact value is determined from the attached Figures 3.2.3-1 and 3.2.3-2 and depends upon measured scram times as defined in specification 3/4.2.3.

We have reviewed the Technical Specification change requested by the licensee. We note that for the limiting event, feedwater controller failure to maximum demand, credit is assumed for operation of the high water level (L8) trip and the turbine bypass system. Accordingly, we require that technical specifications be included to ensure the operability of these systems. (Attachment 1 is a sample specification which we have found acceptable for other plants).

With the addition of technical specifications for the turbine bypass system and the L8 trip, we find that the technical specification change proposed by the licensee is acceptable. This conclusion is based upon our review of the licensee's submittal which indicates that the proposed action does not:

- (1) Involve a significant increase in the probability or consequences of an accident previously evaluated;
- (2) Create the possibility of an accident of a type different from any evaluated previously; or
- (3) Involve a significant reduction in a margin of safety.

PLANT SYSTEMS

3/4.7.8 MAIN TURBINE BYPASS SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.8 The main turbine bypass system shall be OPERABLE.


APPLICABILITY: OPERATIONAL CONDITION 1.

ACTION: With the main turbine bypass system inoperable, restore the system to OPERABLE status within 2 hours or determine MCPR to be equal to or greater than the applicable MCPR limit without bypass within one hour or take the ACTION required by Specification 3.2.3.

SURVEILLANCE REQUIREMENTS

4.7.8 The main turbine bypass system shall be demonstrated OPERABLE at least once per:

- a. 7 days by cycling each turbine bypass valve through at least one complete cycle of full travel, and
- b. 18 months by:
 1. Performing a system functional test which includes simulated automatic actuation and verifying that each automatic valve actuates to its correct position.
 2. Demonstrating TURBINE BYPASS SYSTEM RESPONSE TIME to be less than or equal to 0.30 seconds.



3/4.3.8 FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.8 The feedwater/main turbine trip system actuation instrumentation channels shown in Table 3.3.8-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.8-2.

APPLICABILITY: As shown in Table 3.3.8-1.

ACTION:

With a feedwater/main turbine trip system actuation instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.8-2, declare the channel inoperable and either place the inoperable channel in the tripped condition until the channel is restored to OPEABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value, or declare the associated system inoperable.

- a. With the number of OPERABLE channels one less than required by the Minimum OPERABLE Channels requirement, restore the inoperable channel to OPERABLE status within 7 days or be in at least STARTUP within the next 6 hours.
- b. With the number of OPERABLE channels two less than required by the Minimum OPERABLE Channels per Trip System requirement, restore at least one of the inoperable channels to OPERABLE status within 72 hours or be in at least STARTUP within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.3.8.1 Each plant system actuation instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.9.1-1.

4.3.8.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.

TABLE 3.3.8-1

FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION

APPLICABLE OPERATIONAL CONDITIONS

MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM

FUNCTIONAL UNIT

| | | |
|---|---|---|
| a. Reactor Vessel Water Level-High, Level 8 | 3 | 1 |
|---|---|---|

TABLE 3.3.0-2

FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION SETPOINTS


| <u>FUNCTIONAL UNIT</u> | <u>TRIP SETPOINT</u> | <u>ALLOWABLE VALUE</u> |
|---|----------------------|----------------------------|
| a. Reactor Vessel Water Level-High, Level 0 | < 54.5 inches* | ≤ 56.0 inches |

*See Bases Figure U 3/4 3-1.

TABLE 4.3.8.1-1 (Continued)


FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

| <u>FUNCTIONAL UNIT</u> | <u>CHANNEL CHECK</u> | <u>CHANNEL FUNCTIONAL TEST</u> | <u>CHANNEL CALIBRATION</u> | <u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u> |
|---|----------------------|--------------------------------|----------------------------|---|
| a. Reactor Vessel Water Level-High, Level 0 | NA | M | R | 1 |



1.287

τ MCPR LIMIT FOR 8XSR FUEL AT RATED FLOW
FIGURE 3.2.3-1



1.310

τ MCPR LIMIT FOR PEXSR FUEL AT RATED FLOW

FIGURE 3.2.3-2
3/4 2-7a

Mr. C. V. Morgan --
Vice President
Nuclear Licensing and Engineering
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, N.Y. 13202

Docket File ACPS (16)
MRC PDR EJordan
Local PDR RGrace
MRC System RMescott
RSIC MFliegel
LE#2 Reading
EHylton
MHaughey
EBordenick

Dear Mr. Morgan:

SUBJECT: NINE MILE POINT UNIT 2 FEASIBLE MAXIMUM PRECIPITATION (FMP)

In your letter to Mr. A. Schwencer dated May 11, 1984, concerning the use of Hydro-meteorology Reports (HMR) 51 and 52 as the basis for the FMP at Nine Mile Point Unit 2 (NMP-2), you requested that (1) the MRC request a meeting be arranged with the National Oceanographic and Atmospheric Administration (NOAA) and your staff to discuss and clarify the use of HMR 51 and 52 at the NMP-2 site and (2) the MRC Committee for the Review of Generic Requirements (CGR) review the use of HMR's 51 and 52 as a design basis for NMP-2.

The meeting you requested with NOAA was held on May 15, 1984. During that meeting representatives of NOAA discussed why HMR's 51 and 52 are appropriate for the NMP-2 site. Translation of the Southport, PA storm and the basis of the 0.7 ratio used to determine the one hour FMP rainfall were also discussed. During the meeting the MRC staff also discussed alternate means of dealing with potential flooding.

In our letter from Thomas H. Novak to Gerald K. Rhode dated February 3, 1984, we stated the reasons why use of HMR 51 and 52 as a design basis for NMP-2's FMP have been evaluated to be in conformance with the SRP.

As noted in our letter of February 3, 1984, if there are still objections to the use of HMR's 51 and 52 you have the right to appeal. If you do intend to appeal, it should contain a clear statement of your position along with supporting justification. The appeal process is described in Generic Letter 84-08 "Interim Procedures for NRC Management of Plant-Specific Backfitting."

If you have any questions concerning the above information, please contact the licensing project manager, Mary F. Haughey at (301) 492-7897.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

cc: See next page

| | | | | |
|-------------|----------|------------|----------|-----------|
| *LE#2/DL | *LME/DE | *LE#2/DL | *AD/L/DL | D/DL |
| MHaughey:dh | RBallard | ASchwencer | TNovak | DEisenhut |
| 06/ /84 | 06/ /84 | 06/ /84 | 06/ /84 | 06/10/84 |

*See previous concurrence

~~8407170140~~

Nine Mile Point 2

Mr. B. G. Hooten
Executive Director, Nuclear Operations
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Mr. Troy B. Conner, Jr., Esq.
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Richard Goldsmith
Syracuse University
College of Law
E. J. White Hall Campus
Syracuse, New York 13223

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
Nine Mile Point Nuclear Power Station
P. O. Box 99
Lycoming, New York 13093

Mr. John W. Keib, Esq.
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Jay M. Gutierrez, Esq.
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Norman Raderacher,
Licensing
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

May 11, 1984
(NMP2L 0050)

Mr. A. Schwencer, Chief
U. S. Nuclear Regulatory Commission
Licensing Branch No. 2
Washington, DC 20555

Dear Mr. Schwencer:

SUBJECT: Nine Mile Point - Unit 2
Docket No. 50-410

The Standard Review Plan (NUREG-0800, dated July 19, 1981) requires an analysis of the Probable Maximum Precipitation at Nine Mile Point Unit 2. FSAR Section 2.4 provides the results of the analysis performed for Unit 2. The analysis used Hydromet 33 and Corps of Engineers Engineering Manual as required by NUREG-0800. The Unit 2 design, based upon these references, prevents any local flooding at the site.

Subsequently, in Nuclear Regulatory Commission Question F240.11, it was requested that that we base the Probably Maximum Precipitation on Hydromet 51 and 52. We believe that these bases go beyond the current Standard Review Plan requirements since these reports are not referenced in the Standard Review Plan explicitly. We request the Nuclear Regulatory Commission Committee for the Review of Generic Requirements review this generic new requirement to determine if Hydromet 51 and 52 are applicable to the Nine Mile Point Unit 2 licensing basis.

Our review of Hydromet 52 indicates that the development of the Probable Maximum Precipitation curves for the Nine Mile Point Unit 2 area was heavily influenced by the Smethport, Pennsylvania storm. It is our opinion that it may be inappropriate to translate the Smethport storm to the Nine Mile Point Unit 2 site. Also, it is unclear what the basis is of the 0.7 ratio used to determine the one hour Probable Maximum Precipitation rainfall from the six hour Probable Maximum Precipitation rainfall. If Hydromet 51 and 52, as presently defined, were applicable to the Nine Mile Point Unit 2 site, our preliminary review indicates that local flooding could occur.

~~8406150004~~ 840511
PDR ADOCK 05000410
A PDR

Good
10

During the period that the Committee for the Review of Generic Requirements is reviewing the applicability of Hydromet 51 and 52, we request that a meeting be arranged with the National Oceanographic and Atmospheric Administration (authors of Hydromet 52) and our technical staff to discuss and clarify these technical requirements, if applicable. We believe this to be an expedient approach in completing our evaluation of the Probable Maximum Precipitation.

Very truly yours,

C. V. Mangan

C. V. Mangan
Vice President
Nuclear Licensing and Engineering

CVM/NLR:lf

cc: Director of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, DC 20555



February 3, 1984

Docket No.: 50-410

Mr. Gerald K. Rhode
Senior Vice President
300 Erie Boulevard West
Syracuse, New York 13202

Dear Mr. Rhode:

Subject: Probable Maximum Precipitation (PMP) for Nine Mile Point
Nuclear Station, Unit 2

On August 12, 1983, in a letter from A. Schwencer, we requested, in the Hydrology Section, that Niagara Mohawk Power Corporation (NMPC) provide information on the effects of PMP as determined from NOAA Hydrometeorological Reports 51 and 52. This PMP is considerably higher than the PMP rate of 8.4 inches per hour as stated in the FSAR.

Your response in Amendment 7 to the FSAR submitted December 16, 1983, indicated that your calculated rainfall rate of 8.4 inches per hour was developed from NOAA Hydrometeorological Report No. 33 which was approved at the construction permit stage.

On November 22, 1983, during a meeting on administrative matters, the NRC staff discussed with representatives of NMPC the use of Hydrometeorology Reports 51 and 52 for determining PMP. During that meeting, the NRC staff noted that Hydrometeorology Reports 51 and 52 contain updated information and more advanced methodology to determine the PMP. The staff also noted that although Hydrometeorology Report No. 33 is mentioned in the Standard Review Plan (SRP), NUREG-0800, the SRP also states that the latest methodology should be used when appropriate in determining PMP. The NRC staff further stated that the use of these later reports had been evaluated with respect to the SRP and determined to be in conformance with the SRP.

The staff's review procedures for evaluating flood levels have been and continue to be based on a PMP event. In our independent assessment of Nine Mile Point 2, we used current Corp of Engineering and National Weather Service methodology to determine the PMP depth. The analytical methods used by the staff are in accordance with generally accepted hydrological principles and procedures. Consideration of improvements in calculational methods is specially addressed in NUREG-0800 (SRP), Section 2.4.2 under "Review Procedures". However, NUREG-0800 provides for considerable flexibility in resolving potential flooding problems, recognizing that at the operating license stage the range of solutions may be limited by the status of plant construction. The primary focus is in assuring the capability of the plant to safely shutdown.


~~8407160606~~

Estimates of potential flooding problems, based on PMP, constitute a potential safety problem that must be addressed. In light of the information provided above, and considering the discussion held during the meeting on November 22, 1983, we believe your responses provided in Amendment 7 to the requests for additional information concerning PMP are inadequate. These responses should be revised to include a PMP rate determined in accordance with Hydrometeorology Reports 51 and 52. In order to support the licensing schedule for the SER, this information should be submitted to the NRC as an FSAR amendment no later than May 15, 1984.

If there are objections to use of Hydrometeorological Reports 51 and 52 in determining your PMP for Nine Mile Point 2 you should notify, in writing, Mr. Darrell G. Eisenhut, Director, Division of Licensing, of your desire for informal appeal meetings with the staff.

If you have any questions concerning the above information, please call the Licensing Project Manager, Mary F. Haughey at (301) 492-7897.

Sincerely,



Thomas M. Novak, Assistant Director
for Licensing
Division of Licensing

cc: See next page

Docket No.: 50-410

APPLICANT: Niagara Mohawk Power Corporation (NMPC)

FACILITY: Nine Mile Point Unit 2

SUBJECT: SUMMARY OF MEETING WITH NMPC TO DISCUSS ADMINISTRATIVE
MATTERS RELATED TO NINE MILE POINT UNIT 2 (NMP-2)

On November 22, 1983, the NRC staff met with representatives from NMPC to discuss administrative matters related to NMP-2.

Among the subjects discussed were the bases for a number of requests for additional information that were requested for NMP-2. Specific examples in Seismology (determination of SSE to be used), Hydrology (use of standards to determine PMP), and Structural Engineering (information needed when codes other than those in the SRP are used) were discussed.

The applicant noted that a significant amount of work had been done in the area of seismology that was not accounted for in the requests for information. The NRC staff stated that detailed evaluations are not performed in the requests for information but are done later in the Safety Evaluation Report (SER).

The applicant stated they considered it sufficient to use Hydrometeorology Report No. 33 for determination of Probable Maximum Precipitation (PMP) as it is specifically mentioned in the Standard Review Plan (SRP) NUREG-0900. The NRC staff responded that although this standard is mentioned, the SRP also states that the latest methodology should be used when appropriate in determining PMP. Hydrometeorology reports 51 and 53 contain updated information and more advanced methodology to determine the PMP. These later reports are being used for other plants. The staff has evaluated the use of these later reports with respect to the SRP and have determined it is in conformance with the SRP.


For Category I structures, and interior structures of containment which were designed and built to ACI 318 rather than ACI 349 as referenced in the SRP, the applicant was requested to identify and justify, with respect to safety, all deviations of these structures from the applicable requirements of ACI 349 as amended by the Regulatory Guide 1.142. The NRC staff will then evaluate these deviations and justifications to assure there is no impact to the safety of this plant as a result of these deviations.

~~8312170173~~

The NRC staff noted that the applicant could make use of the appeal process to take discussions to a higher level whenever agreement could not be reached between the NRC staff and the applicant.

The applicant noted that communications between the NRC staff and the NMPC staff should remain open to provide necessary clarifications expeditiously.

A copy of the attendance list is attached.


Mary F. Haughey, Project Manager
Licensing Branch No. 2
Division of Licensing

Attachment:
As stated

cc w/ attachment:
See next page

Nine Mile Point 2. —

Mr. Gerald K. Rhode
Senior Vice President
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

cc: Mr. Troy B. Conner, Jr., Esq.
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 13210

Mr. Jay Dunkleberger, Director
Technological Development Programs
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
Nine Mile Point Nuclear Power Station
P. O. Box 99
Lycoming, New York 13093

Mr. John W. Keib, Esq.
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Jay M. Gutierrez, Esq.
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ATTENDANCE
11/22/83

| <u>Name</u> | <u>Organization</u> | <u>Title</u> |
|---------------|---------------------|---|
| C. Mangan | NMPC | Vice President, Nuclear Engineering & Licensing |
| A. Zallnick | NMPC | Licensing Manager |
| N. Rademacher | NMPC | Licensing Engineer |
| A. Schwander | NRC | Licensing Branch Chief |
| M. Maughey | NRC | Licensing Project Manager |
| G. Lear | NRC | Chief, Structural & Mechanical Engineering Branch |
| R. Ballard | NRC | Chief, Environmental and Hydrological Engineering Branch |
| M. Fliegel | NRC | Section Leader, Hydrology |
| S. Brocum | NRC | Section Leader, Geology |



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 27, 1983

Docket No.: 50-410

APPLICANT: Niagara Mohawk Power Corporation (NMPC)
FACILITY: Nine Mile Point Unit 2
SUBJECT: SUMMARY OF MEETING WITH NMPC ON LIQUID PATHWAYS AT
NINE MILE POINT UNIT 2

On November 17, 1983, the NRC staff met with representatives from NMPC and Stone & Webster Engineering Corporation to discuss Liquid Pathways at Nine Mile Point Unit 2.

During the meeting, NMPC stated that they believed that their use of Hydrometeorology Report No. 33 to determine the Probable Maximum Precipitation (PMP) is appropriate as this report is referenced in the Standard Review Plan (SRP). The NRC staff responded that while the SRP does identify Hydrometeorology Report No. 33, the SRP also notes new improvements in analytical techniques should be taken into account at the OL-stage review if significant changes in estimated flood levels result.

Liquid Pathways and Class 9 accidents were discussed. The NRC staff discussed the level of detail the analysis of liquid pathways should contain, including such things as the amount of water and fish from Lake Ontario which would be consumed. Source terms presently used by the NRC staff are taken from a postulated accident of a PWR. Final research into source terms expected for a BWR event may be available in a research report about June 1984. Ground velocity and permeability at the Nine Mile Point Unit 2 site were discussed. The De watering System at Nine Mile Point was turned off during the summer of 1983 and measurements were taken. Some of this data may be useful in calculating ground permeability at the site.

NMPC was requested to supply the Class 9, liquid pathways information requested during the acceptance review no later than early March 1984, in order to support the schedule for the Draft Environmental Statement (DES).

A list of attendees at this meeting is included as Attachment 1.

Mary F. Haughey
Mary F. Haughey, Project Manager
Licensing Branch No. 2
Division of Licensing

Attachment: As stated

cc: See next page

~~8312090264~~

Nine Mile-Point 2 - -

Mr. Gerald K. Rhode
Senior Vice President
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

cc: Mr. Troy B. Conner, Jr., Esq.
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 13210

Mr. Jay Dunkleberger, Director
Technological Development Programs
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
Nine Mile Point Nuclear Power Station
P. O. Box 99
Lycoming, New York 13093

Mr. John W. Keib, Esq.
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Jay M. Gutierrez, Esq.
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ATTENDANCE
11/17/83 - Liquid Pathways

Name

Organization

Mary Haughey

NRC - PM

Joe Feyder

Stone & Webster

Al Capellini

Stone & Webster

Y. C. Chang

Stone & Webster

Jim Carter

NRC/RSB

R. F. Zallnick

NMPC Licensing

N. L. Rademacher

NMPC Licensing

Mike Fliegel

NRC/EHEB

Rex Mascott

NRC/EHEB

M. S. Stocknoff

Stone & Webster

M. J. Mazzan

Stone & Webster



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 30 1984

Docket Nos.: 50-528/50-529
and 50-530

Mr. E. E. Van Brunt, Jr.
Vice President - Nuclear Projects
Arizona Public Service Company
Post Office Box 21666
Phoenix, Arizona 85036

Dear Mr. Van Brunt:

Subject: Results of Appeal Meeting Concerning the Palo Verde Alternate
Shutdown Capability

The purpose of this letter is to confirm the telephone discussions we had with you on June 25, 1984 regarding the outcome of the subject appeal meeting held on May 31, 1984. The issue involved whether a source range neutron flux monitor would be required for the Palo Verde remote shutdown panel.

As we stated, your appeal has been granted based on the following design features for the Palo Verde plant and your commitment to perform a confirmatory probabilistic risk assessment (PRA) analysis for this issue;


- (1) the extra worth of the control rods in comparison to other typical PWR plants,
- (2) the larger coolant inventory in the primary system,
- (3) the ability to measure boron concentration with the boron meter in the line downstream of the letdown isolation valve, and
- (4) the remote shutdown panel instrumentation includes a log power meter and direct indication of reactor coolant system temperature and pressure.

The purpose of the PRA is to provide further confidence that a source range neutron flux monitor is not necessary to perform and control the required plant functions outside the control room for the Palo Verde plant.

~~8408130160~~

Please advise us as to when you will provide the requested PRA analysis. If you have any questions regarding this letter, you should contact Manny Licitra, the Licensing Project Manager.

Sincerely,



Thomas M. Novak, Assistant Director
for Licensing
Division of Licensing

cc: See next page



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 19 1984

Docket Nos.: 50-528/50-529
and 50-530

Applicant: Arizona Public Service Company

Facility: Palo Verde, Units 1, 2 and 3

Subject: Summary of Appeal Meeting for Palo Verde Regarding Source Range
Neutron Flux Monitor for Alternate Shutdown

A meeting was held on May 31, 1984 in Bethesda, Maryland with representatives of the applicant. The meeting was held at the applicant's request to appeal the staff's position that a source range neutron flux monitor be included as part of the alternate shutdown function so as to provide a capability to directly monitor reactivity. Enclosure 1 lists the meeting attendees, and the viewgraphs used by the applicant are included as Enclosure 2. The meeting is summarized as follows:

Summary

Both the applicant and the staff summarized their positions regarding the need for a source range neutron flux monitor on the remote shutdown panel for Palo Verde.

The staff stated that Appendix R to 10 CFR Part 50 requires that the alternative shutdown capability for a nuclear plant include provisions for direct readings of the process variables necessary to perform and control certain plant functions, including the reactivity control function. To meet this requirement for a direct reading of the reactivity control function, the staff has required that a source range neutron flux monitor be provided as part of the alternative shutdown capability for PWRs.

The applicant stated that a source range neutron flux monitor is not necessary for the Palo Verde remote shutdown panel since, in the event that the control room needs to be evacuated, a criticality occurrence is very unlikely due to the following conditions:

- (1) Prior to leaving the control room area, the operator will assure that the control rods are in by tripping the breakers.

~~8407300145~~

- (2) The initial hot shutdown margin for Palo Verde (CESSAR System 80) with the control rods in is about 14%, which is about twice the margin for other typical PWR designs. This negative reactivity worth is sufficient to maintain the core subcritical in hot shutdown even with unborated water in the reactor.
- (3) The operator will verify that makeup water to the reactor is from a borated source.
- (4) In the event of an inadvertent boron dilution (addition of unborated water to the core) and assuming a maximum cooldown rate of 60°F per hour, there still would be a shutdown margin of 4% nine hours after the start of the incident.
- (5) The operator will check the boron concentration in the reactor coolant by taking samples every hour starting at two hours after the control room is evacuated.

The applicant also stated that direct indication is being provided for all the other process variables (e.g., temperatures, pressure, flow rates and water levels) which can assist in determining whether a boron dilution event is occurring. Also, all other requirements for the remote shutdown panel are being met.

Based on the above, the applicant concluded that there is no apparent problem with the current Palo Verde remote shutdown panel design and that there is little, if any, benefit to including a source range neutron flux monitor on the panel (the applicant estimated it would cost about \$500,000 per unit to install such a monitor). To provide added confidence in support of this conclusion, the applicant offered to perform a PRA analysis on the issue.

Following the presentations, Mr. Novak, chairman for the appeal meeting, told the applicant that we would evaluate the information presented at the meeting. He stated that as soon as a decision is reached on the appeal, the applicant would be informed of the result.

E A Licitra
E. A. Licitra, Project Manager
Licensing Branch No. 3
Division of Licensing

Enclosures:

- (1) Meeting Attendees
- (2) Viewgraphs

Enclosure 1

Palo Verde Appeal Meeting

May 31, 1984

| | |
|-------------------------|-----------------|
| Manny Licitra | NRR/DL/LB#3 |
| George Knighton | NRR/DL/LB#3 |
| Tom Novak | NRR/DL/AD |
| Les Rubenstein | NRR/DSI/AD |
| Olan Parr | NRR/DSI/ASB |
| Jerry Wermiel | NRR/DSI/ASB |
| Nick Fioravante | NRR/DSI/ASB |
| Terry Quan | APS |
| Edwin E. Van Brunt, Jr. | APS |
| W. G. Bingham | Bechtel |
| S. H. Shepherd | Bechtel |
| R. Steve McKinney | APS |
| Donald R. Woodlan | Texas Utilities |
| Nick Baldasari | Bechtel |
| Charles Luguana | C-E |
| John Connally | C-E |
| George Davis | C-E |
| Jeff Brown | C-E |
| J. M. Betancourt | C-E |

BACKGROUND

- HISTORY
 - STAFF/APPLICANT ACTIONS
- APPENDIX R REQUIREMENT

- ASSESSMENT OF STAFF POSITION

- PVINGS POSITION

APPENDIX R REQUIREMENT


- III.L.2.a "THE PROCESS MONITORING FUNCTION SHALL BE CAPABLE OF PROVIDING DIRECT READINGS OF THE PROCESS VARIABLES NECESSARY TO PERFORM AND CONTROL THE ABOVE FUNCTIONS"
- III.L.2.a "THE REACTIVITY CONTROL FUNCTION SHALL BE CAPABLE OF ACHIEVING AND MAINTAINING COLD SHUTDOWN REACTIVITY CONDITIONS"


BASIS FOR PVNGS
REMOTE SHUTDOWN PANEL

- MEET CESSAR INTERFACE
- PROVIDE DISCONNECT SWITCHES TO MEET APPENDIX R
AS AGREED AT THE FIRE PROTECTION INDEPENDENT
REVIEW BOARD MEETING (SEPTEMBER 1981)
- ADD T_{COLD} TO FACILITATE OPERATING PROCEDURES

DESIGN BASIS
CVCS BORATION

- AUTOMATICALLY TERMINATE CHARGING AND LETDOWN ON LOP
- WITH OR WITHOUT LOP, AN OPERATOR CAN READILY ISOLATE CHARGING AND LETDOWN
- CHARGING TO MAKEUP FOR SHRINKAGE IS EQUIVALENT TO EMERGENCY BORATION
- SHUTDOWN SEQUENCE





Palo Verde Nuclear Generating Station
FSAR
SAFE SHUTDOWN FLOW PATHS
CHEMICAL AND VOLUME
CONTROL SYSTEM
Figure 9B-41

SHUTDOWN SEQUENCE

- I CONTROL ROOM FIRE
- II MANUAL SCRAM
- III ACTIVATE RSP - STABILIZE AT HOT STANDBY
- IV BEGIN OPERATOR ROUNDS
 - A. TERMINATE LETDOWN
 - B. ISOLATE NON BORATED WATER SOURCES
- V BEGIN COOLDOWN
 - A. ALIGN BORATED SOURCE
 - B. INJECT AS REQUIRED FOR SHRINKAGE
- VI ACHIEVE COLD SHUTDOWN

SHUTDOWN MARGIN VERSUS TIME FROM CONTROL ROOM EVACUATION



COST

- BACKFIT COST = \$1.5 MILLION (3 UNITS)

- SCOPE

- DISCONNECT PANEL
- CABLING
- ELECTRONIC PROCESSOR
- READOUT/MODIFICATION TO RSP

CONCLUSION

- NO APPARENT PROBLEM AS IS
- LITTLE, IF ANY, BENEFIT TO SFM'S
- WILLING TO DO PRA TO GIVE STAFF FURTHER CONFIDENCE
IN CONCLUSION

JUN 11 1982

Docket Nos.: 50-528/529
and 50-530

Mr. E. E. Van Brunt, Jr.
Vice President - Nuclear Projects
Arizona Public Service Company
Post Office Box 21666
Phoenix, Arizona 85036

Dear Mr. Van Brunt:

Subject: Request for Additional Information - Palo Verde Nuclear
Generating Station


In the course of our review of the alternate safe shutdown capability for Palo Verde in the event of a fire (Appendix R, Section III.L), we have determined that the alternate shutdown system (remote shutdown panel) for the plant does not include the capability to monitor reactivity nor to verify adequate core cooling during natural circulation flow. The alternate shutdown system is required in the event of control room evacuation due to a fire.

Section III.L of Appendix R requires that a capability be provided for direct readings of process variables necessary to perform and control the reactivity control functions, the reactor coolant makeup functions and the reactor heat removal functions. Therefore, we require that you provide a source range neutron flux monitor and either an indication of the reactor coolant loop cold leg temperature (T_c) or reactor coolant average temperature (T_{avg}) as part of the available instrumentation for the remote shutdown panel or an alternate location which is independent of the control room.

We request that, within one week of receipt of this letter, you advise us as to when you will provide the response to the letter.

If you have any questions on this matter, please contact E. Licitra, (301) 492-7200, the Project Manager.

Sincerely,



Frank J. Miraglia, Chief
Licensing Branch No. 3
Division of Licensing

cc: See next page

~~8206150424~~

Arizona Public Service Company

PO BOX 21666 • PHOENIX ARIZONA 85016

May 17, 1983

ANPP-23782 - WFQ/TFQ

Director of Nuclear Reactor Regulation
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. George Knighton, Chief

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 83-056-026; G.1.01.10

Reference: A) Letter from F. J. Miraglia, NRC to E. E. Van Brunt, Jr., APS,
dated June 11, 1982; Subject: Fire Protection
B) NUREG-0857, "Safety Evaluation Report related to the
Operation" of Palo Verde Nuclear Generating Station Units 1,
2, and 3, dated November, 1981

Dear Mr. Knighton:

Reference A describes the results of the NRC's review of the PVNGS Remote Shutdown Panel (RSP). Contrary to 10CFR50.48, Appendix R to 10CFR50, and Section 9.5.1.9 of Reference B, the NRC staff is requiring PVNGS to meet Section III.L of 10CFR50, Appendix R. Reference A states:

"Section III.L of Appendix R requires that a capability be provided for direct readings of process variables necessary to perform and control the reactivity control functions, the reactor coolant makeup functions and the reactor heat removal functions. Therefore, we require that you provide a source range neutron flux monitor and either an indication of the reactor coolant loop cold leg temperature (T_c) or reactor coolant average temperature (T_{avg}) as part of the available instrumentation for the remote shutdown panel or an alternate location which is independent of the control room."

Even though PVNGS is not required, nor have we committed to meet 10CFR50, Appendix R, Section III.L, we have evaluated the above stated request to include a source range neutron flux monitor (N_{source}) and either T_c or T_{ave} in the PVNGS RSP design. In order to further enhance the safety of PVNGS in the unlikely event the RSP will be needed, we will add this direct indication of T_c on the RSP even though other suitable means exist to

Boo!

305200322 830517
DR ADOCK 05000528
PDR

determine this process variable. Installation of this instrument will be accomplished by the end of the first refueling outage for Unit 1, and prior to fuel load for Units 2 and 3. Justification for interim operation of Unit 1 without T_c on the RSP is provided below.

INTERIM OPERATION OF UNIT 1 WITHOUT T_c

The present design provides the following direct indications of core cooling; hot leg temperature (T_{hot}) and pressurizer pressure (P_{pZR}). An increase in either of these parameters would indicate to an operator inadequate core cooling at least as clearly as would T_c .

Furthermore, the operator can indirectly infer natural circulation flow through the use of a pressure-temperature curve for saturated steam. Steam generator pressure ($P_{S/G}$) is already provided on the RSP. Because of the relatively low flow under natural circulation conditions, T_c will be approximately equal to steam generator temperature ($T_{S/G}$). $T_{S/G}$, in turn, can be determined by the use of a saturated steam pressure-temperature curve, using $P_{S/G}$ (a direct RSP readout) as an entry value.

With the above indication available at the RSP, the operator is provided with sufficient instrumentation to determine adequate core cooling under natural circulation conditions. Therefore, the interim operation of Unit 1 without direct indication of T_c will not jeopardize the operator's capability to maintain the plant in a safe condition.

OPERATION WITHOUT N_{source}

In regard to N_{source} , PVNGS provides diverse indications of boron concentration and, accordingly, does not need to provide N_{source} on the RSP. PVNGS can control reactivity in accordance with 10CFR50 Appendix R without direct indication of N_{source} .

The identification of required instrumentation to perform and control reactivity is dependent upon the operating mode of the reactor. We have committed that prior to evacuation of the control room due to a fire, the operator will trip the reactor, verify that CEA's are fully inserted, and verify that core power is decreasing. Thus, the control functions of the RSP are limited to hot and cold shutdown modes.

A. HOT SHUTDOWN

The negative reactivity of the control rods alone is sufficient to maintain shutdown margin during hot shutdown. Thus, the actions taken in the control room prior to evacuation are sufficient to ensure reactivity control.

B. COLD SHUTDOWN

Chemical shim must be added to achieve shutdown margin for cold shutdown. The boron concentration of the charging flow added as shim is verified by Technical Specification every seven (7) days. Thus, it is not necessary to measure the actual neutron flux or RCS boron concentration post fire. Analysis has shown that a dilution event is impossible due to the boron content of the charging flow. However, even with the incredible assumption that boron concentrations become insufficient and the reactor becomes critical, the operator still has adequate indications of an inadvertent boron dilution event. CESSAR Section 15.4 identifies the maximum consequence of an inadvertent dilution event as not challenging fuel integrity. This meets the acceptance criteria of General Design Criterion 3 and of Section III.L of Appendix R. The difference between the Chapter 15 event and the event postulated here is that the control room alarms do not annunciate at the RSP. The RSP operator would instead react to an increase on the pressure and temperature instrumentation (T_{hot} , T_{cold} , P_{PZR} , and $P_{S/G}$). Depending upon the severity of the control room fire, logarithmic power (N_{log}) could also be available on the RSP. The operator response is the same, namely, suspend charging and institute emergency boration procedures.

It is stressed, however, that such an event is unlikely, and there are indirect methods of shutdown margin verification available through the use of suitable procedures.

There are several methods of inferring reactivity control, of which N_{source} is one. Another method utilizes T_H , which is provided on the RSP in conjunction with RCS boron concentration. RCS boron concentration can be determined by several methods outside of the control room. These include the boronometer associated with the Post Accident Sampling System and grab sampling.

Figure 1, RCS temperature versus required boron concentration during a cooldown, illustrates how a minimum required boron concentration can be determined to maintain a given shutdown margin during a cooldown. This figure provides the operator with a valuable tool and an additional aid in maintaining reactivity control. Although shutdown margin is not necessary to verify reactivity control, it would be useful in the event of an unexpected cooldown while controlling the plant from outside the control room.

The operator has controls available locally to preclude boron dilutions and to align the charging system for boron additions, along with charging pump controls, valve control and indication is provided on the PVNGS RSP for the isolation valve between the Volume Control Tank (VCT) and the charging pumps. Since the VCT is the only low concentrated boron source that could be aligned to the RCS, the operator can verify that this source has been isolated to

Mr. George Knighton, Chief
Director of Nuclear Reactor Regulation
ANPP-23782 - WFO/TFQ
Page 4

preclude a boron dilution. Control and indication is also provided locally for the valve between the Refueling Water Tank (RWT) and the charging pumps. This enables the operator to align a highly concentrated boron source to the RCS and assure reactivity control.

We believe the present design allows reactivity control outside of the control room, thus precluding the need for a source range neutron flux monitor.

Please contact me if you have any questions on this matter.


Very truly yours,

E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects
ANPP Project Director

EEVB/TFQ/wp
Attachment

cc: E. Licitra (w/attach.)
G. Wermiel (NRC) "
A. C. Gehr "

FIGURE 1 : ILLUSTRATION OF ALLOWABLE RCS TEMPERATURE VS. REQUIRED BORON CONCENTRATION DURING A COOLDOWN



NOTE 1 : REACTIVITY CURVE CONSIDERS EQUIL. TENDON, END OF CORE LIFE, WORST ROD STUCK OUT,

NOTE 2 : REACTIVITY CURVE REPRESENTS A MINIMUM BORON CONCENTRATION NECESSARY TO MAINTAIN A 2% SUBCRITICALITY.

NOTE 3 : BORON CONCENTRATION OF CHARGING FLOW IS ASSUMED TO BE THE TECHNICAL SPECIFICATION REQUIREMENT OF 4000 TO 4400 PPM.

JUL 28 1983

Docket Nos.: 50-528, 50-529
and 50-530

Mr. E. E. Van Brunt, Jr.
Vice President - Nuclear Projects
Arizona Public Service Company
Post Office Box 21666
Phoenix, Arizona 85036

DISTRIBUTION
Document Control 50-528/529/530
NRC PDR
L PDR
NSIC
PRC System
LB#3 Reading
EA Licitra
JLee
Attorney, OELD
ACRS (16)
Jordan, IE
Taylor, IE
TMNovak
OParr

Dear Mr. Van Brunt:

Subject: Source Range Flux Monitor for Palo Verde Remote Shutdown Panel

By letter dated May 17, 1983, you responded to our request to add two additional instruments to the Remote Shutdown Panel for Palo Verde for direct indication of process variables.

In your response, you state that as requested a direct indication of the reactor coolant loop cold leg temperature will be added to the Remote Shutdown Panel and you commit to complete installation of this instrument by the end of the first refueling for Unit 1 and prior to fuel load for Units 2 and 3. You also provide justification for interim operation of Unit 1 until the instrument is installed. Based on our evaluation of your submittal, we find this commitment to be acceptable.

In your response, you also state that the source range neutron flux monitor requested by us is not needed since reactivity can be controlled without direct indication of neutron source range flux. We have reviewed your response and conclude that it does not meet the staff position with regard to monitoring source range flux as shown in Enclosure 1. Therefore, we request that you revise your response to include a direct capability for monitoring source range flux from the Remote Shutdown Panel.

Please advise us as to when you plan to respond to this request. If you have any questions regarding the request, you should contact Manny Licitra, the Licensing Project Manager.

Sincerely,

Original signed by
George W. Knighton

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Enclosure:
Staff Position

23-8-5-571

Palo Verde

Mr. E. E. Van Brunt, Jr.
Vice President - Nuclear Projects
Arizona Public Service Company
P. O. Box 21666
Phoenix, Arizona 85036

cc: Arthur C. Gehr, Esq.
Snell & Wilmer
3100 Valley Center
Phoenix, Arizona 85073

Charles S. Pierson
Assistant Attorney General
200 State Capitol
1700 West Washington
Phoenix, Arizona 85007

Charles R. Kocher, Esq., Assistant Counsel
James A. Boeletto, Esq.
Southern California Edison Company
P. O. Box 800
Rosemead, California 91770

Ms. Margaret Walker
Deputy Director of Energy Programs
Economic Planning and Development Office
1700 West Washington
Phoenix, Arizona 85007

Mr. Rand L. Greenfield
Assistant Attorney General
Bataan Memorial Building
Santa Fe, New Mexico 87503

Resident Inspector Palo Verde/NPS
U. S. Nuclear Regulatory Commission
P. O. Box 21324
Phoenix, Arizona 85001

Ms. Patricia Lee Hourihan
6413 S. 26th Street
Phoenix, Arizona 85040

Regional Administrator-Region V
U. S. Nuclear Regulatory Commission
1450 Maria Lane
Suite 210
Walnut Creek, California 94596

Kenneth Bertin, Esq.
Winston & Strawn
Suite 500
2550 M Street, N. W.
Washington, D. C. 20037

Lynne Bernabei
Government Accountability Project
of the Institute for Policy
Studies
1901 Que Street, N. W.
Washington, D. C. 20009

Enclosure

Staff Position

Section III.L.1 of Appendix R to 10 CFR 50 requires that alternative shutdown capability shall be able to achieve and maintain subcritical reactivity conditions in the reactor. Section III.L.2 of Appendix R to 10 CFR 50 requires provision for direct readings of the process variables necessary to perform and control the reactor shutdown function.

Among the process variables which are to be monitored are: source range flux, reactor coolant temperature, and steam generator pressure. These three have been controversial so we have set forth our basis for concluding that they are necessary in order to meet Section III.L of Appendix R.

Source Range Flux

Monitoring of core flux provides a direct indication of the reactor shutdown condition. The monitoring of other process variables would provide an inferred answer only. With regard to the fission process, changes in neutron flux provides the quickest means of assessing reactor criticality conditions. Disturbance events caused by the postulated spurious operation of valves could result in power excursion which would not be readily detected by interpreting the changes in other process variables (such as reactor coolant temperature or pressure). Periodic sampling of the reactor coolant boron concentration is considered inadequate for determining "real-time" boron requirements. Additionally, should the operators fail to detect a loss of negative reactivity in a timely manner, the capability to prevent a criticality is indeterminate since components needed for such actions may be unavailable due to fire. Thus, the provision for post fire source range flux monitoring is necessary to meet Section III.L.2 of Appendix R.

Reactor Coolant Temperatures

The reactor coolant temperatures, in conjunction with the reactor coolant system (RCS) pressure, are essential parameters necessary for plant cooldown and control and, hence, conformance with Section III.L.2 of Appendix R. The plant control elements which rely on accurate reactor coolant temperature indication are natural circulation, subcooling and pressurized thermal shock concerns.

- (1) Natural Circulation: In the natural circulation mode of operation, the hot leg temperature, cold leg temperature and the difference between the hot leg and cold leg temperatures, $(T_H - T_C)$, provide indication by which natural circulation conditions can be determined. In order to verify that natural circulation has been established, normal plant procedures require the operator to use cold leg temperature T_C . It has been suggested that the saturation temperature corresponding to the secondary side steam generator pressure T_{sat} , will approximate T_C . The staff

acknowledges that such a condition can exist if natural circulation is occurring; however, the converse cannot be assumed. Cooldown is usually achieved by the operator controlling the steam generator pressure and auxiliary feedwater flow to the steam generators. Due to the inherent lag in response between the secondary and primary side, T_C cannot be inferred from T_{sat} . Natural circulation is normally determined by knowing T_H , T_C , observing that T_H and T_C are constant or decreasing, and by monitoring $(T_H - T_C)$. Since normal control room procedures require the use of T_C in confirming natural circulation, emergency procedures should not deviate from this practice. Thus the provision for post fire cold leg temperature, T_C wide range indication is necessary for meeting Section III.L.2 of Appendix R.

(2) Upper Vessel Voiding: (Deleted)

(3) Subcooling: The bulk fluid temperature T_H provides a reliable indication of the degree of RCS subcooling when used in conjunction with the RCS pressure. T_H is also used as a means of verifying natural circulation. It has been suggested that exit core thermocouples (ECTs) provide temperature indications equivalent to T_H . ECT readings provide local temperature conditions above the core, and can give representative equivalent T_H provided the individual ECTs are judiciously selected, since ECT readings are dependent not only upon radial positioning, but also local flow rates past the ECTs. Thus, the provision for wide range ECTs is an acceptable alternate to wide range T_H loop RTDs for meeting Section III.L.2 of Appendix R, provided that the licensee demonstrates that their selection of ECTs will result in averaged temperature readings representative of T_H . Also, the licensees should demonstrate that under conditions where the reactor vessel upper head void is expanding thus, bringing higher temperature fluid into the outlet plenum and hot legs, the ECTs give a conservative indication of outlet plenum temperature.

(4) Pressurized Thermal Shock and Appendix G Considerations: T_C , in conjunction with the RCS pressure, provides a direct indication of the plant condition relative to the plant's pressure/temperature limits as it pertains to the Pressurized Thermal Shock considerations and the low temperature overpressure protection as outlined in Appendix G of 10 CFR 50. Due to the collective effect of the steam generator conditions (i.e., feedwater flow and steam generator pressure) on the primary coolant temperatures, and the inherent lag between the secondary and primary sides conditions especially during transient conditions, T_C may not be accurately inferred from the secondary side steam conditions.

Steam Generator Pressure

During non-power modes of operation, "control" is effected principally by adjusting secondary system parameters (the parameter usually specified by procedures is pressure) to compensate for variances in primary system

performance. Maintenance of level in the steam generators may not be sufficient in itself to control the heat removal rate and thereby maintain a "hot standby" or "hot shutdown" mode, or translate from "hot shutdown" mode to "cold shutdown" mode. Improper pressure control may cause an imbalance in heat removal which could result in excessive depressurization, the result of which could be generation of an undesired bubble in the primary system (e.g., upper head for all PWRs or candy cane for B&W designs) or rapid cooldown and potential for violation of vessel pressure/temperature limits. For the monitoring of secondary system heat removal, two secondary system parameters should be known: level (inventory), and pressure. Thus, provisions for post fire steam generator pressure and level monitoring are necessary for meeting Section III.L.2 of Appendix R.

Instrumentation Guidelines

Section III.L.6 requires that, "Shutdown systems installed to ensure post-fire shutdown capability need not be designed to meet seismic Category I criteria, single failure criteria, or other design basis accident criteria, except where for required for other reasons; e.g., because of interface with or impact on existing safety systems, or because of adverse valve actions due to fire damage." Thus the monitors for the above listed parameters need not be "safety grade" in order to meet the requirements of Appendix R.

Section III.G.3 requires that, "Alternate or dedicated shutdown capability and its associated circuits, independent of cables, systems or components in the area, room or zone under consideration, shall be provided." For a postulated fire, an electrically independent monitoring capability for the above listed parameters should be provided outside the control room.

Based on the above, the revised list of instrumentation needed for PWRs is:

- a) pressurizer pressure and level,
- b) reactor coolant hot leg temperature or exit core thermocouples, and cold leg temperature,
- c) steam generator pressure and level (wide range),
- d) source range flux monitor,
- e) diagnostic instrumentation for shutdown systems, and
- f) level indication for all tanks used (e.g., CST).

The instrumentation needed for BWRs is unchanged.

Arizona Public Service Company

PO BOX 21546 • PHOENIX ARIZONA 85001

November 23, 1983
ANPP-28284 - WFO/TFQ

Director of Nuclear Reactor Regulation
Attention: Mr. George Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 83-056-026; G.1.01.10

Reference: (A) Letter from E. E. Van Brunt, Jr., APS, to G. W. Knighton,
NRC, ANPP-23782, dated May 17, 1983.
(B) Letter from G. W. Knighton, NRC, to E. E. Van Brunt, Jr.,
APS, dated July 28, 1983.

Dear Mr. Knighton:

By letter, Reference (A), we responded to your request to add a source range neutron flux monitor to the PVNGS Remote Shutdown Panel (RSP). By letter, Reference (B), you stated that our response did not meet the staff position with regard to monitoring source range neutron flux. We would like to take this opportunity to restate our position on this issue.

The NRC staff concern is the loss of the reactivity control function from the Remote Shutdown Panel (RSP) due to potential boron dilution events caused by fire induced spurious operation of components. At PVNGS, the RSP would be used only when the control room becomes uninhabitable. Prior to evacuation of the control room, the operator will trip the reactor and verify that all control rods are fully inserted.

PVNGS has such an extremely high control rod worth that it is impossible to achieve a critical state at any temperature or at anytime during a fuel cycle provided that all rods are inserted. This can be further realized by noting that the HOT (564°F) Zero Power, Beginning of Cycle (BOC), clean critical all-rods-in boron level is estimated to be -364 ppm. Allowing an additional 250 ppm for cooldown to approximately 60°F, there is still a shutdown margin equivalent to -114 ppm boron. Thus, a subcritical condition is maintained, assuming no boron in the RCS, and all rods in. This indicates that the occurrence of a boron dilution event does not affect the reactivity control function.

8312010223-831123
PDR ADOCK 05000528
A PDR

Boo1

110


Mr. G. W. Knighton

Page 2

Therefore, a source range neutron flux monitor is not required to assure reactivity control is maintained from the RSP.

Please contact me if you have any questions on this matter.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects Management
ANPP Project Director

EEVB/TFQ/sp

cc: E. A. Licitra
G. Wermiel
A. C. Gehr

Arizona Public Service Company

PO BOX 21666 • PHOENIX, ARIZONA 85036

ANPP 28863 WLH/TFQ
February 14, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. George Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 84-056-026; G.1.01.10

Reference: (A) Letter from G.W. Knighton, NRC, to E.E. Van Brunt, Jr. APS
dated July 28, 1983.
(B) Letter from E.E. Van Brunt, Jr. APS, to G.W. Knighton, NRC
dated November 23, 1983.

Dear Mr. Knighton:

The NRC, per Reference (A), reiterated its position with regard to the need for an independent source range neutron flux monitor at the PVNGS Remote Shutdown Panel (RSP). APS had provided a response, Reference (B). Further review has indicated a need to modify that response. This letter is also a response to Reference (A), which is to supersede our previous response.

Reference (A) states that the PVNGS design does not meet the NRC staff's position with regard to 10CFR50, Appendix R, Item II.L.2, which is to include the direct capability for monitoring source range neutron flux from the RSP. The NRC staff concern is the potential loss of reactivity control function from RSP due to potential boron dilution events caused by fire induced spurious operation of components.

APS believes that the NRC position is not justified for PVNGS because:

1. Other than Section III.G, III.J, and III.O, 10CFR50, Appendix R is not applicable to plants other than those "...licensed nuclear power electric generating stations that were operating prior to January 1, 1979..."

~~8402220386~~ 840214
PDR ADOCK 05000528
F PDR

Boo2
1/c

2. PVNGS has committed to meet Appendix R, Sections III.G, III.J, and III.O. Compliance with Section III.L.2 is not applicable.

[APS did advise the NRC (in the Fire Protection Independent Design Review, held February 25, 1981, and subsequently in the Fire Protection Evaluation Report, Amendment 3) that "PVNGS alternative shutdown capability provides the functions" that APS considers as meeting Appendix R, Section III.L. These evaluations contemplated that the features described in 3.B, C, and D below were adequate to meet the NRC position.]

3. There are sufficient design features and procedural guidance in the existing design for PVNGS to comply with the requirements of Criterion 3 of Appendix A of 10CFR50, which is the applicable licensing standard. Specifically the PVNGS design incorporates the following features:
- A. Only in the event of control room evacuation is alternate shutdown capability from the remote shutdown panel required.
 - B. When evacuation of the control room becomes necessary, the control room operator manually trips the reactor, verifies power is decreasing and all rods are inserted.
 - C. By procedure and by the proposed PVNGS Technical Specifications, the operator is required to maintain a shutdown margin of $6\% \Delta K/K$, in modes 3 and 4, hot standby and hot shutdown respectively, and $4\% \Delta K/K$ in mode 5, cold shutdown. Upon control room evacuation these margins will be verified by sampling of the reactor coolant system to monitor boron concentration, at least once per hour.
 - D. The Reactor Makeup Water Tank is the only source of unborated water, which could lead to a boron dilution event. This tank is isolated from the charging pumps prior to the cooldown of the RCS. This assures RCS makeup will be from the Refueling Water Tank (RWT). The RWT, which has a Technical Specification requirement of 4000 to 4400 ppm boron concentration, provides water to the charging pumps via a gravity feed path or, alternatively, via the boric acid makeup pumps (if non-IE electrical power is available).

Palo Verde Nuclear Generating Station (PVNGS)

Units 1, 2 and 3

Docket Nos. STN-50-528/529/530


File: 84-056-026; G.1.01.10

Page Three

Based upon the preceding discussion, APS believes that the current design is adequate and that a backfit of a source range monitor at the remote shutdown panel is not required to assure reactivity control is maintained while shutting down the plant at that station.

If you do not accept the APS position as stated above, please arrange for appeal meeting at your earliest convenience.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President, Nuclear
ANPP Project Director

EEVB/TFQ:pt

cc: E.A. Licitra
G. Wermiel
A.C. Gehr



RICHARD P. CROUSE
Vice President
Nuclear
(419) 259-5221

Docket No. 50-346

License No. NPF-3

Serial No. 1049

May 10, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz
Operating Reactor Branch No.
Division of Operating Reactors
United States Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Stolz:

On March 26, 1984 (Serial No. 1036) Toledo Edison requested on Appeal meeting on the NRC proposed Technical Specifications concerning the Auxiliary Feedwater System. This was in response to your letter dated February 21, 1984 (Log No. 1455). Toledo Edison has re-evaluated its request for the appeal meeting and hereby withdraws that request. We will submit requested Technical Specification by June 30, 1984 for the Davis-Besse Nuclear Power Station Unit No. 1.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'R. Crouse'.

RPC:GAB:lah

cc: DB-1 NRC Resident Inspector

8405180053 840510
PDR ADOCK 05000346
P PDR

ADD
1/0



RICHARD P. CROUSE
Vice President
Nuclear
419/259-9221

Docket No. 50-346

License No. NPF-3

Serial No. 1036

March 26, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz
Operating Reactor Branch No. 4
Division of Operating Reactors
United States Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Stolz:

This is in response to your letter dated February 21, 1984 (Log No. 1455) concerning Safety Evaluation Report (SER) addressing TMI Task Action Plan NUREG 0737 Item II.E.1.1 for Davis-Besse Nuclear Power Station Unit No. 1 Auxiliary Feedwater (AFW) System. The SER closed out five open items, but three items remain open and you requested proposed Technical Specifications for the open items listed below:

- Item 1 Proposed Technical Specifications which would require that all local manual valves in the auxiliary feedwater pumps suction and discharge lines are locked in the open position and that the locked open position of these valves would be verified on a monthly basis.

- Item 2 That your letter dated June 15, 1983, (Serial No. 956) be supplemented with proposed Technical Specifications which would require a flow verification test of the AFW system to put water into the Steam Generators after each extended cold shutdown.

- Item 3 Proposed Technical Specifications which would require that a dedicated individual who would be in communication with the Control Room to be stationed at the manual valves of the AFW system when conducting periodic tests of the AFW system which require local manual realignment of valves to conduct the periodic tests of the AFW system.


8404020054 840326
PDR ADOCK 05000346
P PDR

APYB
/10

The AFW system (II.E.1.1) has been discussed between Toledo Edison and the NRC staff for the past two years. The above open items were subject to verbal agreement and proposed Technical Specifications for item two were submitted on June 15, 1983 (Serial No. 956). Also discussed and mutually agreed upon were items one and three for which no submittal was required. We have implemented the submittal resulting from our discussions concerning the AFW system, but now your letter requests us to negate that verbal agreement.

Your letter requests Toledo Edison to either submit the proposed Technical Specifications or to request an appeal meeting. Toledo Edison hereby requests an appeal meeting.

Very truly yours,

A handwritten signature in dark ink, appearing to be 'M. L. ...', is written over the closing text.

RPC:GAB:lrh

cc: DBI Resident Inspector

cj a/22

RANCHO SECO NUCLEAR GENERATING STATION UNIT 1

Effect of Internally Generated Missiles on the Auxiliary
Feedwater System Outside Containment

Christie F. Kelton

Prepared By: C. Kelton

Taj M. Khan / V. Arora

Reviewed by: V. Arora/T. Khan

DATE: 4-27-84

David Abbott

Approved by: D. Abbott
Supervising Mechanical Engineer
Sacramento Municipal Utility District

8405080342 840503
PDR ADOCK 05000312
P PDR



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

May 3, 1984

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTENTION JOHN F STOLZ CHIEF
OPERATING REACTORS BRANCH 4
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON D C 20555

DOCKET 50-312
RANCHO SECO NUCLEAR GENERATING STATION
UNIT NO 1
AUXILIARY FEEDWATER SYSTEM (AFWS) UPGRADE REVIEW
NUREG 0737 ITEM II.E.1.1

The District committed in our June 3, 1983 letter, to a walkdown of the AFWS which would determine any areas where a single, internally generated, missile could disable both AFWS trains. The District has completed an analysis, and the attached report shows that a single internally generated missile can not disable both AFWS trains.

We, therefore, conclude that adequate protection is provided and that a walkdown, per se, is no longer required. If we can provide any additional information, please advise.

John J. Mattimoe
General Manager
and Chief Engineer

Attachment

8405080306 840503
PDR ADOCK 05000312
P PDR

A046
11

TABLE OF CONTENTS

- I. Summary
- II. Purpose
- III. Scope
- IV. Description
 - A. Auxiliary Feedwater Protection Philosophy
 - B. Methods of Analysis
- V. Analysis
- VI. Conclusions
- VII. References
- VIII. Figures
 - 1. Auxiliary Feedwater System/Piping and Instrumentation Schematic
 - 2. Auxiliary Feedwater/System Layout Outside Containment
 - 2A. Auxiliary Feedwater/System Layout Outside Containment
 - 3. Auxiliary Feedwater System Class 1E Electrical/Control Component Wiring Schematic

APPENDICES

- Appendix 1 High Energy Piping
- Appendix 2 Moderate Energy Piping
- Appendix 3 Electrical Circuit Locations
- Appendix 4 Rotating Equipment
- Appendix 5 Auxiliary Feedwater - Missile Protection Design Criteria

I. SUMMARY

The purpose of this study was to evaluate the effects of postulated internally generated missiles on the Auxiliary Feedwater System (AFWS) components located outside containment. Missile protection is required if a single missile can simultaneously damage components of both AFWS trains.

AFWS components located in the yard area and auxiliary building include mechanical and electrical equipment, and instrumentation and controls. High energy piping, rotating equipment, and compressed gas storage systems were considered as credible missile sources.

There were no cases where a single missile could simultaneously impact both AFWS trains. It was therefore concluded that the AFWS is adequately protected from the effects of internally generated missiles and no additional protection is required.

II. PURPOSE

This study was prepared for the Rancho Seco Nuclear Generating Station Unit 1, to evaluate the effects of postulated internally generated missiles on the Auxiliary Feedwater System (AFWS) essential components located outside the containment building. The study was based on the Design Criteria attached to this report as Appendix 5.

III. SCOPE

The scope of this study is defined as follows:

- A. Only those portions of the AFWS that are quality Class I and are located outside the containment building are considered. Internal missile protection for AFWS components inside containment is documented in the Updated Safety Analysis Report, Section 5.1.2.1.3.
- B. Turbine missiles or externally generated missiles are not considered.
- C. Secondary missiles or ricochet targets are not considered.
- D. Future modifications to the AFWS as part of the EFIC package scheduled for installation during the 1986 outage will be evaluated for missile considerations at a later date and are not included here.
- E. Gravity missiles are not considered.
- F. Missile protection is required only if a single missile can simultaneously disable both trains of the AFWS. Damage to one train of the AFWS is permitted.

IV. DESCRIPTION

A. Auxiliary Feedwater System Protection Philosophy

The AFWS is shown schematically in Figure 1. Protection of the AFWS from internally generated missiles is limited to those Class I components which are required to mitigate the consequences of an accident, prevent a significant uncontrolled release of radiation, or place the plant in a cold shutdown condition.

The Class I components are as follows:

1. Mechanical equipment including the pumps, turbine driver, valves, and associated piping.
2. Instrumentation/control components used for indication, monitoring and control, and associated tubing.
3. Class 1E electrical components used for signal transmission and for powering and control of the mechanical and instrumentation components described above.

Piping and instrumentation diagrams, logic diagrams, and elementary drawings were used to identify the Class I components described above. A schematic of the Class 1E electrical components is shown on Figure 3.

This study has been limited to existing components, or components for which installation drawings have been released for construction. Future additions to the AFWS, such as the EFIC modifications, will be evaluated for missile protection as part of Rancho Seco's standard plant review procedure.

B. Methods of Analysis

The missile study was performed in two steps. The first step was to identify the physical location of all the Class I AFWS components using the piping area, and conduit and tray drawings for the yard areas and auxiliary building. The second step was to identify and locate all the potential missile sources in the vicinity of the AFWS: high energy piping, rotating equipment, and compressed gas storage system components.

1. High Energy Piping: Piping area drawings, piping and instrumentation diagrams (P&ID's), and physical inspection techniques were used for the location of all high energy lines⁽¹⁾ running through the yard areas. The line designation list (Ref. VII. F) was used to define the normal operating conditions. Lines which did not meet the high energy criteria were considered moderate energy with not enough energy to generate destructive missiles and were excluded from any further consideration. Lines that qualified as high energy because the temperature was greater than 200^oF but where the pressure was less than 10 psig were also not considered to generate destructive missiles and were classified as moderate energy for the purposes of this study. These lines are identified by a double asterisk in the tabulation of moderate energy lines which are attached to this report as Appendix 2. Portions of the AFWS

(1) High energy fluid systems are defined as those pressurized systems or portions thereof in which the normal operating pressure or temperature exceed 275 psig and 200^oF, respectively, for more than 2% of the time it operates during normal plant conditions.

which are not pressurized during normal plant conditions are also excluded from consideration as a high energy missile source and are included in Appendix 2.

High energy fluid system components that were considered as credible missile sources include:

- a. Valve bonnets, stems, and body drain plugs
- b. Temperature and pressure instrumentation connections
- c. Welded dead-end flanges and caps
- d. Vents, drains, and test connections

A tabulation of the missile sources by line number was compiled using the yard area piping drawings, P&ID's, and physical inspection. (This tabulation is included in this report as Appendix 1). The exclusions listed in Section II.C of the Design Criteria (Appendix 5) were then used to generate a list of design missiles. The missiles were assumed to eject in the direction of the applied force. The target or impactee for each of these design missiles was determined by physical inspection.

2. Rotating Equipment: General plant equipment arrangement drawings and the yard area piping drawings were used for the identification of all rotating equipment located in the yard area. Some of these are included in the AFWS piping layout shown on Figures 2 and 2A. Missiles from impeller fragmentation were assumed to eject in the plane of rotation of the impeller centerline. Targets of these missile sources were identified by physical inspection and are tabulated in Appendix 4.

3. Compressed Gas Storage: Compressed gas storage systems located in the yard area were identified on the piping drawings and equipment location drawings. Components were assumed to eject in the direction of the applied force with targets identified by physical inspection.

V. ANALYSIS

A. Yard Area

1. High Energy Piping Missiles: From the list of design missiles originating from high energy piping, a physical inspection was performed to determine the potential targets located within the direction of these design missiles. In most cases, these design missiles were found to hit either a concrete floor or ceiling, steel beams or columns, another section of the same line that ejected the missile, a walkway grating, or nothing at all (the missile would eject into free space and would not impact anything until it returned to earth as a gravity missile). Where the target was a walkway grating, consideration was given to the targets located on the other side of the grating for any possible damage. No consideration was given to secondary missiles or ricochet missiles. In only one instance, a capped weldolet on the main feedwater line to Steam Generator E-205A was determined to impact the valve positioner on FV-20527, the flow control valve on the auxiliary feedwater line to Steam Generator E-205A. Since the valve is related to only one AFWS train, no further analysis was performed. Electrical and instrumentation components of either AFWS train were not impacted by any missiles generated by high energy piping in the yard area.
2. Rotating Equipment: All of the pumps in the yard area were evaluated for AFWS missile impact and are tabulated in Appendix 4.

Four of the pumps, the Nuclear Service Cooling Water Pumps A & B (P-482A and P-482B), the Miscellaneous Water Hold-Up Tank Pump (P-983), and the Low Pressure Injection Header Warming Pump (P-251) are physically oriented such that there are no AFWS components within the plane of rotation at the impeller centerline.

The Component Cooling Water Pump P-462A is shielded from AFWS impact by its redundant pump, P-462B. Pump P-462B, however, could impact the AFWS at two points: line 31827-6"-GB and conduit M11249. The piping target is the AFWS common test line which is located above ground outside the missile shield. The point of impact of a missile generated by P-462B would be on non-seismically qualified piping downstream of FV-31855 as shown on Figure 1. The valve FV-31855 is a "fail-closed" valve which is normally closed except during AFWS testing. Damage to the line downstream of this valve will not compromise the ability of the AFWS to perform its safety function. The electrical target of P-462B is conduit M11249 which contains one of the redundant channels of cables for the AFW pump (P-318, P-319) bearing heaters. From the electrical schematic, Figure 3, it can be seen that the bearing heaters for both AFW pumps are powered independently by both electrical channels. The cable for the other channel is located in cable tray L11AD1, which runs parallel to M11249 on the other side of the overhead pipeway. It is conceivable that this cable tray could also be impacted by a missile from P-462B, even though it is some distance away.

However, it is not possible for both cables to be impacted by the same missile simultaneously because of their locations relative to the pump (A single impeller fragment ejected radially in the plane of the impeller cannot impact two parallel overhead cables located 20 feet apart at the same elevation).

The Demineralized Reactor Coolant Storage Tank Pumps P-622A and P-622B are partially shielded by structural columns supporting an overhead pipe rack. There is a possibility, however, that cable tray L11AD1 could be impacted. As noted above, however, the cable for the AFWS pump bearing heaters that runs through this cable tray is a redundant cable. A missile ejected from P-622A or P-622B cannot simultaneously impact the cable tray and conduit M11249 containing the redundant cable.

The Spent Fuel Coolant Pump, P-272, is shielded on both sides by concrete support pillars and there are no AFWS components overhead. Spent Fuel Coolant Pump P-274 is shielded on one side by a concrete support pillar. Radiation monitor R-15018 is immediately adjacent to the pump on the opposite side and effectively shields the pump from AFW line 31823-6"-DB2 to Steam Generator E-205A.

In reviewing the effects of missiles generated by rotating equipment, it should be noted that this analysis has assumed that the pump casings are actually penetrated by impeller fragments that have enough residual energy to be destructive missiles. Even though it is unlikely that this would happen, it has been postulated to avoid the lengthy calculations that would be

required to prove that the pump casings are not penetrated and that no missiles are ejected.

C. Compressed Gas Storage

Two compressed gas storage systems were considered as possible missile sources. The first was the Nitrogen System. The components associated with the nitrogen storage system are located outside the yard area (west of the turbine laydown area) and would be prevented from reaching the yard area by the missile protection wall separating the yard area and the equipment laydown areas. The second system considered was the carbon dioxide system used for fire protection. The CO₂ storage tank is located in the yard area behind the grade level emergency personnel hatch of the reactor containment building. The personnel hatch was regarded as an intervening structure between any CO₂ storage tank generated missiles and AFWS components. It should also be noted here that the main shutoff valve at the CO₂ storage tank is normally closed so the CO₂ header that runs through the yard area was classified as moderate energy piping based on the 2 $\frac{1}{2}$ operating time criteria. The CO₂ header was therefore not considered as a source of missiles.

2. Auxiliary Building

Inside the auxiliary building there are no mechanical or instrumentation components of the AFWS. The electrical components, however, were reviewed for missile protection. The location of the high energy piping in the auxiliary building was determined using the HELB analysis. The plant general equipment arrangement drawings were used to identify the rooms containing

rotating equipment or compressed gas storage systems. The auxiliary building plan drawings were marked up to show the rooms containing high energy piping, rotating equipment, or compressed gas storage systems and are included in Appendix 3. It was found that there are no rooms where the two AFWS electrical trains are routed together that also contain a missile source. In general, the two electrical trains were physically separated from one another, and the electrical equipment areas were separated from mechanical equipment areas. The areas south and west of the main corridor above grade in the auxiliary building are where the electrical relay cabinets, control panels, motor control centers and computer equipment are housed, and there are no missile sources in these areas. Therefore, there is no AFWS impact from missiles generated in the auxiliary building.

VI. CONCLUSION

In reviewing all the postulated internally generated missiles from the various sources (high energy piping, rotating equipment, and compressed gas storage), it was found that there are no missiles which can simultaneously impact components of both AFWS trains. Therefore, the AFWS is considered adequately protected from the effect of internally generated missiles and no additional protection is required. The AFWS will perform its design function of supplying emergency feedwater to the steam generators to remove reactor decay heat during all design basis internally generated missile events.

VII. REFERENCES

- A. USNRC Standard Review Plan 3.5.1.1, "Internally Generated Missiles (outside containment)", NUREG-0800, Rev. 2, July 1981.
- B. General Design Criterion 4, "Environmental and Missile Design Bases", Appendix A to 10 CFR 50.
- C. Rancho Seco Unit 1, "Updated Safety Analysis Report", Section 5.1.2.1.3.
- D. Letter from John F. Stolz of NRC to R. J. Rodriguez of SMUD, titled "Status of Auxiliary Feedwater Upgrade Review", dated September 26, 1983.
- E. Rancho Seco Unit 1, Calculation No. M21.30-363, titled "HELB Analysis for AFWS", dated June 14, 1983, Revision 0. by Bechtel Power Corporation, Job No. 12334.
- F. Line Designation List M-853, Rev. 8.
- G. Master Equipment List dated October 25, 1981.
- H. Cable Raceway Tracking System.
- I. General Arrangement Drawings
 - 1. M-300, Rev. 9
 - 2. M-301, Rev. 6
 - 3. M-302, Rev. 11
 - 4. M-303, Rev. 7
- J. Yard Area Piping Drawings
 - 1. M-162, Rev. 9
 - 2. M-163, Rev. 13
 - 3. M-187, Rev. 7
 - 4. M-188, Rev. 8
 - 5. M-189, Rev. 9

6. M-190, Rev. 4
7. M-198, Rev. 9
8. M-199, Rev. 7
9. M-200, Rev. 4
10. M-204, Rev. 8
11. M-205, Rev. 5
12. M-329, Rev. 9
13. M-331, Rev. 8

K. Piping and Instrumentation Diagrams

1. M-530, Sheet 1, Rev. 3
2. M-530, Sheet 2, Rev. 4 and DCN's 7 and 10
3. M-530, Sheet 3, Rev. 6
4. M-532, Rev. 20 and DCN's 42, 46, 48, 49, and 50
5. M-533, Sheet 1, Rev. 5
6. M-533, Sheet 2, Rev. 4
7. M-533, Sheet 3, Rev. 2
8. M-537, Sheet 1, Rev. 7
9. M-537, Sheet 2, Rev. 1
10. M-537, Sheet 3, Rev. 4

L. Electrical Conduit and Tray Location Drawings

1. E-703, Sheet 1, Rev. 22
2. E-709, Sheet 2, Rev. 2
3. E-710, Sheet 2, Rev. 2
4. E-711, Sheet 2, Rev. 2
5. E-712, Sheet 2, Rev. 3
6. E-719, Rev. 15
7. E-720, Rev. 17

8. E-721, Rev. 16
9. E-735, Sheet 2, Rev. 3
10. E-739, Sheet 1, Rev. 21 and DCN 62
11. E-739, Sheet 2, Rev. 4
12. E-740, Sheet 1, Rev. 18 and DCN 45
13. E-740, Sheet 2, Rev. 3
14. E-741, Sheet 1A, Rev. 6
15. E-741, Sheet 2, Rev. 5 and DCN 12
16. E-742, Sheet 2, Rev. 3
17. E-743, Sheet 1, Rev. 30
18. E-743, Sheet 2, Rev. 6
19. E-744, Sheet 1, Rev. 23
20. E-744, Sheet 3, Rev. 5
21. E-744, Sheet 3A, Rev. 5
22. E-745, Sheet 2, Rev. 6
23. E-745, Sheet 3, Rev. 0
24. E-747, Sheet 1, Rev. 13
25. E-749, Rev. 24
26. E-751, Rev. 24

M. Electrical Elementary and Wiring Diagrams

1. E-104, Sheet 2, Rev. 8
2. E-104, Sheet 3, Rev. 10
3. E-105, Sheet 1, Rev. 5
4. E-105, Sheet 2, Rev. 6
5. E-107, Sheet 4, Rev. 0
6. E-205, Sheet 20F, Rev. 0

7. E-304, Sheet 32, Rev. 17
8. E-307, Sheet 25, Rev. 0
9. E-323, Sheet 11, Rev. 0
10. E-323, Sheet 13, Rev. 0
11. E-323, Sheet 14, Rev. 0
12. E-323, Sheet 15, Rev. 0
13. E-342, Sheet 1, Rev. 23
14. E-342, Sheet 29, Rev. 29
15. E-342, Sheet 32, Rev. 2
16. E-342, Sheet 56A, Rev. 1

N. Mechanical Equipment Vendor Drawings - Pumps


1. M5.06-1
2. M5.06-2
3. M29.03-31
4. M29.03-32
5. M29.03-34
6. M29.03-40
7. M29.03-43
8. M29.03-43A
9. M29.03-44
10. M29.03-51

O. Mechanical Equipment Vendor Drawings - Valves

1. M19.02-338
2. M19.02-348
3. M19.05.1-1

4. M22.02-8
5. M22.02-14
6. M22.02-15
7. M22.02-16
8. M22.05-53
9. M22.05-55
10. M22.05-115
11. M22.06-23
12. M22.06-42
13. M22.06-47
14. M22.14-12
15. M22.30-28
16. N06.03-17
17. N06.03-18
18. N21.01-94

FIGURE 1



AUXILIARY FEEDWATER SYSTEM PIPING & INSTRUMENTATION SCHEMATIC

REVISED: 10/15/64
 DRAWN BY: J. R. BROWN
 CHECKED BY: J. R. BROWN
 DATE: 10/15/64

SMUD
 STATE METRO UTILITIES DISTRICT

PROJECT: RANCHO SECO NUCLEAR GENERATING STA., UNIT 1
 DRAWING NO.: 1000-1000-1000-1000
 SHEET NO.: 1000-1000-1000-1000

AFWS MISSILE STUDY
 FIGURE 1

FIGURE 2





FIGURE 2A




NUCLEAR REACTOR
SYSTEM LAYOUT
OUTSIDE OF CONTAINMENT AREA

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|
| NO. 1 | NO. 2 | NO. 3 | NO. 4 | NO. 5 | NO. 6 | NO. 7 | NO. 8 | NO. 9 | NO. 10 | NO. 11 | NO. 12 | NO. 13 | NO. 14 | NO. 15 | NO. 16 | NO. 17 | NO. 18 | NO. 19 | NO. 20 | NO. 21 | NO. 22 | NO. 23 | NO. 24 | NO. 25 | NO. 26 | NO. 27 | NO. 28 | NO. 29 | NO. 30 | NO. 31 | NO. 32 | NO. 33 | NO. 34 | NO. 35 | NO. 36 | NO. 37 | NO. 38 | NO. 39 | NO. 40 | NO. 41 | NO. 42 | NO. 43 | NO. 44 | NO. 45 | NO. 46 | NO. 47 | NO. 48 | NO. 49 | NO. 50 | NO. 51 | NO. 52 | NO. 53 | NO. 54 | NO. 55 | NO. 56 | NO. 57 | NO. 58 | NO. 59 | NO. 60 | NO. 61 | NO. 62 | NO. 63 | NO. 64 | NO. 65 | NO. 66 | NO. 67 | NO. 68 | NO. 69 | NO. 70 | NO. 71 | NO. 72 | NO. 73 | NO. 74 | NO. 75 | NO. 76 | NO. 77 | NO. 78 | NO. 79 | NO. 80 | NO. 81 | NO. 82 | NO. 83 | NO. 84 | NO. 85 | NO. 86 | NO. 87 | NO. 88 | NO. 89 | NO. 90 | NO. 91 | NO. 92 | NO. 93 | NO. 94 | NO. 95 | NO. 96 | NO. 97 | NO. 98 | NO. 99 | NO. 100 |
|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|

FIGURE 2A

FIGURE 3



AUXILIARY FEEDWATER CLASS 1E ELECTRICAL / CONTROL COMPONENT WIRING SCHEMATIC

SMUD

AF WS MISSILE STUDY

FIGURE 3

PROJECT: RANCHO SECO NUCLEAR GENERATING STA. UNIT 1

DATE: 11/14/68

SCALE: 1/8" = 1'-0"

REVISIONS:

| NO. | DATE | BY | DESCRIPTION |
|-----|------|----|-------------|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |
| 24 | | | |
| 25 | | | |
| 26 | | | |
| 27 | | | |
| 28 | | | |
| 29 | | | |
| 30 | | | |
| 31 | | | |
| 32 | | | |
| 33 | | | |
| 34 | | | |
| 35 | | | |
| 36 | | | |
| 37 | | | |
| 38 | | | |
| 39 | | | |
| 40 | | | |
| 41 | | | |
| 42 | | | |
| 43 | | | |
| 44 | | | |
| 45 | | | |
| 46 | | | |
| 47 | | | |
| 48 | | | |
| 49 | | | |
| 50 | | | |
| 51 | | | |
| 52 | | | |
| 53 | | | |
| 54 | | | |
| 55 | | | |
| 56 | | | |
| 57 | | | |
| 58 | | | |
| 59 | | | |
| 60 | | | |
| 61 | | | |
| 62 | | | |
| 63 | | | |
| 64 | | | |
| 65 | | | |
| 66 | | | |
| 67 | | | |
| 68 | | | |
| 69 | | | |
| 70 | | | |
| 71 | | | |
| 72 | | | |
| 73 | | | |
| 74 | | | |
| 75 | | | |
| 76 | | | |
| 77 | | | |
| 78 | | | |
| 79 | | | |
| 80 | | | |
| 81 | | | |
| 82 | | | |
| 83 | | | |
| 84 | | | |
| 85 | | | |
| 86 | | | |
| 87 | | | |
| 88 | | | |
| 89 | | | |
| 90 | | | |
| 91 | | | |
| 92 | | | |
| 93 | | | |
| 94 | | | |
| 95 | | | |
| 96 | | | |
| 97 | | | |
| 98 | | | |
| 99 | | | |
| 100 | | | |

— CIRCUIT ORIGINATING FROM EQUIPMENT IN YARD AREA OR TURBINE BLDG.

- - - CIRCUIT TOTALLY WITHIN THE AUXILIARY BUILDING

APPENDIX 1: HIGH ENERGY PIPING AND
MISSILE SOURCES



CALCULATION SHEET

APPENDIX I

REVISIONS

CALCULATION NO.

SIGNATURE *Charles S. ...* DATE 4-25-84 CHECKED *...* DATE 4-22-84

PROJECT *...* UNIT *...* JOB NO. 12334-030

SUBJECT *...* SHEET 1 OF 7 SHEETS

HIGH ENERGY PIPING

| DESCRIPTION | LINE NO. | DIAMETER P/D | PIPE Dwg. NO. | VALVES | MARK NO. | PRESS. RATING | VENDOR LOG NO. | BONNET MISSILE EXCLUSION | READY MADE PLATE N/A | OTHER POTENTIAL MISSILES | AFWJ IMPACT | COMMENTS |
|---|----------------|-----------------|------------------|-----------|-------------|------------------|-------------------|--------------------------------|----------------------------|--------------------------------|----------------|--|
| Main steam from A | 20520-36-EA | 700/600 | M-329 | | | | | | | vent | none | vent valve tag MSS-521 (1") |
| Low pressure steam from line 20520-36-EA | 20521-10-EA | 700/600 | M-329 | HPT-525 | | 1040 | M.I. 1 | 3c | N/A | | | Motor operated Bulb bonnet determined by walkdown |
| | 20521-10-1B | | | HPT-526 | | 1040 | M.I. 1 | 3b | N/A | | | " |
| | 20521-10-2B | | | HPT-527 | | 1070 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-3B | | | HPT-497 | | 1070 | M.I. 1 | 3b | N/A | | | " |
| | 20521-10-4B | | | PSV-20545 | | 1040 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-5B | | | PSV-20547 | | 1040 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-6B | | | PSV-20549 | | 1070 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-7B | | | PSV-20551 | | 1070 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-8B | | | PSV-20553 | | 1070 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-9B | | | PSV-20555 | | 1101.5 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-10B | | | PSV-20557 | | 1090 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-11B | | | PSV-20559 | | 1090 | M.I. 1 | 3a | N/A | | | " |
| | 20521-10-12B | | | PSV-20561 | | 1101.5 | M.I. 1 | 3a | N/A | | | " |
| Main steam from A | 20521-10-13-1B | 700/600 | M-102 | | | | | | | weld cap | none | Pressure rating from nameplate |
| Steam to HP Condenser | 20521-10-13-2B | | | | | | | | | | | Pressure rating from nameplate |

a. Valve mark number, pressure rating, and vendor drawing log number are from the Plant Equipment List dated 10-25-81, unless commented otherwise.
 b. For explanation of bonnet missile exclusion categories, see App. 5. Internally Generated Missiles Design Criteria, Section II.C.
 c. AFWJ impact determined by visual inspection during 5-lbm walkdown. If valve body does not have a drain plug, AFWJ impact is "N/A." If missile does not impact both AFWJ trains, AFWJ impact is "none."
 d. Operating P/T are from the Line Identification List M-253 Rev. 8.



140 0018 12/18

CALCULATION SHEET

APPENDIX I

MISSISSIPPI VALVE MANUFACTURING COMPANY
MEMPHIS, MISSISSIPPI 38117

SIGNATURE Charles S. White DATE 4-13-84 CHECKED J. J. White DATE 4-26-84

PROJECT Parakee Sewer Unit JOB NO. 1334-030

SUBJECT Low AFW Jettable Generator SHEET 2 OF 7 SHEETS

HIGH ENERGY PIPING

| DESCRIPTION | LINE NO. | ORIENTING P/T (N/S/E) | PIPING (NB/MB) | VALVES | MAK. No. | PRESS. RATING | VENDOR LOG # | VEN. MISSILE EXCLUSION | OTHER POTENTIAL MISSILES | AFW IMPACT | COMMENTS |
|---------------------------------------|------------|-----------------------|----------------|--------------------------------|-------------------|-------------------|-------------------------------------|------------------------|--|------------------------------|---|
| Main steam loop A loop to atmosphere | 20550-B-EA | 900/600 | M-329 | MSS-017 PV-20571A | 3BB | 600 | M21-02-16 | none | Pressure tap | none | Air operated |
| | 20550-B-EA | 900/600 | M-329 | MSS-017 | 3BB | 600 | M22-02-16 | none | | none | (MSS-545) Tapping attached Air operated |
| | 20550-B-EA | 900/600 | M-329 | MSS-011 PV-20571C | 3BB | 600 | M21-01-94 | none | Capped weldlet | none | Location determined by walkdown Air operated |
| Main steam loop A to AFW pump turbine | 30802-W-EA | 900/600 | M-187 | MSS-052 MSS-050 HY-20569 | 154 3BB 4BS | 900 600 600 | M22-06-23 M22-02-19 M22-06-47 | none none none | | none | Pressure rating from nameplate Motor operated |
| | 30800-W-EA | 900/600 | M-204 | FJ-30801 | 3C | 600 | N100 | none | 4" blinded tee 4" blinded tee T1-30804 P1-30803 | none none none none | Bulb flange, location by walkdown " location by walkdown Inside missile shield Inside missile shield Motor operated |
| Low point drain for line 20810-W-EA | 30800-W-EA | 900/600 | M-204 | MSS-544 MSS-545 MSS-546 | 3B 3B 3B | 600 | N/A N/A N/A | none N/A N/A | ICV-50801 | none | Bulb binned determined by walkdown Steam trap w/ bulb 0.5" walkdown Bulb binned determined by walkdown |

a. Valve mark number, pressure rating, and vendor drawing tag number are from the Plant Equipment List listed 4025-B, unless commented otherwise.
 b. For explanation of binned missile exclusion categories, see **App. 5** "Internally Generated Missiles Design Criteria," Section II.C.
 c. AFW impact determined by visual inspection during system walkdown. If valve body does not have a drain plug, AFW impact is "N/A". If missile does not impact both AFW tanks, AFW impact is "none".
 d. Operating P/T are from the Line Identification List M-253, Rev. 8.



CALCULATION SHEET

APPENDIX I

CALCULATION NO.

SIGNATURE Calvin S. Wilson DATE 4-23-84 CHECKED L. J. ... DATE 4-26-84

PROJECT Reaction Site Unit JOB NO. 13334-930

SUBJECT Aux. Fuel for normally Generated Missiles SHEET 3 OF 7 SHEETS

HIGH ENERGY PIPING

| DESCRIPTION | LINE NO. | OPERATING P/T (PSI/°F) | PIPING (Inch) | VALVES | MARK No. | PRESS. RATING | VENDOR LOG NO. | BARNET EXCLUSION | LONG LEAD PLUG (NEW/REPL) | OTHER POTENTIAL MISSILES | AFW IMPACT | COMMENTS |
|---------------------------------------|-------------|------------------------|---------------|-----------|----------|---------------|----------------|------------------|---------------------------|--------------------------|------------|--|
| Main steam from S.G. B | 10421-14-EA | 900/600 | M-329 | PSV-20544 | - | 1050 | NOW-03-1B | 3b | N/A | - | - | Pressure rating from nameplate |
| | | | " | PSV-20546 | - | 1050 | " | 3b | N/A | - | - | |
| | | | " | PSV-20548 | - | 1070 | " | 3b | N/A | - | - | |
| | | | " | PSV-20534 | - | 1102.5 | " | 3b | N/A | - | - | |
| | | | " | PSV-20540 | - | 1070 | " | 3b | N/A | - | - | |
| | | | " | PSV-20552 | - | 1070 | " | 3b | N/A | - | - | |
| | | | " | PSV-20554 | - | 1090 | NOW-03-17 | 3b | N/A | - | - | |
| | | | " | PSV-20556 | - | 1070 | " | 3b | N/A | - | - | |
| | | | " | PSV-20558 | - | 1102.5 | NOW-03-1B | 3b | N/A | - | - | |
| Ins. point drain for | 30083-1-EA | 900/600 | M-329 | HT-20571 | - | 2350 | M22-14-12 | 5c | N/A | - | - | Motor operated |
| line 10421-16-EA | 20570-2-EA | 900/600 | M-910 | HPT-529 | - | - | - | 5b | N/A | 104-20571 | none | Outlet bonnet determined by walkdown location by steam trap w/ boltedassy walkdown |
| | | | " | HPT-930 | - | - | - | 3b | N/A | - | - | Outlet bonnet determined by walkdown |
| | | | " | HPT-528 | - | - | - | 3b | N/A | - | - | " |
| | | | " | HPT-531 | - | - | - | 3b | N/A | - | - | " |
| | | | " | HPT-495 | 144 | 600 | - | 3b | N/A | - | - | " |
| Main steam loop B dump to HP condensa | 20630-10-EA | 900/600 | M-142 | - | - | - | - | - | - | - | - | No valves or other potential missiles on this line in yard area or on B14 |
| Main steam loop B to AFW pump by line | 30804-6-EA | 700/600 | M-187 | MSS-051 | 134 | 900 | 2-06-15 | 3a | none | - | - | Pressure rating from nameplate |
| | 20570-6-EA | 900/600 | M-187 | MSS-049 | 38B | 600 | M22-02-15 | 3b | none | - | - | Motor-operated |
| | 20570-6-EA | 900/600 | M-187 | HT-20596 | 385 | 600 | M22-06-41 | 3b, c | none | - | - | |

a. Valve mark number, pressure rating, and vendor drawing log number are from the Plant Equipment List dated 10-15-81, unless commented otherwise.

b. For explanation of barnet missile exclusion categories, see APP. 5. Internally Generated Missiles Design Criteria, Section II.C.

c. AFW impact determined by visual inspection during system walkdown. If valve body does not have a drain plug, AFW impact is "N/A". If missile does not impact both AFW trains, AFW impact is "none".

d. Operating P/T are from the line designation list M-853 Rev. B.



1 40 9418 12/78

CALCULATION SHEET

APPENDIX I

CALCULATION NO.

SIGNATURE *Charles A. V. G. G.* DATE 4-13-84 CHECKED *W. J. G. G.* DATE 11-26-84

PROJECT *Electric Service Unit #1* JOB NO. 12334-030

SUBJECT *Line for electrical connection to busbar* SHEET 4 OF 7 SHEETS

HIGH ENERGY PIPING

| DESCRIPTION | LINE NO. | OPERATING P/T | PIPING DWG. NO. | VALVES | MARK No. | PRESS RATING | VENDOR LOG NO. | BUNNET MISSILE EXCLUSION | OTHER POTENTIAL MISSILES | AFW IMPACT | COMMENTS |
|--|------------|---------------|-----------------|----------------------|----------|--------------|---------------------------|--------------------------|--------------------------|------------|--|
| Minimum drain loop to dump to atmosphere | 20532-B-EA | 700/600 | M-329 | M55-01B P4-20562A | 50B | 600 | M12.02-16 M21.01-94 | 3b 3c | none none | none | Air operated |
| | 20558-B-EA | 700/600 | M-329 MID | M55-020 P4-20562C | 50B | 600 | M12.02-16 M21.01-94 | 3b 3c | Pressure loop none | none | Tubing attached (mass-564) Air operated |
| | 20519-B-EA | 700/600 | M-329 | M55-022 P4-20562B | 50B | 600 | M12.02-16 M21.01-94 | 3b 3c | none none | none | Air operated |
| Auxiliary Cooler to AFW Pump Turbine | 30208-B-EA | 700/600 | M-157 | M55-006 M55-005 | 242 | 600 | M12.02-A90 M12.02-A37A | 3b 3b | none none | none | Air operated |

a. Valve mark number, pressure rating, and vendor drawing log number are from the Plant Equipment List dated 10-25-81, unless commented otherwise.
 b. For explanation of bunnet missile exclusion categories, see App. 5. Internally Generated Missiles Design Criteria, Section II.C.
 c. AFW impact determined by visual inspection during system walkthrough. If valve body does not have a drain plug, AFW impact is "N/A." If missile does not impact both AFW trains, AFW impact is "none."
 d. Operating P/T are from the Line Designation List M-253 Rev. B.

CALCULATION SHEET
FORM 100-100-100-100

APPENDIX I
 CALCULATION NO.

SIGNATURE C.D. [Signature] DATE 4.23.85 CHECKED [Signature] DATE 1.16.84
 PROJECT LOCATION see sheet JOB NO. 11314-030
 SUBJECT For 1st Safetyably Controlled Maximum SHEET 5 OF 7 SHEETS

HIGH ENERGY PIPING

| DESCRIPTION | LINE NO. | OPERATING P/T (psig/ft) | PIPING DWG NO. | VALVES | MARK NO. | PRESS RATING | VENDOR DWG LOG NO. | BONNET MISSILE EXCLUSION | BODY DRG. PLUG P/W/IMPACT | OTHER POTENTIAL MISSILES | AFW IMPACT | COMMENTS |
|----------------------------|-------------|-------------------------|----------------|----------|----------|--------------|--------------------|--------------------------|---------------------------|------------------------------------|------------------|---|
| Feedwater to SG A | 32190-20-DB | 1100/404 | M-331,086 | FW5-015 | 21865 | 900 | M11.05-53 | 3a | none | 11-32147 Capped weldolet | none EJ 20527 | Location determined by walkdown. Indicator is active. (see log) building instrument tag in inside penetration. Location determined by walkdown. missile impact Train A only. date not affect Train B. |
| | 32110-20-DB | 1150/404 | M-331,086 | FW5-015 | 21865 | 900 | M11.05-53 | 3a | none | Capped weldolet | none | Location determined by walkdown |
| | | | M-331,180 | FW5-015 | 231 | 900 | M11.05-55 | 3a | none | Hinge pin cover Capped weldolet | none | Location determined by walkdown |
| | | | M-331 | | | | | | | PDT-20567B PDT-20567A | none | Attached tubing, log number verified in field |
| | | | M-331,187 | FW-20529 | 225 | 900 | M11.05-115 | 3a, c | none | Capped weldolet | none | Location determined by walkdown |
| | | | M-331,187 | FW-20525 | | 900 | M11.02-34B | 3c | none | Capped weldolet | none | Motor operated |
| | | | M-331,187 | FW5-132 | 22 | 900 | | 3a | none | Capped weldolet | none | Location determined by walkdown |
| | | | M-331,187 | | | | | | | PDT-20567B Capped weldolet | none | Attached tubing (PDT) |
| | | | M-331,187 | | | | | | | PDT-20567A FE-20535 | none | Location determined by walkdown |
| | | | M-331,188 | | | | | | | | none | Air operated |
| 100% D12 Bypass Loop A | 32147-12-DB | 1180/404 | M-331,188 | | | | | | | | none | Location determined by walkdown |
| | 32146-12-DB | 1180/404 | | FW5-10B | 154 | 1140 | M11.02-6 | 5b | N/A | | none | Attached tubing (PDT) |
| FW5 Stand by Bypass Loop A | 32139-12-DB | 1155/404 | M-331,188 | FW5-021 | | | | | | | none | Location determined by walkdown |

a. Valve mark number, pressure rating, and vendor drawing log number are from the Plant Equipment List dated 10-25-81, unless commented otherwise.
 b. For explanation of bonnet missile exclusion categories, see App. 5 "Internally Generated Missiles Design Criteria" Section II.C.
 c. AFW impact determined by visual inspection during system walkdown. If valve body does not have a drain plug, AFW impact is "N/A". If missile does not impact both AFW trains, AFW impact is "none".
 d. Operating P/T are from the Line Designation List M-253 Rev. 8.



140 0018 11/78

CALCULATION SHEET

APPENDIX I

CALCULATION NO.

DATE 9-15-89 CHECKED J. DeSoto DATE 11-26-91

PROJECT San Jose Sewer Plant JOB NO. 17339-030

SUBJECT Area 101 Substation Grounded Busbar SHEET 6 OF 7 SHEETS

11611 ENERGY PIPING

| DESCRIPTION | LINE NO. | OPERATING P/T (PSI/FEET) | PIPING DWG NO. | VALVES | MARK NO. | PRESS RATING | VENDOR DWG LOG NO. | BONNET MISSILE EXCLUSION | BODY MISSILE PLUG AFW IMPACT | OTHER POTENTIAL MISSILES | AFW IMPACT | COMMENTS |
|---|------------|--------------------------|----------------|--------------------------------|---------------|--------------|---------------------------------------|--------------------------|------------------------------|--------------------------|------------|--|
| FWS-015, 016, 017, 018, 019, 020, 021, 022, 023, 024, 025, 026, 027, 028, 029, 030, 031, 032, 033, 034, 035, 036, 037, 038, 039, 040, 041, 042, 043, 044, 045, 046, 047, 048, 049, 050, 051, 052, 053, 054, 055, 056, 057, 058, 059, 060, 061, 062, 063, 064, 065, 066, 067, 068, 069, 070, 071, 072, 073, 074, 075, 076, 077, 078, 079, 080, 081, 082, 083, 084, 085, 086, 087, 088, 089, 090, 091, 092, 093, 094, 095, 096, 097, 098, 099, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000 | 32132-8-DB | 1150/404 | M-331 | FWS-019 FY-20575 FWS-017 | 22 | 900 | M17-02-14 M19-02-33B M22-02-A3B | 3a 3c 3a | none none none | FE-20539 | none | Air-operated Attached tubing |
| 32125-8-DB | 1150/404 | M-331 | | | | 900 | | | | | | Location determined by walkdown table for it outside weather. Mfg. instrument for it inside protection. Location determined by walkdown. |
| 32141-20-DB1 | 1100/404 | M-331, 103 | | FWS-016 FWS-014 | 22 BGS 231 | 900 900 | M22-05-53 M22-05-55 | 3a 3a | none none | | none | Location determined by walkdown |
| 32124-10-DB | 1150/404 | | M-331 | | | 900 | | | | | none | Location determined by walkdown |
| | | | M-331 | | | 900 | | | | | none | Attached tubing |
| | | | M-331, 187 | FY-20530 FY-20526 | 22.5 | 900 900 | M22-05-115 M19-02-34B | 3a, c 3c | none none | | none | Attached tubing Location determined by walkdown |
| | | | M-331, 187 | FWS-133 | 22 | 900 | | 3a | none | | none | Location determined by walkdown |
| | | | M-331 | | | 900 | | | | | none | Attached tubing |
| | | | | | | 900 | | | | | none | Attached tubing |
| | | | | | | 900 | | | | | none | Location determined by walkdown |

a. Valve track number, pressure rating, and vendor drawing log number are from the Plant Equipment List dated 10-25-81, unless commented otherwise.
 b. For explanation of bonnet missile exclusion categories, see App. 5 "Internally Generated Missiles Design Criteria," Section II.C.
 c. AFW impact determined by visual inspection during 50-psi walkdown. If valve body does not have a drain plug, AFW impact is "N/A." If valve does not impact both AFW trains, AFW impact is "none."
 d. Operating P/T are from the Line Presentation List for 2055, May 8.



640 0016 1174

CALCULATION SHEET

APPENDIX I
CALCULATION NO.

SIGNATURE: Sanjay K. V. S. DATE: 9.13.83 CHECKED: L. K. S. DATE: 4.26.84
 PROJECT: Reaction Separator JOB NO: 1334-030
 SUBJECT: AFU Jet Assemblies Generated Missiles SHEET 7 OF 7 SHEETS

HIGH ENERGY PIPING

| DESCRIPTION | LINE NO. | OPERATING P/T (PSI/°F) | PIPING DWG NO. | VALVES | MARK NO. | PRESS. RATING | VENDOR LOG NO. | BONNET MISSILE EXCLUSION | OTHER POTENTIAL MISSILES | AFW IMPACT | COMMENTS |
|--------------------------|-----------------|------------------------|------------------------|---------------------|----------|---------------|--------------------------|--------------------------|--------------------------|------------|---|
| Fire rig Bypass | 32109-1 1/2" DB | 1150/404 | M-331 | FWS-107 | 195 | 2240 | M12-02-B | 3b | N/A | | |
| Loop B | 32108-1 1/2" DB | 1150/404 | " | | | | | | | | |
| Fire relief up Bypass | 32136-12" DB | 1150/404 | M-331 | FWS-032 | 21865 | 900 | M12-06-42 | 3a | none | | |
| Loop B | 32136-12" DB | 1150/404 | (280) M-331, (CH 4) | | | | | | | | Air operated |
| Fire relief, down Bypass | 32136-0" DB | 1150/404 | M-331, 187 | FWS-020 | 216 | 900 | M12-02-14 | 3a | none | | |
| Loop B | 32136-0" DB | 1150/404 | (280) M-331, 187 | FV-20576 FWS-018 | | | M17-02-338 M12-02-A3B | 3c 3a | none none | | Attached tubing |
| Arbitrary steam header | 30020-12" GB | 250/406 | M-187 | | | | | | FE-20940 | none | |
| | 30020 6" GB | 250/406 | M-107, 103 | | | | | | vent 6" blind clamp | none | 5" gnd valve ASC-021, location by walk down Location by walk down |
| | 30020-2 1/2" GB | 250/406 | 187, 180 | | | | | | drain | none | drain valve ASC-624 |
| Arbitrary header | 30098-6" GB | 250/406 | M-187 | PV-30028 | | 200 | M19-05-1-1 | 5b | N/A | | Boiler bypass |
| for fire relief | 30088-6" GB | 250/406 | " | PV-3002A | | 275 | M19-05-1-1 | 3b | N/A | | " |
| Arbitrary header | 30120-6" GB | 250/406 | M-103 | 14-30050 | 53 | 300 | M12-30-2B | 3c | N/A | | Water operated; valve info from M-372 design valve is water operated; valve info from M-372 design; line open P/T from M-372 design |
| for fire relief | 30120-4" GB | 250/406 | " | 14-30051 | 53 | 300 | M12-30-2B | 3c | N/A | | Water operated; valve info from M-372 design valve is water operated; valve info from M-372 design; line open P/T from M-372 design |
| Arbitrary header | 30001-5" GB | 250/406 | M-181 | | | | | | | | Water operated; valve info from M-372 design valve is water operated; valve info from M-372 design; line open P/T from M-372 design |
| Loop turbine | | | | | | | | | | | Water operated; valve info from M-372 design valve is water operated; valve info from M-372 design; line open P/T from M-372 design |

a. Valve mark number, pressure rating, and vendor drawing tag numbers are from the Plant Equipment List dated 10-25-81, unless commented otherwise.
 b. For explanation of bonnet missile exclusion categories, see APP 5 "Internally Generated Missiles Design Criteria," Section II.C.
 c. AFW impact determined by visual inspection during system walk-down. If valve body does not have a drain plug, AFW impact is "N/A." If
 missile does not impact both AFU turbine, AFW impact is "same."
 d. Operating P/T are from the Line Identification List, 10-25-81, Rev. 8.

APPENDIX 2: MODERATE ENERGY PIPING



CALCULATION SHEET

LAO 0013 072

APPENDIX 2

CALC. NO. _____

SIGNATURE Christina J. Kelly DATE 4-26-84CHECKED J. Dostal DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12324-030SUBJECT Aux FW Internally Generated MissilesSHEET 1 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | | |
|--------------------------|-----------------|-----------------------------|-----------------------------|--------------------|
| 2 | Line No. | Oper. P/T (psig / °F) | Description | Piping Dwg. No. |
| 3 | | | | |
| 4 | | | | |
| 5 | * 20516-8"-HC | 50/280 | SG A Stm Dump to Atmos | M-329 |
| 6 | * 20519-8"-HC | 50/280 | SG B Stm Dump to Atmos | M-329 |
| 7 | * 20533-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 8 | * 20534-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 9 | * 20535-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 10 | * 20536-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 11 | * 20537-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 12 | * 20538-8"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 13 | * 20539-8"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 14 | * 20540-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 15 | * 20541-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 16 | * 20542-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 17 | * 20543-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 18 | * 20544-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 19 | * 20545-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 20 | * 20546-8"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 21 | * 20547-8"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 22 | * 20548-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 23 | * 20551-10"-HC | 40/270 | SG A Relief to Atmos | M-329 |
| 24 | * 20557-10"-HC | 40/270 | SG B Relief to Atmos | M-329 |
| 25 | * 20571-8"-HC | 50/280 | SG B Stm Dump to Atmos | M-329 |
| 26 | * 20575-8"-HC | 50/280 | SG A Stm Dump to Atmos | M-329 |
| 27 | * 20577-8"-HC | 50/280 | SG B Stm Dump to Atmos | M-329 |
| 28 | * 20597-8"-HC | 50/280 | SG A Stm Dump to Atmos | M-329 |
| 29 | 25020-16"-HD | 60/90 | BWST to DHR Pp A | M-198,163 |
| 30 | 25020-2-1/2"-HD | 60/90 | BWST to DHR Pp A | M-198 |
| 31 | 25021-2-1/2"-HD | 60/90 | BWST to DHR Pp B | M-198 |
| 32 | 25021-16"-HD | 60/90 | BWST to DHR Pp B | M-198 |
| 33 | 25022-16"-HD | 60/100 | SF Stg Pool to DHR Pp | M-188,187 |
| 34 | 25024-3"-HD | 60/90 | BWST to SF Coolant Demin Pp | M-188 |
| 35 | 25080-3"-HD | Atm/90 | BWST O'flow to RC Drn Tk | M-198, 163 |
| 36 | 25081-3"-HD | Atm/90 | Hose Conn on BWST | M-188 |



CALCULATION SHEET

LAO 0013 0-73

CALC. NO. _____

SIGNATURE Christine J. Kelton DATE 4-26-84CHECKED L. D. D. D. DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 2 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | | |
|--------------------------|--------------------|--------------------------|----------------------------------|-------------------|
| 2 | Line No. | Oper. P/T (psig / °F) | Description | Piping Dwg. No. |
| 3 | | | | |
| 4 | | | | |
| 5 | 25083-4"-HD | 60/90 | BWST Port Pp Conn | M-198 |
| 6 | 25101-3"-HD | 60/90 | BWST to LP Inj Hdr Warming Pp | M-198 |
| 7 | 25120-2-1/2"-HD | 35/90 | LP Inj Hdr Warming Pp to BWST | M-198 |
| 8 | 25121-2-1/2"-HD | 60/90 | LP Inj Hdr Warming Pp to BWST | M-198 |
| 9 | 25123-2-1/2"-HD | 60/90 | LP Inj Hdr Warming Pp to BWST | M-163,190,198,162 |
| 10 | * 26022-8"-GD | 450/200 | DHR Cooler to SF Stg Pool | M-162,163 |
| 11 | 26033-8"-HD | 100/120 | DHR Cooler to BWST | M-163,188,198 |
| 12 | 26060-18"-HE | 80/145 | DHR Cooler to NSCW HEX | M-163,198,188 |
| 13 | 26061-18"-HE | 80/145 | DHR Cooler to NSCW HEX | M-198, 201 |
| 14 | 27000-8"-HD | 30/120 | SF Coolant Pp to SF Cooler | M-188 |
| 15 | 27060-8"-HE | 90/113 | SF Cooler to CCW Pp | M-188 |
| 16 | 27020-8"-HD | 30/120 | SF Cooler to SF Stg Pool | M-188,163,162 |
| 17 | 27050-8"-HE | 90/95 | CCW HEX to SF Cooler | M-188 |
| 18 | 27200-8"-HD | 20/120 | SF Stg Pool to SF Coolant Pp | M-188 |
| 19 | 27400-3"-HD | 30/120 | SF Cooler to SF Coolant Demin Pp | M-188 |
| 20 | 27420-3"-HD | 110/120 | SF Clnt Demin Pp to SF Clnt Fltr | M-188,163,162,190 |
| 21 | 27620-3"-HD | 150/120 | SF Cool Demin to SF Stg Pool | M-190,188 |
| 22 | 27622-3"-HD | 100/120 | SF Clnt Demin to BWST | M-190,163,187,198 |
| 23 | 27623-3"-HD | 100/120 | SF Clnt Demin to SF Stg Pool | M-190,163,162 |
| 24 | 27626-3"-HD | 100/120 | SF Clnt Demin to BWST | M-190,163,187 |
| 25 | 27700-3"-HD | 25/120 | SF Stg Pool to Skimmer Pp | M-163,188 |
| 26 | 27701-3"-HD | 25/120 | SF Stg Pool to Skimmer Pp | M-188 |
| 27 | 27822-2-1/2"-HD | 100/120 | SF Pool Fltr to SF Stg Pool | M-188 |
| 28 | * 30890-8"-HC | 2/435 | AFW Pp Turbine Exhaust to Atmos | M-204 |
| 29 | * 30890-12"-HC | 2/435 | AFW Pp Turbine Exhaust to Atmos | M-204 |
| 30 | * 30926-4"-EAL | 900/200 | SG Drn Booster Pp to Demin Area | M-162,163 |
| 31 | * 30934-1-1/2"-DB2 | 25/Amb | SG Drn Booster Pp to SG A and B | M-163 |
| 32 | 31800-8"-HC | 15/90 | CST to AFW Pp P318 | M-204 |
| 33 | 31801-8"-HC | 20/Amb | Folsom S Canal Pp to AFW Pp P318 | M-204 |
| 34 | 31802-8"-HE2 | 40/Amb | Folsom S Canal Pp to AFW Pp P318 | M-204 |
| 35 | 31803-8"-HC | 20/Amb | Folsom S Canal Pp to AFW Pp P319 | M-204 |
| 36 | * 31820-6"-DB2 | 1120/90 | AFW Pp 318 to SG A | M-188 |



CALCULATION SHEET

LAO 0012 073

APPENDIX 2

CALC. NO. _____

SIGNATURE Christie F. Wilson DATE 4-26-74CHECKED L. Duntach DATE 4-26-74PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 3 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | | |
|--------------------------|-------------------|----------------------|---------------------------------------|--------------------|
| 2 | Line No. | Oper. P/T | Description | Piping Dwg. No. |
| 3 | | | | |
| 4 | | | | |
| 5 | * 31821-6"-DB | 1120/90 | AFW Pp 319 to SG B | M-187,162,163 |
| 6 | 31822-6"-DB | 0/90 | AFW Pp 318 Recirc to LP Cond | M-188 |
| 7 | 31822-2-1/2"-DB | 0/90 | AFW Pp 318 Recirc to LP Cond | M-204,205 |
| 8 | * 31823-6"-DB | 1150/90 | AFW Pp 319 to SG A | M-204,189,188 |
| 9 | * 31824-6"-DB2 | 1150/90 | AFW Pp 318 Exer Line to LP Cond | M-204,198,188 |
| 10 | * 31825-2-1/2"-DB | 1150/90 | AFW Pp 319 Recirc to LP Cond | M-204 |
| 11 | * 31826-6"-DE | 1150/90 | AFW Pp 319 to SG B | M-187,188 |
| 12 | * 31827-6"-GB | 1150/90 ^L | AFW Pp 318 Exer Line to LP Cond | M-198 |
| 13 | * 31891-6"-DB2 | 1150/90 | AFW Pp Crosstie | M-204 |
| 14 | 31900-8"-HC | 15/90 | CST to AFW Pp P319 | M-204 |
| 15 | * 31920-6"-DB | 1150/90 | AFW Pp 319 to SG B | M-204,205,189 |
| 16 | 31922-2-1/2"-DB2 | 0/90 | AFW Pp 319 Recirc to LP Cond | M-204,205,189,188 |
| 17 | 31922-6"-DB | 0/90 | AFW Pp 319 Recirc to LP Cond | M-188 |
| 18 | * 32291-12"-HC | 127/365 | 2nd Pt Htr PSV to B/D Tk Relief | M-198,188,187 |
| 19 | ** 32880-20"-HC | Atm/210 | B/D Tk Vent | M-198 |
| 20 | 34285-4"-HC | Atm/130 | Air Ejector to Vent | M-162 |
| 21 | ** 34420-6"-HC | 1/208 | Gland Stm Exhauster to Atm | M-162 |
| 22 | 34500-6"-HD | 30/100 | Misc Wtr HU Tk to Sluice Pumps | M-188 |
| 23 | 34501-6"-HC | 30/100 | Misc Wtr HU Tk to Sluice Pumps | M-188 |
| 24 | * 35620-16"-HC | 15/210 | Hogging Ejector to Atm | M-162 |
| 25 | 35823-12"-HC | 1/90 | CST to LP Condenser | M-204 |
| 26 | 35824-3"-HC | 1/90 | CST to LP Condenser | M-204 |
| 27 | 35824-12"-HC | 1/90 | CST to LP Condenser | M-204 |
| 28 | 35880-12"-HC | Atm/Amb | CST Overflow | M-204 |
| 29 | 35881-12"-HC | 1/Amb | CST Overflow | M-204 |
| 30 | 35882-4"-HC | 25/90 | CST Overflow | M-204 |
| 31 | 35891-4"-HD | 120/Amb | MU Demin to CST | M-190,204,198,188 |
| 32 | 36089-6"-HC | Atm/Amb | Aux Stm Bdr Relief to Atm | M-187 |
| 33 | 36099-6"-HC | Atm/Amb | Aux Stm Bdr Relief to Atm | M-187 |
| 34 | 40226-3"-HE2 | 45/125 | Circ Wtr Pp CW to CCW Pp A&B | M-204 |
| 35 | 42521-24"-HE2 | 40/Amb | Plant CW to Gen H ₂ Cooler | M-188 |
| 36 | | | | |

1. From M-853, DCN 139B



CALCULATION SHEET

LAO 0612 8-73

APPENDIX 2
CALC. NO. _____

SIGNATURE Clintia O. Nelson DATE 4-26-84 CHECKED L. Deutsch DATE 4-26-84
 PROJECT Rancho Seco Unit 1 JOB NO. 12334-030
 SUBJECT Aux FW Internally Generated Missiles SHEET 4 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | | |
|--------------------------|------------------|---------------------------|--------------------------------|--------------------|
| 2 | Line No. | Oper. P/T (psig/°F) | Description | Piping Dwg. No. |
| 4 | | | | |
| 5 | 45750-10"-HE | 90/95 | CCW HEX to Exciter Air Cooler | M-188 |
| 6 | 45760-10"-HE | 85/125 | Exciter Air Cooler to CCW Pp | M-188 |
| 7 | 46047-3"-HE | 90/95 | CCW HEX to Circ Wtr Pps | M-204 |
| 8 | 46050-20"-HE | 95/125 | CCW Pp A to CCW HEX | M-204 |
| 9 | 46051-20"-HE | 95/125 | CCW Pp B to CCW HEX | M-204 |
| 10 | 46053-30"-HE | 40/Amb | CW Pp to CCW HEX A | M-204 |
| 11 | 46054-30"-HE | 40/Amb | CW Pp to CCW HEX B | M-204 |
| 12 | 46060-18"-HE | 90/99 | CCW HEX to RCP | M-163,188 |
| 13 | 46060-20"-HE | 90/95 | CCW HEX A to RCP A | M-204,198,188 |
| 14 | 46061-20"-HE | 90/95 | CCW HEX B to RCP A | M-204 |
| 15 | 46062-30"-HE2 | 40/105 | CCW HEX A to Circ Water Intake | M-204 |
| 16 | 46063-30"-HE2 | 40/105 | CCW HEX B to Circ Water Intake | M-204 |
| 17 | 46068-2"-HE2 | 40/Amb | CCW HEX A Vent (tubeside) | M-204 |
| 18 | 46069-2"-HE2 | 40/Amb | CCW HEX B Vent (tubeside) | M-204 |
| 19 | 46076-2"-HE | 90/95 | CCW HEX B Vent (shellside) | M-204 |
| 20 | 46077-2"-HE | 90/95 | CCW HEX A Vent (shellside) | M-204 |
| 21 | 46200-18"-HE | 85/125 | RCP to CCW Pp | M-163,188 |
| 22 | 46200-20"-HE | 85/125 | RCP's to CCW Pp A Suction | M-198,204,188 |
| 23 | 46201-24"-HE | 85/125 | RCP's to CCW Pp B Suction | M-204 |
| 24 | 46280-6"-HE | 90/125 | CCW Pp A Miniflow | M-204,198 |
| 25 | 46420-6"-HE | 30/Amb | CCW Surge Tk to CCW Pumps | M-163,162 |
| 26 | 46701-1-1/2"-HED | 125/130 | CRDM CW from Sample Station | M-163 |
| 27 | 46750-4"-HE | 90/95 | CCW HEX to CRD CW HEX | M-163 |
| 28 | 46755-3"-HD | 125/130 | CRD Units to CRD HEX | M-163 |
| 29 | 46760-4"-HE | 85/124 | CRD CW HEX to CCW Pp | M-163 |
| 30 | 46762-3"-HD | 70/100 | CRD HEX A to CRD Pp | M-163 |
| 31 | 46902-1-1/2"-HD1 | 70/100 | CRD CW Srg Pipe to CRD CW Pp | M-163,162 |
| 32 | 46981-10"-HD | 70/100 | CRD CW Pp Surge Pipe | M-162,163 |
| 33 | 47081-4"-HE2 | 120/Amb | Fire Loop Line to W Spray Pd | M-198 |
| 34 | 47090-4"-HE2 | 120/Amb | Svc Wtr Fltrs to E Spray Pd | M-198,200 |
| 35 | 47091-4"-HE2 | 120/Amb | Svc Wtr Fltrs to W Spray Pond | M-198 |
| 36 | 47096-4"-HE2 | 130/Amb | Fire Loop Line to W Spray Pd | M-198 |



CALCULATION SHEET

LAO 0613 0-73

APPENDIX 2
CALC. NO. _____SIGNATURE Christina A. Keenan DATE 4-26-84CHECKED L. Deutch DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 5 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | | |
|--------------------------|------------------|------------------------|---|-------------------|
| 2 | Line No. | Oper. P/T (psig/°F) | Description | Piping Dwg. No. |
| 4 | | | | |
| 5 | 47097-4"-HE2 | 130/Amb | Fire Loop Line to E Spray Pd | M-198,200 |
| 6 | 47098-4"-HE2 | 35/Amb | Fire Loop Line to NS Spray Pd | M-198,200 |
| 7 | 47350-10"-HE2 | 35/87 | NSRW Pp A to DG HEX A | M-163,188,198,204 |
| 8 | 47351-10"-HE2 | 35/87 | NSRW Pp to DG CW HEX | M-198,200,163 |
| 9 | 47360-10"-HE2 | 35/106 | DG CW HEX to W Spray Pd | M-204,198,163,188 |
| 10 | 47361-10"-HE2 | 35/108 | DG HEX B to E Spray Pd | M-163 |
| 11 | 47451-3"-HE2 | 35/87 | NSRW Pp A to Chem Add Tk | M-198 |
| 12 | 47452-3"-HE2 | 35/87 | NSRW to DG CW HEX | M-200,198 |
| 13 | 47461-3"-HE2 | 35/87 | NSRW from Chem Add Tk to DG HEX | M-198 |
| 14 | 47462-3"-HE2 | 35/87 | NSRW Pp to Chem Add Tk | M-198 |
| 15 | 48054-24"-HE2 | 35/87 | NSRW Pp A to NSCW HEX | M-198 |
| 16 | 48055-24"-HE2 | 35/87 | NSRW Pp to NSCW HEX | M-198 |
| 17 | 48060-18"-HE | 60/95 | NSCW HEX to NSCW Pp | M-198 |
| 18 | 48061-18"-HE | 60/95 | CCW HEX to RCP | M-198 |
| 19 | 48062-24"-HE2 | 35/109 | NSCW HEX to W NS Wtr Spray Pond | M-198 |
| 20 | 48063-24"-HE2 | 35/105 | CCW HEX to Circ Wtr Intake | M-198 |
| 21 | 48222-18"-HE | 110/95 | NSCW Pp to DHR Cooler | M-198,163 |
| 22 | 48223-18"-HE | 110/95 | NSCW Pp Disch to DHR Cooler | M-198 |
| 23 | 48400-6"-HE | 110/145 | NSCW Srg Tk PSV to NSCW Mx xchgr | M-163,162 |
| 24 | 48480-4"-HE | 20/145 | NSCW Surge Tk PSV to SRT | M-163,162 |
| 25 | 48486-1-1/2"-HE | Atm/Amb | CRD CW Srg Pipe to O'flw to SRT | M-162,163 |
| 26 | 48490-2"-HE | 50/Amb | N ₂ Supply to NSCW Surge Tank | M-162,163 |
| 27 | 48495-3"-HD | 120/Amb | Mixed Bed Demin to NSCW Surge Tk | M-187,162,163 |
| 28 | 48750-4"-HE2 | 55/87 | NSRW Pp to DHR Pp BOC | M-163 |
| 29 | 48760-4"-HE2 | 55/100 | DHR Pp BOC to W Spray Pd | M-163 |
| 30 | 53520-12"-HC | 1/120 | RB Purge Air Supply Fan to RB | M-162 |
| 31 | 53800-2"-HD1 | Atm/Amb | H ₂ Purge Exhaust Blower to Vent | M-162 |
| 32 | 53802-2"-HD1 | Atm/Amb | H ₂ Purge Exhaust Blower to Vent | M-162 |
| 33 | 61281-1-1/2"-HD1 | 120/Amb | MB Demin to Boric Acid Conc/MWE | M-162 |
| 34 | 61720-3"-HD | 100/120 | Deborating Ion Exchanger to RCST | M-190,198,162,163 |
| 35 | 61722-1-1/2"-HD1 | 80/Amb | Cstc Xfer Pp to Dbrtng Ion Xchgr | M-163 |
| 36 | 62120-4"-HD | 15/Amb | Demin RCST to RCST Pp A Suction | M-198 |



CALCULATION SHEET

LAO 0013 0-72
 APPENDIX 2
 CALC. NO. _____

SIGNATURE Christina F. Kelso DATE 4-26-84 CHECKED L. Dente L. DATE 4-26-84
 PROJECT Rancho Seco Unit 1 JOB NO. 12334-030
 SUBJECT Aux FW Internally Generated Missiles SHEET 6 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | |
|--------------------------|-------------|---|----------------------|
| 2 | Oper. | | Piping |
| 3 | P/T | Description | Dwg. No. |
| 4 | (psig / °F) | | |
| 5 | Atm/Amb | RCST Overflow to BWST | *198 |
| 6 | Atm/Amb | Demin RCST Drain | *198 |
| 7 | 100/Amb | RCST Pp to RCST Demin | *162,163,190,198 |
| 8 | 100/Amb | Demin RCST Pp B to RCST Demin | *198 |
| 9 | 15/Amb | Demin RCST to RCST Pp B Suction | *198 |
| 10 | Atm/120 | Ship Cask Decon Area Drn to SPT | *162,163,187,190 |
| 11 | Atm/120 | Emer Shwr Drn to SCD Drn | *187,190 |
| 12 | Atm/120 | SF Pl Area Drn to SCD Drn | *162 |
| 13 | 70/120 | Misc Waste Cond Fltr to MWHU Tk | *190 |
| 14 | 70/120 | Misc Waste cond fltr to MWHU Tk | *162,163,187,188,198 |
| 15 | 135/100 | Boric Acid Filter to BWST | *162,163,190,198 |
| 16 | 90/95 | CCW HEX to Chiller | *162,163 |
| 17 | 85/125 | Chiller to CCW Pp Suction | *162,163 |
| 18 | Atm/Amb | Chilled Wtr Stg Tk PSV to Drain | *162 |
| 19 | 49/55 | Chlld Wtr Pp to Chlld Wtr Sply | *162 |
| 20 | 35/55 | Chilled Wtr to Chilled Wtr Stg Tk | *162 |
| 21 | 1/130 | Trbn LO Resv Vapor Extr to Demst | *188,187 |
| 22 | 0/130 | Demister Vent | *187 |
| 23 | 0/130 | Demister Vent | *187 |
| 24 | 0/130 | Demister Vent | *187 |
| 25 | 0/130 | Gen Brg Drn Vapor Extractor Vent | *162 |
| 26 | 40/100 | Gen H ₂ Clr to Circ Wtr Intake Cnl | *188 |
| 27 | 0/130 | FP Turbine LO Extr A to Demst | *187,188 |
| 28 | 0/130 | FP Turbine LO Extr B to Demis | *187,188 |
| 29 | Atm/750 | DG A Exhaust to Atm | *162,163 |
| 30 | Atm/750 | DG B Exhaust to Atm | *162,163 |
| 31 | Atm/Amb | DG Air A Intake Fltr & Slncr A | *163 |
| 32 | Atm/Amb | DG Air B Intake Fltr & Slncr B | *163 |
| 33 | 35/100 | Diesel FC Pp to DG FO Day Tk | *163 |
| 34 | 35/100 | Diesel FO Pp to DG FO Day Tk A | *188 |
| 35 | 35/100 | Diesel FO Pp to DG FO Day Tk B | *163 |
| 36 | 35/100 | Diesel FO Pp to DG FO Day Tk B | *188 |



CALCULATION SHEET

LAO 013 073

APPENDIX 2
CALC. NO. _____

SIGNATURE Christina F. Kelso DATE 4-26-84 CHECKED L. T. Taitel DATE 4-25-84
 PROJECT Rancho Seco Unit 1 JOB NO. 12334-030
 SUBJECT Aux Fw Internally Generated Missiles SHEET 7 OF 9 SHEETS

| 1 MODERATE ENERGY PIPING | | | | |
|--------------------------|-----------------|-------------|----------------------------------|---------------|
| 2 | 3 | 4 | 5 | |
| Line No. | Oper. P/T | Description | Piping Dwg. No. | |
| 5 | 88825-2-1/2"-HC | 35/100 | Diesel FO Pp to Aux Blr FO Pp | M-188 |
| 6 | 88829-1-1/2"-HC | 35/100 | Diesel FO Pp to DG FO Day Tk | M-163 |
| 7 | 88830-1-1/2"-HC | 1/100 | Diesel FO Pp to DG FO Day Tk | M-163 |
| 8 | 88920-1-1/2"-HE | 250/Amb | DG Mtr Drvn Comp A to DG | M-163 |
| 9 | 88921-1-1/2"-HE | 250/Amb | DG MD Comp A to Air St Rec A | M-163 |
| 10 | 88922-1-1/2"-HE | 250/Amb | DG MD Comp A to Air St Rec B | M-163 |
| 11 | 88923-1-1/2"-HE | 250/Amb | DG MD Comp A to Air St Rec C | M-163 |
| 12 | 88924-1-1/2"-HE | 250/Amb | AC Comp B to DG B | M-163 |
| 13 | 88925-1-1/2"-HE | 250/Amb | AC Comp B to Receiver G | M-163 |
| 14 | 88926-1-1/2"-HE | 250/Amb | AC Comp B to Receiver H | M-163 |
| 15 | 88927-1-1/2"-HE | 250/Amb | AC Comp B to Receiver I | M-163 |
| 16 | 88928-1-1/2"-HE | Atm/Amb | DG Crankcase Drain | M-163 |
| 17 | 88931-1-1/2"-HE | Atm/Amb | DG B Crankcase Drain | M-163 |
| 18 | 89120-1-1/2"-HE | 250/Amb | DG Mtr/Eng Drvn Air St to DG | M-163 |
| 19 | 89121-1-1/2"-HE | 250/Amb | DG Mtr/Eng Drvn Comp A to Rec E | M-163 |
| 20 | 89122-1-1/2"-HE | 250/Amb | DG Mtr/Eng Drvn Comp A to Rec D | M-163 |
| 21 | 89123-1-1/2"-HE | 250/Amb | DG Mtr/Eng Drvn Comp A to Rec F | M-163 |
| 22 | 89124-1-1/2"-HE | 250/Amb | DG AC&DC Mtr Drvn Comp Crosstie | M-163 |
| 23 | 89125-1-1/2"-HE | 250/Amb | DG DC Mtr Drvn Comp B to DG B | M-163 |
| 24 | 89126-1-1/2"-HE | 250/Amb | DG AC Mtr Drvn Comp B to Rec J | M-163 |
| 25 | 89127-1-1/2"-HE | 250/Amb | DG AC Mtr Drvn Comp B to Rec K | M-163 |
| 26 | 89128-1-1/2"-HE | 250/Amb | DG AC Mtr Drvn Comp B to Rec L | M-163 |
| 27 | 89129-1-1/2"-HE | 250/Amb | DC & AC Crosstie to DG | M-163 |
| 28 | 89390-2"-HC | Atm/Amb | DG FO Day Tk to Diesel FO Stg Tk | M-163 |
| 29 | 89391-2"-HC | Atm/Amb | DG FO Day Tk A to Dsl FO Stg Tk | M-163 |
| 30 | 89394-2"-HC | Atm/Amb | DG FO Day Tk Vent | M-162,163 |
| 31 | 89395-2"-HC | Atm/Amb | DG FO Day Tk Vent | M-162,163 |
| 32 | 90528-1-1/2"-HE | 100/Amb | SVC Air to Reactor Yd Area | M-188,190 |
| 33 | 90531-2"-HE | 100/Amb | SVC Air to Aux Bldg | M-162,163 |
| 34 | 90536-2"-HE | 100/Amb | SVC Air to Radwaste | M-162,163,190 |
| 35 | 90536-3"-HE | 100/Amb | SVC Air to Radwaste Area | M-188,190 |
| 36 | | | | |



CALCULATION SHEET

LAC 8812 8-73

APPENDIX 2

CALC. NO. _____

SIGNATURE Christina Kelton DATE 4-26-84CHECKED D. Dutach DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 8 OF 9 SHEETS

MODERATE ENERGY PIPING

| Line No. | Oper. P/T (psig / °F) | Description | Piping Dwg. No. |
|------------------|-----------------------------|--|-----------------------|
| 91528-1-1/2"-HE2 | 95/Amb | Instr Air to Aux Bldg | M-188,190,162,163 |
| 91528-2"-HE2 | 95/Amb | Instr Air to Aux Bldg | M-188,190 |
| 92080-3"-HE | 0/Amb | Generator H ₂ Vent to Atm | M-187,162 |
| 92520-2"-HE | 50/Amb | N ₂ to Reactor Bldg | M-162,163,188,190 |
| 92525-2"-HE | 2/Amb | N ₂ to Turbine Area | M-162 |
| 96522-6"-HD | 25/Amb | Demin Area Sump Pp to SRT | M-162,163 |
| 96720-4"-HE4 | 25/Amb | Acid Waste Sump Pp to SRT | M-162 |
| 98127-2"-HE2 | 120/Amb | Svc Wtr to Reactor Yd | M-188,190 |
| 98160-3"-HE2 | 120/Amb | SVC Wtr Fltr to B/D Tk | M-188 |
| 98220-3"-HE2 | 120/Amb | Domes Wtr Cl ₂ Cntct Tk to Aux Bl | M-162,163,187,188,190 |
| 98221-2-1/2"-HE | 120/Amb | Domes Wtr Cl ₂ Cntct Tk to Adm Bl | M-188 |
| 98300-6"-HD | 10/Amb | MWBU Tk to MWBU Tk Pp | M-198 |
| 98320-4"-HD | 80/Amb | MWBU Tk Pp to Radwst Demin Hdr | M-198,162,163,190 |
| 98397-3"-HD | 80/Amb | MWBU Tk Pp to SF St Pool | M-162 |
| 98399-2"-HD | 80/Amb | MWBU Tk Pp to BWST | M-198 |
| 98823-2"-HD1 | 120/Amb | MB Demin to Lab & Sample Snks | M-162,163 |
| 99380-4"-HD | 10/Amb | MWBU Tank Drain | M-198 |
| 99520-4"-HD | 120/Amb | MB Demin to MWBU Tk | M-188,187,190,198 |
| 99622-8"-HE1 | 125/Amb | Fire Loop Line to Aux Bl @ TD | M-162,163,188,190,198 |
| * 99820-4"-GE | 300/0 | CO ₂ Header | M-187,188,190 |

* Line operates less than 2% of the time during normal plant conditions.

** Based on engineering judgement, pressure is too low for credible missile ejection.



CALCULATION SHEET

LAO 0012 0-73

APPENDIX 2

CALC. NO. _____

SIGNATURE Christina F. Kelber DATE 4-26-84

CHECKED P. Deutch DATE 4-26-84

PROJECT Rancho Seco Unit 1

JOB NO. 12334-030

SUBJECT Aux FW Internally Generated Missiles

SHEET 9 OF 9 SHEETS

ACRONYMS AND ABBREVIATIONS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

- B/D Blowdown
- BOC Bearing Oil Cooler
- BWST Borated Water Storage Tank
- CCW Component Cooling Water
- CRD Control Rod Drive
- CRDM Control Rod Drive Mechanism
- CST Condensate Storage Tank
- CW Cooling Water
- DG Diesel Generator
- DEH Decay Heat Removal
- MB Mixed Bed
- MD Motor Driven
- MWE Miscellaneous Waste Evaporator
- MWHU Miscellaneous Water Hold-Up Tank
- NSCW Nuclear Service Cooling Water
- NSRW Nuclear Service Raw Water
- Pp Pump
- RB Reactor Building
- RCP Reactor Coolant Pump
- SCD Shipping Cask Decon
- SF Spent Fuel
- SRT Spent Regenerant Tank

APPENDIX 3: ELECTRICAL EQUIPMENT



CALCULATION SHEET

Appendix 3
 CALC. NO. _____

SIGNATURE Christie K. Khan DATE: 4-26-84

CHECKED Rim DATE: 4-26-84

PROJECT Rancho Seco Unit 1

JOB NO. 12334-030

SUBJECT Aux FW Internally Generated Missiles

SHEET 1 OF 10 SHEETS

ELECTRICAL EQUIPMENT

| EQUIPMENT | CABLE ^a | | SCHEME ^a CABLE No. | WIRING DIAGRAM No. | CIRCUIT SCH ^b PAGE No. |
|----------------------|--------------------|-----------|----------------------------------|-----------------------|--------------------------------------|
| | FROM | TO | | | |
| P-318 | S4B10 | P-318 | 141B10 | | 1486 |
| P-318 Bearing Heater | H7J921 | P-318 Htr | 111 H1 - HC | | 1253 |
| | H7J924 | " " | 111 H2 - HC | | 1264 |
| | H7J921 | H7JFPA | 111 H1 - GB | E-342-32 | 1251 |
| | H7JFPA | SIFP-A | 111 H1 - FD | E-342-32 | 1250 |
| | SIFP-A | X31P | 111 H1 - FB | | 1250 |
| | X31P | S2A125 | 121A125A | E-307-25 | 1374 |
| | H7J924 | H7JFPB | 111 H2 - FW | E-342-32 | 1262 |
| | H7JFPB | SIFP-B | 111 H2 - ED | E-342-32 | 1262 |
| | SIFP-B | X31N | 111 H2 - FB | | 1261 |
| | X31N | S2B128 | 121B128A | E-307-25 | 1560* |
| P-318 Heater | S2E162 | P-318 | 122E162 (NON CLASS IE) | | |
| P-319 | S4A06 | P-319 | 141A06 | | 1485 |
| P-319 Bearing Heater | H7J922 | P-319 Htr | 111 H1 - HD | | 1253 |
| | H7J925 | P-319 Htr | 111 H2 - HD | | 1264 |
| | H7J922 | H7JFPA | 111 H1 - FY | E-342-32 | 1251 |
| | H7JFPA | SIFP-A | 111 H1 - FE | E-342-32 | 1250 |
| | H7J925 | H7JFPB | 111 H2 - FY | E-342-32 | 1262 |
| | H7JFPB | SIFP-B | 111 H2 - FE | E-342-32 | 1261 |
| P-319 Heater | S2C547 | P-319 | 122C547 (NON CLASS IE) | | |

a. Reference Circuit by Location, dated 1-23-84

b. Reference Circuit Schedule, Rev. 160, dated 3-26-83

* Circuit Schedule Rev. 394 dated 4-6-84.



CALCULATION SHEET

LAO 0013 073
Appendix 3
CALC. NO. _____

SIGNATURE Christine J. Kelton DATE 4-26-84 CHECKED Rlm DATE 4-26-84
 PROJECT Rancho Seco Unit 1 JOB NO. 12334-030
 SUBJECT Aux FW Internally Generated Missiles SHEET 2 OF 10 SHEETS

ELECTRICAL EQUIPMENT

| EQUIPMENT | CABLE ^{a.} | | SCHEME ^{a.} CABLE NO. | WIRING DIAGRAM NO. | CIRCUIT SCH ^{b.} PAGE No. |
|-----------------------|---------------------|---------------|-----------------------------------|-----------------------|---------------------------------------|
| | FROM | TO | | | |
| SFV-20577 | S2B160 | SFV-20577 | 1M1B160E | | 547 |
| | " | " | 121B160E | | 1392 |
| SFV-20578 | S2A122 | SFV-20578 | 1M1A122A | | 516 |
| | " | " | 121A122A | | 1374 |
| FV-20527 | H7J737 | FV-20527 | 1I1F205BD | | 236 |
| H7J737 | H4SDB00 | H7J737 | 1I1F205BB | E-342-29 | 236 |
| FY-20527 | H4IC01 | FY-20527 | 1I2U1082B | (NON CLASS IE) | |
| FY-20527A | H7J737 | FY-20527A | 1I1F205BC | E-342-29 | 236 |
| FV-20528 | H7J738 | FV-20528 | 1I1F205AD | | 236 |
| H7J738 | H4SDA5 | H7J738 | 1I1F205AB | E-342-29 | 236 |
| FY-20528 | H4IC01 | FY-20528 | 1I2U1082A | (NON CLASS IE) | |
| FY-20528A | H7J738 | FY-20528A | 1I1F205AC | E-342-29 | 236 |
| FV-30801 | HBSFV30801 | FV-30801 | 1I1T308D | | 265 |
| | " | " | 1I1T308H | | 265 |
| | " | " | 1I1T308K | | 265 |
| FV-30801 Limit Switch | HBSFY-30801 | FV-30801 L.S. | 1I1T308L | | 266 |
| FV-30801 Solenoid | " | FV-30801 Sol. | 1I1T308M | | 266 |
| HBSFV30801 | H4SDB0 | HBSFV30801 | 1I1T308C | | 265 |
| | " | " | 1I1T308G | | 265 |
| | " | " | 1I1T308X | | 266 |

a. Reference Circuit by Location, dated 1-23-84

b. Reference Circuit Schedule, Rev. 160, dated 3-26-83



CALCULATION SHEET

LAG 0813 673

Appendix 3

CALC. NO. _____

SIGNATURE Christine F. Kelton DATE 4-26-84CHECKED RLM DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 3 OF 10 SHEETS

ELECTRICAL EQUIPMENT

| EQUIPMENT | CABLE ^{a.} | | SCHEME ^{a.} CABLE No. | WIRING DIAGRAM No. | CIRCUIT Sch ^{a.} PAGE No. |
|--------------|---------------------|--------------|-----------------------------------|--|---------------------------------------|
| | FROM | TO | | | |
| FV-31855 LS1 | H4GDAR 6 | FV-31855 LS1 | 143D318B1 | NON CLASS WIRING TO BE UPGRADED TO CLASS 1E DURING 1986 OUTAGE AS PART OF SEC. 1 | 1E CABLES. BE UPGRADED |
| LS2 | " | FV-31855 LS2 | 143D318A1 | | |
| HV-20569 | S2A161 | HV-20569 | 1M1A161B | | 523 |
| | " | | 121A161A | | 1381 |
| HV-20596 | S2B137 | HV-20596 | 1M1B137B | | 540 |
| | " | " | 121B137A | | 1389 |
| HV-31826 | H7J032 | HV-31826 | 1M1B159C | | 546 |
| | " | " | 1M1B159D | | 546 |
| | " | " | 121B159C | | 1392 |
| | " | " | 121B159D | | 1392 |
| H7J032 | S2B159 | H7J032 | 1M1B159B | E-342-56A | 546 |
| | | | 121B159B | E-304-32 | 1392 |
| | | | 121B159A | E-205-20F | 1392 |
| HV-31827 | S2A108 | HV-31827 | 1M1A108B | | 513 |
| | " | " | 1M1A108C | | 513 |
| | " | " | 121A108A | | 1372 |
| | " | " | 121A108B | | 1372 |
| FT-31802 | FT-31802 | H4SCB | 1IIF318B1 | E-323-14 | 239 |
| FT-31803 | FT-31803 | H4SCA | 1IIF318A1 | E-323-11 | 233 |
| FT-31902 | FT-31902 | H4SCB | 1IIF319B1 | E-323-14 | 239 |
| FT-31903 | FT-31903 | H4SCA | 1IIF319A1 | E-323-11 | 239 |

a. Reference Circuit by Location, dated 1-23-84

b. Reference Circuit Schedule, Rev. 160, dated 3-26-83



CALCULATION SHEET

LAO 0812 6-73

Appendix 3

CALC. NO. _____

SIGNATURE Christine F. Kelton DATE 4-26-84CHECKED R. M. DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 4 OF 10 SHEETS

ELECTRICAL EQUIPMENT

| EQUIPMENT | CABLE ^a | | SCHEME ^a CABLE No. | WIRING DIAGRAM No. | CIRCUIT Sch PAGE No. |
|-----------|--------------------|--------|----------------------------------|-----------------------|-------------------------|
| | FROM | TO | | | |
| LT-35809 | LT-35809 | H4SCA | IIIF358A1 | E-323-11 | 239 |
| LT-35810 | LT-35810 | H4SCB | IIIF358B1 | E-323-13 | 240 |
| PT-31801 | PT-31801 | H4SCA | IIIF318C1 | E-323-11 | 239 |
| PT-31803 | PT-31803 | H4SCA | IIIF318D1 | E-323-11 | 239 |
| PT-31901 | PT-31901 | H4SCB | IIIF319C1 | E-323-13 | 239 |
| PT-31903 | PT-31903 | H4SCB | IIIF319D1 | E-323-13 | 239 |
| PSL-31757 | PSL-31757 | H7J319 | IIIT308P | | 266 |
| H7J319 | H4SD80 | H7J319 | IIIT308R | E-342-1 | 266 |
| PSL-31758 | PSL-31758 | H7J319 | IIIT308F | (SPARE | NON-IE) |
| | PSL-31758 | H7J319 | IIIT308Q | | 266 |
| PSL-31759 | PSL-31759 | S4A06 | IIIA06F | (SPARE | NON-IE) |
| | PSL-31759 | S4A06 | IIIA06L | | 656 |
| PSL-31760 | PSL-31760 | S4A06 | IIIA06G | (SPARE | NON-IE) |
| | PSL-31760 | S4A06 | IIIA06M | | 656 |

a. Reference Circuit by Location, dated 1-23-84

b. Reference Circuit Schedule, Rev. 160, dated 3-26-83



CALCULATION SHEET

LAO 0013 6-73

Appendix 3

CALC. NO. _____

SIGNATURE Christine F. Kelton DATE 4-26-84CHECKED pm DATE 4-26-84PROJECT Rancho Seco Unit 1JOB NO. 12334 - 030SUBJECT Aux FW Internally Generated MissilesSHEET 5 OF 10 SHEETS

ELECTRICAL EQUIPMENT

| EQUIPMENT | CABLE ^{a.} | | SCHEME ^{a.} CABLE No. | WIRING DIAGRAM No. | CIRCUIT Sch. PAGE No. |
|-----------|---------------------|--------|-----------------------------------|-----------------------|--------------------------|
| | FROM | TO | | | |
| H4SCA | S1A | H4SCA | 111A03A | E-307 | |
| | 50A10 | S1A | 101A10A | E-107 | |
| | BA | 50A13 | 101A13A | " | |
| | " | " | 101A13B | " | |
| | H4SCA | H4CDAR | 1Y1X318A2 | E-323-11 | |
| | " | " | 1Y1X319A2 | E-323-11 | |
| | " | " | 1Y1X318C2 | E-323-11 | |
| | " | " | 1Y1X318D2 | E-323-11 | |
| | " | " | 1Y1X358A2 | E-323-11 | |
| H4SCB | S1B | H4SCB | 111B03A | E-307 | |
| | 50B10 | S1B | 101B10A | E-107 | |
| | BB | 50B13 | 101B13A | " | |
| | " | " | 101B13B | " | |
| | H4SCB | H4CDAR | 1Y1X318A | E-323-14 | |
| | " | " | 1Y1X319A | E-323-14 | |
| | " | " | 1Y1X319C2 | E-323-13 | |
| | " | " | 1Y1X319D2 | E-323-13 | |
| | " | " | 1Y1X358B2 | E-323-13 | |
| H4SDA5 | 50A01 | H4SDA5 | 101A01A | E-107-4 | |
| H4SDB | 50B01 | H4SDB | 101B01B | E-107-4 | |
| S2A | S3A22 | S2A1 | 131A22A | E-105-1 | |
| S3A | X43A | S3A | | E-105-1 | |
| | S4A09 | X43A | 141A09A | " | |
| S4A | GE A | S4A | 141A08A | E-104-2 | |
| | " | " | 141A08B | " | |

a. Reference Circuit by Location, dated 1-23-84

b. Reference Circuit Schedule, Rev. 100, dated 3-26-83



CALCULATION SHEET

APPENDIX 3 LAG 0813 8-73

CALC. NO. _____

SIGNATURE Christine F. Kelson DATE 4-26-84


CHECKED FAK DATE 4/26/84

PROJECT Rancho Seco Unit 1


JOB NO. 12334-030


SUBJECT Aux FW Internally Generated Missiles

SHEET 7 OF 10 SHEETS



TURBINE DECK LEVEL PLAN ELEVATION 40'



 ROOM CONTAINS HIGH ENERGY PIPING, ROTATING EQUIPMENT, OR COMPRESSED GAS STORAGE EQUIPMENT.

AUXILIARY BUILDING - PLAN AT EL. 40'-0"
STUDY OF INTERNALLY GENERATED MISSILES



CALCULATION SHEET

APPENDIX 3
CALC. NO. _____

SIGNATURE Christine F. Keenan DATE 4-26-84

CHECKED Full DATE 4/26/84


PROJECT Rancho Seco Unit 1

JOB NO. 12334-030

SUBJECT Aux RW Internally Generated Missiles


SHEET 8 OF 10 SHEETS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35



MEZZANINE LEVEL PLAN ELEVATION 20'



 ROOM CONTAINS HIGH ENERGY PIPING, ROTATING EQUIPMENT,
OR COMPRESSED GAS STORAGE EQUIPMENT.

AUXILIARY BUILDING - PLAN AT EL. 20'-0"
STUDY OF INTERNALLY GENERATED MISSILES



CALCULATION SHEET

APPENDIX 3
CALC. NO. _____

SIGNATURE Christina F. Keton DATE 4-26-84

CHECKED Full DATE 4/26/84

PROJECT Rancho Seco Unit 1


JOB NO. 12334-030

SUBJECT Aux FW Internally Generated Missiles

SHEET 9 OF 10 SHEETS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35

(M)




GRADE LEVEL PLAN ELEVATION 0'

0 10 20
SCALE IN FEET



ROOM CONTAINS HIGH ENERGY PIPING,
ROTATING EQUIPMENT, OR COMPRESSED
GAS STORAGE EQUIPMENT.



BASMENT FLOOR PLAN

AUXILIARY BUILDING - PLAN AT EL. 0'-0"
STUDY OF INTERNALLY GENERATED MISSILES



CALCULATION SHEET

APPENDIX 3 LAG 0613 8-73

CALC. NO. _____

SIGNATURE Christie Keenan DATE 4-26-84


CHECKED ALB DATE 4/26/84

PROJECT Rancho Seco Unit 1

JOB NO. 12334-030


SUBJECT Aux FW Internally Generated Missiles

SHEET 10 OF 10 SHEETS



BASEMENT LEVEL PLAN ELEVATION (-)20'



 ROOM CONTAINS HIGH ENERGY PIPING, ROTATING EQUIPMENT, OR COMPRESSED GAS STORAGE EQUIPMENT

AUXILIARY BUILDING. PLAN AT EL. (-)20'-0"
STUDY OF INTERNALLY GENERATED MISSILES

APPENDIX 4: ROTATING EQUIPMENT



CALCULATION SHEET

APPENDIX 4
CALC. NO. _____

LAO 0613 8-73

SIGNATURE Christine J. Kelton DATE 4-26-84CHECKED PMK DATE 4/26/84PROJECT Rancho Seco Unit 1JOB NO. 12334-030SUBJECT Aux FW Internally Generated MissilesSHEET 1 OF 2 SHEETS

| ROTATING EQUIPMENT | | | | | |
|--------------------|---|-------------------------------------|--------------------------------|-------------|---|
| TAG NO. | DESCRIPTION | AFWS COMPONENT IN PLANE OF ROTATION | INTERVENING STRUCTURES | AFWS IMPACT | COMMENTS |
| P-462A | Component Cooling Water Pump A | 31827-6"-GB | P-462 B | NONE | MISSILES FROM P-462A ARE SHIELDED BY P-462B AND ITS ASSOCIATED PIPING. |
| P-462B | Component Cooling Water Pump B | 31827-6"-GB | NONE | NONE | IMPACT IS DOWNSTREAM OF FW-31855 ON NON-SEISMIC PIPING |
| | | CONDUIT M11249 | NONE | NONE | CONDUIT IS REDUNDANT; OTHER CABLE IS NOT IMPACTED. |
| P-482A | Nuclear Service Cooling Water Pump A | NONE | N/A | NONE | |
| P-482B | Nuclear Service Cooling Water Pump B | NONE | N/A | NONE | |
| P-622A | Demineralized Reactor Coolant Storage Tank Pump A | CONDUIT L11ADI | NONE | NONE | CONDUIT IS REDUNDANT; OTHER CABLE IS NOT IMPACTED. MISSILE PARTIALLY SHIELDED BY STEEL COLUMNS. |
| P-622B | Demineralized Reactor Coolant Storage Tank Pump B | CONDUIT L11ADI | NONE | NONE | SAME AS P-622A. |
| P-983 | Miscellaneous water Hold-Up Tank Pump | NONE | N/A | NONE | |
| P-272 | Spent Fuel Coolant Pump | 31823-6"-DB2 | CONCRETE PILLAR @ (3.4) & (HB) | NONE | PILLAR COMPLETELY SHIELDS PUMP FROM AFWS PIPING. |
| P-274 | Spent Fuel Coolant Pump | 31823-6"-DB2 | Radiation monitor RB-15018 | NONE | RADIATION MONITOR CABINET COMPLETELY SHIELDS PUMP FROM AFWS PIPING. |

APPENDIX 5: DESIGN CRITERIA

DESIGN CRITERIA COVER SHEET

| | | | |
|-----------------|---|----------------------------------|-------------|
| DATE 4-27-84 | SACRAMENTO MUNICIPAL UTILITY DISTRICT Rancho Seco Nuclear Generating Unit 1 Bechtel Job No. 12334 | DESIGN CRITERIA | PART N/A |
| REVISION 0 | | Internally Generated Missiles | |

PRINCIPAL RESPONSIBILITY Bechtel Mechanical - Design City

DESIGN CRITERIA Auxiliary Feedwater System - Criteria for Postulating Internally Generated Missiles outside Containment

QUALITY CLASS 1

SAFETY CLASS N/A

SEISMIC CATEGORY N/A

NRC REGULATORY GUIDE R.G. 1.70, Sec. 3.5, S.R.P. 3.5.1.1, S.R.P. 10.4.9

NRC GENERAL DESIGN CRITERIA 4 "Environmental and Missile Design Basis", 10CFR50 APP. "A"

REFERENCES

SAR SECTION 1.4.40

P&I DRAWINGS N/A

OTHER DRAWINGS N/A

APPROVAL SIGNATURES

[Signature] 4-18-84
GL (ORIGIN DATE)

[Signature] 4/18/84
GS (ORIGIN DATE)

[Signature] 4/27/84
MECH. CHIEF DATE

[Signature] 4/27/84
PE DATE

N/A
PLANT DESIGN GS DATE

[Signature] 4-26-84
MECH. GS DATE

[Signature] 4/27/84
EXEC. GS DATE

[Signature] 4/27/84
CIVIL GS DATE

N/A
CONTROL GS DATE

[Signature] 4/26/84
NUC. GS DATE

N/A
ARCH. GS DATE

[Signature] 4/26/84
NUC. CHIEF DATE

DATE OF ORIGIN 4-27-84

DATE(S) OF ALL CHANGES _____

DESIGN CRITERIA

AUXILIARY FEEDWATER SYSTEM - CRITERIA FOR POSTULATING INTERNALLY
GENERATED MISSILES OUTSIDE CONTAINMENT

RANCHO SECO UNIT 1

TABLE OF CONTENTS

| | <u>Page</u> |
|---|-------------|
| I. PURPOSE AND SCOPE | 1 |
| II. MISSILE DESIGN CRITERIA | 1 |
| III. GENERAL MISSILE PROTECTION DESIGN CRITERIA | 7 |
| IV. ANALYSIS CRITERIA | 7 |
| V. ANALYSIS TECHNIQUES | 8 |
| VI. REFERENCES | 10 |

I. PURPOSE AND SCOPE

This design criteria provides the guidance, scope of analysis, analysis criteria and methodology for the protection of Auxiliary Feedwater System (AFWS) components located outside containment building from the effects of postulated internally generated missiles.

The evaluation of the AFWS components (Electrical, Mechanical and Instrumentation/Controls) against the effects of internally generated missiles is limited to those components which fall into one of the following categories.

- . Existing components;
- . Proposed components for which installation drawings have been released for construction.

The evaluation does not consider those components that are in the planning stages, for which installation drawings have not been released for construction. However, evaluation shall be performed for these components whenever installation drawings become available for review.

II. MISSILE DESIGN CRITERIA

A. Definitions

1. Missiles:

A missile shall be defined as a mass which has kinetic energy and is unrestrained.

2. Essential Components (Auxiliary Feedwater System):

Essential components shall be identified as those which are a part of the AFWS and are required to mitigate the consequences of the accident, prevent a significant uncontrolled release of

radiation, or place the plant in a cold shutdown condition.

These essential AFWS components shall include electrical controls, and mechanical items. A schematic of the AFWS is shown in Figure 1.

3. High Energy Fluid Systems:

High energy fluid systems shall include those pressurized systems or portions thereof in which the normal operating temperature exceeds 200^oF or the normal operating pressure exceeds 275 psig for more than two percent of the time it operates during normal plant conditions. For the purposes of the missile analysis, portions of the AFWS, which are not pressurized during normal plant conditions, are excluded from the high energy system criteria.

4. Normal Plant Conditions:

Normal plant conditions include reactor startup, operation at power, hot standby, or reactor cooldown to cold shutdown condition.




Figure 1

II. B. GENERAL

The basic philosophy of missile protection is to assure that one train of the AFWS will always be free of damage (i.e. operable) from the effects of any postulated internally generated missile sources located outside containment building. The purpose of this is to ensure that one train of the AFWS will always be available in any emergency situation to remove reactor decay heat and provide for the cooldown of the Reactor Coolant System to within the temperature and pressure limits at which the Decay Heat System can be placed in operation.

This assurance shall be provided by analyzing the effects of postulated internally generated missiles on AFWS components located outside the containment building. If the analysis indicates damage to components of both AFWS trains from a single postulated missile source, additional measures shall be taken to protect the components of at least one train from postulated missile hazards.

Only sources listed below shall be considered as credible missile sources:

1. Rotating machinery which operates during normal plant conditions.
2. High energy fluid system components including:
 - a. Valve bonnets and stems except as excluded below in Item II.C.
 - b. Temperature instrument wells and thimbles.
 - c. Pressure instruments and connections.
 - d. Welded dead-end flanges and caps.*
 - e. Vents, drains and test connections.*
 - f. Compressed gas storage system components.*

* - Only if failure of single circumferential weld would cause ejection.

C. EXCLUSIONS

1. Externally generated missiles such as those due to tornado winds are dealt with in Volume I of the Updated Safety Analysis Report, Section 1.5.2, and are not considered as part of this criteria document. Only missiles generated internally as a result of equipment failure are considered.
2. Analysis of turbine missiles is not included in these criteria. Turbine missiles are described in Volume VIII of Updated Safety Analysis Report, Appendix 5C.
3. Equipment which utilizes more than one retention feature in its design is not considered as capable of generating missiles.
 - a. Pressure seal bonnet-type valves of ANSI B16.5, 900 psig rating and above, constructed in accordance with ASME Boiler and Pressure Vessel Code, Section III¹, have a retaining ring and yoke. Because of this dual retention feature and because of the highly conservative design of the retaining rings, pressure seal bonnets are not considered credible missiles.
 - b. For valves with bolted bonnets, the bonnet-to-body bolting material limiting stresses and flange design set forth in the ASME Boiler and Pressure Vessel Code, Section III¹, prevent the valve bonnet from becoming a missile. The likelihood of complete severance of all bolts simultaneously is very remote with the result that bolted valve bonnets need not be considered as credible missiles.

1 - Or equivalent Nuclear Pump and Valve Code to which existing equipment were designed and constructed.

- c. Valve stems with backseats or air, solenoid or motor-operated valve stems utilize more than one retention feature and, therefore, are not considered a missile source.
 - d. Components of high energy fluid piping with a nominal diameter of 1" or smaller have only a small amount of energy and are not considered as potential destructive missiles.
 - e. Valve body bypass lines with 1" or smaller valves are not considered as potential destructive missiles since the lines are attached to the valve body at both ends which meets the double retention feature criteria. The bypass valves themselves are excluded based on size criteria per Item d above.
 - f. Instrument connections with integral tubing for pressure differential transmitters or flow elements are not considered as potential missile sources since the tubing will restrain the ejected component from becoming a free missile.
- 4. Nuts, bolts, studs, and combinations of nuts with bolts or studs have only a small amount of energy and are not considered as potential destructive missiles.
 - 5. This document does not consider pressure vessels and heat exchangers, as being capable of failure (producing missiles by fragmentation of the vessel casing).
 - 6. Normally closed gate valves are not considered as potential missile sources.
 - 7. Secondary missiles are excluded from the scope of this design criteria.

III. GENERAL MISSILE PROTECTION DESIGN CRITERIA

Where analysis indicates that internally generated missiles cannot be contained locally, the following protective measures shall be considered in order of preference listed below.

- A. Where a critical target and missile source share a common area, efforts shall be made to provide adequate physical separation by relocating or reorienting either the target or the missile.
- B. The use of non-destructive examination and calibration of high energy equipment to reduce the probability of missile occurrence to a level where consideration of damage is unnecessary (PRA).
- C. Damage to one train of the AFWS is permitted from a potential missile source originating from another system. This is an exception to the Single Active Failure Criteria of SRP.3.5.1.1 (Ref. VI.J).
Protection shall be provided if components in both trains could get damaged from a single potential missile originating from another system.
- D. Where physical separation is not feasible, structural walls or specially erected barriers shall be used as protective devices .

IV. ANALYSIS CRITERIA

- A. The missile analysis shall identify potential missile sources by reviewing high energy sources and rotating machinery.
- B. Determination of missile characteristics (mass, velocity, geometry, trajectory and deformation characteristics) shall be made on a case-by-case basis, based on most probable point of failure. The direction of travel for missiles shall be in the direction of the applied force. For rotating machinery, targets are only considered if they are within the plane of rotation.

C. The kinetic energy of the missile shall be determined in order to calculate the ability of the missile to perforate the enclosure or restraining device and reach the target, or to penetrate concrete walls to a depth sufficient to cause spalling. This calculation shall account for any physical object which may separate the target and source. Missiles which are physically remote from the target need not be given further consideration. Methods for determination of depth of penetration, perforation, spalling, and residual velocity shall be those of BC-TOP-9A. If it is identified that barriers are required, the design of barriers for missile impact shall be performed in accordance with Civil Design Guide C2.45.

V. ANALYSIS TECHNIQUES

The missile analysis for the Auxiliary Feedwater System will be conducted as follows:

A. The first step in the missile review is the identification of all the safety-related equipment including pumps, valves, tanks, piping, instrument, instrument sensing lines and electrical cables associated with the Auxiliary Feedwater System. This can be accomplished by using the piping and instrumentation diagrams, logic diagrams and elementary drawings. Once all the safety-related components associated with the AFWS are identified, their physical location can be determined by using the piping area drawings, equipment location drawings, conduit and tray drawings, and any other applicable drawings.

- B. The second step in the missile review is the identification of those areas outside containment building, where missiles from one single source can damage components of both trains of the AFWS simultaneously.
- C. If the potential missiles identified in Step B above cannot be excluded based on the criteria outlined in Section II.C, then determine if the essential targets are located within the direction of these missiles. If there are no targets, then the missile analysis is complete and no protection is required. If essential targets belonging to both trains of AFWS are located within the direction of these missiles, then calculate the kinetic energy, depth of penetration, perforation thickness, spalling and residual velocity utilizing the formulas provided in BC-TOP-9A.
- D. If the analysis based on the calculations performed in Step C indicates damage to components of both train simultaneously, then protection shall be provided for components of at least one train in accordance with the steps outlined in Section III of this design criteria.
- E. Deviations from this procedure to reduce unnecessary work are acceptable as long as the basic philosophy of protection is not violated as described in paragraph II.B of this design criteria.

VI. REFERENCES

- A. USNRC Standard Review Plan 3.5.1.1, "Internally Generated Missile (outside containment)", NUREG-0800, Rev. 2, July 1981.
- B. Bechtel Power Corporation, Design Guide C2.45, "Design of Structures for Tornado Missile Impact", Revision 0, April 1982.
- C. USNRC Standard Review Plan 3.5.3, "Barrier Design Procedures", NUREG-0800, Rev. 1, July 1981.
- D. "Plant Design Against Missiles", American Nuclear Society, ANSI N177, April 1974.
- E. BC-TOP-9A, "Design of Structures for Missile Impact, Bechtel Power Corporation, Rev. 2, September 1974.
- F. General Design Criterion 4, "Environmental and Missile Design Bases", Appendix A to 10 CFR 50.
- G. Regulator Guide 1.70, Section 3.5.
- H. Rancho Seco Design Guide for assumptions and criteria for pipe break protection review, Revision 2, March 1983.
- I. Letter from John F. Stolz of NRC to R. J. Rodriguez of SMUD on "Status of Auxiliary Feedwater Upgrade Review", dated September 26, 1983.
- J. IOM from T. Khan of BPC to D. Abbott/R. Dietrich on Auxiliary Feedwater System, dated March 5, 1984.
- K. Bechtel Power Corporation, SNUPPS FSAR, Section 3.5.1, Revision 1, September 1980.
- L. USNRC Standard Review Plan 10.4.9, "Auxiliary Feedwater System (PWR)", NUREG-08700, Rev. 2, July 1981.

0004m

4/16/84



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

RJR 83-733

November 7, 1983

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTENTION JOHN F STOLZ CHIEF
OPERATING REACTOR BRANCH IV
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON D C 20555

DOCKET 50-312
RANCHO SECO NUCLEAR GENERATING STATION
UNIT NO 1
AUXILIARY FEEDWATER SYSTEM UPGRADE REVIEW - NUREG 0737 ITEM II.E.1.1

The Sacramento Municipal Utility District has reviewed your letter of September 26, 1983 which provided a status of your evaluation of the Rancho Seco Auxiliary Feedwater System (AFWS) Upgrade. You stated that our position regarding the protection of the AFWS from internally generated missiles was not acceptable. This letter is to inform you of our desire to appeal your decision.


The requirements of the TMI action plan, NUREG 0737, Items II.E.1.1 and 2 have been completed. In particular, the auxiliary feedwater system now meets the automatic initiation and flow indication requirements of Item II.E.1.2. The District's decision to upgrade the auxiliary feedwater system with the addition of an Emergency Feedwater Initiation and Control (EFIC) system was beyond the scope of this document. The Class I control system is intended to prevent reactor system overcooling transients and steam generator overfill. We object to the staff's provision that the upgraded system be protected against the affects of internally generated missiles in accordance with the guidelines of Standard Review Plan Sections 3.5.1.1 and 3.5.1.2. We therefore wish to appeal to NRR management in accordance with the Commission's policy statement in the Federal Register dated Wednesday, September 28, 1983, page 44173, since we feel this is a backfitting requirement. An internally generated missile study has never been performed for the Rancho Seco Nuclear Generating Station.

~~041180066 831107~~
PDR ADOCK 05000312
PDR

A046
1/1

We did commit, however, on June 3, 1983, to address this issue by a walkdown of the auxiliary feedwater system to identify any components which due to their location or proximity of one component to the other could be susceptible to a single internally generated missile. At such locations, we also committed to provide missile protection. We feel this action is adequate even though it is not in accordance with current guidelines.

We will remain in contact with our Project Manager, Sydney Miner, to determine the scheduling for the proper actions in this appeal process. At this time, we have requested a quotation from Bechtel Corporation for the performance of an internally generated missile study. This information will provide input to a cost benefit analysis, however, the cost of missile protection will remain an unknown since we do not intend to actually perform the study. If we can provide any further information at this time, please advise.



R. J. Rodriguez
Executive Director, Nuclear



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 26, 1983

Docket No. 50-312

Mr. Ronald J. Rodriguez
Executive Director, Nuclear
Sacramento Municipal Utility District
6201 S Street
Post Office Box 15830
Sacramento, California 95813

Dear Mr. Rodriguez:

SUBJECT: RANCHO SECO - STATUS OF THE AUXILIARY FEEDWATER (AFWS)
UPGRADE REVIEW (NUREG-0737 ITEM II.E.1.1)

By letter dated April 7, 1983, we provided you with status report of our evaluation of the Rancho Seco upgrade AFWS. In our letter we stated that three open items remain where we require additional information to complete our review. These were: (1) protection of the AFWS from internal missiles; (2) additional protection for the condensate storage tank; and (3) pipe break analysis for all AFWS components including existing components. By letters dated May 2, 1983, June 3, 1983, and June 21, 1983, you provided additional information regarding these items. We have completed our review of the information and the results of the review are provided in the enclosed Safety Evaluation Report (SER).

As outlined in the SER we have concluded that you have satisfied our requirements for items (2) and (3) above and we, therefore, consider these items completed. For item (1) protection of the AFWS from internal missiles you proposed evaluating the effects of internal missiles and will provide missile protection where a single missile could incapacitate both AFWS trains. This is not acceptable to us. Our position is that the effects of missiles should not adversely affect the AFWS function considering a single active failure. Therefore, within 30 days of receipt of this letter, please provide in writing a commitment that you will meet the staff's position.

As discussed with Mr. Bob Dieterick of your staff, NRR procedures provide an opportunity for an appeal by a licensee to NRR management when the staff imposes new requirements on a licensee (backfit) and the licensee objects to the position. Since our internal missile position is a potential backfit requirement for Rancho Seco, you may wish to appeal our position to NRR management. If you decide to appeal to NRR management to have the staff's position modified, within 30 days of receipt of this letter, please indicate in writing that (a) you object to the staff's position; (b) you wish to appeal the staff's position to NRR management to have it modified; and (c) your proposed modification. Should you have any additional questions regarding the staff's position or the appeal process, please contact the NRR project manager.

8310110471

R. Rodriguez

-2-

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents, therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script that reads "John F. Stolz". The signature is written in dark ink and is positioned above the typed name and title.

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

Sacramento Municipal Utility
District

- 1 -

Rancho Seco, Docket No. 80-312

cc w/enclosure(s):

David S. Kaplan, Secretary and
General Counsel
Sacramento Municipal Utility
District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Sacramento County
Board of Supervisors
827 7th Street, Room 424
Sacramento, California 95814

Mr. John B. Martin, Regional
Administrator
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Regional Radiation Representative
EPA Region IX
215 Fremont Street
San Francisco, California 94111

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Thomas Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Heleen Hubbard
P. O. Box 63
Sunol, California 94586

Christopher Ellison, Esq.
Dian Gruevich, Esq.
California Energy Commission
1111 Howe Avenue
Sacramento, California 95825

Ms. Eleanor Schwartz
California State Office
600 Pennsylvania Avenue, S.E., Rm. 201
Washington, D. C. 20003

Docketing and Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Resident Inspector/Rancho Seco
c/o U. S. N. R. C.
14410 Twin Cities Rd.
Herald, CA 95638

Atomic Safety and Licensing Appeal
Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Alan S. Rosenthal, Chairman
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. John H. Buck
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Christine W. Kohl
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Joseph J. Ward, Chief
Radiological Health Branch
State Department of Health Services
714 P Street, Office Building #8
Sacramento, California 95814

SAFETY EVALUATION REPORT
RANCHO SECO - AUXILIARY FEEDWATER SYSTEM

In accordance with the requirements of Item II.E.1.1 of NUREG-0660, "NRC Action Plan Developed as a Result of the TMI-2 Accident," and NUREG-0737, "Clarification of TMI Action Plan Requirements," the Licensee is required to:

- (1) Perform a simplified auxiliary feedwater (AFW) system reliability analysis that uses event-tree and fault-tree logic techniques to determine the potential for AFW system failure under various loss-of-main feedwater-transient conditions. Particular emphasis is given to determine potential failures that could result from human errors, common causes, single-point vulnerabilities and test and maintenance outages.
- (2) Perform a deterministic review of the AFW system using the acceptance criteria of Standard Review Plan Section 10.4.9 and associated Branch Technical Position ASB 10-1 as principal guidance; and
- (3) Reevaluate the AFW system flow rate design bases and criteria.

Our evaluation of the Rancho Seco auxiliary feedwater system (AFWS) against the requirements of Item II.E.1.1 is presented in two parts. Part I is our evaluation of the proposed AFWS upgrade design against the criteria of the Standard Review Plan. Part II is our evaluation of the (1) AFWS against the criteria developed after the Three Mile Island Unit 2 accident and enumerated in NUREG-0611 and NUREG-0635, (2) the licensee's reliability analyses, and (3) the licensee's reevaluation of the design basis for the AFWS flow requirements. Our evaluation of the immediate actions required by the Commission shutdown order of May 7, 1979 was provided in a Safety Evaluation Report which was transmitted to the licensee by letter dated June 27, 1979. Nothing in our current review has resulted in a change to the conclusions expressed in the

5. General Design Criterion 44, "Cooling Water," to assure:
 - a. The capability to transfer heat loads from the reactor system to a heat sink under both normal operating and accident conditions.
 - b. Redundancy of components so that under accident conditions the safety function can be performed assuming a single active component failure. (This may be coincident with the loss of offsite power for certain events.)
 - c. The capability to isolate components, subsystems, or piping if required so that the system safety function will be maintained.
6. General Design Criterion 45, "Inspection of Cooling Water System," as related to design provisions made to permit periodic inservice inspection of system components and equipment.
7. General Design Criterion 46, "Testing of Cooling Water System," as related to design provisions made to permit appropriate functional testing of the system and components to assure structural integrity and leak-tightness, operability and performance of active components, and capability of the integrated system to function as intended during normal, shutdown, and accident conditions.
8. Regulatory Guide 1.26, "Quality Group Classification and Standards for Water-, Steam- and Radioactive Waste Containing Components for Nuclear Power Plants," as related to the quality group classification of system components.
9. Regulatory Guide 1.29, "Seismic Design Classification," as related to seismic design classification of system components.
10. Regulatory Guide 1.52, "Manual Initiation of Protective Actions," as related to design provisions made for manual initiation of each protective action.

initiation and control. One AFWS train is served by pump P-318, a combination turbine-driven/motor-driven pump with both the turbine and electric motor on a common shaft. Either motive source can drive the pump at its rated capacity of 840 gpm at 1150 psig with a normal recirculation flow of 60 gpm. The turbine driver is used as the primary motive source for this pump and is automatically initiated. The motor driver can only be manually initiated. The pump serving the other train, pump P-319, is a motor-driven pump which has the same rated capacity and recirculation flow as pump P-318. Pump P-319 is automatically initiated and automatically loaded on the emergency bus. The discharge lines from the pumps are cross-connected by a full-flow line containing two normally-open motor operated valves in series. This cross-connect permits either pump to feed either or both steam generators. The primary water source for both AFWS trains is the seismic Category I condensate storage tank. Alternative AFWS suction sources are available from the on-site reservoir and the Folsom South Canal. Piping from these alternative sources enters the cross-connect in the suction piping between locked closed manual valves. The alternative source is fed by transfer pumps from the Folsom South Canal or by gravity flow from the reservoir.

Rancho Seco is a one unit site, therefore General Design Criterion 5 is not applicable.

1. We have reviewed the licensee's submittals listed above in order to verify the acceptability of the AFWS design with respect to its classification and operating characteristics.
 - a. There is not sufficient information available to ensure that the AFWS will meet all the current guidelines for the various functions of the system. Specifically, the licensee has not verified that the proposed upgraded AFWS will be protected against the effects of internally generated missiles in accordance with the guidelines of Standard Review Plan Sections 3.5.1.1 and 3.5.1.2. Therefore we cannot conclude that the AFWS meets all the minimum performance requirements of General Design

ANSI B31.1 criteria with the exception of the AFWS containment penetrations which were designed to ANSI B31.7 Class 2 criteria. These are the criteria that were in effect at the time the existing Rancho Seco AFWS was designed and they pre-date the ASME codes specified in Regulatory Guide 1.26. However, the essential design criteria of the ANSI B31.1 and B31.7 Class 2 codes are basically the same as current design criteria. Therefore, we conclude that the AFWS, as upgraded, meets the requirements of General Design Criterion 2 and the guidelines of Regulatory Guide 1.29 and meets the essential features of Regulatory Guide 1.26 and is, therefore, acceptable.

- d. Provisions for AFWS testing and inspection are included in the design. Each AFW pump is equipped with a full flow recirculation line to the condensers which can be used for periodic functional testing purposes. Periodic testing of the AFWS pumps and valves is identified in the plant Technical Specifications. In addition, plant Technical Specifications require periodic inspection of all valves, including those that are locked, sealed, or otherwise secured in position. Therefore, we conclude that the AFWS meets the requirements of General Design Criteria 45 and 46 with regard to design provisions for inservice inspection and functional testing.
2. We have reviewed the AFWS design for protection against the effects of natural phenomena, pipe breaks or cracks in fluid systems outside containment, single system component failures, loss of an onsite motive power source, or loss of offsite power.
 - a. We have evaluated the upgraded AFWS design against the requirements of General Design Criterion 2 with respect to the structures housing the system and the system itself being capable of withstanding the effects of earthquakes. By letter dated January 14, 1983 the licensee verified that all AFWS essential components will be located either outdoors or in seismic Category I structures or will be otherwise provided with

relative to turbine missile protection as defined by the guidelines of Regulatory Guide 1.115, we conclude that the upgraded system adequately meets the requirements in effect at the time of the license.*

Internally Generated Missiles

By letter dated December 8, 1982, we requested the licensee to provide information regarding the protection afforded the AFWS against the effects of internally-generated missiles. At a meeting on February 9, 1983, the licensee stated that an evaluation of internally generated missiles had never been performed for the Rancho Seco AFWS. Subsequently, in a letter dated June 3, 1983, the licensee stated that protection from internally generated missiles will be addressed by a walkdown of the AFWS trains to identify AFWS components and piping which, due to their location or their proximity of one train to the other and lack of intervening structures, could be susceptible to a single internally generated missile. At such locations, potential missiles will be evaluated and where a single missile could incapacitate both AFWS trains, missile protection will be provided. In a letter dated June 21, 1983, the licensee reiterated his position that the AFWS will only be protected against missile sources that can damage both redundant AFWS trains simultaneously. The licensee's position is not in accordance with current guidelines for internally generated missiles as discussed in Standard Review Plan Sections 3.5.1.1 and 3.5.1.2. These guidelines state that the effects of missiles should be evaluated in conjunction with a single active failure. Consequently, when the missile source is a nonsafety-related system, the effect of missile impact on one train of a safety-related

*As discussed in Section II.C of this report, the staff is currently developing a multi-plant position relative to AFWS reliability requirements for all operating reactors which could lead to modifications to increase system reliability for Rancho Seco.

Tornado Missiles

By letter dated January 14, 1983, the licensee stated that tornado missiles are not part of the design basis for the Rancho Seco plant. The licensee's Final Safety Analysis Report (FSAR) notes that the AFW pumps are protected against missiles generated by 175 mph winds and the piping and CST are protected against missiles generated by 101 mph winds. These winds are not in accordance with the wind speeds specified in current guidelines (see above). In addition, the missiles used for the FSAR analysis do not meet the current guidelines in Standard Review Plan Section 3.5.1.4. However, the Rancho Seco AFWs meets tornado missile protection criteria in effect at the time the plant was licensed.

In addition, a recent analysis of the CST indicates that this essential component is adequately protected against tornado missiles. By letters dated June 3 and June 21, 1983, the licensee stated that the lower 8 feet of the CST, being thicker than the upper portion, could withstand missiles generated by a 175 mph wind. The missile spectrum used in the reanalysis included the missiles defined in Standard Review Plan Section 3.5.1.4. Therefore, missile penetration of the lower 8 feet of the CST is not expected for local wind speeds up to 175 mph. As noted above, the probability of occurrence of a 175 mph wind is 10^{-6} per year. The protected 8 feet of CST water, in conjunction with low level and low-low level alarms for the CST, ensures adequate time for operator action to switch over to an alternate source of AFW water. We, therefore, conclude that the CST meets the requirements of General Design Criterion 4 with respect to wind generated missiles.

- c. The AFWs is not used for startup and normal shutdown; therefore, it is considered a moderate energy system for pipe breaks in the AFWs. The only high-energy piping in the system is located

sphere via the atmospheric dump valves. The turbine-driven pump receives main steam from connections to both main steam lines upstream of the turbine stop valves which serve as main steam isolation valves at Rancho Seco. The AFW steam supply lines are six-inch lines each containing a check valve, a locked open manual valve and a normally open AC motor operated valve. Downstream of the motor-operated valves, the AFW steam supply lines connect to provide a common supply to the AFW pump turbine. The common steam supply line contains a normally-closed DC motor-operated valve which opens on an emergency feedwater initiation signal. The motor-driven AFW pump also starts automatically on the emergency feedwater initiation signal. The motor driven pump will be modified to provide automatic loading on a diesel generator powered emergency bus on loss of offsite power. All of the valves associated with each pump train are normally open with the exception of four normally closed isolation valves. In each train, there will be one DC motor-operated isolation valve and one AC motor-operated isolation valve in parallel piping paths. A normally open air-operated valve will be provided in series with the DC motor operated valve and a normally open solenoid valve will be provided in series with the AC motor-operated valve. In the AFW system description (Revision 3) transmitted by the April 28, 1983 letter, the licensee stated that both motor-operated isolation valves will open on AFW initiation and the flow to each steam generator will be controlled by the air-operated and solenoid flow control valves. The licensee will provide power to the flow control valves from two separate battery-backed buses. In addition, the air-operated valves will be equipped with seismic Category I air accumulators which will enable the valves to be operated for up to two hours following a loss of plant air supply to the valves. Final drawings for the emergency feedwater instrumentation and control (EFIC) system will be provided by the licensee no sooner than January 1984. Pending review of the final EFIC system drawings and verification of

be provided with position indication in the control room. Because normally shut manual valves isolate the AFWs from nonessential systems, isolability of the AFWs is not jeopardized by active valve failure. Thus, adequate feedwater will be assured in the event of a postulated design basis accident concurrent with a single failure. We, therefore, conclude that the AFWs meet the requirements of General Design Criterion 44 with respect to the single failure criterion.

- f. AFW Train A pump, P-318, is a combination turbine-driven and motor-driven pump with both a turbine and electric motor on a common shaft. AFW Train B pump, P-319, is a motor-driven pump with the same rated capacity as the Train A pump. The turbine-driven pump train provides a diverse means of assuring feedwater supply to the steam generator independent of all offsite or onsite AC power sources for at least two hours. The pump and turbine are not dependent on secondary support systems. The bearings on the pump and turbine are lubricated by slinging oil from reservoirs near the bearings. Lube oil cooling is accomplished by heat transfer to the pumped fluid. In the AFW system description (Rev.-3) transmitted by the April 23, 1983 letter, the licensee stated that automatic actuation and control of the turbine train will be provided with battery-backed DC power. The steam admission valve to the AFW pump turbine is a DC motor-operated valve. The control power to the flow control valves in each pump train will be from redundant battery-backed buses. Control air to the air-operated flow control valves will be ensured by safety-related nitrogen accumulators. As discussed in Section I.B.2.d of this report, EFIC system drawings will be provided later by the licensee. Therefore, pending staff review of the final EFIC system drawings and verification of the adequacy of the EFIC system to automatically initiate and control the AFW flow with no AC power available, we conclude that the AFWs meet the power diversity position of BTP 488 10-1.

i. In the Revision 3 AFW system description, the licensee stated that the AFW function will be initiated automatically in the event of a main feedwater or main steam line rupture. Both AFW pumps will automatically start and steam generator level will be automatically controlled for the condition where main feedwater line and steam line ruptures depressurize the steam generators. Automatic isolation of AFW flow to a leaking steam generator will be provided, and a steam line break or main feedwater line break that depressurizes a steam generator will cause isolation of the main feedwater lines on the depressurized steam generator. If isolation of the steam generator main feed line does not isolate the break, AFW flow will be isolated from the leaking steam generator so that AFW flow will be provided only to the intact steam generator. By letter dated June 21, 1983, the licensee verified that the design will ensure that no single active failure in the upgraded AFW design will prevent AFW flow from being supplied to the intact steam generator or allow AFW flow to be supplied to the leaking steam generator. However, a main steam rupture with failure of a single turbine stop valve could result in blowdown of both steam generators with consequent AFW pump runout. By letter dated November 3, 1982, the licensee was requested to evaluate this matter and propose a solution. A licensee response is expected in late 1983. This matter is being resolved as part of Multiplant Action B-69, "Main Steam Line Break with Continued Feedwater Addition," and is beyond the scope of this AFW evaluation. The results of the B-69 evaluation could result in the need for further AFW modifications and will, therefore, be evaluated for their impact on the AFW. Until Multiplant Action B-69 is resolved we cannot conclude that the AFW meets the requirements of General Design Criterion 44 with respect to its ability to transfer heat under accident conditions and provide isolation to assure system function.

j. Each AFW pump is designed to provide 100% of the flow for residual heat removal over the entire range of accidents as

PART II

INTRODUCTION AND BACKGROUND

The Three Mile Island Unit 2 (TMI-2) accident and subsequent investigations and studies highlighted the importance of the Auxiliary Feedwater System (AFWS) in the mitigation of transients and accidents. As part of our assessment of the TMI-2 accident and related implications for operating plants, we evaluated the AFWS systems for all operating plants having nuclear steam supply systems (NSSS) designed by Westinghouse (NUREG-0611) or Combustion Engineering (NUREG-0635). Our evaluations of these system designs are contained in the NUREGs along with our recommendations. The objectives of the evaluation were to: (1) identify necessary changes in AFWS system design or related procedures of these plants, and (2) to identify other system characteristics of the AFWS systems which, on a long term basis, may require system modifications. To accomplish these objectives, we:

- (1) Reviewed plant specific AFWS system designs in light of current regulatory requirements (SRP) and,
- (2) Assessed the relative reliability of the AFWS systems under various loss of feedwater transients (one of which was the initiating event of TMI-2) and other postulated failure conditions by determining the potential for AFWS system failure due to common causes, single point vulnerabilities, and human error.

We have applied the generic results and recommendations of the above described review to the Rancho Seco auxiliary feedwater system (AFWS) design. The detailed reliability analyses submitted by the licensee were also evaluated. We also evaluated the licensee's design basis for AFWS flow requirements.

Section A of Part II is our evaluation of the present AFWS against our generic short-term recommendations. Section B is our evaluation of the proposed AFWS upgrade design against our generic long-term recommendations. Section C is our evaluation of the reliability analysis provided by the licensee for the

These modifications were approved by the staff and issued by letter dated March 27, 1981. We conclude that the Technical Specifications are in compliance with our recommendations and are, therefore, acceptable.

3. Recommendation GS-3 - "The licensee has stated that it throttles AFW system flow to avoid water hammer. The licensee should reexamine the practice of throttling AFW system flow to avoid water hammer. The licensee should verify that the AFW system will supply on demand sufficient initial flow to the necessary steam generators to assure adequate decay heat removal following loss of main feedwater flow and reactor trip from 100% power. In cases where this reevaluation results in an increase in initial AFW system flow, the licensee should provide sufficient information to demonstrate that the required initial AFW system will not result in plant damage due to water hammer."

By letter dated April 29, 1982, the licensee transmitted a Licensee Event Report, which reported damage to the AFW header in both steam generators. At a meeting on June 24, 1982, the licensee and the Babcock and Wilcox Company presented their plan to retire-in-place the existing internal AFW header and to install an external AFW header on each of the two steam generators. The new design is a modified design of the external AFW header used at several other Babcock and Wilcox designed plants. Details of the proposed design modifications were provided by a licensee letter dated August 3, 1982, and approved by the staff in a letter dated August 19, 1982. By letter dated August 13, 1982, the licensee committed to perform a water hammer test after installation of the new header arrangement. The water hammer test was performed and it was verified that no water hammer occurred. Therefore, we conclude that the design is acceptable.

4. Recommendation GS-4 - "Emergency procedures for transferring to alternate sources of AFW supply should be available to the plant

only locked-open valves and check valves. Thus, the primary AFW water source is always aligned to provide suction flow to the pumps. The CST is designed to seismic Category I criteria and would be available in the event of an earthquake. Although the CST is not protected against tornado wind speeds in accordance with current guidelines, it is protected against wind damage and against missiles generated by winds of speeds up to 175 miles per hour. The probability of occurrence of wind speeds greater than 175 miles per hour is sufficiently low that catastrophic loss of the CST is not expected. Therefore, we conclude that the AFW pumps are adequately protected against loss of suction flow in accordance with this short-term requirement (see also Section II.B.4 of this report).

5. Recommendation GS-5 - "The as-built plant should be capable of providing the required AFW flow for at least two hours from one AFW pump train, independent of any alternating current power source. If manual AFW system initiation or flow control is required following a complete loss of alternating current power, emergency procedures should be established for manually initiating and controlling the system under these conditions. Since the water for cooling of the lube oil for the turbine-driven pump bearings may be dependent on alternating current power, design or procedural changes shall be made to eliminate this dependency as soon as possible. Until this is done, the emergency procedures should provide for an individual to be stationed at the turbine-driven pump in the event of the loss of all alternating current power to monitor pump bearing and/or lube oil temperatures. If necessary, this operator would operate the turbine-driven pump in a manual on-off mode until alternating current power is restored. Adequate lighting powered by direct current power sources and communications at local stations should also be provided if manual initiation and control of the AFW system is needed. (See Recommendation GL-3 for the longer-term resolution of this concern.)"

On loss of all AC power, the steam turbine-driven AFW pump will start as a result of the DC powered steam inlet valve opening. The

staff by letter dated March 27, 1981. We conclude that the Technical Specifications are in compliance with our recommendations and are, therefore, acceptable.

7. Recommendation GS-7 - "The licensee should verify that the automatic start AFW system signals and associated circuitry are safety grade. If this cannot be verified, the AFW system automatic initiation system should be modified in the short-term to meet the functional requirements listed below. For the longer term, the automatic initiation signals and circuits should be upgraded to meet safety-grade requirements as indicated in Recommendation GL-5.

- (1) The design should provide for the automatic initiation of the auxiliary feedwater system flow.
- (2) The automatic initiation signals and circuits should be designed so that a single failure will not result in the loss of auxiliary feedwater system function.
- (3) Testability of the initiation signals and circuits shall be a feature of the design.
- (4) The initiation signals and circuits should be powered from the emergency buses.
- (5) Manual capability to initiate the auxiliary feedwater system from the control room should be retained and should be implemented so that a single failure in the manual circuits will not result in the loss of system function.
- (6) The alternating current motor-driven pumps and valves in the auxiliary feedwater system should be included in the automatic actuation (simultaneous and/or sequential) of the loads to the emergency buses.

the motor-driven AFW pump onto the existing diesel generator-supplied emergency bus. By letter dated October 5, 1982, the licensee provided additional information to verify the acceptability of this interim action. This additional information has been reviewed by the staff and the licensee's proposal has been found to be acceptable inasmuch as the licensee provided adequate assurance that the AFW pump can be automatically loaded on the diesel generator with no adverse effect to the diesel generator or safety loads.

Therefore, we conclude, that the existing initiation and control system is in conformance with the guidelines of Recommendation GS-7 and is, therefore, acceptable.

8. Additional Short Term Recommendation 1 - "The licensee should provide redundant level indication and low level alarms in the control room for the AFW system primary water supply, to allow the operator to anticipate the need to makeup water or transfer to an alternate water supply and prevent a low pump suction pressure condition from occurring. The low level alarm setpoint should allow at least 20 minutes for operator action, assuming that the largest capacity AFW pump is operating.

For long-term, the level indication and alarms must be safety grade with redundant sensors, detectors readouts, and alarms all the way from the CST to control room, including power supplies. Circuitry equipment and power supplies are required to be Class 1E."

As indicated in the licensee letter of December 17, 1979, the condensate storage tank level is indicated in the control room. Previously, in a letter dated June 27, 1979, the staff noted that condensate storage tank low level alarms in the control room provide 40 minutes for operator action to transfer to an alternative water source. The staff concluded that the alarms and operating procedures were adequate to assure timely transfer to an alternative source when the condensate storage tank supply is being depleted.

10. Additional Short-Term Recommendation 3 - "The licensee should implement the following requirements as specified by Item 2.1.7.b on page A-32 of NUREG-0578:

'Safety-grade indication of auxiliary feedwater flow to each steam generator shall be provided in the control room. The auxiliary feedwater flow instrument channels shall be powered from the emergency buses consistent with satisfying the emergency power diversity requirements for the auxiliary feedwater system set forth in Auxiliary Systems Branch Technical Position 10-1 of the Standard Review Plan, Section 10.4.9.'"

By letter dated December 17, 1979, the licensee indicated that the existing AFWS obtains an indication of AFW flow from clamp-on ultrasonic flow meters on each AFWS train. Previously, by letter dated October 18, 1979, the licensee committee is to provide a safety-grade flow indication system in the upgraded AFWS design. In a letter dated February 26, 1980, the staff required that a procedure for performing channel functional tests of the existing AFW flow indication system be established and implemented until the upgraded AFW flow indication system is installed. By letter dated November 30, 1981, the licensee verified that these procedures are in place. By letter dated September 8, 1981, the licensee provided the design description of the upgraded AFW flow indication system. The long-term design modifications were reviewed by the staff and found acceptable. The safety-grade flow indication system will be added during the refueling outage which began in February 1983. Therefore, we conclude that the AFW flow indication system is in compliance with this recommendation and is, therefore, acceptable.

11. Additional Short-Term Recommendation 4 - "Licensees with plants which require local manual realignment of valves to conduct periodic tests on one AFW system train, and there is only one remaining AFW train available for operation, should propose Technical Specifications to provide that a dedicated individual who is in communication

The existing AFWS contains a control-grade automatic initiation system. The proposed upgrade of this system to a safety-grade system is evaluated in Section II.B.5, "Recommendations GL-5," of this report.

2. Recommendation GL-2 - "Licensees with plant designs in which the primary AFW system water supply passes through valves in a single flow path, but the alternate AFW system water supplies connect to the AFW system pump suction piping downstream of the above valve(s); should: (a) install redundant valves parallel to the above valve(s) or (b) provide automatic opening of the valve(s) from the alternate water supply upon low pump suction pressure."

Each AFW pump is provided with separate suction piping to the condensate storage tank. The suction piping to each pump has two locked-open manual valves and a check valve. We conclude that the AFWS suction piping is acceptable.

3. Recommendation GL-3 - "At least one AFW system pump and its associated flow path and essential instrumentation should automatically initiate AFW system flow and be capable of being operated independently of any AC power source for at least two hours. Conversion of DC power to AC power is acceptable."

The capability of the AFWS to operate for two hours in the event of a loss of all AC power is discussed in detail in Sections I.B.2.d and I.B.2.f of this report. By letter dated January 14, 1983, the licensee verified that the flow control valves in the upgraded design will be capable of being operated for two hours independent of AC power. Therefore, we conclude that the AFWS is in compliance with this recommendation and is, therefore, acceptable.

4. Recommendation GL-4 - "Licensees having plants with unprotected normal AFW water supplies should evaluate the design of their AFW systems to determine if automatic protection of the pumps is necessary following a seismic event or a tornado. The time available

licensee letter dated September 8, 1981. Subsequent to the staff review of the Revision 1 design, a Revision 3 AFW system design with further modifications to the EPIC system, was submitted by licensee letter dated April 28, 1983. The safety-related auto-initiation system, as described in the Revision 3 design description, will be installed during the refueling outage which began in February 1983. The staff will perform a post-implementation review of the auto-initiation system upon receipt of final system drawings and design description. Pending approval of the final design, we find the safety-related automatic initiation and control system to be acceptable.

C. Auxiliary Feedwater System Reliability Evaluation

In accordance with the requirements of NUREG-0660 and NUREG-0737, the licensee has performed a reliability study of the upgraded Rancho Seco auxiliary feedwater system (AFWS). The design description of the upgraded AFWS and the reliability study for the upgraded design were provided by the licensee in letters dated September 8, 1981 and January 18, 1982, respectively.

The licensee's reliability study was performed in a manner similar to that employed in the NUREG-0611 study using generic failure rate data as modified by Rancho Seco experience. The NUREG-0611 study considered the following three transient conditions for determining the reliability of the AFWS:

1. LMFW - Loss of Main Feedwater
2. LOOP - Loss of Offsite Power/Loss of Main Feedwater
3. LOAC - Loss of all AC Power/Loss of Main Feedwater

The licensee's evaluation does not present a separate value of AFWS unavailability for each of the three transients, but rather reports

TABLE 1: AFWS UNAVAILABILITY FOR THREE TRANSIENTS CASES

| | BNL Estimate, Per Demand No Operator Recovery | BNL Estimate, Per Demand Operator Recovery | Licensee Estimate, Per Demand, Operator Recovery |
|---------|---|--|---|
| 1. LMFV | 7.6×10^{-4} | 2.6×10^{-4} | 1.0×10^{-4} |
| 2. LOOP | 1.5×10^{-3} | 5×10^{-4} | 3.6×10^{-4} |
| 3. LOAC | 2.7×10^{-2} | 1.3×10^{-2} | 1.6×10^{-2} |

TABLE 2
Dominant Contributors to AFW5 Unavailability

| <u>BHL Estimate</u> | <u>Licensee Estimate</u> | <u>Comments</u> |
|---|--------------------------|--|
| <u>Dual (turbine/motor) driven pump train</u> | | |
| <u>Hardware^Δ</u> | | |
| 5x10 ⁻⁴ | 5x10 ⁻⁴ | Turbine/motor pump fails to start. |
| 1x10 ⁻³ | 5x10 ⁻³ | Steam turbine driver fails to start. |
| 3.1x10 ⁻³ | 3.9x10 ⁻³ | Steam admission valve fails to operate. |
| 1x10 ⁻³ | ~3x10 ⁻⁴ | Actuation signal failure, per train. |
| 5x10 ⁻³ | * | Steam admission valve left disabled after maintenance. |
| 3.6x10 ⁻² | * | Diesel generator B fails to start because of hardware failure (3x10 ⁻²) or in maintenance (6x10 ⁻³). |
| 1x10 ⁻³ | 8x10 ⁻⁴ | Battery fails in the loss of all AC power transient. |
| <u>Maintenance</u> | | |
| 5.8x10 ⁻³ | 1.15x10 ⁻³ | Turbine pump maintenance (motor driven is not considered here). |
| 2.1x10 ⁻³ | | Steam admission valve maintenance. |
| 2.1x10 ⁻³ | | Four parallel valves are under maintenance. |

*Events did not appear in the licensee fault trees.
^ΔAll failure rates are in per demand basis.

TABLE 3

Dominant Failure Models

BNL Analysis

Licensee Analysis

A. Loss of Main Feedwater (LMFW) Case

1. One pump under maintenance and hardware failure of second pump.

2. Failure of both actuation trains: control logic A (EFIC-A) actuates MDP and logic B (EFIC-B) actuates DDP (dual drive pump).

3. Leakage from test line valve FWS-X5 can divert AFW flow and potentially dry out the steam generators.

4. Miscalibration of all four steam generator level setpoints by the operator.

5. Hardware failure of both DDP and MDP.

1. The motor driven pump (MDP) unavailability due to loss of off-site power and diesel generator A failure.

2. The dual drive pump (DDP) unavailability due to steam admission valve failure or hardware failure of the turbine driver.

3. Valve FWS-X5 fails to close after the test.

4. Miscalibration of all four steam generator level setpoints.

5. Valves FWS-045 and FWS-046 fail to reopen after pump maintenance

B. Loss of Off-site Power (LOOP) Case

1. Diesel generator A failure or being maintained which disables MDP train while DDP train is unavailable due to maintenance or the steam admission valve failure.

2. Same as A.3, A.4.

6. The Feed-only-good-generator (FOGG) Logic fails due to miscalibration.

C. Loss of All AC Power

1. Actuation channel B fails.

2. Turbine driven pump being maintained.

3. Steam admission valve fails to open.

4. Local control to steam admission valve fails.

that, until a staff position is developed regarding the need for further modifications to improve AFWS reliability, operation of Rancho Seco, with the proposed upgraded AFWS design, is acceptable.

D. Auxiliary Feedwater Flow Requirements

The design basis event originally used for sizing the auxiliary feedwater system (AFWS) is loss of main feedwater (LMFW) with a concurrent loss of offsite power (LOOP), and subsequent loss of the reactor coolant pumps. The pertinent parameters for this accident relative to the AFWS are design flowrate and required time to full AFW flow. The design values which resulted from this original (FSAR) analysis are 780 gpm deliverable to the steam generator within 40 seconds of the initiation signal. The 40 second time was chosen to allow the AFWS to inject feedwater and begin increasing steam generator level to the 50% operating range level required for natural circulation prior to completion of the reactor coolant pump coastdown. The design flowrate was selected to be equal to or greater than the decay heat generation rate at 40 seconds. As described in the licensee submittal of September 8, 1981, each AFW pump has a rated capacity of 840 gpm at 1150 psig with a normal recirculation flow of 60 gpm; thus the net flow rate to the steam generators is 780 gpm.

Following the Three Mile Island Accident, the licensee provided an additional flow rate analysis which had been provided to the licensee in a letter from the Babcock and Wilcox Company (B&W) dated May 16, 1979. This new B&W analysis indicated that at 35 seconds after reactor trip, an AFW flow rate of 760 gpm would be adequate to remove decay heat, and at 40 seconds the minimum required flow rate would decrease to 748 gpm. By letter dated February 26, 1980 and at a meeting with the licensee on February 9, 1983, the staff requested additional information from the licensee to verify that the criteria used to establish minimum AFW flow requirements would assure adequate decay heat removal. The licensee responded to this request by providing the "Rancho Seco Auxiliary Feedwater Flow Evaluation" in a letter dated November 30, 1981 and a revised minimum flow analysis by letter dated February 18, 1983. Our evaluation of the February 18, 1983 revised minimum flow analysis is provided below.

Part III

CONCLUSION

Although substantial progress has been made in the staff's evaluation of the design and operation of the existing and proposed upgrade design of the Rancho Seco auxiliary feedwater system, we cannot complete our review until the licensee provides the required additional information identified in Part I above. While the upgraded design will not meet the current reliability guidelines, the staff has not yet fully resolved the need for additional modifications to increase system reliability. A staff position in this regard is being developed for all plants whose AFWS reliability does not meet current guidelines. Should Rancho Seco be required to implement modifications to increase system reliability such as adding a third train (pump), this solution could aid in resolution of deficiencies relative to other current guidelines noted in Part I. Until these matters are resolved, it is the staff's judgment that operation with the proposed upgraded AFWS is acceptable. Also, since many of the concerns associated with the existing system have been resolved and some of the proposed system upgrades will be implemented during the current refueling outage,* it is the staff's judgment that interim operation with the existing AFWS is acceptable. The licensee should, however, provide the information requested in Part I of this report. The information needed to complete our review is identified on page 9 (internally generated missiles) above.

*The safety grade AFWS initiation system and a safety grade flow indication system will be installed during the refueling outage which began in February 1983.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GR

September 2, 1983

Docket No. 50-366

Licensee: Georgia Power Company

Facility: Hatch Unit 2

SUBJECT: SUMMARY OF JULY 13, 1983 MEETING WITH GEORGIA POWER COMPANY
CONCERNING HIGH WATER LEVEL TRIP AND TURBINE BYPASS SYSTEM
TECHNICAL SPECIFICATIONS

The staff met with Georgia Power Company (GPC) representatives in Bethesda, Maryland, on July 13, 1983 to hear and discuss GPC's arguments concerning the staff's prior request for Technical Specifications related to assuring operability of the Hatch Unit 2 high water level trip and turbine bypass systems. GPC had indicated in its earlier response to the staff request for Technical Specifications on this subject that it believed the staff's request concerned generic issues that should have been reviewed under the formal NRC system for reviewing generic requirements.

GPC representatives, together with their consultants from General Electric, expressed their views that the failures they were asked to assume (i.e. to have both the flow controller and the turbine bypass valve fail), as the basis for requiring Technical Specifications, were so improbable that they should not be considered in the moderate frequency category.

GPC's General Electric Company consultants contended that:


1. Staff approved methodology in a generic report referred to as GESTAR was used in performing the analyses of the failure of the flow controller and turbine bypass.
2. The probability that both the feedwater flow controller and the turbine bypass system would fail is extremely low and is lower than values assumed for transients.
3. The staff's Standard Review Plan does not explicitly require safety-grade equipment for mitigation of transients. The staff is treating this case as if it involved an accident rather than a transient.
4. The equipment in question was not designed for or meant to have the type of surveillance testing that the staff has requested be performed on it. They don't know how they would perform the surveillance testing if it were required. The requested Technical Specification would add to the cost and complexity of testing.
5. The reliability of the equipment in question is such that it will work in a transient (without the proposed surveillance testing).
6. It is a new staff requirement to require Technical Specifications to assure operability of nonsafety-grade equipment.

~~53-1915-348~~

The staff explained that it considers that GPC is assuming credit for equipment that is not classified as safety related to mitigate the consequences of an operational transient. The staff also stated that General Design Criterion (GDC) 1 requires that equipment important to safety be designed, fabricated, erected and tested to quality standards commensurate with the importance of the safety function to be performed. And since the turbine bypass system and the high reactor water level trip are not classified as safety related, the staff has no assurance as to the reliability of the equipment and therefore considers that GDC 1 is not satisfied. The staff considers the proposed Technical Specifications and surveillance requirements sufficient to satisfy GDC 1.

The staff also stated that it is fairly clear that the issue in question is a generic issue. And it agreed to hold its previously stated requirement for these Technical Specifications in abeyance until it has considered the GPC arguments.

A list of meeting attendees is enclosed.



George W. Rivenbark
Operating Reactors Branch #4
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

MEETING SUMMARY DISTRIBUTION

Licensee: Georgia Power Company

*Copies also sent to those people on service (cc) list for subject plant(s).

Docket File

NRC PDR

L PDR

ORB#4 Rdg

Project Manager -GRivenbark

JStolz

BGrimes (Emerg. Preparedness only)

OELD

NSIC

ELJordan, IE

JHTaylor, IE

ACRS (10)

NRC Meeting Participants:

RHouston

TCollins

DVassallo

TCox

JKane

July 13, 1983

MEETING WITH GEORGIA POWER COMPANY CONCERNING HIGH WATER
LEVEL TRIP AND TURBINE BYPASS SYSTEM TECHNICAL SPECIFICATIONS

List of Attendees

| <u>Name</u> | <u>Organization</u> |
|------------------|---------------------------|
| G. Rivenbark | NRC/DL ORB #4 |
| R. W. Houston | NRC/NRR/DSI |
| Tim Collins | NRC/NRR/DSI/RSB |
| Ken Turnage | Southern Company Services |
| Larry K. Mathews | Southern Company Services |
| J. S. Charnley | General Electric |
| R. L. Wagne | General Electric |
| Tom Cox | EDO/DEDROGR |
| W. F. Kane | EDO/DEDROGR |
| J. D. Heidt | General Electric |
| D. L. Townley | GPC |
| R. D. Baker | GPC |
| D. B. Vassallo | NRC/DL |



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 28, 1983

Docket No. 50-366

Mr. J. T. Beckham, Jr.
Vice President, Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302


Dear Mr. Beckham:

In our Safety Evaluation supporting Amendment No. 33 to the Hatch Unit 2 Operating License, we indicated that the Georgia Power Company (GPC) disagreed with the staff position that Technical Specifications for surveillance of the high water level (Level 8) turbine trip and the turbine bypass systems are required in order to assure operability of these trip and turbine bypass systems when required to mitigate a transient involving failure of the feedwater flow controller. We also stated that we would defer implementation of such Technical Specifications for 60 days following startup in order to allow time for further discussion with GPC on this subject. We subsequently met with GPC on July 13, 1983 and discussed GPC's arguments concerning the need for these Technical Specifications. At that time, we informed GPC that it appeared to us that the issue in question is generic and that we would hold our previously stated requirements for these Technical Specifications in abeyance until we had further considered the GPC arguments discussed at the meeting.

We have now concluded that this subject should be treated as a generic issue, and we plan to handle it in accordance with our internal procedures for dealing with such issues. We have also determined, based on preliminary analysis, that the risk of operating Hatch Unit 2 without Technical Specifications concerning surveillance of highwater level turbine trip or turbine bypass systems until the generic issue is resolved is small.

Accordingly, we will not require implementation, at this time, of any Technical Specifications on this issue for the Hatch Plant. We will inform you of the results of our consideration of this issue when it is finally resolved.

Sincerely,


John F. Stoiz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

~~8311140215~~

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Project Manager

July 11, 1983

Docket No. 50-321

MEMORANDUM FOR: John F. Stolz, Chief, Operating Reactors Branch #4, DL
FROM: George Rivenbark, Project Manager, Operating Reactors Branch #4, DL
SUBJECT: FORTHCOMING MEETING WITH GEORGIA POWER COMPANY (GPC)
Time & Date: Wednesday, July 13, 1983
1:00pm-4:00pm
Location: Maryland National Bank Building, Rm. 1713
Bethesda, Maryland
Purpose: Discuss Georgia Power Company's arguments relative to the staffs request for Technical Specifications to assure the operability of the Hatch Unit 2 high water level trip and turbine bypass systems.
Requested Participants: NRC-GRivenbark, DVassallo, WHouston, WHodges, TCollins.
GPC-RBaker, and consultants, including GE.

George Rivenbark

George Rivenbark, Project Manager
Operating Reactors Branch #4, DL

cc:
See next page

~~8307180424~~

MEETING NOTICE DISTRIBUTION

OPERATING REACTORS BRANCH #4, DIVISION OF LICENSING

Docket File
NRC PDR
L PDR
ORB#4 Rdg
Project Manager
JStolz
GLainas
BGrimes
OELD
Tippolito, ORAB
HDenton
ELJordan, IE
JMTaylor, IE
ACRS (1-0)
MSchaaf
NSIC
Receptionist
Regional Administrator Region(s) II
Resident Inspector

NRC Meeting Participants:

DVassallo
WHouston
WHodges
TCollins



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Tom Cox

MABD 6113

JULY 6 1983

Docket No. 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

By letter dated May 12, 1983, we requested that you submit Technical Specifications (TSs) for Hatch Unit 2 to assure the operability of the high water level trip and turbine bypass systems that you assumed operable in your cycle 4 reload analysis. Your letter of May 26, 1983, pointed out a number of objections to our request for these TSs that you believed to be new staff requirements involving generic issues.

We want to assure you that we did not intentionally withhold our request for these TSs until a short time before your scheduled restart of Hatch Unit 2. Our delay in submitting this request was solely due to an oversight on our part.

We agree with your concern that a short period of time was provided for you to present your arguments and discuss this request with the staff. Therefore, we have decided to defer implementation of these TSs for a period of 60 days following startup for Cycle 4 operation. This should allow you and the staff time to consider and discuss the objections that you raised in your May 26, 1983 letter. Based on discussions between George Rivenbark of our staff and Ray Baker of Georgia Power Company, we understand that a tentative date of July 13, 1983 has been selected for a meeting to discuss this matter.

Sincerely,

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

~~8307270048~~

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-7020

Mailing Address
Post Office Box 4545
Atlanta, Georgia 30302

J. T. Beckham, Jr.
Vice President and General Manager
Nuclear Generation



Georgia Power

the southern electric system

NED-83-303

May 26, 1983

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC DOCKET 50-366
OPERATING LICENSE NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNIT 2
RESPONSE TO REQUEST FOR TECHNICAL SPECIFICATIONS

Gentlemen:

Georgia Power Company (GPC) has received your letter of May 12, 1983, which requests that Georgia Power Company submit additional Technical Specifications prior to restart of Plant Hatch Unit 2 from the current refueling outage. Consequently, GPC amends its submittal of March 30, 1983, to include the attached Technical Specifications which propose additional surveillance requirements on the high reactor water level trip function (i.e., for main turbine and feedwater turbines) and which specify surveillance testing of the main turbine bypass valves.

GPC does not agree with the conclusion presented in your letter of May 12, 1983, regarding the need for additional Technical Specifications. More importantly, we are concerned over the issuance of this letter by the NRC staff for two reasons: 1) the sense of urgency implied by attaching this requirement to our cycle 4 reload and formally informing GPC of the request only 17 days before the originally scheduled startup date is not supported by an appropriate technical basis; 2) the NRC staff is apparently avoiding the established generic issues review process by withholding reload licenses on a plant-by-plant basis until additional Technical Specifications are backfitted when the stated issue is an obvious generic concern.

First, we want to point out that the issues involved have been the subject of several conversations between GPC licensing personnel, the NRC Hatch Licensing Project Manager, and other NRC staff personnel. These conversations have occurred over a period of several months, and actually began during the latter part of the previous operating cycle. At that time we stated our position that the NRC proposed requirements were more appropriately discussed in a generic review since their implementation was being imposed generically and since the proposal was in variance with

8306010367 830526
PDR ADOCK 05000366
P PDR

Acc 1
//

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4
May 26, 1983
Page Two

accepted licensing bases. At that time we also requested that the NRC transmit the request to GPC in writing, so that a forum for discussion of the technical merit of the request could be established. A letter was not issued by the NRC, and Unit 2 continued to the end of cycle 3 operation and into the current refueling/maintenance outage.

Second, only 17 days prior to the originally scheduled startup date for cycle 4 operation, the NRC finally chose to issue the request with the additional arbitrary requirement that it be resolved prior to unit startup. GPC objects to being informed at such a late date that the reload license will be withheld until the requested Technical Specifications are accepted by GPC. Furthermore, the technical questions involved relate to pressurization transients which historically are not limiting at beginning of cycle operation. Clearly, in light of GPC's objections to its substance, the requirement to resolve this request prior to restart and without adequate time for GPC and NRC to mutually and fully discuss the issues is inappropriate.

Third, the procedure being followed by the NRC avoids the established generic issues review process. It is inappropriate to impose backfits lacking a finding of need for substantial additional public protection. The NRC staff conclusion expressed in the May 12, 1983, letter clearly rejects the assumptions previously accepted by NRC as stated in General Electric's Generic Reload Fuel Application licensing report (NEDE-24011-P). As such, this is an issue that should be addressed by the Committee to Review Generic Requirements (CRGR) so that the nuclear industry can comment on the staff conclusions. However, we understand that these requirements have previously been imposed on at least one other operating nuclear unit during a refueling outage and on two near term operating license (NTOL) units as they approached receipt of an operating license. The staff is apparently masking generic requirements as plant-specific modifications and issuing them without the formal analysis required by the Commission. By applying this requirement on a plant-by-plant basis as a particular nuclear plant is placed in a vulnerable position, a commitment can be easily extracted due to the threat of non-approval of a reload licensing package or an operating license. GPC objects to this procedure.

GPC is ready to discuss with the staff the reasons why additional Technical Specifications are not required. However, that issue should be properly dealt with by referring the subject to the CRGR. We propose a meeting in the near future (possibly June 1983) of representatives from the NRC, GE licensing, and GPC licensing staffs to discuss the issues expressed in this letter as well as the technical merits of the proposed specifications.


Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4
May 26, 1983
Page Three

In the meantime, GPC proposes additional Technical Specifications in compliance with your request. The Plant Review Board and Safety Review Board have reviewed these changes and have determined that the implementation of these changes does not constitute an unreviewed safety question because these changes merely establish LCOs and codify surveillances on equipment and/or systems that were previously being serviced by plant maintenance and surveillance procedures. Since there is no change to the plant and only a codifying of surveillances, the probability of occurrence and the consequences of an accident or malfunction of equipment important to safety are not increased above those analyzed in the FSAR. The possibility of an accident or malfunction of a different type than analyzed in the FSAR does not result, nor is the margin of safety as defined in Technical Specifications reduced due to implementation of these changes. Because we desire to resolve the technical issues regarding this submittal, we request that these Technical Specifications be made applicable to cycle 4 operation only, pending resolution of this subject.


The proposed Technical Specifications have been determined to be an amendment, as requested, to a previous submittal. As such, no fee is required.

J. T. Beckham, Jr. states that he is Vice President of Georgia Power Company and is authorized to execute this oath on behalf of Georgia Power Company, and that to the best of his knowledge and belief the facts set forth in this letter are true.

GEORGIA POWER COMPANY

By: 
J. T. Beckham, Jr.

Sworn to and subscribed before me this 26th day of May, 1983.



Notary Public, Georgia, State at Large
My Commission Expires Sept. 20, 1983

Notary Public

DLT/mb

Enclosure

xc: J. T. Beckham, Jr.
H. C. Nix, Jr.
J. P. O'Reilly (NRC- Region II)
Senior Resident Inspector
V. Stello
J. R. Tourtellotte


TABLE 3.3.9-1

FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION

| <u>FUNCTIONAL UNIT</u> | <u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM</u> | <u>APPLICABLE OPERATIONAL CONDITIONS</u> |
|---|--|--|
| a. Reactor Vessel Water Level-High, Level 8 | 2 | 1, when THERMAL POWER \geq 25% RATED THERMAL POWER |

3/4 3-67

8306010371 830526
PDR ADDOCK 05000366
P PDR



PLANT SYSTEMS

3/4.7.9 MAIN TURBINE BYPASS SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.9 The main turbine bypass system shall be OPERABLE.

APPLICABILITY: CONDITION 1, when THERMAL POWER \geq 25% RATED THERMAL POWER

ACTION: With the main turbine bypass system inoperable, restore the system to OPERABLE status within 2 hours or determine MCPR to be equal to or greater than the MCPR limit in Specifications 3.2.3 within one hour or take the ACTION required by that Specification.

SURVEILLANCE REQUIREMENTS

4.7.9 The main turbine bypass system shall be demonstrated OPERABLE at least once per:

- a. 7 days by cycling each turbine bypass valve through at least one complete cycle of full travel, and
- b. 18 months by:
 1. Performing a system functional test which includes simulated automatic actuation and verifying that each automatic valve actuates to its correct position.
 2. Demonstrating TURBINE BYPASS SYSTEM RESPONSE TIME to be less than or equal to 0.30 seconds.

ATTACHMENT 1

NRC DOCKET 50-366
OPERATING LICENSE NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNIT 2
PROPOSAL FOR TECHNICAL SPECIFICATION CHANGES

The proposed change to the Technical Specification (Appendix A to Operating License NPF-5) would be incorporated as follows:

Remove Page

--
--
--
--
--
B 3/4 3-6

Insert Page

3/4 3-66
3/4 3-67
3/4 3-68
3/4 3-69
3/4 7-33
B 3/4 3-6

INSTRUMENTATION

3/4.3.9 FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.9 The feedwater/main turbine trip system actuation instrumentation channels shown in Table 3.3.9-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.9-2.

APPLICABILITY: Condition 1, when THERMAL POWER \geq 25% RATED THERMAL POWER

ACTION:

With a feedwater/main turbine trip system actuation instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.9-2, declare the channel inoperable and either place the inoperable channel in the tripped condition until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value, or declare the associated system inoperable.

- a. With the number of OPERABLE channels one less than required by the Minimum OPERABLE Channels requirement, restore the inoperable channel to OPERABLE status within 7 days or reduce thermal power $<$ 25% Rated thermal power within the next 4 hours.
- b. With the number of OPERABLE channels two less than required by the Minimum OPERABLE Channels per Trip System requirement, restore at least one of the inoperable channels to OPERABLE status within 72 hours or reduce thermal power $<$ 25% rated thermal power within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.3.9.1 Each plant system actuation instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.9.1-1.

4.3.9.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.

TABLE 3.3.9-2

FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

| <u>FUNCTIONAL UNIT</u> | <u>TRIP SETPOINT</u> | <u>ALLOWABLE VALUE</u> |
|---|----------------------|------------------------|
| a. Reactor Vessel Water Level-High, Level 8 | ≤ 58.0 Inches | ≤ 58.0 Inches |

*See Bases Figure B 3/4 3-1.

TABLE 4.3.9.1-1 (Continued)

FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

| <u>FUNCTIONAL UNIT</u> | <u>CHANNEL CHECK</u> | <u>CHANNEL FUNCTIONAL TEST</u> | <u>CHANNEL CALIBRATION</u> | <u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u> |
|---|----------------------|--------------------------------|----------------------------|---|
| a. Reactor Vessel Water Level-High, Level 8 | NA | M | R | 1, when THERMAL POWER \geq 25% RATED THERMAL POWER |