

DMB 016

FEB 1 1985

Docket 50-368

MEMORANDUM TO: File

FROM: Guy S. Vissing, Project Manager  
Operating Reactors Branch #4  
Division of Licensing

SUBJECT: PROPOSED TECHNICAL SPECIFICATIONS CONCERNING KEY LOCK  
SWITCHES FOR PURGE VALVES FOR ANO-2

The enclosed proposed draft Technical Specification was transmitted to Arkansas Power and Light Company via the NRC IBM 5520 system on January 31, 1985 for discussion purpose.

**"ORIGINAL SIGNED BY:"**

Guy S. Vissing, Project Manager  
Operating Reactors Branch #4  
Division of Licensing

Enclosure  
As stated

DISTRIBUTION:  
 Docket File  
 NRC PDR  
 L PDR  
 ORB#4 Rdg  
 GVissing  
 JStolz  
 Memo File

*GV*  
 ORB#4:DL  
 GVissing;cf  
 2/1/85

*JStolz*  
 ORB#4:DL  
 JStolz  
 2/1/85

3.6.1.6 The containment purge supply and exhaust isolation valves shall be closed and handswitch keys removed (locked closed).

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION

With one or more containment purge supply and/or exhaust isolation valves not locked closed, lock close the valves to the locked closed state within 1 hour or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

---

4.6.1.6 The containment purge supply and exhaust isolation valves shall be determined locked closed at least once per 31 days.