


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-87 is hereby amended to read as follows:

2. Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 49, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Timothy J. Polich, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: April 1, 1996


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-89 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 35, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Timothy J. Polich, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: April 1, 1996

Mr. C. Lance Terry
TU Electric Company

Comanche Peak, Units 1 and 2

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 1029
Granbury, TX 76048

Honorable Dale McPherson
County Judge
P. O. Box 851
Glen Rose, TX 76043

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Office of the Governor
ATTN: Susan Rieff, Director
Environmental Policy
P. O. Box 12428
Austin, TX 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, TX 75224

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Mr. Roger D. Walker, Manager
Regulatory Affairs for Nuclear
Engineering Organization
Texas Utilities Electric Company
1601 Bryan Street, 12th Floor
Dallas, TX 75201-3411

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 610
Bethesda, MD 20814

George L. Edgar, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

TABLE 2.2-1 (Continued)
TABLE NOTATIONS

NOTE 1: Overtemperature N-16

$$N = K_1 - K_2 \left[\frac{1 + \tau_1 s}{1 + \tau_2 s} T_c - T_c^o \right] + K_3 (P - P^1) - f_1 (\Delta Q)$$

- Where:
- N = Measured N-16 Power by ion chambers,
 - T_c = Cold leg temperature, °F,
 - T_c^o = 560.5°F for Unit 1, 560.8°F for Unit 2 - Reference T_c at RATED THERMAL POWER, |
 - K_1 = 1.150,
 - K_2 = 0.0134/°F for Unit 1
0.0138/°F for Unit 2 |
 - $\frac{1 + \tau_1 s}{1 + \tau_2 s}$ = The function generated by the lead-lag controller for T_c dynamic compensation,
 - τ_1, τ_2 = Time constants utilized in the lead-lag controller for T_c , $\tau_1 \geq 10$ s, and $\tau_2 \leq 3$ s,
 - K_3 = 0.000719/psig for Unit 1
0.000720/psig for Unit 2 |

TABLE 2.2-1 (Continued)

TABLE NOTATIONS (Continued)

NOTE 1: (Continued)

- P = Pressurizer pressure, psig,
P¹ ≥ 2235 psig (Nominal RCS operating pressure),
S = Laplace transform operator, s⁻¹,

and $f_1(\Delta q)$ is a function of the indicated difference between top and bottom halves of detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant STARTUP tests such that:

For Unit 1

- (i) for $q_t - q_b$ between -65% and +4%, $f_1(\Delta q) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER,
(ii) for each percent that the magnitude of $q_t - q_b$ exceeds -65%, the N-16 Trip Setpoint shall be automatically reduced by 1.81% of its value at RATED THERMAL POWER, and
(iii) for each percent that the magnitude of $q_t - q_b$ exceeds +4%, the N-16 Trip Setpoint shall be automatically reduced by 2.26% of its value at RATED THERMAL POWER.