

FEB 06 1985

DOCKET/LICENSE: 50-317/DPR-53
50-318/DPR-69

Baltimore Gas and Electric Company
ATTN: Mr. A. E. Lundvall, Jr.
Vice President, Supply
Post Office Box 1475
Baltimore, Maryland 21203

Gentlemen:

Subject: NRC:RI Inspection 50-317/84-31, 50-318/84-31

This transmits the November 5 - December 18, 1984, resident inspection findings by Messrs. T. Foley and D. Trimble at the Calvert Cliffs Nuclear Power Plant, Lusby, Maryland. Those findings were based on observation of activities, interviews, independent measurements, and document reviews, and have been discussed with Mr. Russell of your staff.

Within the scope of this inspection no violations were observed, however, the declaration of the No. 12 Main Steam Isolation Valve (MSIV) as "operable" although the specific root cause of the failure has not been positively identified is of concern to us. We understand that you plan further testing to determine the root cause of the failure, in order to establish a higher degree of confidence of valve operability. In view of the importance of the function of this valve in ensuring plant safety we feel that a high degree of confidence is necessary.

In addition, we have reviewed your letter dated December 21, 1984 in response to our letter dated November 21, 1984 (Inspection Report No. 84-23) and your corrective action to the improper lifting of a power lead to the Hydrogen Analyzing System Valve O-SV-6509 on June 5, 1984, which partially disabled that system (Inspection Report No. 84-11). Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during future inspections of your licensed program. Your corrective action to the improper lifting of a power lead was reviewed and found adequate. This violation is considered closed.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

8502200088 850206
PDR ADDCK 05000317
G PDR

Edward C. Wenzinger, Chief
Projects Branch No. 3
Division of Project and Resident
Programs

OFFICIAL RECORD COPY

DL50-317/84-31 - 0001.0.0
01/23/85

IEO1 |

Enclosure: NRC:RI Report 50-317/84-31, 50-318/84-31

cc w/enclosure:

- R. M. Douglass, Manager, Quality Assurance
- L. B. Russell, Plant Superintendent
- S. M. Davis, General Supervisor, Operations QA
- T. Magette, Administrator, Nuclear Evaluations
- R. C. L. Olson, Principal Engineer, Nuclear Licensing & Analysis Unit
- J. A. Tiernan, Manager, Nuclear Power Department
- R. E. Denton, General Supervisor, Training and Technical Services
- Public Document Room (PDR)
- Local Public Document Room (LPDR)
- Nuclear Safety Information Center (NSIC)
- NRC Resident Inspector
- State of Maryland (2)

bcc w/enclosure:

- Region I Docket Room (with concurrences)
- Senior Operations Officer (w/o enclosure)
- T. Elsasser, DPRP Section Chief

RI:DPRP
 Foley/Trimble/mjd
LPF
 1/8/85
 1/31/85

W RI:DPRP
 Elsasser
 1/31/85

RI:DPRP
 Weitzinger
 2/5/85